

**Duke Energy Ohio
OPSB Case No. 20-1392-GA-BTA
STAFF Second Set of Data Requests
Date Received: November 13, 2020**

STAFF-DR-02-003

REQUEST:

Test boring site 20-2 was near the bore of I-275 (Ohio Department of Transportation Permit No. 08-298-20 Interstate 275) and proposed Route Adjustment RA-1, are there any subsurface conditions at this location to **preclude** a bore under Interstate-275 at this location.

RESPONSE: No. As described in the response to STAFF-DR-02-02, the subsurface conditions merely require the Company to be prepared to handle any impacted soil appropriately.

PERSON RESPONSIBLE: James Olberding