



**METERING SALES & SERVICE, INC.**

*Distributors of Metering Equipment & Systems*

1930 PIONEER ROAD  
HUNTINGDON VALLEY, PA 19008  
(215) 875-5117 • FAX (215) 875-4960

October 19, 2011

Ryan Marlborough  
Photovoltaic Specialist  
United Electric Supply Co.  
10 Bellecor Drive  
New Castle, DE 19720

Dear Mr. Marlborough:

The reconditioned Sangamo meter, S/N 42-837-802, that we shipped was fully tested and met the standards common to utilities. This meter was physically examined, cleaned and then tested utilizing a Watthour Engineering computerized test set with a Radian Research RM-11 Standard. When this meter left our facility, it measured +/- 1/2% full load and light load and +/- 1% power factor. These are the normally required test points.

If you have any further questions, please contact our office.

Very truly yours,

  
Steven J. Helzner

SIH:mms