

Cincinnati Public Schools Mercantile Self  
Direct CUSTOM Applications – Part 1 of 4



**Case No.:** \_\_\_\_-\_\_\_\_-EL-EEC

**Mercantile Customer:** Cincinnati Public Schools

**Electric Utility:** Duke Energy

**Program Title or  
Description:** HVAC and Lighting (Custom)

Rule 4901:1-39-05(F), Ohio Administrative Code (O.A.C.), permits a mercantile customer to file, either individually or jointly with an electric utility, an application to commit the customer's existing demand reduction, demand response, and energy efficiency programs for integration with the electric utility's programs. The following application form is to be used by mercantile customers, either individually or jointly with their electric utility, to apply for commitment of such programs in accordance with the Commission's pilot program established in Case No. [10-834-EL-POR](#)

Completed applications requesting the cash rebate reasonable arrangement option (Option 1) in lieu of an exemption from the electric utility's energy efficiency and demand reduction (EEDR) rider will be automatically approved on the sixty-first calendar day after filing, unless the Commission, or an attorney examiner, suspends or denies the application prior to that time. Completed applications requesting the exemption from the EEDR rider (Option 2) will also qualify for the 60-day automatic approval so long as the exemption period does not exceed 24 months. Rider exemptions for periods of more than 24 months will be reviewed by the Commission Staff and are only approved up the issuance of a Commission order.

Complete a separate application for each customer program. Projects undertaken by a customer as a single program at a single location or at various locations within the same service territory should be submitted together as a single program filing, when possible. Check all boxes that are applicable to your program. For each box checked, be sure to complete all subparts of the question, and provide all requested additional information. Submittal of incomplete applications may result in a suspension of the automatic approval process or denial of the application.

Any confidential or trade secret information may be submitted to Staff on disc or via email at [ee-pdr@puc.state.oh.us](mailto:ee-pdr@puc.state.oh.us).

## Section 1: Mercantile Customer Information

Name: **Cincinnati Public Schools**

Principal address: **2651 Burnet Avenue Cincinnati, Ohio 45219**

Address of facility for which this energy efficiency program applies:

Bond Hill Academy 1510 California Ave Cinti, Oh 45237	(HVAC)
Carson School 4323 Glenway Ave Cinti, Oh 45205	(HVAC)
Fairview-Clifton 3689 Clifton Ave Cinti, Oh 45220	(HVAC)
Kilgour School 1339 Herschel Cinti, Oh 45208	(Lighting)
Mt Airy School 5730 Colerain Cinti, Oh 45211	(HVAC and Lighting)
Pleasant Ridge Montessori School Cinti, Oh 45213	(HVAC and Lighting)
Roselawn Condon School Cinti, Oh 45237	(Lighting)
South Avondale Schools 636 Prospect Pl Cinti, Oh	(HVAC and Lighting)

Name and telephone number for responses to questions:

**Grady Reid Jr 513-287-1038**

Electricity use by the customer (check the box(es) that apply):

- The customer uses more than seven hundred thousand kilowatt hours per year at the above facility. (See - Appendix A)**
- The customer is part of a national account involving multiple facilities in one or more states. (Please attach documentation.)

## Section 2: Application Information

A) The customer is filing this application (choose which applies):

- Individually, without electric utility participation.
- Jointly with the electric utility.**

B) The electric utility is: **Duke Energy**

C) The customer is offering to commit (check any that apply):

- Energy savings from the customer's energy efficiency program. (Complete Sections 3, 5, 6, and 7.)
- Capacity savings from the customer's demand response/demand reduction program. (Complete Sections 4, 5, 6, and 7.)
- Both the energy savings and the capacity savings from the customer's energy efficiency program. (Complete all sections of the Application.)**

### Section 3: Energy Efficiency Programs

A) The customer's energy efficiency program involves (check those that apply):

- Early replacement of fully functioning equipment with new equipment. (Provide the date on which the customer replaced fully functioning equipment, and the date on which the customer would have replaced such equipment if it had not been replaced early. Please include a brief explanation for how the customer determined this future replacement date (or, if not known, please explain why this is not known)).
- Installation of new equipment to replace equipment that needed to be replaced. The customer installed new equipment on the following date(s):  
\_\_\_\_\_.

**Installation of new equipment for new construction or facility expansion. The customer installed new equipment on the following date(s):**

<b>Bond Hill Academy</b>	<b>HVAC</b>	<b>March 2008</b>
<b>Carson School</b>	<b>HVAC</b>	<b>April 2008</b>
<b>Fairview Clifton School</b>	<b>HVAC</b>	<b>August 2008</b>
<b>Kilgour School</b>	<b>Lighting</b>	<b>August 2008</b>
<b>Mt Airy School</b>	<b>HVAC/Lighting</b>	<b>March 2008</b>
<b>Pleasant Ridge School</b>	<b>HVAC/Lighting</b>	<b>August 2008</b>
<b>Roselawn School</b>	<b>Lighting</b>	<b>August 2008</b>
<b>South Avondale School</b>	<b>HVAC/Lighting</b>	<b>November 2008</b>

- Behavioral or operational improvement.

B) Energy savings achieved/to be achieved by the energy efficiency program:

1) If you checked the box indicating that the project involves the early replacement of fully functioning equipment replaced with new equipment, then calculate the annual savings [(kWh used by the original equipment) - (kWh used by new equipment) = (kWh per year saved)]. Please attach your calculations and record the results below:

Annual savings: \_\_\_\_\_kWh

2) If you checked the box indicating that the customer installed new equipment to replace equipment that needed to be replaced, then calculate the annual savings [(kWh used by less efficient new equipment) - (kWh

used by the higher efficiency new equipment) = (kWh per year saved)].  
Please attach your calculations and record the results below:

Annual savings: \_\_\_\_\_kWh

Please describe any less efficient new equipment that was rejected in favor of the more efficient new equipment.

- 3) If you checked the box indicating that the project involves equipment for new construction or facility expansion, then calculate the annual savings [(kWh used by less efficient new equipment) - (kWh used by higher efficiency new equipment) = (kWh per year saved)]. Please attach your calculations and record the results below:

Annual savings: **491,888 kWh savings**  
**(Refer to Appendix B for calculations and supporting documents).**

Please describe the less efficient new equipment that was rejected in favor of the more efficient new equipment.

- 4) If you checked the box indicating that the project involves behavioral or operational improvements, provide a description of how the annual savings were determined.
-

## Section 4: Demand Reduction/Demand Response Programs

A) The customer's program involves (check the one that applies):

- Coincident peak-demand savings from the customer's energy efficiency program.**
- Actual peak-demand reduction. (Attach a description and documentation of the peak-demand reduction.)
- Potential peak-demand reduction (check the one that applies):
  - The customer's peak-demand reduction program meets the requirements to be counted as a capacity resource under a tariff of a regional transmission organization (RTO) approved by the Federal Energy Regulatory Commission.
  - The customer's peak-demand reduction program meets the requirements to be counted as a capacity resource under a program that is equivalent to an RTO program, which has been approved by the Public Utilities Commission of Ohio.

B) On what date did the customer initiate its demand reduction program?

**March 2008**

**August 2008**

C) What is the peak demand reduction achieved or capable of being achieved (show calculations through which this was determined):

**243 KW**

**Refer to Appendix B for calculations and supporting documentation**

## Section 5: Request for Cash Rebate Reasonable Arrangement (Option 1) or Exemption from Rider (Option 2)

Under this section, check the box that applies and fill in all blanks relating to that choice.

Note: If Option 2 is selected, the application will not qualify for the 60-day automatic approval. All applications, however, will be considered on a timely basis by the Commission.

A) The customer is applying for:

**Option 1: A cash rebate reasonable arrangement.**

OR

Option 2: An exemption from the energy efficiency cost recovery mechanism implemented by the electric utility.

OR

Commitment payment

B) The value of the option that the customer is seeking is:

Option 1: A cash rebate reasonable arrangement, which is the lesser of (show both amounts):

A cash rebate of **\$28,000.00. Refer to Appendix C.** (Rebate shall not exceed 50% project cost. Attach documentation showing the methodology used to determine the cash rebate value and calculations showing how this payment amount was determined.)

Option 2: An exemption from payment of the electric utility's energy efficiency/peak demand reduction rider.

An exemption from payment of the electric utility's energy efficiency/peak demand reduction rider for \_\_\_ months (not to exceed 24 months). (Attach calculations showing how this time period was determined.)

OR

A commitment payment valued at no more than \$\_\_\_\_\_. (Attach documentation and

calculations showing how this payment amount was determined.)

OR

- Ongoing exemption from payment of the electric utility's energy efficiency/peak demand reduction rider for an initial period of 24 months because this program is part of the customer's ongoing efficiency program. (Attach documentation that establishes the ongoing nature of the program.) In order to continue the exemption beyond the initial 24 month period, the customer will need to provide a future application establishing additional energy savings and the continuance of the organization's energy efficiency program.)

### Section 6: Cost Effectiveness

The program is cost effective because it has a benefit/cost ratio greater than 1 using the (choose which applies):

- Total Resource Cost (TRC) Test. The calculated TRC value is: \_\_\_\_\_  
(Continue to Subsection 1, then skip Subsection 2)
- ✓ Utility Cost Test (UCT). The calculated UCT value is **12.04 (Skip to Subsection 2.) Refer to Appendix D for calculations and supporting documents.**

#### Subsection 1: TRC Test Used (please fill in all blanks).

The TRC value of the program is calculated by dividing the value of our avoided supply costs (generation capacity, energy, and any transmission or distribution) by the sum of our program overhead and installation costs and any incremental measure costs paid by either the customer or the electric utility.

The electric utility's avoided supply costs were \_\_\_\_\_.

Our program costs were \_\_\_\_\_.

The incremental measure costs were \_\_\_\_\_.

Subsection 2: UCT Used (please fill in all blanks).

We calculated the UCT value of our program by dividing the value of our avoided supply costs (capacity and energy) by the costs to our electric utility (including administrative costs and incentives paid or rider exemption costs) to obtain our commitment.

Our avoided supply costs were **\$523,815**

The utility's program costs were **\$15,491**

The utility's incentive costs/rebate costs were **\$28,000.00**

**Refer to Appendix D for calculations**

**Section 7: Additional Information**

Please attach the following supporting documentation to this application:

Narrative description of the program including, but not limited to, make, model, and year of any installed and replaced equipment.

A copy of the formal declaration or agreement that commits the program or measure to the electric utility, including:

- 1) any confidentiality requirements associated with the agreement;
- 2) a description of any consequences of noncompliance with the terms of the commitment;
- 3) a description of coordination requirements between the customer and the electric utility with regard to peak demand reduction;
- 4) permission by the customer to the electric utility and Commission staff and consultants to measure and verify energy savings and/or peak-demand reductions resulting from your program; and,
- 5) a commitment by the customer to provide an annual report on your energy savings and electric utility peak-demand reductions achieved.

**Refer to Rebate Offer Letter following this application**

A description of all methodologies, protocols, and practices used or proposed to be used in measuring and verifying program results. Additionally, identify and explain all deviations from any program measurement and verification guidelines that may be published by the Commission.



DUKE ENERGY CORPORATION  
Mercantile Self Direct Program  
139 East Fourth Street  
Cincinnati, OH 45202  
513 629 5572 fax

March 21, 2012

Don Elbe  
Cincinnati Public Schools  
2651 Burnet Avenue  
Cincinnati, Ohio 45219

Subject: Your Application for a Duke Energy Mercantile CUSTOM Self-Direct Rebate

Dear Mr. Don Elbe:

Thank you for your Duke Energy Mercantile Self Direct rebate application. As noted in the Energy Conservation Measure (ECM) chart on page three, a total rebate of \$28,000.00 has been proposed for your HVAC and Lighting projects completed in the 2008 calendar year. All Self Direct Rebates are contingent upon approval by the Public Utilities Commission of Ohio (PUCO).

At your earliest convenience, please indicate if you accept this rebate by

- providing your signature on page two
- completing the PUCO-required affidavit on page four.

Please return the documents to my attention via fax at 513-629-5572 or e-mail to [SelfDirect@Duke-Energy.com](mailto:SelfDirect@Duke-Energy.com). Upon receipt, Duke Energy will submit the necessary documentation to PUCO. Following PUCO's approval, Duke Energy will remit payment.

At Duke Energy, we value your business and look forward to working with you on this and future energy efficiency projects. We hope you will consider our Smart Saver® incentives, when applicable. Please contact me if you have any questions.

Sincerely,

Grady Reid, Jr  
Product Manager  
Mercantile Self Direct Rebates

cc: Mike Heath, Duke Energy  
Rob Jung, WECC  
Lucas Dixon, PlugSmart

Please indicate your response to this rebate offer within 30 days of receipt.

Rebate is accepted.

Rebate is declined.

By accepting this rebate, Cincinnati Public Schools affirms its intention to commit and integrate the energy efficiency projects listed on the following pages into Duke Energy's peak demand reduction, demand response and/or energy efficiency programs.

Additionally, Cincinnati Public Schools also agrees to serve as joint applicant in any future filings necessary to secure approval of this arrangement as required by PUCO and to comply with any information and reporting requirements imposed by rule or as part of that approval.

Finally, Cincinnati Public Schools affirms that all application information submitted to Duke Energy pursuant to this rebate offer is true and accurate. Information in question would include, but not be limited to, project scope, equipment specifications, equipment operational details, project costs, project completion dates, and the quantity of energy conservation measures installed.

If rebate is accepted, will you use the monies to fund future energy efficiency and/or demand reduction projects?

YES  NO

If rebate is declined, please indicate reason (optional):



Customer Signature

Donald M. Elbe

Printed Name

3-23-12

Date

### Proposed Rebate Amounts

Measure ID	Energy Conservation Measure (ECM) (CUSTOM)	Proposed Rebate Amount
ECM-1	Bond Hill School – Energy Recovery Ventilator(s) (Total Rebate)	\$2,000.00
ECM-2	Carson School - Energy Recovery Ventilator(s) (Total Rebate)	\$4,000.00
ECM-3	Fairview School - Energy Recovery Ventilator(s) (Total Rebate)	\$4,150.00
ECM-4	Kilgour School – New Construction Lighting	\$1,050.00
ECM-5	Mt Airy School- Energy Recovery Ventilator(s) (Total Rebate)	\$4,000.00
ECM-6	Mt Airy School – New Construction Lighting	\$1,050.00
ECM-7	Pleasant Ridge School- Energy Recovery Ventilator(s) (Total Rebate)	\$3,250.00
ECM-8	Pleasant Ridge School – New Construction Lighting	\$2,200.00
ECM-9	Roselawn School – New Construction Lighting	\$3,250.00
ECM-10	South Avondale School- Energy Recovery Ventilator(s) (Total Rebate)	\$2,150.00
ECM-11	South Avondale School – New Construction Lighting	\$900.00
Total		\$28,000.00



**Public Utilities  
Commission**

**Application to Commit  
Energy Efficiency/Peak  
Demand Reduction  
Programs  
(Mercantile Customers  
Only)**

Case No.: \_\_\_\_ - \_\_\_\_ -EL-EEC

State of Ohio :

Donald M. Elbe, Affiant, being duly sworn according to law, deposes and says that:

1. I am the duly authorized representative of:

Cincinnati Public Schools

[insert customer or EDU company name and any applicable name(s) doing business as]

2. I have personally examined all the information contained in the foregoing application, including any exhibits and attachments. Based upon my examination and inquiry of those persons immediately responsible for obtaining the information contained in the application, I believe that the information is true, accurate and complete.

3. I am aware of fines and penalties which may be imposed under Ohio Revised Code Sections 2921.11, 2921.31, 4903.02, 4903.03, and 4903.99 for submitting false information.


Donald M. Elbe  
Signature of Affiant & Title

Sworn and subscribed before me this 23<sup>rd</sup> day of March,  
2012 Month/Year

Pamula Thomas  
Signature of official administering oath

Pamula Thomas - Notary  
Print Name and Title

My commission expires on June 19, 2012



**PAMULA R. THOMAS**  
Notary Public, State of Ohio  
My Commission Expires  
June 19, 2012

## Appendix A

91103676 01		
CINCINNATI PUBLIC SCHOOLS		
5945 MONTGOMERY RD		
CINCINNATI, OH 45213		
Date	Days	Actual KWH
12/29/2011	30	89,624
11/29/2011	33	99,166
10/27/2011	29	102,362
9/28/2011	30	119,392
8/29/2011	31	166,765
7/29/2011	30	162,193
6/29/2011	29	132,830
5/31/2011	32	118,148
4/29/2011	30	105,178
3/30/2011	29	115,864
3/1/2011	29	118,427
1/31/2011	32	128,341
<b>Total</b>		<b>1,458,290</b>

Please note additional supportive documentation is available upon request. Some documentation does not convert from Excel to PDF such that it fits into a manageable format within this application while other documents create file size issues or is larger in size than most other documents contained. Available documents are:

- **Lighting schedules**
- **Lighting counts**
- **Lighting plans**
- **Representative interior lighting and power compliance results (Com Check print outs)**
- **Vendor-submitted energy recovery unit calculations**

Additionally, pertinent data from the lighting count spreadsheet is summarized in the documents presented immediately following the Appendix B, page 1, summarization of project savings.

Appendix B - Energy Savings Achieved

ECM #	Facility	Baseline Used			Post Project Actual				Hours of Operation <sup>1</sup>	Savings		
		Description	Annual kWh	Operating kW	Summer Coincident kW <sup>3</sup>	Description	Annual kWh	Operating kW		Summer Coincident kW <sup>3</sup>	Annual kWh	Summer Coincident kW
1	Bond Hill	38,000 CFM AHU without heat recovery	41,102	33.6	33.6	Heat recovery unit added	8,700	7.1	7.1	1,225	32,402	26.5
2	Carson	25,760 CFM AHU without heat recovery; 25,840 CFM AHU without heat recovery	67,097	54.8	54.8	Heat recovery units added	15,369	12.5	12.5	1,225	51,728	42.2
3	Fairview	14,096 CFM AHU without heat recovery; 23,253 CFM AHU without heat recovery; 23,849 CFM AHU without heat recovery	75,905	62.0	62.0	Heat recovery units added	22,605	18.5	18.5	1,225	53,300	43.5
4	Kilgour	Code Lighting Power Density (67,232 SF) <sup>2</sup>	214,408	78.5	78.5	As Installed <sup>2</sup>	189,235	69.3	69.3	2,730	25,172	9.2
5	Mt Airy	Code Lighting Power Density (84,144 SF) <sup>2</sup>	210,023	101.0	50.5	As Installed <sup>2</sup>	184,263	88.6	44.3	2,080	25,761	6.2
6	Mt Airy	37,000 CFM AHU without heat recovery; 24,000 CFM AHU without heat recovery	63,621	51.9	51.9	Heat recovery units added	12,328	10.1	10.1	1,225	51,293	41.9
7	Pleasant Ridge	Code Lighting Power Density (75,310 SF) <sup>2</sup>	162,670	90.4	0.0	As Installed <sup>2</sup>	112,317	62.4	0.0	1,800	50,353	0.0
8	Pleasant Ridge	33,700 CFM AHU without heat recovery; 16,925 CFM AHU without heat recovery	51,943	42.4	42.4	Heat recovery units added	10,342	8.4	8.4	1,225	41,601	34.0
9	Roselawn	Code Lighting Power Density (113,529 SF) <sup>2</sup>	260,549	136.2	0.0	As Installed <sup>2</sup>	180,444	94.3	0.0	1,913	80,105	0.0
10	South Avondale	Code Lighting Power Density (85,470 SF) <sup>2</sup>	213,333	102.6	0.0	As Installed <sup>2</sup>	191,925	92.3	0.0	2,080	21,408	0.0
11	South Avondale	33,700 CFM AHU without heat recovery; 16,925 CFM AHU without heat recovery	39,031	31.9	31.9	Heat recovery units added	11,484	9.4	9.4	1,225	27,548	22.5
<b>Totals</b>			<b>1,399,683</b>	<b>785</b>	<b>406</b>		<b>939,012</b>	<b>473</b>	<b>180</b>		<b>460,671</b>	<b>226</b>

After consideration of line losses, total energy savings are **491,888 kWh** and **243 summer coincident kW**. These values may also reflect minor DSMore modeling software rounding error.

Notes:

- 1 Hours of operation do not apply simply to heat recovery unit measures. kWh and kW values presented are the results of bin analysis presented in the attached pages.
- 2 Building Code baseline lighting power density allowances as well as the as installed fixture wattages & quantities are detailed on the attached pages.
- 3 In some cases, facility operating hours end during the summer coincident hour. As such, one half the operating kW is shown as summer coincident demand savings.

**DETAILED CALCULATIONS - ECM1**

**JAN 2012 V2**

Salesforce Opportunity Name	Cincinnati Public Schools - Bond Hill - HVAC Lighting
Project Name	Cincinnati Public Schools - Bond Hill - HVAC Lighting

Application # 12-007

Rev.	0
State	OH

Note: all data from "Duke.CinciPub\_BondHill.HRW.Calcs.xlsx" received 3-5-2012, except as otherwise noted

USA\_OH\_Cincinnati.Muni.AP-Lunken.Field.724297\_TMY3.bin

HEAT RECOVERY WHEEL SAVINGS AHU-1

Minimum Fraction Outdoor Air: 37.1%  
 Heat Recover Effectiveness: 80.0%  
 Set Point Temperature: 77 F  
 Set Point Enthalpy: 28.27 Btu/lba  
 Supply Air Temperature: 52.6 F  
 Supply Air Enthalpy: 22.51 Btu/lba  
 Supply Air Volume: 38,000 cfm  
 Supply Air Density: 0.075 lb/ft^3

StrTemp (F)	EndTemp (F)	Toa (F)	hoa (Btu/lba)	hrs	foa	Tma (F)	hma (Btu/lba)	Savings Q (mmBTU)	Baseline Q (mmBTU)	Proposed Q (mmBTU)
105	109	107.0	0	0	37%	88.1	17.78	0.00	0.00	0.00
100	104	102.0	0	0	37%	86.3	17.78	0.00	0.00	0.00
95	99	96.1	42.6	12	37%	84.1	33.59	8.73	10.91	2.18
90	94	92.2	39.6	41	37%	82.6	32.48	23.57	29.47	5.89
85	89	87.6	37.7	142	37%	80.9	31.77	67.95	84.94	16.99
80	84	82.4	35.0	250	37%	79.0	30.77	85.37	106.71	21.34
75	79	77.2	33.4	287	37%	77.1	30.18	74.69	93.36	18.67
70	74	72.5	31.9	241	100%	72.5	31.90	119.58	149.47	29.89
65	69	68.0	29.1	252	100%	68.0	29.10	28.51	35.64	7.13
60	64	62.6	24.8	322	100%	62.6	24.80	0.00	0.00	0.00
55	59	57.1	21.9	222	100%	57.1	21.90	0.00	0.00	0.00
50	54	52.0	19.2	226	98%	52.6	19.42	0.00	0.00	0.00
45	49	47.5	17.3	151	83%	52.6	19.20	0.00	0.00	0.00
40	44	43.1	15.2	211	72%	52.6	18.86	0.00	0.00	0.00
35	39	37.6	12.9	206	62%	52.6	18.75	0.00	0.00	0.00
30	34	32.4	10.8	135	55%	52.6	18.71	0.00	0.00	0.00
25	29	27.7	9.0	99	49%	52.6	18.73	0.00	0.00	0.00
20	24	23.3	7.5	66	45%	52.6	18.83	0.00	0.00	0.00
15	19	18.3	5.9	36	42%	52.6	18.97	0.00	0.00	0.00
10	14	12.5	4.1	16	38%	52.6	19.13	0.00	0.00	0.00
5	9	7.5	2.7	5	37%	51.2	18.78	0.00	0.00	0.00
0	4	3.0	1.4	0	37%	49.5	18.30	0.00	0.00	0.00
<b>Annual Total mmBTU:</b>								<b>408.39</b>	<b>510.49</b>	<b>102.10</b>

<b>Energy recovery wheel motor</b>	
Motor Size hp:	0.5
Load Factor:	0.85
Motor Efficiency:	81.0%
hp to kW conversion:	0.7456
<b>Motor kW:</b>	<b>0.391</b>
<b>Motor kWh:</b>	<b>479</b>

Annual Ton-hours:	34,033	42,541	8,508
75% Load EER:	12.42	12.42	12.42
75% Load kW/Ton:	0.966	0.966	0.966
<b>Cooling kWh:</b>	<b>32,882</b>	<b>41,102</b>	<b>8,220</b>
Heat Recovery Hours of Operation:	1,225	1,225	1,225
<b>Cooling kW:</b>	<b>26.84</b>	<b>33.55</b>	<b>6.71</b>

**Allocation of annual savings by month** (Added During Tech Review)

Trade ally only provided annual savings numbers. Use % of cooling degree days by month to distribute annual savings appropriately.

Cooling Degree Day Source: <http://www.climate-zone.com/climate/united-states/ohio/greater-cincinnati-airport/>

	Jan	Feb	Mar	April	May	June	July	Aug	Sep	Oct	Nov	Dec	Annual
CDD by Month	0.0	0.0	0.0	0.0	86.0	191.0	313.0	266.0	120.0	20.0	0.0	0.0	996.0
Degree Days % of Annual	0.0%	0.0%	0.0%	0.0%	8.6%	19.2%	31.4%	26.7%	12.0%	2.0%	0.0%	0.0%	100%
Degree Days % of Maximum	0.0%	0.0%	0.0%	0.0%	27.5%	61.0%	100.0%	85.0%	38.3%	6.4%	0.0%	0.0%	
Baseline kWh	0	0	0	0	3,549	7,882	12,917	10,977	4,952	825	0	0	41,102
Proposed kWh	0	0	0	0	751	1,668	2,734	2,323	1,048	175	0	0	8,700
kWh Savings	0	0	0	0	2,798	6,214	10,183	8,654	3,904	651	0	0	32,403
Baseline kW	0.00	0.00	0.00	0.00	9.22	20.47	33.55	28.51	12.86	2.14	0.00	0.00	33.55
Proposed kW	0.00	0.00	0.00	0.00	1.95	4.33	7.10	6.04	2.72	0.45	0.00	0.00	7.10
kW Savings	0.00	0.00	0.00	0.00	7.27	16.14	26.45	22.48	10.14	1.69	0.00	0.00	26.45

**Cell:** A8

**Comment:** zacho:

This text is from TA calculations. Don't have a copy, but file name (TMY3) indicates they used typical 30 year average temperature data.

**Cell:** D11

**Comment:** zacho:

Per "Duke.CPS\_BondHill.HRW.Specs.5.pdf", total supply airflow for AHU is 38,000 cfm and ERV Supply is 14,100.

Therefore, Fraction Outside Air =  $14,100 \div 38,000 = 37.1\%$

**Cell:** D17

**Comment:** zacho:

TA set up calculations to use "supply" through just the energy recovery unit and applied the fraction outside air to that value. However, the "supply" going through the energy recovery unit is really the full outside air CFM (14,100). Therefore, revised Supply Air Volume input for calculations to be total AHU cfm (38,000), so that when Supply Air Volume is multiplied by Minimum Fraction Outside Air, the result is the outside air CFM through the energy recovery unit.

Per "Duke.CPS\_BondHill.HRW.Specs.5.pdf", total supply airflow for AHU is 38,000 cfm

Therefore, Fraction Outside Air =  $14,100 \div 38,000 = 37.1\%$

**Cell:** J19

**Comment:** zacho:

Baseline energy is energy to cool outside air with mechanical cooling. Uses same formula as savings...but removes the heat recover effectiveness input.

**Cell:** A20

**Comment:** zacho:

Start temperature for bin

**Cell:** B20

**Comment:** zacho:

End temperature for bin

**Cell:** C20

**Comment:** zacho:

Temp. of outside air in deg. F

**Cell:** D20

**Comment:** zacho:

Enthalpy of outside air

**Cell:** F20

**Comment:** zacho:

Fraction outside air

**Cell:** G20

**Comment:** zacho:

Temperature of mixed air

**Cell:** H20

**Comment:** zacho:

Enthalpy of mixed air

**Cell:** I20

**Comment:** zacho:

Heat Recover Effectiveness x Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

**Cell:** J20

**Comment:** zacho:

NOTE: This column developed by WECC

Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

**Cell:** K20

**Comment:** bchiesa:

NOTE: This column developed by WECC

**Cell:** H44

**Comment:** zacho:

= Q in mmBTU x 1,000,000 btu per mmBTU ÷ 12,000 BTU per ton

**Cell:** B45

**Comment:** zacho:

Per "Duke.CPS\_BondHill.HRW.Specs.5.pdf"

**Cell:** H45

**Comment:** zacho:

per "Duke.CPS\_BondHill.Chiller.Specs.1.pdf"

**Cell:** B46

**Comment:** zacho:

Estimate...typically between 80-90%, so chose 85% load factor.

**Cell:** H46

**Comment:** zacho:

$\text{kW/ton} = 12 \div \text{EER}$

**Cell:** B47

**Comment:** zacho:

Motor efficiency for 1.0 hp TEFC EPACT efficient motor is 82.5%...so used slightly less efficient than that for 0.5 hp motor.

**Cell:** H47

**Comment:** zacho:

=annual ton hours x 75% load kW/ton

**Cell:** B49

**Comment:** zacho:

Motor size hp x Load Factor x hp to kW conversion  $\div$  Motor Efficiency

**Cell:** B50

**Comment:** zacho:

Motor kW x Heat Recovery Hours of Operation

**Cell:** A59

**Comment:** zacho:

Degree Days % of Annual x (Sum baseline kW for all energy recovery units)

**Cell:** A60

**Comment:** zacho:

Degree Days % of Annual x [(sum of proposed kWh for all energy recovery units) + sum of energy recovery wheel motor kWh used for all energy recovery units]]

**Cell:** A62

**Comment:** zacho:

Degree Days % of Maximum x (Sum baseline kW for all energy recovery units)

**Cell:** A63

**Comment:** zacho:

Degree Days % of Maximum x [(sum of proposed kW for all energy recovery units) + sum of energy recovery wheel motor kW used for all energy recovery units]]

DETAILED CALCULATIONS - ECM2

JAN 2012 V2

Salesforce Opportunity Name Cincinnati Public Schools - Carson - HVAC Lighting  
 Project Name Cincinnati Public Schools - Carson - HVAC Lighting

Application # 12-008

Rev. 0  
 State OH

Note: all data from "HeatRecov.Calc.Cinci.xlsx" received 3-5-2012, except as otherwise noted

USA\_OH\_Cincinnati.Muni.AP-Lunken.Field.724297\_TMY3.bin

HEAT RECOVERY WHEEL SAVINGS **HRU-1 (Serves AHU-3)**

Minimum Fraction Outdoor Air: 38.9%  
 Heat Recover Effectiveness: 79.4%  
 Set Point Temperature: 75 F  
 Set Point Enthalpy: 28.43 Btu/lba  
 Supply Air Temperature: 52 F  
 Supply Air Enthalpy: 20.82 Btu/lba  
 Supply Air Volume: 25,760 cfm  
 Supply Air Density: 0.075 lb/ft^3

StrTemp (F)	EndTemp (F)	Toa (F)	hoa (Btu/lba)	hrs	foa	Tma (F)	hma (Btu/lba)	Savings Q (mmBTU)	Baseline Q (mmBTU)	Proposed Q (mmBTU)
105	109	107.0	0	0	39%	87.4	17.38	0.00	0.00	0.00
100	104	102.0	0	0	39%	85.5	17.38	0.00	0.00	0.00
95	99	96.1	42.6	12	39%	83.2	33.94	6.08	7.66	1.58
90	94	92.2	39.6	41	39%	81.7	32.77	16.38	20.62	4.25
85	89	87.6	37.7	142	39%	79.9	32.03	47.06	59.28	12.21
80	84	82.4	35.0	250	39%	77.9	30.98	58.72	73.95	15.23
75	79	77.2	33.4	287	39%	75.9	30.36	50.99	64.21	13.23
70	74	72.5	31.9	241	100%	72.5	31.90	76.90	96.86	19.95
65	69	68.0	29.1	252	100%	68.0	29.10	15.47	19.48	4.01
60	64	62.6	24.8	322	100%	62.6	24.80	0.00	0.00	0.00
55	59	57.1	21.9	222	100%	57.1	21.90	0.00	0.00	0.00
50	54	52.0	19.2	226	100%	52.0	19.20	0.00	0.00	0.00
45	49	47.5	17.3	151	84%	52.0	19.12	0.00	0.00	0.00
40	44	43.1	15.2	211	72%	52.0	18.89	0.00	0.00	0.00
35	39	37.6	12.9	206	61%	52.0	18.88	0.00	0.00	0.00
30	34	32.4	10.8	135	54%	52.0	18.91	0.00	0.00	0.00
25	29	27.7	9.0	99	49%	52.0	18.98	0.00	0.00	0.00
20	24	23.3	7.5	66	44%	52.0	19.12	0.00	0.00	0.00
15	19	18.3	5.9	36	41%	52.0	19.29	0.00	0.00	0.00
10	14	12.5	4.1	16	39%	50.7	18.98	0.00	0.00	0.00
5	9	7.5	2.7	5	39%	48.8	18.43	0.00	0.00	0.00
0	4	3.0	1.4	0	39%	47.0	17.93	0.00	0.00	0.00

Annual Total mmBTU **271.60 342.06 70.47**

Energy recovery wheel motor  
 Annual Ton-hours: 22,633 28,505 5,872  
 Motor Size hp: 0.375  
 Load Factor: 0.85  
 75% Load EER: 10.50 10.50 10.50  
 75% Load kW/Ton: 1.143 1.143 1.143  
 Motor Efficiency: 81.0%  
**Cooling kWh: 25,867 32,577 6,711**  
 hp to kW conversion: 0.7456  
 Heat Recovery Hours of Operation: 1,225 1,225 1,225  
**Motor kW: 0.293**  
**Cooling kW: 21.12 26.59 5.48**  
**Motor kWh: 359**

DETAILED CALCULATIONS - ECM2

JAN 2012 V2

Salesforce Opportunity Name **Cincinnati Public Schools - Carson - HVAC Lighting**  
 Project Name **Cincinnati Public Schools - Carson - HVAC Lighting**

Application # **12-008**

Rev. **0**  
 State **OH**

Note: all data from "HeatRecov.Calc.Cinci.xlsx" received 3-5-2012, except as otherwise noted

USA\_OH\_Cincinnati.Muni.AP-Lunken.Field.724297\_TMY3.bin

HEAT RECOVERY WHEEL SAVINGS **HRU-2 (Serves AHU-4)**

Minimum Fraction Outdoor Air: 43.0%  
 Heat Recover Effectiveness: 77.0%  
 Set Point Temperature: 75 F  
 Set Point Enthalpy: 28.43 Btu/lba  
 Supply Air Temperature: 52 F  
 Supply Air Enthalpy: 20.82 Btu/lba  
 Supply Air Volume: 25,480 cfm  
 Supply Air Density: 0.075 lb/ft^3

StrTemp (F)	EndTemp (F)	Toa (F)	hoa (Btu/lba)	hrs	foa	Tma (F)	hma (Btu/lba)	Savings Q (mmBTU)	Baseline Q (mmBTU)	Proposed Q (mmBTU)
105	109	107	0	0	43%	88.8	16 20	0.00	0.00	0 00
100	104	102	0	0	43%	86.6	16 20	0.00	0.00	0 00
95	99	96.1	42.6	12	43%	84.1	34 52	6.46	8.38	1 93
90	94	92.2	39.6	41	43%	82.4	33 23	17.39	22.58	5.19
85	89	87.6	37.7	142	43%	80.4	32.42	49.98	64.91	14 93
80	84	82.4	35	250	43%	78.2	31 26	62.36	80.99	18.63
75	79	77.2	33.4	287	43%	75.9	30 57	54.16	70.34	16.18
70	74	72.5	31.9	241	100%	72.5	31 90	73.83	95.89	22 05
65	69	68	29.1	252	100%	68.0	29.10	14.91	19.36	4.45
60	64	62.6	24.8	322	100%	62.6	24 80	0.00	0.00	0 00
55	59	57.1	21.9	222	100%	57.1	21 90	0.00	0.00	0 00
50	54	52	19.2	226	100%	52.0	19 20	0.00	0.00	0 00
45	49	47.5	17.3	151	84%	52.0	19.12	0.00	0.00	0 00
40	44	43.1	15.2	211	72%	52.0	18 89	0.00	0.00	0 00
35	39	37.6	12.9	206	61%	52.0	18 88	0.00	0.00	0 00
30	34	32.4	10.8	135	54%	52.0	18 91	0.00	0.00	0 00
25	29	27.7	9	99	49%	52.0	18 98	0.00	0.00	0 00
20	24	23.3	7.5	66	44%	52.0	19.12	0.00	0.00	0 00
15	19	18.3	5.9	36	43%	50.6	18.74	0.00	0.00	0 00
10	14	12.5	4.1	16	43%	48.1	17 97	0.00	0.00	0 00
5	9	7.5	2.7	5	43%	46.0	17 36	0.00	0.00	0 00
0	4	3	1.4	0	43%	44.0	16 81	0.00	0.00	0 00

Energy recovery wheel motor	
Motor Size hp:	0.375
Load Factor:	0.85
Motor Efficiency:	81.0%
hp to kW conversion:	0.7456
<b>Motor kW:</b>	<b>0.293</b>
<b>Motor kWh:</b>	<b>359</b>

Annual Total mmBTU	<b>279.09</b>	<b>362.45</b>	<b>83.36</b>
Annual Ton-hours:	23,257	30,204	6,947
75% Load EER:	10.5	10.5	10.5
75% Load kW/Ton:	1.143	1.143	1.143
<b>Cooling kWh:</b>	<b>26,580</b>	<b>34,519</b>	<b>7,939</b>
Heat Recovery Hours of Operation:	1,225	1,225	1,225
<b>Cooling kW:</b>	<b>21.70</b>	<b>28.18</b>	<b>6.48</b>

Allocation of annual savings by month (Added During Tech Review)

Trade ally only provided annual savings numbers. Use % of cooling degree days by month to distribute annual savings appropriately.

Cooling Degree Day Source:

<http://www.climate-zone.com/climate/united-states/ohio/greater-cincinnati-airport/>

	Jan	Feb	Mar	April	May	June	July	Aug	Sep	Oct	Nov	Dec	Annual
CDD by Month	0.0	0.0	0.0	0.0	86.0	191.0	313.0	266.0	120.0	20.0	0.0	0 0	996 0
Degree Days % of Annual	0.0%	0.0%	0.0%	0.0%	8.6%	19.2%	31.4%	26.7%	12.0%	2.0%	0.0%	0 0%	100%
Degree Days % of Maximum	0.0%	0.0%	0.0%	0.0%	27.5%	61.0%	100 0%	85.0%	38.3%	6.4%	0.0%	0 0%	
Baseline kWh	0	0	0	0	5,794	12,867	21,086	17,919	8,084	1,347	0	0	67,097
Proposed kWh	0	0	0	0	1,327	2,947	4,830	4,105	1,852	309	0	0	15,369
kWh Savings	0	0	0	0	4,466	9,920	16,256	13,815	6,232	1,039	0	0	51,728
Baseline kW	0.00	0.00	0.00	0.00	15.05	33.42	54.77	46.55	21.00	3.50	0.00	0.00	54.77
Proposed kW	0.00	0.00	0.00	0.00	3.45	7.66	12.55	10.66	4 81	0.80	0.00	0.00	12.55
kW Savings	0.00	0.00	0.00	0.00	11.60	25.77	42.23	35.89	16.19	2.70	0.00	0.00	42.23

**Cell:** A8

**Comment:** zacho:

This text is from TA calculations. Don't have a copy, but file name (TMY3) indicates they used typical 30 year average temperature data.

**Cell:** D11

**Comment:** zacho:

Per "CPS.Carson.hvac.schedule.pdf", total supply airflow for AHU is 25,760 cfm. Per "Duke.CinciPub\_Carson.HRU.specs.1.JPG", ERV Supply is 10,010.

Therefore, Fraction Outside Air =  $10,010 \div 25,760 = 38.9\%$

**Cell:** D17

**Comment:** zacho:

TA set up calculations to use "supply" through just the energy recovery unit and applied the fraction outside air to that value. However, the "supply" going through the energy recovery unit is really the full outside air CFM (10,010). Therefore, revised Supply Air Volume input for calculations to be total AHU cfm (25,760), so that when Supply Air Volume is multiplied by Minimum Fraction Outside Air, the result is the outside air CFM through the energy recovery unit.

Per "CPS.Carson.hvac.schedule.pdf", total supply airflow for AHU is 25,760 cfm

Per "Duke.CinciPub\_Carson.HRU.specs.1.JPG", total outside airflow for AHU is 10,010 cfm

Therefore, Fraction Outside Air =  $10,010 \div 25,760 = 38.9\%$

**Cell:** J19

**Comment:** zacho:

Baseline energy is energy to cool outside air with mechanical cooling. Uses same formula as savings...but removes the heat recover effectiveness input.

**Cell:** A20

**Comment:** zacho:

Start temperature for bin

**Cell:** B20

**Comment:** zacho:

End temperature for bin

**Cell:** C20

**Comment:** zacho:

Temp. of outside air in deg. F

**Cell:** D20

**Comment:** zacho:

Enthalpy of outside air

**Cell:** F20

**Comment:** zacho:

Fraction outside air

**Cell:** G20

**Comment:** zacho:

Temperature of mixed air

**Cell:** H20

**Comment:** zacho:

Enthalpy of mixed air

**Cell:** I20

**Comment:** zacho:

Heat Recover Effectiveness x Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

**Cell:** J20

**Comment:** zacho:

NOTE: This column developed by WECC

Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

**Cell:** K20

**Comment:** bchiesa:

NOTE: This column developed by WECC

**Cell:** H44

**Comment:** zacho:

= Q in mmBTU x 1,000,000 btu per mmBTU ÷ 12,000 BTU per ton

**Cell:** B45

**Comment:** zacho:

Motor hp not listed in submittal data provided by TA, nor is it listed on Mfg. website. Therefore, estimated motor hp using App. 12-007 (Bond Hill) as a basis:

Bond Hill = 0.5 hp for 14,100 cfm ERV

This ERV is 10,010 cfm, so  $0.5 \times 10,010 \div 14,100 = 0.35$ , so rounded to nearest motor size: 3/8 hp (0.375)

**Cell:** H45

**Comment:** zacho:

per "CPS.Carson.hvac.Chiller.specs.2.pdf" for model RTUA125 chiller (which is listed on "CPS.Carson.hvac.schedule.pdf")

**Cell:** B46

**Comment:** zacho:

Estimate...typically between 80-90%, so chose 85% load factor.

**Cell:** H46

**Comment:** zacho:

$\text{kW/ton} = 12 \div \text{EER}$

**Cell:** B47

**Comment:** zacho:

Motor efficiency for 1.0 hp TEFC EPACT efficient motor is 82.5%...so used slightly less efficient than that for 3/8 hp motor.

**Cell:** H47

**Comment:** zacho:

=annual ton hours x 75% load kW/ton

**Cell:** B49

**Comment:** zacho:

Motor size hp x Load Factor x hp to kW conversion  $\div$  Motor Efficiency

**Cell:** B50

**Comment:** zacho:

Motor kW x Heat Recovery Hours of Operation

**Cell:** D56

**Comment:** zacho:

Per "CPS.Carson.hvac.schedule.pdf", total supply airflow for AHU is 25,480 cfm. Per "Duke.CinciPub\_Carson.HRU.specs.2.JPG", ERV Supply is 10,958.

Therefore, Fraction Outside Air =  $10,958 \div 25,480 = 43.0\%$

**Cell:** D62

**Comment:** zacho:

TA set up calculations to use "supply" through just the energy recovery unit and applied the fraction outside air to that value. However, the "supply" going through the energy recovery unit is really the full outside air CFM (10,958). Therefore, revised Supply Air Volume input for calculations to be total AHU cfm (25,480), so that when Supply Air Volume is multiplied by Minimum Fraction Outside Air, the result is the outside air CFM through the energy recovery unit.

Per "CPS.Carson.hvac.schedule.pdf", total supply airflow for AHU is 25,480 cfm

Per "Duke.CinciPub\_Carson.HRU.specs.2.JPG", total outside airflow for AHU is 10,958 cfm

Therefore, Fraction Outside Air =  $10,958 \div 25,480 = 43.0\%$

**Cell:** J64

**Comment:** zacho:

Baseline energy is energy to cool outside air with mechanical cooling. Uses same formula as savings...but removes the heat recover effectiveness input.

**Cell:** A65

**Comment:** zacho:

Start temperature for bin

**Cell:** B65

**Comment:** zacho:

End temperature for bin

**Cell:** C65

**Comment:** zacho:

Temp. of outside air in deg. F

**Cell:** D65

**Comment:** zacho:

Enthalpy of outside air

**Cell:** F65

**Comment:** zacho:

Fraction outside air

**Cell:** G65

**Comment:** zacho:  
Temperature of mixed air

**Cell:** H65

**Comment:** zacho:  
Enthalpy of mixed air

**Cell:** I65

**Comment:** zacho:  
Heat Recover Effectiveness x Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

**Cell:** J65

**Comment:** zacho:  
NOTE: This column developed by WECC  
  
Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

**Cell:** K65

**Comment:** bchiesa:  
NOTE: This column developed by WECC

**Cell:** H89

**Comment:** zacho:  
 $= Q \text{ in mmBTU} \times 1,000,000 \text{ btu per mmBTU} \div 12,000 \text{ BTU per ton}$

**Cell:** B90

**Comment:** zacho:  
Motor hp not listed in submittal data provided by TA, nor is it listed on Mfg. website. Therefore, estimated motor hp using App. 12-007 (Bond Hill) as a basis:  
  
Bond Hill = 0.5 hp for 14,100 cfm ERV  
  
This ERV is 10,958 cfm, so  $0.5 \times 10,958 \div 14,100 = 0.386$ , so rounded to nearest motor size: 3/8 hp (0.375)

**Cell:** H90

**Comment:** zacho:  
per "Duke.CPS\_BondHill.Chiller.Specs.1.pdf"

**Cell:** B91

**Comment:** zacho:  
Estimate...typically between 80-90%, so chose 85% load factor.

**Cell:** H91

**Comment:** zacho:  
 $\text{kW/ton} = 12 \div \text{EER}$

**Cell:** B92

**Comment:** zacho:  
Motor efficiency for 1.0 hp TEFC EPACT efficient motor is 82.5%...so used slightly less efficient than that for 3/8 hp motor.

**Cell:** H92

**Comment:** zacho:  
 $= \text{annual ton hours} \times 75\% \text{ load kW/ton}$

**Cell:** B94

**Comment:** zacho:  
Motor size hp x Load Factor x hp to kW conversion  $\div$  Motor Efficiency

**Cell:** B95

**Comment:** zacho:  
Motor kW x Heat Recovery Hours of Operation

**Cell:** A104

**Comment:** zacho:  
Degree Days % of Annual x (Sum baseline kW for all energy recovery units)

**Cell:** A105

**Comment:** zacho:  
Degree Days % of Annual x [(sum of proposed kWh for all energy recovery units) + sum of energy recovery wheel motor kWh used for all energy recovery units]

**Cell:** A107

**Comment:** zacho:  
Degree Days % of Maximum x (Sum baseline kW for all energy recovery units)

**Cell:** A108

**Comment:** zacho:  
Degree Days % of Maximum x [(sum of proposed kW for all energy recovery units) + sum of energy recovery wheel motor kW used for all energy recovery units]

**DETAILED CALCULATIONS - ECM3**

**JAN 2012 V2.0**

Salesforce Opportunity Name	Cincinnati Public Schools - Fairview - HVAC Lighting
Project Name	Cincinnati Public Schools - Fairview - HVAC Lighting
ECM	2

Application # 12-009 MSD

Rev.	0
State	OH

Note: all data from "Duke.CinciPub\_Fairview.HRW.Calcs.xlsx" received 3-9-2012, except as otherwise noted

USA\_OH\_Cincinnati.Muni.AP-Lunken.Field.724297\_TMY3.bin

**HEAT RECOVERY WHEEL SAVINGS HRU-1 (Serves AHU-1)**

Minimum Fraction Outdoor Air: 88.7%  
 Heat Recover Effectiveness: 72.7%  
 Set Point Temperature: 75 F  
 Set Point Enthalpy: 28.80 Btu/lba  
 Supply Air Temperature: 52.25 F  
 Supply Air Enthalpy: 21.42 Btu/lba  
 Supply Air Volume: 14,096 cfm  
 Supply Air Density: 0.075 lb/ft^3

StrTemp (F)	EndTemp (F)	Toa (F)	hoa (Btu/lba)	hrs	foa	Tma (F)	hma (Btu/lba)	Savings Q (mmBTU)	Baseline Q (mmBTU)	Proposed Q (mmBTU)
105	109	107.0	0	0	89%	103.4	3.26	0.00	0.00	0.00
100	104	102.0	0	0	89%	98.9	3.26	0.00	0.00	0.00
95	99	96.1	42.6	12	89%	93.7	41.04	6.77	9.32	2.55
90	94	92.2	39.6	41	89%	90.3	38.38	18.10	24.91	6.81
85	89	87.6	37.7	142	89%	86.2	36.69	51.65	71.10	19.44
80	84	82.4	35.0	250	89%	81.6	34.30	63.35	87.20	23.85
75	79	77.2	33.4	287	89%	77.0	32.88	53.96	74.28	20.31
70	74	72.5	31.9	241	100%	72.5	31.90	34.44	47.41	12.97
65	69	68.0	29.1	252	100%	68.0	29.10	3.50	4.81	1.32
60	64	62.6	24.8	322	100%	62.6	24.80	0.00	0.00	0.00
55	59	57.1	21.9	222	100%	57.1	21.90	0.00	0.00	0.00
50	54	52.0	19.2	226	99%	52.3	19.30	0.00	0.00	0.00
45	49	47.5	17.3	151	89%	50.6	18.60	0.00	0.00	0.00
40	44	43.1	15.2	211	89%	46.7	16.74	0.00	0.00	0.00
35	39	37.6	12.9	206	89%	41.8	14.70	0.00	0.00	0.00
30	34	32.4	10.8	135	89%	37.2	12.84	0.00	0.00	0.00
25	29	27.7	9.0	99	89%	33.1	11.24	0.00	0.00	0.00
20	24	23.3	7.5	66	89%	29.2	9.91	0.00	0.00	0.00
15	19	18.3	5.9	36	89%	24.7	8.49	0.00	0.00	0.00
10	14	12.5	4.1	16	89%	19.6	6.90	0.00	0.00	0.00
5	9	7.5	2.7	5	89%	15.1	5.66	0.00	0.00	0.00
0	4	3.0	1.4	0	89%	11.2	4.50	0.00	0.00	0.00

Annual Total mmBTU:	<b>231.77</b>	<b>319.02</b>	<b>87.25</b>
Annual Ton-hours:	19,314	26,585	7,271
Chiller IPLV EER:	13.90	13.90	13.90
Chiller IPLV kW/Ton:	0.863	0.863	0.863
<b>Cooling kWh:</b>	<b>16,674</b>	<b>22,951</b>	<b>6,277</b>
Heat Recovery Hours of Operation:	1,225	1,225	1,225
<b>Cooling kW:</b>	<b>13.61</b>	<b>18.74</b>	<b>5.12</b>

<b>Energy recovery wheel motor</b>	
Motor Size hp:	0.5
Load Factor:	0.85
Motor Efficiency:	81.0%
hp to kW conversion:	0.7456
<b>Motor kW:</b>	<b>0.391</b>
<b>Motor kWh:</b>	<b>479</b>

DETAILED CALCULATIONS - ECM3

JAN 2012 V2.0

Salesforce Opportunity Name	Cincinnati Public Schools - Fairview - HVAC Lighting
Project Name	Cincinnati Public Schools - Fairview - HVAC Lighting
ECM	2

Application # 12-009 MSD

Rev.	0
State	OH

Note: all data from "Duke.CinciPub\_Fairview.HRW.Calcs.xlsx" received 3-9-2012, except as otherwise noted

USA\_OH\_Cincinnati.Muni.AP-Lunken.Field.724297\_TMY3.bin

HEAT RECOVERY WHEEL SAVINGS **HRU-2 (Serves AHU-2)**

Minimum Fraction Outdoor Air: 57.8%  
 Heat Recover Effectiveness: 72.6%  
 Set Point Temperature: 75 F  
 Set Point Enthalpy: 28.80 Btu/lba  
 Supply Air Temperature: 50.85 F  
 Supply Air Enthalpy: 20.68 Btu/lba  
 Supply Air Volume: 23,253 cfm  
 Supply Air Density: 0.075 lb/ft^3

StrTemp (F)	EndTemp (F)	Toa (F)	hoa (Btu/lba)	hrs	foa	Tma (F)	hma (Btu/lba)	Savings	Baseline	Proposed
								Q (mmBTU)	Q (mmBTU)	Q (mmBTU)
105	109	107	0	0	58%	93.5	12.14	0.00	0.00	0.00
100	104	102	0	0	58%	90.6	12.14	0.00	0.00	0.00
95	99	96.1	42.6	12	58%	87.2	36.78	7.28	10.02	2.74
90	94	92.2	39.6	41	58%	84.9	35.05	19.47	26.80	7.34
85	89	87.6	37.7	142	58%	82.3	33.95	55.56	76.49	20.94
80	84	82.4	35	250	58%	79.3	32.39	68.14	93.82	25.68
75	79	77.2	33.4	287	58%	76.3	31.46	58.04	79.92	21.87
70	74	72.5	31.9	241	100%	72.5	31.90	56.80	78.20	21.40
65	69	68	29.1	252	100%	68.0	29.10	5.76	7.94	2.17
60	64	62.6	24.8	322	100%	62.6	24.80	0.00	0.00	0.00
55	59	57.1	21.9	222	100%	57.1	21.90	0.00	0.00	0.00
50	54	52	19.2	226	100%	52.0	19.20	0.00	0.00	0.00
45	49	47.5	17.3	151	88%	50.9	18.70	0.00	0.00	0.00
40	44	43.1	15.2	211	76%	50.9	18.50	0.00	0.00	0.00
35	39	37.6	12.9	206	65%	50.9	18.53	0.00	0.00	0.00
30	34	32.4	10.8	135	58%	50.4	18.39	0.00	0.00	0.00
25	29	27.7	9	99	58%	47.6	17.35	0.00	0.00	0.00
20	24	23.3	7.5	66	58%	45.1	16.48	0.00	0.00	0.00
15	19	18.3	5.9	36	58%	42.2	15.55	0.00	0.00	0.00
10	14	12.5	4.1	16	58%	38.9	14.51	0.00	0.00	0.00
5	9	7.5	2.7	5	58%	36.0	13.70	0.00	0.00	0.00
0	4	3	1.4	0	58%	33.4	12.95	0.00	0.00	0.00

<b>Energy recovery wheel motor</b>	
Motor Size hp:	0.5
Load Factor:	0.85
Motor Efficiency:	81.0%
hp to kW conversion:	0.7456
<b>Motor kW:</b>	<b>0.391</b>
<b>Motor kWh:</b>	<b>479</b>

Annual Total mmbTU:	<b>271.05</b>	<b>373.19</b>	<b>102.14</b>
Annual Ton-hours:	22,588	31,100	8,512
Chiller IPLV EER:	13.90	13.90	13.90
Chiller IPLV kW/Ton:	0.863	0.863	0.863
<b>Cooling kWh:</b>	<b>19,500</b>	<b>26,849</b>	<b>7,348</b>
Heat Recovery Hours of Operation:	1,225	1,225	1,225
<b>Cooling kW:</b>	<b>15.92</b>	<b>21.92</b>	<b>6.00</b>

**DETAILED CALCULATIONS - ECM3**

**JAN 2012 V2.0**

Salesforce Opportunity Name	Cincinnati Public Schools - Fairview - HVAC Lighting
Project Name	Cincinnati Public Schools - Fairview - HVAC Lighting
ECM	2

Application # 12-009 MSD

Rev.	0
State	OH

Note: all data from "Duke.CinciPub\_Fairview.HRW.Calcs.xlsx" received 3-9-2012, except as otherwise noted

USA\_OH\_Cincinnati.Muni.AP-Lunken.Field.724297\_TMY3.bin

HEAT RECOVERY WHEEL SAVINGS **HRU-3 (Serves AHU-3)**

Minimum Fraction Outdoor Air:	53.9%
Heat Recover Effectiveness:	71.1%
Set Point Temperature:	75 F
Set Point Enthalpy:	28.80 Btu/lba
Supply Air Temperature:	52.3 F
Supply Air Enthalpy:	21.51 Btu/lba
Supply Air Volume:	23,849 cfm
Supply Air Density:	0.075 lb/ft^3

StrTemp (F)	EndTemp (F)	Toa (F)	hoa (Btu/lba)	hrs	foa	Tma (F)	hma (Btu/lba)	Savings	Baseline	Proposed
								Q (mmBTU)	Q (mmBTU)	Q (mmBTU)
105	109	107	0	0	54%	92.3	13.27	0.00	0.00	0.00
100	104	102	0	0	54%	89.6	13.27	0.00	0.00	0.00
95	99	96.1	42.6	12	54%	86.4	36.24	6.82	9.59	2.77
90	94	92.2	39.6	41	54%	84.3	34.62	18.23	25.63	7.40
85	89	87.6	37.7	142	54%	81.8	33.60	52.02	73.16	21.13
80	84	82.4	35	250	54%	79.0	32.14	63.80	89.73	25.92
75	79	77.2	33.4	287	54%	76.2	31.28	54.35	76.43	22.08
70	74	72.5	31.9	241	100%	72.5	31.90	57.03	80.21	23.17
65	69	68	29.1	252	100%	68.0	29.10	5.79	8.14	2.35
60	64	62.6	24.8	322	100%	62.6	24.80	0.00	0.00	0.00
55	59	57.1	21.9	222	100%	57.1	21.90	0.00	0.00	0.00
50	54	52	19.2	226	99%	52.3	19.33	0.00	0.00	0.00
45	49	47.5	17.3	151	83%	52.3	19.31	0.00	0.00	0.00
40	44	43.1	15.2	211	71%	52.3	19.12	0.00	0.00	0.00
35	39	37.6	12.9	206	61%	52.3	19.15	0.00	0.00	0.00
30	34	32.4	10.8	135	54%	52.0	19.09	0.00	0.00	0.00
25	29	27.7	9	99	54%	49.5	18.12	0.00	0.00	0.00
20	24	23.3	7.5	66	54%	47.1	17.31	0.00	0.00	0.00
15	19	18.3	5.9	36	54%	44.4	16.45	0.00	0.00	0.00
10	14	12.5	4.1	16	54%	41.3	15.48	0.00	0.00	0.00
5	9	7.5	2.7	5	54%	38.6	14.72	0.00	0.00	0.00
0	4	3	1.4	0	54%	36.2	14.02	0.00	0.00	0.00

Energy recovery wheel motor	
Motor Size hp:	0.5
Load Factor:	0.85
Motor Efficiency:	81.0%
hp to kW conversion:	0.7456
<b>Motor kW:</b>	<b>0.391</b>
<b>Motor kWh:</b>	<b>479</b>

Annual Total mmBTU:	<b>258.04</b>	<b>362.87</b>	<b>104.83</b>
Annual Ton-hours:	21,503	30,239	8,736
Chiller IPLV EER:	13.90	13.90	13.90
Chiller IPLV kW/Ton:	0.863	0.863	0.863
<b>Cooling kWh:</b>	<b>18,564</b>	<b>26,106</b>	<b>7,542</b>
Heat Recovery Hours of Operation:	1,225	1,225	1,225
<b>Cooling kW:</b>	<b>15.15</b>	<b>21.31</b>	<b>6.16</b>

**Allocation of annual savings by month** (Note: this table prepared by WECC)

Trade ally only provided annual savings numbers. Use % of cooling degree days by month to distribute annual savings appropriately.

Cooling Degree Day Source: <http://www.climate-zone.com/climate/united-states/ohio/greater-cincinnati-airport/>

	Jan	Feb	Mar	April	May	June	July	Aug	Sep	Oct	Nov	Dec	Annual
CDD by Month	0.0	0.0	0.0	0.0	86.0	191.0	313.0	266.0	120.0	20.0	0.0	0.0	996.0
Degree Days % of Annual	0.0%	0.0%	0.0%	0.0%	8.6%	19.2%	31.4%	26.7%	12.0%	2.0%	0.0%	0.0%	100%
Degree Days % of Maximum	0.0%	0.0%	0.0%	0.0%	27.5%	61.0%	100.0%	85.0%	38.3%	6.4%	0.0%	0.0%	
Baseline kWh	0	0	0	0	6,554	14,556	23,854	20,272	9,145	1,524	0	0	75,905
Proposed kWh	0	0	0	0	1,952	4,335	7,104	6,037	2,724	454	0	0	22,605
kWh Savings	0	0	0	0	4,602	10,221	16,750	14,235	6,422	1,070	0	0	53,300
Baseline kW	0.00	0.00	0.00	0.00	17.03	37.81	61.96	52.66	23.76	3.96	0.00	0.00	61.96
Proposed kW	0.00	0.00	0.00	0.00	5.07	11.26	18.45	15.68	7.07	1.18	0.00	0.00	18.45
kW Savings	0.00	0.00	0.00	0.00	11.95	26.55	43.51	36.98	16.68	2.78	0.00	0.00	43.51

**Cell:** A9

**Comment:** zacho:

This text is from TA calculations. Don't have a copy, but file name (TMY3) indicates they used typical 30 year average temperature data.

**Cell:** D12

**Comment:** zacho:

Per "Duke.CinciPub\_Fairview.HRW.specs.5.JPG", total supply airflow for AHU is 14,096 cfm. Per "Duke.CinciPub\_Fairview.HRW.specs.2.JPG", ERV Supply is 12,500.

Therefore, Fraction Outside Air =  $12,500 \div 14,096 = 88.7\%$

**Cell:** D18

**Comment:** zacho:

TA set up calculations to use "supply" through just the energy recovery unit and applied the fraction outside air to that value. However, the "supply" going through the energy recovery unit is really the full outside air CFM (12,500). Therefore, revised Supply Air Volume input for calculations to be total AHU cfm (14,096), so that when Supply Air Volume is multiplied by Minimum Fraction Outside Air, the result is the outside air CFM through the energy recovery unit.

Per "Duke.CinciPub\_Fairview.HRW.specs.5.JPG", total supply airflow for AHU is 14,096 cfm

Per "Duke.CinciPub\_Fairview.HRW.specs.2.JPG", total outside airflow for AHU is 12,500 cfm

Therefore, Fraction Outside Air =  $12,500 \div 14,096 = 88.7\%$

**Cell:** J20

**Comment:** zacho:

Baseline energy is energy to cool outside air with mechanical cooling. Uses same formula as savings...but removes the heat recover effectiveness input.

**Cell:** A21

**Comment:** zacho:

Start temperature for bin

**Cell:** B21

**Comment:** zacho:

End temperature for bin

**Cell:** C21

**Comment:** zacho:

Temp. of outside air in deg. F

**Cell:** D21

**Comment:** zacho:

Enthalpy of outside air

**Cell:** F21

**Comment:** zacho:

Fraction outside air

**Cell:** G21

**Comment:** zacho:

Temperature of mixed air

**Cell:** H21

**Comment:** zacho:

Enthalpy of mixed air

**Cell:** I21

**Comment:** zacho:

Heat Recover Effectiveness x Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

**Cell:** J21

**Comment:** zacho:

NOTE: This column developed by WECC

Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

**Cell:** K21

**Comment:** bchiesa:

NOTE: This column developed by WECC

**Cell:** H45

**Comment:** zacho:

= Q in mmBTU x 1,000,000 btu per mmBTU ÷ 12,000 BTU per ton

**Cell:** B46

**Comment:** zacho:

Motor hp not listed in submittal data provided by TA. Therefore, estimated motor hp using App. 12-007 (Bond Hill) as a basis:

Bond Hill = 0.5 hp for 14,100 cfm ERV

This ERV is 12,500 cfm, so  $0.5 \times 12,500 \div 14,100 = 0.44$ , so rounded to nearest motor size: 1/2 hp (0.5)

**Cell:** H46

**Comment:** zacho:

per "Duke.CinciPub\_Fairview.Chiller.Specs.2.pdf" for model RTUA225 chiller (which is listed on "Duke.CinciPub\_Fairview.Chiller.Specs.1.JPG")

**Cell:** B47

**Comment:** zacho:  
Estimate...typically between 80-90%, so chose 85% load factor.

**Cell:** H47

**Comment:** zacho:  
 $\text{kW/ton} = 12 \div \text{EER}$

**Cell:** B48

**Comment:** zacho:  
Motor efficiency for 1.0 hp TEFC EPACT efficient motor is 82.5%...so used slightly less efficient than that for this motor.

**Cell:** H48

**Comment:** zacho:  
=annual ton hours x Chiller IPLV kW/ton

**Cell:** B50

**Comment:** zacho:  
Motor size hp x Load Factor x hp to kW conversion  $\div$  Motor Efficiency

**Cell:** B51

**Comment:** zacho:  
Motor kW x Heat Recovery Hours of Operation

**Cell:** D57

**Comment:** zacho:  
Per "Duke.CinciPub\_Fairview.HRW.specs.4.JPG", total supply airflow for AHU is 23,253 cfm. Per "Duke.CinciPub\_Fairview.HRW.specs.4.JPG", ERV Supply is 13,449.

Therefore, Fraction Outside Air =  $13,449 \div 23,253 = 57.8\%$

**Cell:** D63

**Comment:** zacho:  
TA set up calculations to use "supply" through just the energy recovery unit and applied the fraction outside air to that value. However, the "supply" going through the energy recovery unit is really the full outside air CFM (13,449). Therefore, revised Supply Air Volume input for calculations to be total AHU cfm (23,253), so that when Supply Air Volume is multiplied by Minimum Fraction Outside Air, the result is the outside air CFM through the energy recovery unit.

Per "Duke.CinciPub\_Fairview.HRW.specs.4.JPG", total supply airflow for AHU is 23,253 cfm

Per "Duke.CinciPub\_Fairview.HRW.specs.4.JPG", total outside airflow for AHU is 13,449 cfm

Therefore, Fraction Outside Air =  $13,449 \div 23,253 = 57.8\%$

**Cell:** J65

**Comment:** zacho:  
Baseline energy is energy to cool outside air with mechanical cooling. Uses same formula as savings...but removes the heat recover effectiveness input.

**Cell:** A66

**Comment:** zacho:  
Start temperature for bin

**Cell:** B66

**Comment:** zacho:  
End temperature for bin

**Cell:** C66

**Comment:** zacho:  
Temp. of outside air in deg. F

**Cell:** D66

**Comment:** zacho:  
Enthalpy of outside air

**Cell:** F66

**Comment:** zacho:  
Fraction outside air

**Cell:** G66

**Comment:** zacho:  
Temperature of mixed air

**Cell:** H66

**Comment:** zacho:  
Enthalpy of mixed air

**Cell:** I66

**Comment:** zacho:  
Heat Recover Effectiveness x Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

**Cell:** J66

**Comment:** zacho:

NOTE: This column developed by WECC

Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

**Cell:** K66

**Comment:** bchiesa:

NOTE: This column developed by WECC

**Cell:** H90

**Comment:** zacho:

= Q in mmBTU x 1,000,000 btu per mmBTU ÷ 12,000 BTU per ton

**Cell:** B91

**Comment:** zacho:

Motor hp not listed in submittal data provided by TA, nor is it listed on Mfg. website. Therefore, estimated motor hp using App. 12-007 (Bond Hill) as a basis:

Bond Hill = 0.5 hp for 14,100 cfm ERV

This ERV is 13,449 cfm, so  $0.5 \times 13,449 \div 14,100 = 0.478$ , so rounded to nearest motor size: 1/2 hp (0.5)

**Cell:** H91

**Comment:** zacho:

per "Duke.CinciPub\_Fairview.Chiller.Specs.2.pdf" for model RTUA225 chiller (which is listed on "Duke.CinciPub\_Fairview.Chiller.Specs.1.JPG")

**Cell:** B92

**Comment:** zacho:

Estimate...typically between 80-90%, so chose 85% load factor.

**Cell:** H92

**Comment:** zacho:

kW/ton = 12 ÷ EER

**Cell:** B93

**Comment:** zacho:

Motor efficiency for 1.0 hp TEFC EPACT efficient motor is 82.5%...so used slightly less efficient than that for 3/8 hp motor.

**Cell:** H93

**Comment:** zacho:

=annual ton hours x 75% load kW/ton

**Cell:** B95

**Comment:** zacho:

Motor size hp x Load Factor x hp to kW conversion ÷ Motor Efficiency

**Cell:** B96

**Comment:** zacho:

Motor kW x Heat Recovery Hours of Operation

**Cell:** D102

**Comment:** zacho:

Per "Duke.CinciPub\_Fairview.HRW.specs.4.JPG", total supply airflow for AHU is 23,849 cfm. Per "Duke.CinciPub\_Fairview.HRW.specs.4.JPG", ERV Supply is 12,862.

Therefore, Fraction Outside Air =  $12,862 \div 23,849 = 53.9\%$

**Cell:** D108

**Comment:** zacho:

TA set up calculations to use "supply" through just the energy recovery unit and applied the fraction outside air to that value. However, the "supply" going through the energy recovery unit is really the full outside air CFM (12,862). Therefore, revised Supply Air Volume input for calculations to be total AHU cfm (23,849), so that when Supply Air Volume is multiplied by Minimum Fraction Outside Air, the result is the outside air CFM through the energy recovery unit.

Per "Duke.CinciPub\_Fairview.HRW.specs.4.JPG", total supply airflow for AHU is 23,849 cfm

Per "Duke.CinciPub\_Fairview.HRW.specs.4.JPG", total outside airflow for AHU is 12,862 cfm

Therefore, Fraction Outside Air =  $12,862 \div 23,849 = 53.9\%$

**Cell:** J110

**Comment:** zacho:

Baseline energy is energy to cool outside air with mechanical cooling. Uses same formula as savings...but removes the heat recover effectiveness input.

**Cell:** A111

**Comment:** zacho:

Start temperature for bin

**Cell:** B111

**Comment:** zacho:

End temperature for bin

**Cell:** C111

**Comment:** zacho:

Temp. of outside air in deg. F

**Cell:** D111

**Comment:** zacho:  
Enthalpy of outside air

**Cell:** F111

**Comment:** zacho:  
Fraction outside air

**Cell:** G111

**Comment:** zacho:  
Temperature of mixed air

**Cell:** H111

**Comment:** zacho:  
Enthalpy of mixed air

**Cell:** I111

**Comment:** zacho:  
 $\text{Heat Recover Effectiveness} \times \text{Supply Air Volume} \times \text{foa} \times \text{Supply Air Density} \times \text{hrs} \times (\text{hoa} - \text{Set Point Enthalpy}) \times 60 \text{ minutes per hour}$

**Cell:** J111

**Comment:** zacho:  
NOTE: This column developed by WECC  
 $\text{Supply Air Volume} \times \text{foa} \times \text{Supply Air Density} \times \text{hrs} \times (\text{hoa} - \text{Set Point Enthalpy}) \times 60 \text{ minutes per hour}$

**Cell:** K111

**Comment:** bchiesa:  
NOTE: This column developed by WECC

**Cell:** H135

**Comment:** zacho:  
 $= Q \text{ in mmBTU} \times 1,000,000 \text{ btu per mmBTU} \div 12,000 \text{ BTU per ton}$

**Cell:** B136

**Comment:** zacho:  
Motor hp not listed in submittal data provided by TA, nor is it listed on Mfg. website. Therefore, estimated motor hp using App. 12-007 (Bond Hill) as a basis:  
  
Bond Hill = 0.5 hp for 14,100 cfm ERV  
  
This ERV is 12,862 cfm, so  $0.5 \times 12,862 \div 14,100 = 0.456$ , so rounded to nearest motor size: 1/2 hp (0.5)

**Cell:** H136

**Comment:** zacho:  
per "Duke.CinciPub\_Fairview.Chiller.Specs.2.pdf" for model RTUA225 chiller (which is listed on "Duke.CinciPub\_Fairview.Chiller.Specs.1.JPG")

**Cell:** B137

**Comment:** zacho:  
Estimate...typically between 80-90%, so chose 85% load factor.

**Cell:** H137

**Comment:** zacho:  
 $\text{kW/ton} = 12 \div \text{EER}$

**Cell:** B138

**Comment:** zacho:  
Motor efficiency for 1.0 hp TEFC EPACT efficient motor is 82.5%...so used slightly less efficient than that for 3/8 hp motor.

**Cell:** H138

**Comment:** zacho:  
 $= \text{annual ton hours} \times 75\% \text{ load kW/ton}$

**Cell:** B140

**Comment:** zacho:  
 $\text{Motor size hp} \times \text{Load Factor} \times \text{hp to kW conversion} \div \text{Motor Efficiency}$

**Cell:** B141

**Comment:** zacho:  
 $\text{Motor kW} \times \text{Heat Recovery Hours of Operation}$

**Cell:** A150

**Comment:** zacho:  
 $\text{Degree Days \% of Annual} \times (\text{Sum baseline kW for all energy recovery units})$

**Cell:** A151

**Comment:** zacho:  
 $\text{Degree Days \% of Annual} \times [(\text{sum of proposed kWh for all energy recovery units}) + \text{sum of energy recovery wheel motor kWh used for all energy recovery units}]$

**Cell:** A153

**Comment:** zach0:  
Degree Days % of Maximum x (Sum baseline kW for all energy recovery units)

**Cell:** A154

**Comment:** zach0:  
Degree Days % of Maximum x [(sum of proposed kW for all energy recovery units) + sum of energy recovery wheel motor kW used for all energy recovery units]]

**DETAILED CALCULATIONS - ECM4**

**JAN 2012 V2.0**

Salesforce Opportunity Name	Cincinnati Public Schools - Kilgour - Lighting
Project Name	Cincinnati Public Schools - Kilgour - Lighting
ECM	1

Application # 12-010

Rev.	0
State	OH

Note: all data from "Duke.CinciPub\_Kilgour.Lighting.Count.xlsx" received 3/9/12, except as otherwise noted

2,730	hr/yr operation - before implementation
2,730	hr/yr operation - after implementation

Only show total savings

Line items not 1 for 1 match between Baseline and Proposed Sections

Site ID	Baseline (Code)						Proposed						Savings		Other Annual Savings	Total Implementation Costs	
	Space Type	Square Feet	Watts per Sq Ft	kw per fixture	total kw	kw-hr/yr	Fixture	Qty	Watts per fixture	kw per fixture	total kw	kw-hr/yr	kw	kw-hr/yr			
1	Classroom	23,665	1.40		33.1	90,448	CH1	32	58	0.058	1.9	5,067			\$	3,008	
	Conference Room	739	1.30		1.0	2,623	CL3	12	91	0.091	1.1	2,981			\$	1,308	
	Dining	2,810	0.90		2.5	6,904	CL4	1	91	0.091	0.1	248			\$	95	
	Food Prep	871	1.20		1.0	2,853	R1	147	91	0.091	13.4	36,519			\$	13,965	
	Gym	5,957	2.30		13.7	37,404	R2	7	91	0.091	0.6	1,739			\$	735	
	Hall	16,437	0.50		8.2	22,437	R3	96	91	0.091	8.7	23,849			\$	10,080	
	Laboratory	1,654	1.40		2.3	6,322	R3A	23	91	0.091	2.1	5,714			\$	2,415	
	Laundry	48	0.60		0.0	79	R4	66	91	0.091	6.0	16,396			\$	6,270	
	Lobby	1,170	1.30		1.5	4,152	R4A	19	91	0.091	1.7	4,720			\$	1,805	
	Locker	699	0.60		0.4	1,145	R5	14	75	0.075	1.1	2,867			\$	1,666	
	Lounge	511	1.20		0.6	1,674	R7	14	35	0.035	0.5	1,338			\$	2,982	
	Mail Sorting	486	1.20		0.6	1,592	R8	29	88	0.088	2.6	6,967			\$	7,714	
	Mech/Elec	3,011	1.50		4.5	12,330	R9	3	32	0.032	0.1	262			\$	225	
	Nurse	226	1.00		0.2	617	S1	25	458	0.458	11.5	31,259			\$	5,250	
	Office	1,012	1.10		1.1	3,039	S2	151	90	0.090	13.6	37,101			\$	46,206	
	Reading	1,200	1.20		1.4	3,931	S3	18	64	0.064	1.2	3,145			\$	11,502	
	Restroom	2,443	0.90		2.2	6,002	S4	7	148	0.148	1.0	2,828			\$	1,071	
	Stacks	100	1.70		0.2	464	S5	2	90	0.090	0.2	491			\$	1,278	
	Stairs	1,782	0.60		1.1	2,919	S6	4	64	0.064	0.3	699			\$	2,556	
	Storage	1,676	0.80		1.3	3,660	T1	0	250	0.250	0.0	0			\$	-	
	Workshop	735	1.90		1.4	3,812	W1	1	129	0.129	0.1	352			\$	189	
							W2	6	14	0.014	0.1	229			\$	306	
							W3	0	150	0.150	0.0	0			\$	-	
							W4	17	57	0.057	1.0	2,645			\$	1,326	
							W5	16	36	0.036	0.6	1,572			\$	960	
							W6	0	186	0.186	0.0	0			\$	-	
							W7	1	90	0.090	0.1	246			\$	163	
<b>Totals</b>		<b>67,232</b>			<b>78.5</b>	<b>214,408</b>		<b>711</b>			<b>69.3</b>	<b>189,235</b>	<b>9.2</b>	<b>25,172</b>	<b>\$ -</b>	<b>\$ 123,075</b>	
															% of total cost that is incremental cost over code-efficient lighting system:		10.0%
															Total Incremental Project Cost:		\$ 12,308

**Cell:** H12

**Comment:** zacho:  
Proposed fixture type, quantity, and watts per fixture from "Duke.CinciPub\_Kilgour.Lighting.Count.xlsx"

**Cell:** Q12

**Comment:** zacho:  
Install Costs are per "Duke.CinciPub.Kilgour.PoP Signed.pdf"

**Cell:** J14

**Comment:** zacho:  
Fixture input watts per "Duke.CinciPub\_kilgour.Lighting.Specs6.pdf" and "Duke.CinciPub\_kilgour.Lighting.Specs7.pdf"

**Cell:** J15

**Comment:** zacho:  
Per "2012-03-09 email fm D Dumond re tech info response to 12-010.pdf", no IES files were available for CL3 fixture. Therefore, calculated input watts based on: 3 lamps x 32 watts per lamp x 0.95 estimated ballast factor = 91W

**Cell:** H16

**Comment:** zacho:  
Per "2012-03-09 email fm D Dumond re tech info response to 12-010.pdf", CL4 replaced 1 R4 fixture per Bulletin 18. It is the same as Fixture CL3

**Cell:** Q16

**Comment:** zacho:  
Per comment cell H15, CL4 fixture replaced one R4 fixture, so assumed same per-fixture cost as CL4.

**Cell:** H20

**Comment:** zacho:  
Per "2012-03-09 email fm D Dumond re tech info response to 12-010.pdf", R3A replaced R3 per Bulletin 18. It is the same as fixture R3.

**Cell:** H22

**Comment:** zacho:  
Per "2012-03-09 email fm D Dumond re tech info response to 12-010.pdf", R4A replaced R4 per Bulletin 18. It is the same as fixture R4.

**Cell:** J23

**Comment:** zacho:  
Per "Duke.CinciPub\_kilgour.Lighting.Specs9.pdf" and "Duke.CinciPub\_kilgour.Lighting.Specs10.pdf"

**Cell:** J24

**Comment:** zacho:  
per "Duke.CinciPub\_kilgour.Lighting.Specs4.pdf", specific IES files for this fixture don't exist. Calculated based on 1.1 ballast factor:

32W lamp x 1 lamp x 1.1 Ballast Factor = 35 input watts

**Cell:** J25

**Comment:** zacho:  
Per "Duke.CinciPub\_kilgour.Lighting.Specs11.pdf" and "Duke.CinciPub\_kilgour.Lighting.Specs12.pdf"

12-010 MSD Custom DSMore Input Cincinnati Public Schools-Kilgour-Light, Rev 0.xlsx  
Calculations - ECM1

**Cell:** J27

**Comment:** zacho:  
Per "Duke.CinciPub\_kilgour.Lighting.Specs13.pdf" and "Duke.CinciPub\_kilgour.Lighting.Specs14.pdf"

**Cell:** H30

**Comment:** zacho:  
per "Duke.CinciPub\_kilgour.Lighting.Specs4.pdf", no IES files exist for exact fixture. Therefore, used input watts for similar fixture with (1) 32W CFL lamp (37W) and multiplied by number of lamps in fixture S4 (4):  
 $37W \times 4 = 148W$

**Cell:** J30

**Comment:** zacho:  
(4) at 37W input each, for total of 148W

**Cell:** I33

**Comment:** zacho:  
Per "2012-03-09 email fm D Dumond re tech info response to 12-010.pdf", this fixture is excluded per exception M under ASHRAE 90.1 9.2.2.3 (stage lighting) as long as it's controlled independently from general lighting.

**Cell:** J34

**Comment:** zacho:  
Per "Duke.CinciPub\_kilgour.Lighting.Specs15.pdf"

**Cell:** I36

**Comment:** zacho:  
Per "2012-03-09 email fm D Dumond re tech info response to 12-010.pdf", was excluded since couldn't locate on the plans.

**Cell:** J38

**Comment:** zacho:  
Updated from 30W to 36W to match product data in "Duke.CinciPub\_kilgour.Lighting.Specs1.pdf"

**Cell:** I39

**Comment:** zacho:  
Per "2012-03-09 email fm D Dumond re tech info response to 12-010.pdf", excluded since only used on exterior of building.

**Cell:** J39

**Comment:** zacho:  
Estimated per Xcel Energy's Input Wattage Guide: 70W MH = 93 watts, this fixture has two 70W MH

**Cell:** J40

**Comment:** zacho:  
Fixture input watts per "Duke.CinciPub\_kilgour.Lighting.Specs8.pdf"

**Cell:** Q42

**Comment:** zacho:  
Estimate based on professional judgement

**DETAILED CALCULATIONS - ECM5**

**JAN 2012 V2.0**

Salesforce Opportunity Name	Cincinnati Public Schools - Mt Airy - HVAC Lighting
Project Name	Cincinnati Public Schools - Mt Airy - HVAC Lighting
ECM	1

Application #	12-011 MSD
---------------	---------------

Rev.	0
State	OH

Note: all data from "Duke.CinciPub\_MTAiry.Lighting.Form.xls", except as otherwise noted

2,080	hr/yr operation - before implementation
2,080	hr/yr operation - after implementation

Only show total savings

Line items not 1 for 1 match between Baseline and Proposed Sections

Site ID	Baseline (Code)						Proposed						Savings		Other Annual Savings	Total Implementation Costs	
	Building Area Type	Square Feet	Watts per Sq Ft	kw per fixture	total kw	kw-hr/yr	Fixture	Qty	Watts per fixture	kw per fixture	total kw	kw-hr/yr	kw	kw-hr/yr			
1	School	84,144	1.20		101.0	210,023	B10	24	240	0.240	5.8	11,981				\$	2,760
							B2	50	61	0.061	3.1	6,344					4,500
							B3	724	91	0.091	65.9	137,039					68,780
							B5	8	87.6	0.088	0.7	1,458					1,496
							B7	16	91	0.091	1.5	3,028					2,928
							B8	4	67	0.067	0.3	557					748
							C1	19	61	0.061	1.2	2,411					1,786
							F1	19	50	0.050	1.0	1,976					1,786
							F4	16	200	0.200	3.2	6,656					832
							H1	35	176	0.176	6.2	12,813					2,730
<b>Totals</b>		<b>84,144</b>			<b>101.0</b>	<b>210,023</b>		<b>915</b>		<b>88.6</b>	<b>184,263</b>	<b>12.4</b>	<b>25,761</b>	<b>\$ -</b>	<b>\$</b>	<b>88,346</b>	
															% of total cost that is incremental cost over code-efficient lighting system:		10.0%
															Total Incremental Project Cost:		\$ 8,835

**Cell:** B9

**Comment:** zacho:

Per updated "Duke.CinciPub\_MTAiry.Lighting.Form.xls" received 3/9/12.

**Cell:** H12

**Comment:** zacho:

Proposed fixture type, quantity, and watts per fixture from "Duke.CinciPub\_MTAiry.Lighting.Count.xlsx"

**Cell:** Q12

**Comment:** zacho:

Install Costs are per "Duke.CinciPub.Mt Airy.PoP Signed.pdf"

**Cell:** J14

**Comment:** zacho:

Revised from 200 to 240W to match IES data file from manufacturer's website ("FSK444T5HPS.IES" and "FSK-44-B-4-T5HO-S-120-G-PS-WH.pdf")

**Cell:** J15

**Comment:** zacho:

Revised from 56 to 61W to match product data ("Duke.CinciPub\_MTAiry.Lighting.Specs1.pdf" and "Duke.CinciPub\_MTAiry.Lighting.Specs2.pdf")

**Cell:** J16

**Comment:** zacho:

Revised from 85 to 91W to match product data ("Duke.CinciPub\_MTAiry.Lighting.Specs1.pdf" and "Duke.CinciPub\_MTAiry.Lighting.Specs2.pdf")

**Cell:** J17

**Comment:** zacho:

Per "Duke.CinciPub\_MtAiry.Lighting.Specs4.pdf"

**Cell:** J18

**Comment:** zacho:

Revised from 85 to 91W to match product data ("Duke.CinciPub\_MTAiry.Lighting.Specs1.pdf" and "Duke.CinciPub\_MTAiry.Lighting.Specs2.pdf")

**Cell:** J19

**Comment:** zacho:

Revised from 57 to 67W to match product data ("Duke.CinciPub\_MTAiry.Lighting.Specs1.pdf" and "Duke.CinciPub\_MTAiry.Lighting.Specs2.pdf")

**Cell:** J20

**Comment:** zacho:

Revised from 56 to 61W to match product data ("Duke.CinciPub\_MTAiry.Lighting.Specs1.pdf" and "Duke.CinciPub\_MTAiry.Lighting.Specs2.pdf")

**Cell:** H23

**Comment:** zacho:

Labeled as fixture "H" in application, but product data refers to as "H1"

**Cell:** Q25

**Comment:** zacho:

Estimate based on professional judgment

DETAILED CALCULATIONS - ECM6

JAN 2012 V2.0

Salesforce Opportunity Name	Cincinnati Public Schools - Mt Airy - HVAC Lighting
Project Name	Cincinnati Public Schools - Mt Airy - HVAC Lighting
ECM	2

Application # 12-011 MSD

Rev.	0
State	OH

Note: all data from "Duke.CinciPub\_Mt. Airy.HRW.Calcs.xlsx" received 3-9-2012, except as otherwise noted

USA\_OH\_Cincinnati.Muni.AP-Lunken.Field.724297\_TMY3.bin

HEAT RECOVERY WHEEL SAVINGS AHU-1

Minimum Fraction Outdoor Air: 38.8%  
 Heat Recover Effectiveness: 80.0%  
 Set Point Temperature: 75 F  
 Set Point Enthalpy: 28.14 Btu/lba  
 Supply Air Temperature: 53 F  
 Supply Air Enthalpy: 21.63 Btu/lba  
 Supply Air Volume: 37,000 cfm  
 Supply Air Density: 0.075 lb/ft^3

StrTemp (F)	EndTemp (F)	Toa (F)	hoa (Btu/lba)	hrs	foa	Tma (F)	hma (Btu/lba)	Savings	Baseline	Proposed
								Q (mmBTU)	Q (mmBTU)	Q (mmBTU)
105	109	107.0	0	0	39%	87.4	17.23	0.00	0.00	0.00
100	104	102.0	0	0	39%	85.5	17.23	0.00	0.00	0.00
95	99	96.1	42.6	12	39%	83.2	33.75	8.96	11.20	2.24
90	94	92.2	39.6	41	39%	81.7	32.59	24.27	30.34	6.07
85	89	87.6	37.7	142	39%	79.9	31.85	70.11	87.64	17.53
80	84	82.4	35.0	250	39%	77.9	30.80	88.57	110.71	22.14
75	79	77.2	33.4	287	39%	75.9	30.18	77.96	97.45	19.49
70	74	72.5	31.9	241	100%	72.5	31.90	120.64	150.80	30.16
65	69	68.0	29.1	252	100%	68.0	29.10	32.16	40.20	8.04
60	64	62.6	24.8	322	100%	62.6	24.80	0.00	0.00	0.00
55	59	57.1	21.9	222	100%	57.1	21.90	0.00	0.00	0.00
50	54	52.0	19.2	226	96%	53.0	19.59	0.00	0.00	0.00
45	49	47.5	17.3	151	80%	53.0	19.47	0.00	0.00	0.00
40	44	43.1	15.2	211	69%	53.0	19.22	0.00	0.00	0.00
35	39	37.6	12.9	206	59%	53.0	19.18	0.00	0.00	0.00
30	34	32.4	10.8	135	52%	53.0	19.19	0.00	0.00	0.00
25	29	27.7	9.0	99	47%	53.0	19.24	0.00	0.00	0.00
20	24	23.3	7.5	66	43%	53.0	19.36	0.00	0.00	0.00
15	19	18.3	5.9	36	39%	53.0	19.51	0.00	0.00	0.00
10	14	12.5	4.1	16	39%	50.8	18.82	0.00	0.00	0.00
5	9	7.5	2.7	5	39%	48.8	18.27	0.00	0.00	0.00
0	4	3.0	1.4	0	39%	47.1	17.77	0.00	0.00	0.00

Energy recovery wheel motor	
Motor Size hp:	0.5
Load Factor:	0.85
Motor Efficiency:	81.0%
hp to kW conversion:	0.7456
<b>Motor kW:</b>	<b>0.391</b>
<b>Motor kWh:</b>	<b>479</b>

Annual Total mmBTU	<b>422.67</b>	<b>528.33</b>	<b>105.67</b>
Annual Ton-hours	35,222	44,028	8,806
Chiller IPLV EER:	13.30	13.30	13.30
Chiller IPLV kW/Ton:	0.902	0.902	0.902
<b>Cooling kWh:</b>	<b>31,780</b>	<b>39,724</b>	<b>7,945</b>
Heat Recovery Hours of Operation:	1,225	1,225	1,225
<b>Cooling kW:</b>	<b>25.94</b>	<b>32.43</b>	<b>6.49</b>

DETAILED CALCULATIONS - ECM6

JAN 2012 V2.0

Salesforce Opportunity Name	Cincinnati Public Schools - Mt Airy - HVAC Lighting
Project Name	Cincinnati Public Schools - Mt Airy - HVAC Lighting
ECM	2

Application # 12-011 MSD

Rev.	0
State	OH

Note: all data from "Duke.CinciPub\_Mt. Airy.HRW.Calcs.xlsx" received 3-9-2012, except as otherwise noted  
 USA\_OH\_Cincinnati.Muni.AP-Lunken.Field.724297\_TMY3.bin  
 HEAT RECOVERY WHEEL SAVINGS AHU-2

Minimum Fraction Outdoor Air: 34.4%  
 Heat Recover Effectiveness: 85.0%  
 Set Point Temperature: 75 F  
 Set Point Enthalpy: 28.14 Btu/lba  
 Supply Air Temperature: 53 F  
 Supply Air Enthalpy: 21.74 Btu/lba  
 Supply Air Volume: 24,000 cfm  
 Supply Air Density: 0.075 lb/ft^3

StrTemp (F)	EndTemp (F)	Toa (F)	hoa (Btu/lba)	hrs	foa	Tma (F)	hma (Btu/lba)	Savings	Baseline	Proposed
								Q (mmBTU)	Q (mmBTU)	Q (mmBTU)
105	109	107	0	0	34%	86.0	18.47	0.00	0.00	0.00
100	104	102	0	0	34%	84.3	18.47	0.00	0.00	0.00
95	99	96.1	42.6	12	34%	82.3	33.11	5.47	6.44	0.97
90	94	92.2	39.6	41	34%	80.9	32.08	14.82	17.44	2.62
85	89	87.6	37.7	142	34%	79.3	31.43	42.83	50.39	7.56
80	84	82.4	35	250	34%	77.5	30.50	54.10	63.65	9.55
75	79	77.2	33.4	287	34%	75.8	29.95	47.62	56.02	8.40
70	74	72.5	31.9	241	100%	72.5	31.90	83.14	97.81	14.67
65	69	68	29.1	252	100%	68.0	29.10	22.16	26.07	3.91
60	64	62.6	24.8	322	100%	62.6	24.80	0.00	0.00	0.00
55	59	57.1	21.9	222	100%	57.1	21.90	0.00	0.00	0.00
50	54	52	19.2	226	96%	53.0	19.59	0.00	0.00	0.00
45	49	47.5	17.3	151	80%	53.0	19.47	0.00	0.00	0.00
40	44	43.1	15.2	211	69%	53.0	19.22	0.00	0.00	0.00
35	39	37.6	12.9	206	59%	53.0	19.18	0.00	0.00	0.00
30	34	32.4	10.8	135	52%	53.0	19.19	0.00	0.00	0.00
25	29	27.7	9	99	47%	53.0	19.24	0.00	0.00	0.00
20	24	23.3	7.5	66	43%	53.0	19.36	0.00	0.00	0.00
15	19	18.3	5.9	36	39%	53.0	19.51	0.00	0.00	0.00
10	14	12.5	4.1	16	35%	53.0	19.68	0.00	0.00	0.00
5	9	7.5	2.7	5	34%	51.8	19.40	0.00	0.00	0.00
0	4	3	1.4	0	34%	50.3	18.95	0.00	0.00	0.00

Annual Total mmBTU	270.15	317.83	47.67
Annual Ton-hours	22,513	26,486	3,973
Chiller IPLV EER:	13.30	13.30	13.30
Chiller IPLV kW/Ton:	0.902	0.902	0.902
<b>Cooling kWh:</b>	<b>20,312</b>	<b>23,897</b>	<b>3,585</b>
Heat Recovery Hours of Operation:	1,225	1,225	1,225
<b>Cooling kW:</b>	<b>16.58</b>	<b>19.51</b>	<b>2.93</b>

Energy recovery wheel motor	
Motor Size hp:	0.333
Load Factor:	0.85
Motor Efficiency:	81.0%
hp to kW conversion:	0.7456
<b>Motor kW:</b>	<b>0.261</b>
<b>Motor kWh:</b>	<b>319</b>

Allocation of annual savings by month (Note: this table prepared by WECC)

Trade ally only provided annual savings numbers. Use % of cooling degree days by month to distribute annual savings appropriately.

Cooling Degree Day Source: <http://www.climate-zone.com/climate/united-states/ohio/greater-cincinnati-airport/>

	Jan	Feb	Mar	April	May	June	July	Aug	Sep	Oct	Nov	Dec	Annual
CDD by Month	0.0	0.0	0.0	0.0	86.0	191.0	313.0	266.0	120.0	20.0	0.0	0.0	996.0
Degree Days % of Annual	0.0%	0.0%	0.0%	0.0%	8.6%	19.2%	31.4%	26.7%	12.0%	2.0%	0.0%	0.0%	100%
Degree Days % of Maximum	0.0%	0.0%	0.0%	0.0%	27.5%	61.0%	100.0%	85.0%	38.3%	6.4%	0.0%	0.0%	
Baseline kWh	0	0	0	0	5,493	12,200	19,993	16,991	7,665	1,278	0	0	63,621
Proposed kWh	0	0	0	0	1,064	2,364	3,874	3,292	1,485	248	0	0	12,328
kWh Savings	0	0	0	0	4,429	9,836	16,119	13,699	6,180	1,030	0	0	51,293
Baseline kW	0.00	0.00	0.00	0.00	14.27	31.69	51.94	44.14	19.91	3.32	0.00	0.00	51.94
Proposed kW	0.00	0.00	0.00	0.00	2.77	6.14	10.06	8.55	3.86	0.64	0.00	0.00	10.06
kW Savings	0.00	0.00	0.00	0.00	11.50	25.55	41.87	35.58	16.05	2.68	0.00	0.00	41.87

Cell: A9

Comment: zacho:

This text is from TA calculations. Don't have a copy, but file name (TMY3) indicates they used typical 30 year average temperature data.

Cell: D12

Comment: zacho:

Per "Duke.CPS.HRW.Specs.TIF", total supply airflow for AHU is 37,000 cfm and ERV Supply is 14,350.

Therefore, Fraction Outside Air =  $14,350 \div 37,000 = 38.8\%$

Cell: D18

Comment: zacho:

TA set up calculations to use "supply" through just the energy recovery unit and applied the fraction outside air to that value. However, the "supply" going through the energy recovery unit is really the full outside air CFM (14,350). Therefore, revised Supply Air Volume input for calculations to be total AHU cfm (37,000), so that when Supply Air Volume is multiplied by Minimum Fraction Outside Air, the result is the outside air CFM through the energy recovery unit.

Per "Duke.CPS.HRW.Specs.TIF", total supply airflow for AHU is 37,000 cfm

Per "Duke.CPS.HRW.Specs.TIF", total outside airflow for AHU is 14,350 cfm

Therefore, Fraction Outside Air =  $14,350 \div 37,000 = 38.8\%$

Cell: J20

Comment: zacho:

Baseline energy is energy to cool outside air with mechanical cooling. Uses same formula as savings...but removes the heat recover effectiveness input.

Cell: A21

Comment: zacho:

Start temperature for bin

Cell: B21

Comment: zacho:

End temperature for bin

Cell: C21

Comment: zacho:

Temp. of outside air in deg. F

Cell: D21

Comment: zacho:

Enthalpy of outside air

Cell: F21

Comment: zacho:

Fraction outside air

Cell: G21

Comment: zacho:

Temperature of mixed air

Cell: H21

Comment: zacho:

Enthalpy of mixed air

Cell: I21

Comment: zacho:

Heat Recover Effectiveness x Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

Cell: J21

Comment: zacho:

NOTE: This column developed by WECC

Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

Cell: K21

Comment: bchiesa:

NOTE: This column developed by WECC

Cell: H45

Comment: zacho:

= Q in mmBTU x 1,000,000 btu per mmBTU ÷ 12,000 BTU per ton

Cell: B46

Comment: zacho:

Motor hp not listed in submittal data provided by TA, nor is it listed on Mfg. website. Therefore, estimated motor hp using App. 12-007 (Bond Hill) as a basis:

Bond Hill = 0.5 hp for 14,100 cfm ERV

This ERV is 14,350 cfm, so assume same motor hp as Bond Hill project.

Cell: H46

Comment: zacho:

per "Duke.CPS\_MTAiry.Chiller.Specs.1.pdf" for model RTAC200 chiller (which is listed on "Duke.CPS\_MTAiry.Chiller.Specs.2.JPG")

**Cell:** B47

**Comment:** zacho:

Estimate...typically between 80-90%, so chose 85% load factor.

**Cell:** H47

**Comment:** zacho:

$\text{kW/ton} = 12 \div \text{EER}$

**Cell:** B48

**Comment:** zacho:

Motor efficiency for 1.0 hp TEFC EPACT efficient motor is 82.5%...so used slightly less efficient than that for 3/8 hp motor.

**Cell:** H48

**Comment:** zacho:

=annual ton hours x Chiller IPLV kW/ton

**Cell:** B50

**Comment:** zacho:

Motor size hp x Load Factor x hp to kW conversion  $\div$  Motor Efficiency

**Cell:** B51

**Comment:** zacho:

Motor kW x Heat Recovery Hours of Operation

**Cell:** D57

**Comment:** zacho:

Per "Duke.CPS.HRW.Specs.TIF", total supply airflow for AHU is 24,000 cfm and ERV Supply is 8,250.

Therefore, Fraction Outside Air =  $8,250 \div 24,000 = 34.4\%$

**Cell:** D63

**Comment:** zacho:

TA set up calculations to use "supply" through just the energy recovery unit and applied the fraction outside air to that value. However, the "supply" going through the energy recovery unit is really the full outside air CFM (8,250). Therefore, revised Supply Air Volume input for calculations to be total AHU cfm (24,000), so that when Supply Air Volume is multiplied by Minimum Fraction Outside Air, the result is the outside air CFM through the energy recovery unit.

Per "Duke.CPS.HRW.Specs.TIF", total supply airflow for AHU is 24,000 cfm

Per "Duke.CPS.HRW.Specs.TIF", total outside airflow for AHU is 8,250 cfm

Therefore, Fraction Outside Air =  $8,250 \div 24,000 = 34.4\%$

**Cell:** J65

**Comment:** zacho:

Baseline energy is energy to cool outside air with mechanical cooling. Uses same formula as savings...but removes the heat recover effectiveness input.

**Cell:** A66

**Comment:** zacho:

Start temperature for bin

**Cell:** B66

**Comment:** zacho:

End temperature for bin

**Cell:** C66

**Comment:** zacho:

Temp. of outside air in deg. F

**Cell:** D66

**Comment:** zacho:

Enthalpy of outside air

**Cell:** F66

**Comment:** zacho:

Fraction outside air

**Cell:** G66

**Comment:** zacho:

Temperature of mixed air

**Cell:** H66

**Comment:** zacho:

Enthalpy of mixed air

**Cell:** I66

**Comment:** zacho:

Heat Recover Effectiveness x Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

**Cell:** J66

**Comment:** zacho:

NOTE: This column developed by WECC

Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

**Cell:** K66

**Comment:** bchiesa:

NOTE: This column developed by WECC

**Cell:** H90

**Comment:** zacho:

= Q in mmBTU x 1,000,000 btu per mmBTU ÷ 12,000 BTU per ton

**Cell:** B91

**Comment:** zacho:

Motor hp not listed in submittal data provided by TA, nor is it listed on Mfg. website. Therefore, estimated motor hp using App. 12-007 (Bond Hill) as a basis:

Bond Hill = 0.5 hp for 14,100 cfm ERV

This ERV is 8,250 cfm, so  $0.5 \times 8,250 \div 14,100 = 0.29$ , so rounded to nearest motor size: 1/3 hp (0.333)

**Cell:** H91

**Comment:** zacho:

per "Duke.CPS\_MTAiry.Chiller.Specs.1.pdf" for model RTAC200 chiller (which is listed on "Duke.CPS\_MTAiry.Chiller.Specs.2.JPG")

**Cell:** B92

**Comment:** zacho:

Estimate...typically between 80-90%, so chose 85% load factor.

**Cell:** H92

**Comment:** zacho:

kW/ton = 12 ÷ EER

**Cell:** B93

**Comment:** zacho:

Motor efficiency for 1.0 hp TEFC EPACT efficient motor is 82.5%...so used slightly less efficient than that for 3/8 hp motor.

**Cell:** H93

**Comment:** zacho:

=annual ton hours x Chiller IPLV kW/ton

**Cell:** B95

**Comment:** zacho:

Motor size hp x Load Factor x hp to kW conversion ÷ Motor Efficiency

**Cell:** B96

**Comment:** zacho:

Motor kW x Heat Recovery Hours of Operation

**DETAILED CALCULATIONS - ECM7**

**JAN 2012 V2.0**

Salesforce Opportunity Name	Cincinnati Public Schools - Pleasant Ridge - HVAC Lighting
Project Name	Cincinnati Public Schools - Pleasant Ridge - HVAC Lighting
ECM	1

Application # 12-012

Rev.	0
State	OH

Note: all data from "Duke.CinciPub\_PleasantRidge.custom.lighting.form.xls", except as otherwise noted

Lighting Product data supplied by TA for this project is general spec sheets from manufacturer's website (vs. actual lighting submittal for the project that was submitted for other CPS MDS projects.

1,800	hr/yr operation - before implementation
1,800	hr/yr operation - after implementation

Only show total savings  
Line items not 1 for 1 match between Baseline and Proposed Sections

Site ID	Baseline (Code)						Proposed						Savings		Other Annual Savings	Total Implementation Costs	
	Building Area Type	Square Feet	Watts per Sq Ft	kw per fixture	total kw	kw-hr/yr	Fixture	Qty	Watts per fixture	kw per fixture	total kw	kw-hr/yr	kw	kw-hr/yr			
1	School	75,310	1.20		90.4	162,670	B4	18	112	0.112	2.0	3,629					
							B4G	5	112	0.112	0.6	1,008					
							C1	36	58	0.058	2.1	3,758					
							C1G	2	58	0.058	0.1	209					
							D1	3	265	0.265	0.8	1,429					
							D2	2	441	0.441	0.9	1,588					
							D4	9	176	0.176	1.6	2,858					
							F1	63	56	0.056	3.5	6,350					
							F2	3	55	0.055	0.2	295					
							F4	3	56	0.056	0.2	302					
							H1	30	202	0.202	6.0	10,886					
							H1G	10	202	0.202	2.0	3,629					
							K3	0	58	0.058	0.0	0					
							R1	707	58	0.058	41.0	73,811					
							R2	27	39	0.039	1.1	1,895					
R3	12	31	0.031	0.4	670												
<b>Totals</b>		<b>75,310</b>			<b>90.4</b>	<b>162,670</b>		<b>930</b>		<b>62.4</b>	<b>112,317</b>	<b>28.0</b>	<b>50,353</b>	<b>\$ -</b>	<b>\$ 168,624</b>		
															% of total cost that is incremental cost over code-efficient lighting system:		10.0%
															Total Incremental Project Cost:		\$ 16,862

**Cell:** B11

**Comment:** zacho:

Per "Duke.CinciPub\_PleasantRidge.custom.lighting.form.xls" received 3/9/12, which listed 1800 annual hours (this is equivalent to 8 hrs/day x 5 days/wk x 45 wks).

Daily schedule in "Duke.CinciPub\_PleasantRidge.custom.lighting.form.xls" listed 8.5 hours/day x 5 days/wk x 45 wks (for annual total of 1,912.5), but went with 1,800 hours to be conservative.

**Cell:** H14

**Comment:** zacho:

Proposed fixture type, quantity, and watts per fixture from "Duke.CinciPub\_PleasantRidge.Lighting.Count.xlsx"

**Cell:** Q14

**Comment:** zacho:

Install Costs are per "Duke.CinciPub\_PleasantRidge.PoP Signed.pdf"

**Cell:** J16

**Comment:** zacho:

Per "Duke.CinciPub\_PleasantRidge.Lighting.Specs.13.pdf"

**Cell:** J17

**Comment:** zacho:

Per "Duke.CinciPub\_PleasantRidge.Lighting.Specs.13.pdf"

**Cell:** J18

**Comment:** zacho:

Per "Duke.CinciPub\_PleasantRidge.Lighting.Specs.11.pdf"

**Cell:** J19

**Comment:** zacho:

Per "Duke.CinciPub\_PleasantRidge.Lighting.Specs.11.pdf"

**Cell:** H20

**Comment:** zacho:

TA reported that product data does not list input watts so they used 1.05 ballast factor x lamp quantity x lamp watts.

**Cell:** J20

**Comment:** zacho:

Per "e601.pdf" this as 9 lamp 28W T8 fixture, which has 3 lamps in cross section for 12 ft (3 bulb) long suspended direct/indirect fixture. Lamps are 28W T5.

**Cell:** H21

**Comment:** zacho:

TA reported that product data does not list input watts so they used 1.05 ballast factor x lamp quantity x lamp watts.

**Cell:** J21

**Comment:** zacho:

Per "e601.pdf" this as 15 lamp 28W T8 fixture, which has 3 lamps in cross section for 20 ft (5 bulb) long suspended direct/indirect fixture. Lamps are 28W T5.

**Cell:** H22

**Comment:** zacho:

TA reported that product data does not list input watts so they used 1.05 ballast factor x lamp quantity x lamp watts.

**Cell:** J22

**Comment:** zacho:

Per "e601.pdf" this as 6 lamp 28W T8 fixture, which has 3 lamps in cross section for 8 ft (2 bulb) long suspended direct/indirect fixture. Lamps are 28W T5.

**Cell:** J23

**Comment:** zacho:

Input watts per "Duke.CinciPub\_PleasantRidge.Lighting.Specs.9.pdf"

**Cell:** H24

**Comment:** zacho:

TA reported that product data does not list input watts so they used 1.05 ballast factor x lamp quantity x lamp watts.

**Cell:** J24

**Comment:** zacho:

(2) 26W CFL fixture

**Cell:** J25

**Comment:** zacho:

Input watts per "Duke.CinciPub\_PleasantRidge.Lighting.Specs.9.pdf"

**Cell:** H26

**Comment:** zacho:

TA reported that product data does not list input watts so they used 1.05 ballast factor x lamp quantity x lamp watts.

**Cell:** J26

**Comment:** zacho:

6 lamp 32W T8 high bay

**Cell:** H27

**Comment:** zacho:

TA reported that product data does not list input watts so they used 1.05 ballast factor x lamp quantity x lamp watts.

**Cell:** J27

**Comment:** zacho:

6 lamp 32W T8 high bay

**Cell:** J30

**Comment:** zacho:

Changed watts per fixture from 25 to 39 to match product data ("Duke.CinciPub\_PleasantRidge.Lighting.Specs.2.pdf")

**Cell:** Q33

**Comment:** zacho:

Estimate based on professional judgment

DETAILED CALCULATIONS - ECM8

JAN 2012 V2.0

Salesforce Opportunity Name Cincinnati Public Schools - Pleasant Ridge - HVAC Lightir  
 Project Name Cincinnati Public Schools - Pleasant Ridge - HVAC Lighting  
 ECM 2

Application # 12-012

Rev. 0  
 State OH

Note: all data from "Duke.CinciPub\_PleasantRidge.HRW.Calcs.xlsx" received 3-9-2012, except as otherwise noted

Savings are based off of Air Handling Unit and Energy Recovery Unit information on mechanical equipment schedule drawing. Per TA email "2012-03-09 email fm D Dumond re tech info response to 12-012.pdf": "No further data was available on in the form of submittals for the air handlers or heat wheels at this time. If the data provided is insufficient then the project will have to be stricken."

For other CPS Projects (12-007 to 12-009, 12-011, 12-014), energy recovery unit submittals have closely matched mechanical equipment schedules. Therefore (and since all other technical information requested was provided), WECC left this ECM in the project.

USA\_OH\_Cincinnati.Muni AP-Lunken.Field.724297\_TMY3.bin

HEAT RECOVERY WHEEL SAVINGS **AHU-1**

Minimum Fraction Outdoor Air: 40.2%  
 Heat Recover Effectiveness: 79.6%  
 Set Point Temperature: 75 F  
 Set Point Enthalpy: 28.14 Btu/lba  
 Supply Air Temperature: 52.8 F  
 Supply Air Enthalpy: 21.45 Btu/lba  
 Supply Air Volume: 33,700 cfm  
 Supply Air Density: 0.075 lb/ft^3

StrTemp (F)	EndTemp (F)	Toa (F)	hoa (Btu/lba)	hrs	foa	Tma (F)	hma (Btu/lba)	Savings	Baseline	Proposed
								Q (mmBTU)	Q (mmBTU)	Q (mmBTU)
105	109	107.0	0	0	40%	87.9	16.83	0.00	0.00	0.00
100	104	102.0	0	0	40%	85.9	16.83	0.00	0.00	0.00
95	99	96.1	42.6	12	40%	83.5	33.96	8.42	10.58	2.16
90	94	92.2	39.6	41	40%	81.9	32.75	22.80	28.64	5.84
85	89	87.6	37.7	142	40%	80.1	31.99	65.87	82.76	16.88
80	84	82.4	35.0	250	40%	78.0	30.90	83.22	104.54	21.33
75	79	77.2	33.4	287	40%	75.9	30.26	73.24	92.01	18.77
70	74	72.5	31.9	241	100%	72.5	31.90	109.33	137.35	28.02
65	69	68.0	29.1	252	100%	68.0	29.10	29.14	36.61	7.47
60	64	62.6	24.8	322	100%	62.6	24.80	0.00	0.00	0.00
55	59	57.1	21.9	222	100%	57.1	21.90	0.00	0.00	0.00
50	54	52.0	19.2	226	97%	52.8	19.51	0.00	0.00	0.00
45	49	47.5	17.3	151	81%	52.8	19.39	0.00	0.00	0.00
40	44	43.1	15.2	211	70%	52.8	19.14	0.00	0.00	0.00
35	39	37.6	12.9	206	59%	52.8	19.09	0.00	0.00	0.00
30	34	32.4	10.8	135	52%	52.8	19.10	0.00	0.00	0.00
25	29	27.7	9.0	99	47%	52.8	19.16	0.00	0.00	0.00
20	24	23.3	7.5	66	43%	52.8	19.28	0.00	0.00	0.00
15	19	18.3	5.9	36	40%	52.2	19.20	0.00	0.00	0.00
10	14	12.5	4.1	16	40%	49.9	18.48	0.00	0.00	0.00
5	9	7.5	2.7	5	40%	47.9	17.91	0.00	0.00	0.00
0	4	3.0	1.4	0	40%	46.1	17.39	0.00	0.00	0.00

Energy recovery wheel motor	
Motor Size hp:	0.5
Load Factor:	0.85
Motor Efficiency:	81.0%
hp to kW conversion:	0.7456
<b>Motor kW:</b>	<b>0.391</b>
<b>Motor kWh:</b>	<b>479</b>

Annual Total mmBTU:	<b>392.02</b>	<b>492.49</b>	<b>100.47</b>
Annual Ton-hours:	32,669	41,041	8,372
75% Load EER:	13.2	13.2	13.2
75% Load kW/Ton:	0.909	0.909	0.909
<b>Cooling kWh:</b>	<b>29,699</b>	<b>37,310</b>	<b>7,611</b>
Heat Recovery Hours of Operation:	1,225	1,225	1,225
<b>Cooling kW:</b>	<b>24.24</b>	<b>30.46</b>	<b>6.21</b>

DETAILED CALCULATIONS - ECM8

JAN 2012 V2.0

Salesforce Opportunity Name	Cincinnati Public Schools - Pleasant Ridge - HVAC Lightir
Project Name	Cincinnati Public Schools - Pleasant Ridge - HVAC Lighting
ECM	2

Application # 12-012

Rev.	0
State	OH

Note: all data from "Duke.CinciPub\_PleasantRidge.HRW.Calcs.xlsx" received 3-9-2012, except as otherwise noted  
 USA\_OH\_Cincinnati.Muni AP-Lunken.Field.724297\_TMY3.bin  
 HEAT RECOVERY WHEEL SAVINGS AHU-2

Minimum Fraction Outdoor Air:	26.6%
Heat Recover Effectiveness:	86.8%
Set Point Temperature:	75 F
Set Point Enthalpy:	28.14 Btu/lba
Supply Air Temperature:	53 F
Supply Air Enthalpy:	21.45 Btu/lba
Supply Air Volume:	16,925 cfm
Supply Air Density:	0.075 lb/ft^3

StrTemp (F)	EndTemp (F)	Toa (F)	hoa (Btu/lba)	hrs	foa	Tma (F)	hma (Btu/lba)	Savings	Baseline	Proposed
								Q (mmBTU)	Q (mmBTU)	Q (mmBTU)
105	109	107	0	0	27%	83.5	20.66	0.00	0 00	0.00
100	104	102	0	0	27%	82.2	20.66	0.00	0 00	0.00
95	99	96.1	42.6	12	27%	80.6	31.99	3.05	3 51	0.46
90	94	92.2	39.6	41	27%	79.6	31.19	8.26	9 51	1.26
85	89	87.6	37.7	142	27%	78.4	30.68	23.86	27 48	3.63
80	84	82.4	35	250	27%	77.0	29.97	30.14	34 72	4.58
75	79	77.2	33.4	287	27%	75.6	29.54	26.52	30 56	4.03
70	74	72.5	31 9	241	100%	72.5	31.90	59.87	68 98	9.11
65	69	68	29.1	252	100%	68.0	29.10	15.96	18 39	2.43
60	64	62.6	24 8	322	100%	62.6	24.80	0.00	0 00	0.00
55	59	57.1	21 9	222	100%	57.1	21.90	0.00	0 00	0.00
50	54	52	19 2	226	96%	53.0	19.59	0.00	0 00	0.00
45	49	47.5	17 3	151	80%	53.0	19.47	0.00	0 00	0.00
40	44	43.1	15 2	211	69%	53.0	19.22	0.00	0 00	0.00
35	39	37.6	12 9	206	59%	53.0	19.18	0.00	0 00	0.00
30	34	32.4	10 8	135	52%	53.0	19.19	0.00	0 00	0.00
25	29	27.7	9	99	47%	53.0	19.24	0.00	0 00	0.00
20	24	23.3	7 5	66	43%	53.0	19.36	0.00	0 00	0.00
15	19	18.3	5 9	36	39%	53.0	19.51	0.00	0 00	0.00
10	14	12.5	4.1	16	35%	53.0	19.68	0.00	0 00	0.00
5	9	7.5	2.7	5	33%	53.0	19.85	0.00	0 00	0.00
0	4	3	1.4	0	31%	53.0	19.97	0.00	0 00	0.00
Annual Total mmBTU:								167.66	193.15	25.50
Annual Ton-hours:								13,971	16,096	2,125

<i>Energy recovery wheel motor</i>	
Motor Size hp:	0.333
Load Factor:	0.85
Motor Efficiency:	81.0%
hp to kW conversion:	0.7456
Motor kW:	0.261
Motor kWh:	319

75% Load EER:	13.2	13.2	13.2
75% Load kW/Ton:	0.909	0.909	0.909
Cooling kWh:	12,701	14,633	1,932
Heat Recovery Hours of Operation:	1,225	1,225	1,225
Cooling kW:	10.37	11.95	1.58

Allocation of annual savings by month (Added During Tech Review)

Trade ally only provided annual savings numbers. Use % of cooling degree days by month to distribute annual savings appropriately.

Cooling Degree Day Source:

<http://www.climate-zone.com/climate/united-states/ohio/greater-cincinnati-airport/>

	Jan	Feb	Mar	April	May	June	July	Aug	Sep	Oct	Nov	Dec	Annual
CDD by Month	0.0	0 0	0.0	0.0	86.0	191 0	313.0	266.0	120 0	20.0	0.0	0.0	996 0
Degree Days % of Annual	0.0%	0.0%	0 0%	0.0%	8.6%	19 2%	31.4%	26.7%	12.0%	2 0%	0.0%	0.0%	100%
Degree Days % of Maximum	0.0%	0.0%	0 0%	0.0%	27.5%	61 0%	100.0%	85.0%	38.3%	6.4%	0.0%	0.0%	
Baseline kWh	0	0	0	0	4,485	9,961	16,323	13,872	6,258	1,043	0	0	51,943
Proposed kWh	0	0	0	0	893	1,983	3,250	2,762	1,246	208	0	0	10,342
kWh Savings	0	0	0	0	3,592	7,978	13,074	11,110	5,012	835	0	0	41,601
Baseline kW	0 00	0.00	0.00	0 00	11.65	25.87	42.40	36 04	16.26	2.71	0 00	0 00	42.40
Proposed kW	0 00	0.00	0.00	0 00	2.32	5.15	8.44	7.17	3.24	0.54	0 00	0 00	8.44
kW Savings	0 00	0.00	0.00	0 00	9.33	20.72	33.96	28 86	13.02	2.17	0 00	0 00	33.96

Cell: A11

Comment: zacho:

This text is from TA calculations. Don't have a copy, but file name (TMY3) indicates they used typical 30 year average temperature data.

Cell: D14

Comment: zacho:

Per "Duke.CinciPub\_PleasantRidge.HRW.specs.1.JPG", total supply airflow for AHU is 33,700 cfm and ERV Supply is 13,550 cfm.

Therefore, Fraction Outside Air =  $13,550 \div 33,700 = 40.2\%$

Cell: D20

Comment: zacho:

TA set up calculations to use "supply" through just the energy recovery unit and applied the fraction outside air to that value. However, the "supply" going through the energy recovery unit is really the full outside air CFM (13,550). Therefore, revised Supply Air Volume input for calculations to be total AHU cfm (33,700), so that when Supply Air Volume is multiplied by Minimum Fraction Outside Air, the result is the outside air CFM through the energy recovery unit.

Per "Duke.CinciPub\_PleasantRidge.HRW.specs.1.JPG", total supply airflow for AHU is 33,700 cfm

Per "Duke.CinciPub\_PleasantRidge.HRW.specs.1.JPG", total outside airflow for AHU is 13,550 cfm

Therefore, Fraction Outside Air =  $13,550 \div 33,700 = 40.2\%$

Cell: J22

Comment: zacho:

Baseline energy is energy to cool outside air with mechanical cooling. Uses same formula as savings...but removes the heat recover effectiveness input.

Cell: A23

Comment: zacho:

Start temperature for bin

Cell: B23

Comment: zacho:

End temperature for bin

Cell: C23

Comment: zacho:

Temp. of outside air in deg. F

Cell: D23

Comment: zacho:

Enthalpy of outside air

Cell: F23

Comment: zacho:

Fraction outside air

Cell: G23

Comment: zacho:

Temperature of mixed air

Cell: H23

Comment: zacho:

Enthalpy of mixed air

Cell: I23

Comment: zacho:

Heat Recover Effectiveness x Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

Cell: J23

Comment: zacho:

NOTE: This column developed by WECC

Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

Cell: K23

Comment: bchiesa:

NOTE: This column developed by WECC

Cell: H47

Comment: zacho:

= Q in mmBTU x 1,000,000 btu per mmBTU ÷ 12,000 BTU per ton

Cell: B48

Comment: zacho:

Motor hp not listed in submittal data provided by TA, nor is it listed on Mfg. website. Therefore, estimated motor hp using App. 12-007 (Bond Hill) as a basis:

Bond Hill = 0.5 hp for 14,100 cfm ERV

This ERV is 13,700 cfm, so assume same motor hp as Bond Hill project.

Cell: H48

Comment: zacho:  
per "CPS.Carson.hvac.Chiller specs.2.pdf" for model RTUA125 chiller (which is listed on "CPS.Carson.hvac.schedule.pdf")

Cell: B49

Comment: zacho:  
Estimate...typically between 80-90%, so chose 85% load factor.

Cell: H49

Comment: zacho:  
 $\text{kW/ton} = 12 \div \text{EER}$

Cell: B50

Comment: zacho:  
Motor efficiency for 1 0 hp TEFC EPACT efficient motor is 82.5%...so used slightly less efficient than that for 3/8 hp motor.

Cell: H50

Comment: zacho:  
 $= \text{annual ton hours} \times 75\% \text{ load kW/ton}$

Cell: B52

Comment: zacho:  
 $\text{Motor size hp} \times \text{Load Factor} \times \text{hp to kW conversion} \div \text{Motor Efficiency}$

Cell: B53

Comment: zacho:  
 $\text{Motor kW} \times \text{Heat Recovery Hours of Operation}$

Cell: D59

Comment: zacho:  
Per "Duke.CinciPub\_PleasantRidge.HRW.specs.1.JPG", total supply airflow for AHU is 16,925 cfm and ERV Supply is 4,500.

Therefore, Fraction Outside Air =  $4,500 \div 16,925 = 26.6\%$

Cell: D65

Comment: zacho:  
TA set up calculations to use "supply" through just the energy recovery unit and applied the fraction outside air to that value. However, the "supply" going through the energy recovery unit is really the full outside air CFM (4,500). Therefore, revised Supply Air Volume input for calculations to be total AHU cfm (16,925), so that when Supply Air Volume is multiplied by Minimum Fraction Outside Air, the result is the outside air CFM through the energy recovery unit.

Per "Duke.CinciPub\_PleasantRidge.HRW.specs.1.JPG", total supply airflow for AHU is 16,925 cfm

Per "Duke.CinciPub\_PleasantRidge.HRW.specs.1.JPG", total outside airflow for AHU is 4,500 cfm

Therefore, Fraction Outside Air =  $4,500 \div 16,925 = 26.6\%$

Cell: J67

Comment: zacho:  
Baseline energy is energy to cool outside air with mechanical cooling. Uses same formula as savings...but removes the heat recover effectiveness input.

Cell: A68

Comment: zacho:  
Start temperature for bin

Cell: B68

Comment: zacho:  
End temperature for bin

Cell: C68

Comment: zacho:  
Temp. of outside air in deg. F

Cell: D68

Comment: zacho:  
Enthalpy of outside air

Cell: F68

Comment: zacho:  
Fraction outside air

Cell: G68

Comment: zacho:  
Temperature of mixed air

Cell: H68

Comment: zacho:  
Enthalpy of mixed air

**Cell:** I68

**Comment:** zacho:

Heat Recover Effectiveness x Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

**Cell:** J68

**Comment:** zacho:

NOTE: This column developed by WECC

Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

**Cell:** K68

**Comment:** bchiesa:

NOTE: This column developed by WECC

**Cell:** H92

**Comment:** zacho:

= Q in mmBTU x 1,000,000 btu per mmBTU ÷ 12,000 BTU per ton

**Cell:** B93

**Comment:** zacho:

Motor hp not listed in submittal data provided by TA, nor is it listed on Mfg. website. Therefore, estimated motor hp using App. 12-007 (Bond Hill) as a basis:

Bond Hill = 0.5 hp for 14,100 cfm ERV

This ERV is 4,500 cfm, so  $0.5 \times 4,500 \div 14,100 = 0.319$ , so rounded to nearest motor size: 1/3 hp (0.333)

**Cell:** H93

**Comment:** zacho:

per "Duke.CPS\_BondHill.Chiller.Specs.1.pdf"

**Cell:** B94

**Comment:** zacho:

Estimate...typically between 80-90%, so chose 85% load factor.

**Cell:** H94

**Comment:** zacho:

kW/ton = 12 ÷ EER

**Cell:** B95

**Comment:** zacho:

Motor efficiency for 1.0 hp TEFC EPACT efficient motor is 82.5%...so used slightly less efficient than that for 3/8 hp motor.

**Cell:** H95

**Comment:** zacho:

=annual ton hours x 75% load kW/ton

**Cell:** B97

**Comment:** zacho:

Motor size hp x Load Factor x hp to kW conversion ÷ Motor Efficiency

**Cell:** B98

**Comment:** zacho:

Motor kW x Heat Recovery Hours of Operation

**Cell:** A107

**Comment:** zacho:

Degree Days % of Annual x (Sum baseline kW for all energy recovery units)

**Cell:** A108

**Comment:** zacho:

Degree Days % of Annual x [(sum of proposed kWh for all energy recovery units) + sum of energy recovery wheel motor kWh used for all energy recovery units]

**Cell:** A110

**Comment:** zacho:

Degree Days % of Maximum x (Sum baseline kW for all energy recovery units)

**Cell:** A111

**Comment:** zacho:

Degree Days % of Maximum x [(sum of proposed kW for all energy recovery units) + sum of energy recovery wheel motor kW used for all energy recovery units]

**DETAILED CALCULATIONS - ECM9**

**JAN 2012 V2.0**

Salesforce Opportunity Name	Cincinnati Public Schools - Roselawn - Lighting
Project Name	Cincinnati Public Schools - Roselawn - Lighting

Application # 12-013

Rev.	0
State	OH

Note: all data from "Duke.CinciPub\_Roselawn.custom.lighting.form.xls", except as otherwise noted

1,912.5	hr/yr operation - before implementation
1,912.5	hr/yr operation - after implementation

Only show total savings

Line items not 1 for 1 match between Baseline and Proposed Sections

Site ID	Baseline (Code)						Proposed						Savings		Other Annual Savings	Total Implementation Costs	
	Building Area Type	Square Feet	Watts per Sq Ft	kw per fixture	total kw	kw-hr/yr	Fixture	Qty	Watts per fixture	kw per fixture	total kw	kw-hr/yr	kw	kw-hr/yr			
1	School	113,529	1.20		136.2	260,549	A1	9	58	0.058	0.5	998			\$	1,170	
							A2	32	58	0.058	1.9	3,550			\$	4,160	
							A31	52	84	0.084	4.4	8,354			\$	7,020	
							A32	132	168	0.168	22.2	42,412			\$	17,820	
							B28	126	118	0.118	14.8	28,339			\$	54,306	
							C3	2	84	0.084	0.2	321			\$	230	
							C31	7	84	0.084	0.6	1,125			\$	805	
							C32	7	168	0.168	1.2	2,249			\$	805	
							D1	14	59	0.059	0.8	1,574			\$	2,548	
							D2	14	54	0.054	0.8	1,446			\$	4,060	
							D4	16	105	0.105	1.7	3,213			\$	2,432	
							D6	5	59	0.059	0.3	564			\$	910	
							D6F	7	118	0.118	0.8	1,580			\$	1,274	
							G1	25	59	0.059	1.5	2,811			\$	10,775	
							G21	188	118	0.118	22.1	42,283			\$	81,028	
							G4	1	114	0.114	0.1	218			\$	242	
							J3	2	82	0.082	0.2	314			\$	462	
							L14	5	30	0.030	0.2	287			\$	290	
							L24	5	62	0.062	0.3	593			\$	290	
							L28	30	112	0.112	3.4	6,426			\$	2,370	
							S1	47	35	0.035	1.6	3,146			\$	2,350	
							S2	48	35	0.035	1.7	3,213			\$	2,400	
							S5	6	40	0.040	0.2	459			\$	192	
V1	12	250	0.250	3.0	5,738	\$	516										
V2	16	100	0.100	1.6	3,060	\$	432										
X8P	28	302	0.302	8.5	16,172	\$	23,100										
<b>Totals</b>		<b>113,529</b>			<b>136.2</b>	<b>260,549</b>		<b>836</b>		<b>94.3</b>	<b>180,444</b>	<b>41.9</b>	<b>80,105</b>	\$ -	\$	<b>221,987</b>	
															% of total cost that is incremental cost over code-efficient lighting system:		10.0%
															Total Incremental Project Cost:		\$ 22,199

**Per "2012-03-09 email #1 fm D Dumond re tech info response to 12-013.pdf":**

Fixture A3 was counted as A32 or A31

Fixture B28W was counted as B28

Fixture G21S was counted as G21

No S3 or S4 fixtures were installed

Any fixtures with GTD suffix were counted as the same fixture w/o "GTD"

**Cell:** B8

**Comment:** zacho:

Per "Duke.CinciPub\_Roselawn.custom.lighting.form.xls" received 3/9/12, which listed 1,912.5 annual hours (this is equivalent to 8.5 hrs/day x 5 days/wk x 45 wks).

Daily schedule in "Duke.CinciPub\_Roselawn.custom.lighting.form.xls" lists 10.5 hours/day x 5 days/wk x 45 wks (for annual total of 2,362.5), but went with 1,912.5 hours to be conservative.

**Cell:** H11

**Comment:** zacho:

Proposed fixture type, quantity, and watts per fixture from "Duke.CinciPub\_Roselawn.Lighting.Count.xlsx" received 3/9/12.

**Cell:** Q11

**Comment:** zacho:

Install Costs are per "Duke.CinciPub\_Roselawn.PoP Signed.pdf"

**Cell:** J13

**Comment:** zacho:

Changed from 63 to 58W to match product data. Fixture A1 is same mfg/model as A2, but is 1x4 instead of 2x4.

**Cell:** J14

**Comment:** zacho:

Changed from 63 to 58W to match product data ("Duke.CinciPub\_Roselawn.Lighting.specs1.pdf", page 14)

**Cell:** J16

**Comment:** zacho:

This fixture is a pair of A31 fixtures wired for master/satellite ballasts

**Cell:** H17

**Comment:** zacho:

TA reported that product data does not list input watts so they used 1.05 ballast factor x lamp quantity x lamp watts.

**Cell:** J17

**Comment:** zacho:

Product data ("Duke.CinciPub\_Roselawn.Lighting.specs1.pdf", page 26) only lists input watts with T5HO. Actually has (4) 28W T5.

**Cell:** J20

**Comment:** zacho:

This fixture is a pair of C31 fixtures wired for master/satellite ballasts

**Cell:** H21

**Comment:** zacho:

TA reported that product data does not list input watts so they used 1.05 ballast factor x lamp quantity x lamp watts.

**Cell:** J21

**Comment:** zacho:

Product data ("Duke.CinciPub\_Roselawn.Lighting.specs1.pdf", page 36) only lists input watts with T8. Actually has (2) 28W T5.

**Cell:** J22

**Comment:** zacho:

Per "Duke.CinciPub\_Roselawn.Lighting.specs5.pdf"

**Cell:** J24

**Comment:** zacho:

Product data ("Duke.CinciPub\_Roselawn.Lighting.specs1.pdf", page 42) lists 56 and 59 input watts for 2 lamp T8 like this. Used 59W to be conservative in savings estimate.

**Cell:** H26

**Comment:** zacho:

TA reported that product data does not list input watts so they used 1.05 ballast factor x lamp quantity x lamp watts.

**Cell:** J26

**Comment:** zacho:

Product data ("Duke.CinciPub\_Roselawn.Lighting.specs2.pdf", page 6) only lists input watts with T5HO. Actually has (2) 28W T5.

**Cell:** H27

**Comment:** zacho:

TA reported that product data does not list input watts so they used 1.05 ballast factor x lamp quantity x lamp watts.

**Cell:** J27

**Comment:** zacho:

This fixture is a pair of G1 fixtures for an 8 ft section. Total 8 ft section has (4) 28W T5

**Cell:** J28

**Comment:** zacho:

"Duke.CinciPub\_Roselawn.Lighting.specs6.pdf" lists input watts for 2 lamp version of fixture as 57W. This fixture is 4 lamp, so  $57W \times 2 = 114W$ .

**Cell:** J32

**Comment:** zacho:

Input watts per "Duke.CinciPub\_Roselawn.Lighting.specs8.pdf", which is 2 lamp fixture. L28 is (2) 2 lamp fixtures end-to-end, so  $L28 \text{ watts} = 2 \times 56W = 112W$

**Cell:** J38

**Comment:** zacho:

Input watts per "Duke.CinciPub\_Roselawn.Lighting.specs7.pdf"

**Cell:** Q40

**Comment:** zacho:

Estimate based on professional judgment

**DETAILED CALCULATIONS**

**JAN 2012 V2.0**

Salesforce Opportunity Name	Cincinnati Public Schools - South Avondale - HVAC Lighting
Project Name	Cincinnati Public Schools - South Avondale - HVAC Lighting
ECM	1

Application # 12-014

Rev.	0
State	OH

Note: all data from "Duke.CinciPub.SAvondale.CustomLighting.xls", except as otherwise noted

2,080	hr/yr operation - before implementation
2,080	hr/yr operation - after implementation

Only show total savings

Line items not 1 for 1 match between Baseline and Proposed Sections

Site ID	Baseline (Code)						Proposed						Savings		Other Annual Savings	Total Implementation Costs		
	Building Area Type	Square Feet	Watts per Sq Ft	kw per fixture	total kw	kw-hr/yr	Fixture	Qty	Watts per fixture	kw per fixture	total kw	kw-hr/yr	kw	kw-hr/yr				
1	School	85,470	1.20		102.6	213,333	A2	22	59	0.059	1.3	2,700			\$	1,386		
							A3	99	85	0.085	8.4	17,503			\$	7,524		
							A31	117	84	0.084	9.8	20,442			\$	8,892		
							A32	484	84	0.084	40.7	84,564			\$	36,784		
							B3	16	77	0.077	1.2	2,563			\$	1,232		
							D3	13	82	0.082	1.1	2,217			\$	1,625		
							F32	14	84	0.084	1.2	2,446			\$	1,904		
							H4	33	116	0.116	3.8	7,962			\$	4,950		
							K4	40	61	0.061	2.4	5,075			\$	3,200		
							K41	1	61	0.061	0.1	127			\$	80		
							M4	6	86	0.086	0.5	1,073			\$	330		
							N2	130	18	0.018	2.3	4,827			\$	5,200		
							N3	5	26	0.026	0.1	273			\$	200		
							N4	2	29	0.029	0.1	121			\$	80		
							P	8	60	0.060	0.5	998			\$	1,136		
							P2	60	56	0.056	3.4	6,989			\$	7,800		
							PS1	8	258	0.258	2.1	4,293			\$	2,160		
							PS2	4	242	0.242	1.0	2,013			\$	2,400		
							PS4	19	86	0.086	1.6	3,399			\$	5,130		
							PS5	4	63	0.063	0.3	524			\$	540		
S1	22	36	0.036	0.8	1,647			\$	770									
S4	2	28	0.028	0.1	116			\$	104									
T	8	94	0.094	0.8	1,564			\$	584									
W	12	295	0.295	3.5	7,363			\$	660									
W2	12	295	0.295	3.5	7,363			\$	660									
W4	4	452	0.452	1.8	3,761			\$	220									
<b>Totals</b>		<b>85,470</b>			<b>102.6</b>	<b>213,333</b>		<b>1,145</b>		<b>92.3</b>	<b>191,925</b>	<b>10.3</b>	<b>21,408</b>	\$	<b>-</b>	\$	<b>95,551</b>	
															% of total cost that is incremental cost over code-efficient lighting system:		10.0%	
															Total Incremental Project Cost:		\$	9,555

**Per "2012-03-09 email #1 fm D Dumond re tech info response to 12-014.pdf":**

Any fixtures with "E" suffix were counted as the same fixture w/o "E"

**Cell:** H12

**Comment:** zacho:

Proposed fixture type, quantity, and watts per fixture from "Duke.CinciPub\_SAvondale.Lighting.count.xlsx"

**Cell:** Q12

**Comment:** zacho:

Install Costs are per "Duke.CinciPub\_SA.PoP Signed.pdf"

**Cell:** J14

**Comment:** zacho:

Changed from 56 to 59W to match product data ("Duke.CinciPub\_SouthAvondale.Lighting.Specs1.PDF", page 4)

**Cell:** J16

**Comment:** zacho:

Changed from 85 to 84W to match product data ("Duke.CinciPub\_SouthAvondale.Lighting.Specs1.PDF", page 25)

**Cell:** J17

**Comment:** zacho:

Changed from 85 to 84W to match product data ("Duke.CinciPub\_SouthAvondale.Lighting.Specs1.PDF", page 29)

**Cell:** J21

**Comment:** zacho:

Per "Duke.CinciPub\_SouthAvondale.Lighting.Specs5.pdf"

**Cell:** H25

**Comment:** zacho:

TA reported that product data does not list input watts so they used 1.05 ballast factor x lamp quantity x lamp watts.

**Cell:** J25

**Comment:** zacho:

Product data ("Duke.CinciPub\_SouthAvondale.Lighting.Specs3.PDF", page 9) only lists input watts with (1) 4 ft 32W T8. Actually has (1) 2 ft 17W T8.

**Cell:** H26

**Comment:** zacho:

TA reported that product data does not list input watts so they used 1.05 ballast factor x lamp quantity x lamp watts.

**Cell:** J26

**Comment:** zacho:

Product data ("Duke.CinciPub\_SouthAvondale.Lighting.Specs3.PDF", page 12) only lists input watts with (1) 4 ft 32W T8. Actually has (1) 3 ft 25W T8.

**Cell:** J27

**Comment:** zacho:

Per "Duke.CinciPub\_SouthAvondale.Lighting.Specs8.pdf"

**Cell:** J28

**Comment:** zacho:

Per "Duke.CinciPub\_SouthAvondale.Lighting.Specs7.pdf"

**Cell:** J29

**Comment:** zacho:

Per "Fixture P2 - Daybright MS.pdf" obtained by WECC from mfg. website

**Cell:** J30

**Comment:** zacho:

Per "Duke.CinciPub\_SouthAvondale.Lighting.Specs6.pdf" is 86W per 4 ft section. This fixture is 12 ft.

**Cell:** J31

**Comment:** zacho:

Per "SAvondale\_Elec\_AsBuilts\_E201.pdf". Is (8) lamp T8 4x4 recessed fixture.

**Cell:** J32

**Comment:** zacho:

Per "Duke.CinciPub\_SouthAvondale.Lighting.Specs6.pdf" is 86W per 4 ft section. This fixture is 4 ft.

**Cell:** J33

**Comment:** zacho:

Per "SAvondale\_Elec\_AsBuilts\_E201.pdf". Is 2 lamp T8 wall mount similar to PS1/PS2/PS4 (which is 3 lamp in cross section).

**Cell:** J34

**Comment:** zacho:

Changed from 35 to 36W to match product data ("Duke.CinciPub\_SouthAvondale.Lighting.Specs3.PDF", page 31)

**Cell:** J36

**Comment:** zacho:

Per "Duke.CinciPub\_SouthAvondale.Lighting.Specs9.pdf"

**Cell:** J37

**Comment:** zacho:

Updated from 279 to 295W per "Duke.CinciPub\_SouthAvondale.Lighting.Specs3.PDF" page 37

**Cell:** J38

**Comment:** zacho:

Updated from 279 to 295W per "Duke.CinciPub\_SouthAvondale.Lighting.Specs3.PDF" page 41

**Cell:** J39

**Comment:** zacho:

Updated from 432 to 452W per "Duke.CinciPub\_SouthAvondale.Lighting.Specs3.PDF" page 41, which is input watts table for fixture W2. Fixture W4 is same mfg and similar model, just larger housing...with lamp and ballast as listed on page 41.

**Cell:** Q41

**Comment:** zacho:

Estimate based on professional judgment

**DETAILED CALCULATIONS**

**JAN 2012 V2.0**

Salesforce Opportunity Name *Cincinnati Public Schools - South Avondale - HVAC Lightin*  
 Project Name *Cincinnati Public Schools - South Avondale - HVAC Lighting*  
 ECM *2*

Application # *12-014*

Rev. *0*  
 State *OH*

Note: all data from "Duke.CinciPub\_SAvondale.HRW.Calcs.xlsx" received 3-9-2012, except as otherwise noted

USA\_OH\_Cincinnati.Muni.AP-Lunken.Field.724297\_TMY3.bin  
 HEAT RECOVERY WHEEL SAVINGS **AHU-1**

Minimum Fraction Outdoor Air: 35 0%  
 Heat Recover Effectiveness: 73.1%  
 Set Point Temperature: 75 F  
 Set Point Enthalpy: 29.17 Btu/lba  
 Supply Air Temperature: 54 F  
 Supply Air Enthalpy: 22.29 Btu/lba  
 Supply Air Volume: 26,720 cfm  
 Supply Air Density: 0.075 lb/ft^3

StrTemp (F)	EndTemp (F)	Toa (F)	hoa (Btu/lba)	hrs	foa	Tma (F)	hma (Btu/lba)	Savings	Baseline	Proposed
								Q (mmBTU)	Q (mmBTU)	Q (mmBTU)
105	109	107.0	0	0	35%	86.2	18.96	0.00	0.00	0.00
100	104	102.0	0	0	35%	84.4	18.96	0.00	0.00	0.00
95	99	96.1	42.6	12	35%	82.4	33.87	4.96	6.78	1.82
90	94	92.2	39.6	41	35%	81.0	32.82	13.16	17.99	4.83
85	89	87.6	37.7	142	35%	79.4	32.16	37.27	50.96	13.69
80	84	82.4	35.0	250	35%	77.6	31.21	44.84	61.31	16.47
75	79	77.2	33.4	287	35%	75.8	30.65	37.35	51.07	13.72
70	74	72.5	31.9	241	100%	72.5	31.90	57.84	79.08	21.24
65	69	68.0	29.1	252	100%	68.0	29.10	0.00	0.00	0.00
60	64	62.6	24.8	322	100%	62.6	24.80	0.00	0.00	0.00
55	59	57.1	21.9	222	100%	57.1	21.90	0.00	0.00	0.00
50	54	52.0	19.2	226	91%	54.0	20.07	0.00	0.00	0.00
45	49	47.5	17.3	151	76%	54.0	20.11	0.00	0.00	0.00
40	44	43.1	15.2	211	66%	54.0	19.97	0.00	0.00	0.00
35	39	37.6	12.9	206	56%	54.0	20.03	0.00	0.00	0.00
30	34	32.4	10.8	135	49%	54.0	20.11	0.00	0.00	0.00
25	29	27.7	9.0	99	44%	54.0	20.22	0.00	0.00	0.00
20	24	23.3	7.5	66	41%	54.0	20.37	0.00	0.00	0.00
15	19	18.3	5.9	36	37%	54.0	20.55	0.00	0.00	0.00
10	14	12.5	4.1	16	35%	53.1	20.40	0.00	0.00	0.00
5	9	7.5	2.7	5	35%	51.4	19.91	0.00	0.00	0.00
0	4	3.0	1.4	0	35%	49.8	19.45	0.00	0.00	0.00
Annual Total mmBTU:								<b>195.42</b>	<b>267.19</b>	<b>71.77</b>
Annual Ton-hours:								16,285	22,266	5,981
Chiller IPLV EER:								14.00	14.00	14.00
Chiller IPLV kW/Ton:								0.857	0.857	0.857
<b>Cooling kWh:</b>								<b>13,959</b>	<b>19,085</b>	<b>5,126</b>
Heat Recovery Hours of Operation:								1,225	1,225	1,225
<b>Cooling kW:</b>								<b>11.39</b>	<b>15.58</b>	<b>4.18</b>

<b>Energy recovery wheel motor</b>	
Motor Size hp:	0.375
Load Factor:	0.85
Motor Efficiency:	81.0%
hp to kW conversion:	0.7456
<b>Motor kW:</b>	<b>0.293</b>
<b>Motor kWh:</b>	<b>359</b>

**DETAILED CALCULATIONS**

**JAN 2012 V2.0**

Salesforce Opportunity Name Cincinnati Public Schools - South Avondale - HVAC Lightin  
 Project Name Cincinnati Public Schools - South Avondale - HVAC Lighting  
 ECM 2

Application # 12-014

Rev. 0  
 State OH

Note: all data from "Duke.CinciPub\_SAvondale.HRW.Calcs.xlsx" received 3-9-2012, except as otherwise noted

USA\_OH\_Cincinnati.Muni.AP-Lunken.Field.724297\_TMY3.bin

HEAT RECOVERY WHEEL SAVINGS **AHU-4**

Minimum Fraction Outdoor Air: 40.0%  
 Heat Recover Effectiveness: 71.7%  
 Set Point Temperature: 75 F  
 Set Point Enthalpy: 29.17 Btu/lba  
 Supply Air Temperature: 54 F  
 Supply Air Enthalpy: 22.29 Btu/lba  
 Supply Air Volume: 25,370 cfm  
 Supply Air Density: 0.075 lb/ft^3

StrTemp (F)	EndTemp (F)	Toa (F)	hoa (Btu/lba)	hrs	foa	Tma (F)	hma (Btu/lba)	Q (mmBTU)	Q (mmBTU)	Q (mmBTU)
105	109	107	0	0	40%	87.8	17.50	0.00	0.00	0.00
100	104	102	0	0	40%	85.8	17.50	0.00	0.00	0.00
95	99	96.1	42.6	12	40%	83.4	34.54	5.28	7.36	2.08
90	94	92.2	39.6	41	40%	81.9	33.34	14.01	19.53	5.52
85	89	87.6	37.7	142	40%	80.0	32.58	39.67	55.31	15.64
80	84	82.4	35	250	40%	78.0	31.50	47.73	66.55	18.81
75	79	77.2	33.4	287	40%	75.9	30.86	39.76	55.43	15.67
70	74	72.5	31.9	241	100%	72.5	31.90	53.86	75.09	21.23
65	69	68	29.1	252	100%	68.0	29.10	0.00	0.00	0.00
60	64	62.6	24.8	322	100%	62.6	24.80	0.00	0.00	0.00
55	59	57.1	21.9	222	100%	57.1	21.90	0.00	0.00	0.00
50	54	52	19.2	226	91%	54.0	20.07	0.00	0.00	0.00
45	49	47.5	17.3	151	76%	54.0	20.11	0.00	0.00	0.00
40	44	43.1	15.2	211	66%	54.0	19.97	0.00	0.00	0.00
35	39	37.6	12.9	206	56%	54.0	20.03	0.00	0.00	0.00
30	34	32.4	10.8	135	49%	54.0	20.11	0.00	0.00	0.00
25	29	27.7	9	99	44%	54.0	20.22	0.00	0.00	0.00
20	24	23.3	7.5	66	41%	54.0	20.37	0.00	0.00	0.00
15	19	18.3	5.9	36	40%	52.3	19.86	0.00	0.00	0.00
10	14	12.5	4.1	16	40%	50.0	19.14	0.00	0.00	0.00
5	9	7.5	2.7	5	40%	48.0	18.58	0.00	0.00	0.00
0	4	3	1.4	0	40%	46.2	18.06	0.00	0.00	0.00
<b>Annual Total mmBTU:</b>								<b>200.31</b>	<b>279.25</b>	<b>78.94</b>
<b>Annual Ton-hours:</b>								<b>16,692</b>	<b>23,271</b>	<b>6,579</b>
<b>Chiller IPLV EER:</b>								<b>14.00</b>	<b>14.00</b>	<b>14.00</b>
<b>Chiller IPLV kW/Ton:</b>								<b>0.857</b>	<b>0.857</b>	<b>0.857</b>
<b>Cooling kWh:</b>								<b>14,308</b>	<b>19,946</b>	<b>5,639</b>
<b>Heat Recovery Hours of Operation:</b>								<b>1,225</b>	<b>1,225</b>	<b>1,225</b>
<b>Cooling kW:</b>								<b>11.68</b>	<b>16.28</b>	<b>4.60</b>

Energy recovery wheel motor	
Motor Size hp:	0.375
Load Factor:	0.85
Motor Efficiency:	81.0%
hp to kW conversion:	0.7456
<b>Motor kW:</b>	<b>0.293</b>
<b>Motor kWh:</b>	<b>359</b>

**Allocation of annual savings by month** (Added During Tech Review)

Trade ally only provided annual savings numbers. Use % of cooling degree days by month to distribute annual savings appropriately.

Cooling Degree Day Source: <http://www.climate-zone.com/climate/united-states/ohio/greater-cincinnati-airport/>

	Jan	Feb	Mar	April	May	June	July	Aug	Sep	Oct	Nov	Dec	Annual
CDD by Month	0.0	0.0	0.0	0.0	86.0	191.0	313.0	266.0	120.0	20.0	0.0	0.0	996.0
Degree Days % of Annual	0.0%	0.0%	0.0%	0.0%	8.6%	19.2%	31.4%	26.7%	12.0%	2.0%	0.0%	0.0%	100%
Degree Days % of Maximum	0.0%	0.0%	0.0%	0.0%	27.5%	61.0%	100.0%	85.0%	38.3%	6.4%	0.0%	0.0%	
Baseline kWh	0	0	0	0	3,370	7,485	12,266	10,424	4,703	784	0	0	39,031
Proposed kWh	0	0	0	0	992	2,202	3,609	3,067	1,384	231	0	0	11,484
kWh Savings	0	0	0	0	2,379	5,283	8,657	7,357	3,319	553	0	0	27,548
Baseline kW	0.00	0.00	0.00	0.00	8.75	19.44	31.86	27.08	12.22	2.04	0.00	0.00	31.86
Proposed kW	0.00	0.00	0.00	0.00	2.58	5.72	9.37	7.97	3.59	0.60	0.00	0.00	9.37
kW Savings	0.00	0.00	0.00	0.00	6.18	13.72	22.49	19.11	8.62	1.44	0.00	0.00	22.49

**Cell:** A9

**Comment:** zacho:

This text is from TA calculations. Don't have a copy, but file name (TMY3) indicates they used typical 30 year average temperature data.

**Cell:** D12

**Comment:** zacho:

Per "Duke.CinciPub\_SA.HRW Specs.5.JPG", total supply airflow for AHU is 26,720 cfm. Per Duke.CinciPub\_SA.HRW.Specs.6.JPG", ERV Supply is 9,350 cfm.

Therefore, Fraction Outside Air =  $9,350 \div 26,720 = 35\%$

**Cell:** D18

**Comment:** zacho:

TA set up calculations to use "supply" through just the energy recovery unit and applied the fraction outside air to that value. However, the "supply" going through the energy recovery unit is really the full outside air CFM (9,350). Therefore, revised Supply Air Volume input for calculations to be total AHU cfm (26,720), so that when Supply Air Volume is multiplied by Minimum Fraction Outside Air, the result is the outside air CFM through the energy recovery unit.

Per "Duke.CinciPub\_SA.HRW Specs.5.JPG", total supply airflow for AHU is 26,720 cfm

Per "Duke.CinciPub\_SA.HRW Specs.6.JPG", total outside airflow for AHU is 9,350 cfm

Therefore, Fraction Outside Air =  $9,350 \div 26,720 = 35\%$

**Cell:** J20

**Comment:** zacho:

Baseline energy is energy to cool outside air with mechanical cooling. Uses same formula as savings...but removes the heat recover effectiveness input.

**Cell:** A21

**Comment:** zacho:

Start temperature for bin

**Cell:** B21

**Comment:** zacho:

End temperature for bin

**Cell:** C21

**Comment:** zacho:

Temp. of outside air in deg. F

**Cell:** D21

**Comment:** zacho:

Enthalpy of outside air

**Cell:** F21

**Comment:** zacho:

Fraction outside air

**Cell:** G21

**Comment:** zacho:

Temperature of mixed air

**Cell:** H21

**Comment:** zacho:

Enthalpy of mixed air

**Cell:** I21

**Comment:** zacho:

Heat Recover Effectiveness x Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

**Cell:** J21

**Comment:** zacho:

NOTE: This column developed by WECC

Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

**Cell:** K21

**Comment:** bchiesa:

NOTE: This column developed by WECC

**Cell:** H45

**Comment:** zacho:

= Q in mmBTU x 1,000,000 btu per mmBTU ÷ 12,000 BTU per ton

**Cell:** B46

**Comment:** zacho:

Motor hp not listed in submittal data provided by TA. Therefore, estimated motor hp using App. 12-007 (Bond Hill) as a basis:

Bond Hill = 0.5 hp for 14,100 cfm ERV

This ERV is 9,350 cfm, so  $0.5 \times 9,350 \div 14,100 = 0.331$ . Too close to 1/3 hp (no safety factor/oversize) so rounded up to nearest motor size: 3/8 hp (0.375)

Cell: H46

Comment: zacho:

per "Duke.CPS\_MTAiry.Chiller Specs.1.pdf" for model RTAC200 chiller (which is listed on "Duke.CPS\_MTAiry.Chiller Specs 2.JPG")

Cell: B47

Comment: zacho:

Estimate...typically between 80-90%, so chose 85% load factor.

Cell: H47

Comment: zacho:

$\text{kW/ton} = 12 \div \text{EER}$

Cell: B48

Comment: zacho:

Motor efficiency for 1.0 hp TEFC EPACT efficient motor is 82.5%...so used slightly less efficient than that for 3/8 hp motor.

Cell: H48

Comment: zacho:

=annual ton hours x Chiller IPLV kW/ton

Cell: B50

Comment: zacho:

Motor size hp x Load Factor x hp to kW conversion  $\div$  Motor Efficiency

Cell: B51

Comment: zacho:

Motor kW x Heat Recovery Hours of Operation

Cell: D57

Comment: zacho:

Per "Duke.CinciPub\_SA.HRW Specs.5.JPG", total supply airflow for AHU is 25,370 cfm. Per "Duke.CinciPub\_SA.HRW Specs.6.JPG", ERV Supply is 10,148.

Therefore, Fraction Outside Air =  $10,148 \div 25,370 = 40.0\%$

Cell: D63

Comment: zacho:

TA set up calculations to use "supply" through just the energy recovery unit and applied the fraction outside air to that value. However, the "supply" going through the energy recovery unit is really the full outside air CFM (10,148). Therefore, revised Supply Air Volume input for calculations to be total AHU cfm (25,370), so that when Supply Air Volume is multiplied by Minimum Fraction Outside Air, the result is the outside air CFM through the energy recovery unit.

Per "Duke.CinciPub\_SA.HRW Specs.5.JPG", total supply airflow for AHU is 25,370 cfm

Per "Duke.CinciPub\_SA.HRW Specs.6.JPG", total outside airflow for AHU is 10,148 cfm

Therefore, Fraction Outside Air =  $10,148 \div 25,370 = 40.0\%$

Cell: J65

Comment: zacho:

Baseline energy is energy to cool outside air with mechanical cooling. Uses same formula as savings...but removes the heat recover effectiveness input.

Cell: A66

Comment: zacho:

Start temperature for bin

Cell: B66

Comment: zacho:

End temperature for bin

Cell: C66

Comment: zacho:

Temp. of outside air in deg. F

Cell: D66

Comment: zacho:

Enthalpy of outside air

Cell: F66

Comment: zacho:

Fraction outside air

Cell: G66

Comment: zacho:

Temperature of mixed air

Cell: H66

Comment: zacho:

Enthalpy of mixed air

Cell: I66

**Comment:** zacho:  
Heat Recover Effectiveness x Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

**Cell:** J66

**Comment:** zacho:  
NOTE: This column developed by WECC

Supply Air Volume x foa x Supply Air Density x hrs x (hoa - Set Point Enthalpy) x 60 minutes per hour

**Cell:** K66

**Comment:** bchiesa:  
NOTE: This column developed by WECC

**Cell:** H90

**Comment:** zacho:  
 $= Q \text{ in mmBTU} \times 1,000,000 \text{ btu per mmBTU} \div 12,000 \text{ BTU per ton}$

**Cell:** B91

**Comment:** zacho:  
Motor hp not listed in submittal data provided by TA. Therefore, estimated motor hp using App. 12-007 (Bond Hill) as a basis:

Bond Hill = 0.5 hp for 14,100 cfm ERV

This ERV is 10,148 cfm, so  $0.5 \times 10,148 \div 14,100 = 0.360$ . Therefore, rounded up to nearest motor size: 3/8 hp (0.375)

**Cell:** H91

**Comment:** zacho:  
per "Duke.CPS\_MTAiry.Chiller Specs.1.pdf" for model RTAC200 chiller (which is listed on "Duke.CPS\_MTAiry.Chiller Specs 2.JPG")

**Cell:** B92

**Comment:** zacho:  
Estimate...typically between 80-90%, so chose 85% load factor.

**Cell:** H92

**Comment:** zacho:  
 $\text{kW/ton} = 12 \div \text{EER}$

**Cell:** B93

**Comment:** zacho:  
Motor efficiency for 1.0 hp TEFC EPACT efficient motor is 82.5%...so used slightly less efficient than that for 3/8 hp motor.

**Cell:** H93

**Comment:** zacho:  
 $= \text{annual ton hours} \times \text{Chiller IPLV kW/ton}$

**Cell:** B95

**Comment:** zacho:  
 $\text{Motor size hp} \times \text{Load Factor} \times \text{hp to kW conversion} \div \text{Motor Efficiency}$

**Cell:** B96

**Comment:** zacho:  
 $\text{Motor kW} \times \text{Heat Recovery Hours of Operation}$

**Cell:** A105

**Comment:** zacho:  
 $\text{Degree Days \% of Annual} \times (\text{Sum baseline kW for all energy recovery units})$

**Cell:** A106

**Comment:** zacho:  
 $\text{Degree Days \% of Annual} \times [(\text{sum of proposed kWh for all energy recovery units}) + \text{sum of energy recovery wheel motor kWh used for all energy recovery units}]$

**Cell:** A108

**Comment:** zacho:  
 $\text{Degree Days \% of Maximum} \times (\text{Sum baseline kW for all energy recovery units})$

**Cell:** A109

**Comment:** zacho:  
 $\text{Degree Days \% of Maximum} \times [(\text{sum of proposed kW for all energy recovery units}) + \text{sum of energy recovery wheel motor kW used for all energy recovery units}]$

Appendix C – Cincinnati Public Schools (8 Schools) Cash Rebate Calculation

HVAC and Lighting

Measure	Quantity	Commitment Payment/Rebate Rate	Cash Rebate
Bond Hill School – Energy Recovery Ventilator(s) (Total Rebate)	1	50% of incentive that would be offered by the Smart \$aver Custom program	\$2000.00
Carson School - Energy Recovery Ventilator(s) (Total Rebate)	1	50% of incentive that would be offered by the Smart \$aver Custom program	\$4000.00
Fairview School - Energy Recovery Ventilator(s) (Total Rebate)	1	50% of incentive that would be offered by the Smart \$aver Custom program	\$4150.00
Kilgour School – New Construction Lighting	1	50% of incentive that would be offered by the Smart \$aver Custom program	\$1050.00
Mt Airy School- Energy Recovery Ventilator(s) (Total Rebate)	1	50% of incentive that would be offered by the Smart \$aver Custom program	\$4000.00
Mt Airy School – New Construction Lighting	1	50% of incentive that would be offered by the Smart \$aver Custom program	\$1050.00
Pleasant Ridge School- Energy Recovery Ventilator(s) (Total Rebate)	1	50% of incentive that would be offered by the Smart \$aver Custom program	\$3250.00
Pleasant Ridge School – New Construction Lighting	1	50% of incentive that would be offered by the Smart \$aver Custom program	\$2000.00
Roselawn School – New Construction Lighting	1	50% of incentive that would be offered by the Smart \$aver Custom program	\$3250.00
South Avondale School- Energy Recovery Ventilator(s) (Total Rebate)	1	50% of incentive that would be offered by the Smart \$aver Custom program	\$2150.00
South Avondale School – New Construction Lighting	1	50% of incentive that would be offered by the Smart \$aver Custom program	\$900.00
		Total Incentive	\$28,000.00



**Bond Hill School**  
**Supporting Documentation**

# Ohio Mercantile Self Direct Program

## Application Guide & Cover Sheet

Questions? Call 1-866-380-9580 or visit [www.duke-energy.com](http://www.duke-energy.com).

Email this form along with completed Mercantile Self Direct Prescriptive or Custom applications, proof of payment, energy savings calculations and spec sheets to [SelfDirect@Duke-Energy.com](mailto:SelfDirect@Duke-Energy.com). You may also fax to 1-513-419-5572.

Mercantile customers, defined as using at least 700,000 kWh annually are eligible for the Mercantile Self Direct program. Please indicate mercantile qualification:

- a single Duke Energy Ohio account
- multiple accounts in Ohio (energy usage with other utilities may be counted toward the total)

Please list Duke Energy account numbers below (attach listing of multiple accounts an/or billing history for other utilities as required):

Account Number	Annual Usage	Account Number	Annual Usage
0140-3636-01			

Self Direct rebates are available for completed Custom projects that have not previously received a Duke Energy Smart \$aver® Custom Incentive. Self Direct incentives are applicable to Prescriptive measures that were installed more than 90 days prior to submission to Duke Energy and have not previously received a Duke Energy Prescriptive rebate.

Self Direct Program requirements dictate that certain projects that may be Prescriptive in nature under the Smart \$aver program must be evaluated using the Custom process. Use the table on page two as a guide to determine which Self Direct program fits your project(s). Apply for Self Direct projects using the appropriate application forms in conjunction with this cover sheet. Where Mercantile Self Direct Prescriptive applications are listed, please refer to the measure list on that application. If your measure is not listed, you may be eligible for a Self Direct Custom rebate. Self Direct Custom applications, like Smart \$aver Custom applications, should include detailed analysis of pre-project and post-project energy usage and project costs. Please indicate which type of rebate applications are included in the table provided on page two.

Please check each box to indicate completion of the following program requirements:

<input type="checkbox"/> All sections of appropriate application(s) are completed	<input type="checkbox"/> Proof of payment.*	<input type="checkbox"/> Manufacturer's Spec sheets	<input type="checkbox"/> Energy model/calculations and detailed inputs for Custom applications
---	---	---	--

\* If a single payment record is intended to demonstrate the costs of both Prescriptive & Custom projects, please include an additional document with an estimated breakout of costs for each Prescriptive and Custom energy conservation measure.

Application Type	Replaced equipment at end of lifetime or because equipment failed**	Replaced fully operational equipment to improve efficiency***	New Construction
Lighting	MSD Custom Part 1 <input type="checkbox"/> Custom Lighting Worksheet <input type="checkbox"/>	MSD Prescriptive Lighting <input type="checkbox"/>	MSD Prescriptive Lighting <input type="checkbox"/>
		MSD Custom Part 1 <input type="checkbox"/> Custom Lighting Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> Custom Lighting Worksheet <input type="checkbox"/>
Heating & Cooling	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Heating & Cooling <input type="checkbox"/>
			MSD Custom Part 1 <input checked="" type="checkbox"/> MSD Custom General Worksheet <input checked="" type="checkbox"/>
Window Films, Programmable Thermostats, & Guest Room Energy Management Systems	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General and/or EMS Worksheet(s) <input type="checkbox"/>	MSD Prescriptive Heating & Cooling <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General and/or EMS Worksheet(s) <input type="checkbox"/>
Chillers & Thermal Storage	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Chillers & Thermal Storage <input type="checkbox"/>
			MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>
Motors & Pumps	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Motors, Pumps & Drives <input type="checkbox"/>
			MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>
VFDs	Not Applicable	MSD Prescriptive Motors, Pumps & Drives <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom VFD Worksheet <input type="checkbox"/>
		MSD Custom Part 1 <input type="checkbox"/> MSD Custom VFD Worksheet <input type="checkbox"/>	
Food Service	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Food Service <input type="checkbox"/>
			MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>
Process	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Process <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>
		MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	
Energy Management Systems	MSD Custom Part 1 <input type="checkbox"/> MSD Custom EMS Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom EMS Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom EMS Worksheet <input type="checkbox"/>
Behavioral*** & No/Low Cost	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>		

\*\* Under the Self Direct program, failed equipment and equipment at the end of its useful life are evaluated differently than early replacement of fully functioning equipment. **All equipment replacements due to failure or old age will be evaluated via the Custom program.**

\*\*\* Please ensure that you include the age of the replaced equipment for measures classified as "Early Replacement" in your application as well as the estimated date that you would have otherwise replaced the existing equipment if you had not chosen a more energy efficient option.

\*\*\*\* Behavioral energy efficiency and demand reduction projects must be both measurable and verifiable. Provide justification with your application.

# Mercantile Self Direct Nonresidential Custom Rebate Application PART 1



Proposed energy efficiency measures may be eligible for Self-Direct Custom rebates if they clearly reduce electrical consumption and/or demand as compared to the appropriate baseline.

Before you complete this application, please note the following important criteria:

- Submitting this application does not guarantee a rebate will be approved.
- Rebates are based on electricity conservation only.
- Electric demand and/or energy reductions must be well documented with auditable calculations.
- Incomplete applications cannot be reviewed; all fields are required.

Refer to the complete list of Instructions and Disclaimers, beginning on page 6.

## Notes on the Application Process

If you have any questions concerning how to complete any portion of the application or what supplementary information is required, please contact your Duke Energy Ohio, Inc account manager or the Duke Energy Smart Saver® team at 1-866-380-9580.

Every application must include calculations of the baseline electrical usage and the electrical usage of the proposed high-efficiency equipment/system. Monthly calculations are best. You, the Duke Energy Ohio customer, or your equipment vendor / engineer should perform these calculations and submit them to Duke Energy for review. *We strongly encourage the use of modeling software (such as eQuest or comparable) for complex projects.*

Upon receipt of your application, an acknowledgement email will be sent to you with an estimated response time based on an initial assessment of your application. The application review may include some communication to resolve any questions about the project or to request additional information. Applications that are received complete without missing information have a faster review time.

There are two ways to submit your completed application.

Email your scanned form to: [SelfDirect@duke-energy.com](mailto:SelfDirect@duke-energy.com)

Or, fax your form to 513-419-5572

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



**1. Contact Information (Required)**

Duke Energy Customer Contact Information					
Company Name	Cincinnati Public Schools				
Address	2651 Burnet Ave				
Project Contact	Don Elbe				
City	Cincinnati	State	OH	Zip Code	45219
Title	Utility Management Coordinator				
Office Phone	614-580-3352	Mobile Phone		Fax	
E-mail Address	elbedon@cpsboe.k12.oh.us				

Equipment Vendor / Contractor / Architect / Engineer Contact Information					
Company Name	Plug Smart				
Address	1275 Kinnear Road Suite 229				
City	Columbus	State	OH	Zip Code	43212
Project Contact	Lucas Dixon				
Title	Operations Manager				
Office Phone	614-580-3352	Mobile Phone		Fax	1-800-518-5576
E-mail Address	lucas.dixon@plugsmart.com				
Describe Role	Ensures rebate is correctly applied for				

Payment Information					
Payee Legal Company Name (as shown on Federal income tax return):	Cincinnati Public Schools				
Mailing Address	2651 Burnet Ave				
City	Cincinnati	State	OH	Zip Code	45219
Type of organization (check one) <input type="checkbox"/> Individual/Sole Proprietor <input type="checkbox"/> Corporation <input type="checkbox"/> Partnership <input type="checkbox"/> Unit of Government <input type="checkbox"/> Non-Profit (non-corporation)					
Payee Federal Tax ID # of Legal Company Name Above:	31-6000758				
Who should receive incentive payment? (select one) <input checked="" type="checkbox"/> Customer <input type="checkbox"/> Vendor (Customer must sign below)					
If the vendor is to receive payment, please sign below: I hereby authorize payment of incentive directly to vendor:					
Customer Signature _____ Date ____/____/____ (mm/dd/yyyy)					

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



**2. Project Information (Required)**

- A. Please indicate project type:
- New Construction
  - Expansion at an existing facility
  - Replacing equipment due to equipment failure
  - Replacing equipment that is estimated to have remaining useful life of 2 years or less
  - Replacing equipment that is estimated to have remaining useful life of more than 2 years
  - Behavioral, operational and/or procedural programs/projects
- B. Please describe your project, or attach a detailed project description that describes the project.  
New public pre kindergarten - 8<sup>th</sup> grade school.
- C. When did you start and complete implementation?  
Start date / (mm/yyyy) End date 03/ 2008 (mm/yyyy)
- D. Are you also applying for Self-Direct Prescriptive incentives and, if so, which one(s)<sup>1</sup>?  
Lighting Controls
- E. Please indicate which worksheet(s) you are submitting for this application (check all that apply):
- Lighting
  - Variable Frequency Drive (VFD)
  - Compressed Air
  - Energy Management System (EMS)
  - General (for projects not easily submitted using one of the above worksheets)
- F. Please tell us if there is anything about your electrical energy projections (either for the baseline or the proposed project) that you are either unsure about or for which you have made significant assumptions. Attach additional sheets as needed.

Required: Attach a supplier or contractor invoice or other equivalent information documenting the Implementation Cost for each project listed in your application. (Note: self-install costs cannot be included in the Implementation Cost)

---

<sup>1</sup> If your project involves some equipment that is eligible for prescriptive incentives and some equipment that is likely eligible for custom incentives, and if it is feasible to separate the equipment for the energy analysis, then the equipment will be evaluated separately. If it is not feasible to separate the equipment for analysis, then the equipment will be evaluated together in the custom application.

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



**3. Signature** (Required – must be signed by Duke Energy customer)

**Customer Consent to Release of Personal Information**

I, (insert name) Don Elbe, do hereby consent to Duke Energy disclosing my Duke Energy Ohio, Inc Account Number and Federal Tax ID Number to its subcontractors solely for the purpose of administering Duke Energy Ohio's Mercantile Self-Direct Program. I understand that such subcontractors are contractually bound to otherwise maintain my Duke Energy Ohio, Inc Account Number and Federal Tax ID Number in the strictest of confidence.

I realize that under the rules and regulations of the public utilities commission, I may refuse to allow Duke Energy Ohio, Inc to release the information set forth above. By my signature, I freely give Duke Energy Ohio, Inc permission to release the information designated above.

**Application Signature**

I certify that I meet the eligibility requirements of the Duke Energy Ohio, Inc Mercantile Self Direct Custom Incentives Program and that all information provided within this application is correct to the best of my knowledge. I agree to the terms and conditions set forth for this program. I certify that the numbers, energy savings, and responses shown on this form are correct. Further, I certify that the taxpayer identification number is current and correct. I am not subject to backup withholding because: (a) I am exempt from backup withholding; or (b) I have not been notified by the IRS that I am subject to backup withholding as a result of a failure to report all interest or dividends; or (c) the IRS has notified me that I am no longer subject to backup withholding. I am a U.S. citizen (includes a U.S. resident alien).

\_\_\_\_\_  
Duke Energy Ohio, Inc Customer Signature

Print Name Don Elbe

Date 12/30/2011

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



**Checklist for completing the Application**

INCOMPLETE APPLICATIONS WILL RESULT IN DELAYS IN DUKE ENERGY PROCESSING YOUR APPLICATION AND NOTIFYING YOU CONCERNING ANY REBATES. Before submitting the application and the required supplementary information, use the following checklist to ensure that your application is complete and the information in the application is accurate. (Note: this checklist is for your use only – do not submit this checklist with your application)

Section No. & Title	Have You:
1. Contact Information	<input type="checkbox"/> Completed the contact information for the Duke Energy customer? <input type="checkbox"/> Completed the contact information for the equipment vendor / project engineer that can answer questions about the technical aspects of the project, if that is a different person than above?
2. Project Information	<input type="checkbox"/> Answered the questions A-E, including providing a description of your project. <input type="checkbox"/> Completed and attached the lighting, compressed air, VFD, EMS and/or General worksheet(s)?
3. Signature	<input type="checkbox"/> Signed your name? <input type="checkbox"/> Printed your name? <input type="checkbox"/> Entered the date?
Supplementary information (Required)	<input type="checkbox"/> Attached a supplier or contractor's invoice or other equivalent information documenting the Implementation Cost for projects listed in your application? (Note: self-install costs cannot be included in the Implementation Cost) <input type="checkbox"/> (If submitting the General Worksheet) attached calculations documenting the energy usage and energy savings for <b>each</b> project listed in your application?

If you have any questions concerning how to complete any portion of the application or what supplementary information is required, please contact:

- your Duke Energy account manager
- or,
- the Duke Energy Smart \$aver® team at 1-866-380-9580.

# Mercantile Self Direct Nonresidential Custom Rebate Application PART 1



## Instructions/Terms/Conditions

Note: Please keep for your records- do not submit with the application

1. Energy service companies or contractors may assist in preparing the application, but an authorized representative of the customer must sign this application to be eligible to participate in the Mercantile Self Direct Program. Completion of this application does not guarantee the approval of a Self Direct Custom Rebate.
2. Once all documentation requested in this application is received by *Duke Energy Ohio, Inc*, and any follow-up information requested by *Duke Energy* is received, the rebate amount for each Energy Conservation Measure (ECM) will be communicated to the customer. The rebate amount will be based on ECM energy savings and ECM incremental installation cost.
3. All rebates require approval by the Public Utilities Commission of Ohio. *Duke Energy Ohio, Inc* will submit an application for rebate on the customer's behalf upon customer attestation to program terms, conditions and requirements as outlined in the rebate offer letter and upon customer completion of attestation documents required by the Public Utilities Commission of Ohio.
4. *Duke Energy Ohio, Inc* will issue a Self Direct Custom Rebate check, based on the approved rebate amount for each ECM, upon receiving approval from the Public Utilities Commission of Ohio. *Duke Energy Ohio, Inc* does not guarantee PUCO approval.
5. With the application, the customer must provide a list of all sites where the ECMs were installed. *Duke Energy Ohio, Inc* requests that sites of similar size, hours of operation and energy consuming characteristics be grouped together in one application for the determination of the rebate amount. The application should identify the site where each unique ECM was installed.
6. Based on the information submitted with the application and the information gathered both before and after the initial installation of the ECM, *Duke Energy Ohio, Inc* will calculate the rebate amount for each ECM.
7. *Duke Energy Ohio, Inc* may conduct random site inspections of a sample of the locations where the ECMs are installed to verify installation and operability of the ECMs and to obtain information needed to calculate the Approved Incentive Amount.
8. Customers are encouraged to retain copies of all forms, invoices and supporting documentation for their records.
9. Approved rebates are valid for 6 months from the date communicated to the customer by *Duke Energy Ohio, Inc*, subject to the expiration of measure eligibility based on project completion dates and application submission deadlines as defined by PUCO. Customers are encouraged to execute their rebate offer contracts and PUCO-required affidavits promptly to ensure eligibility is not forfeited.
10. *Duke Energy Ohio, Inc* reserves the right to recover all unrecoverable costs associated with the project approval if the customer decides not to execute the rebate contract, after the project is approved by *Duke Energy Ohio, Inc*.
11. Projects financially supported by other funding sources will be evaluated on a case-by-case basis for potential partial funding from *Duke Energy Ohio, Inc*.
12. Participants must be *Duke Energy Ohio, Inc* nonresidential, mercantile customers with the project sites in the *Duke Energy Ohio, Inc* service territory.

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



13. Customers or trade allies may not use any *Duke Energy* logo without prior written permission.
14. Only trade allies registered with *Duke Energy* are eligible to participate.
15. All equipment must be new. Used or rebuilt equipment is not eligible for incentives. All old existing equipment must be removed on retrofit projects.
16. Disclaimers: *Duke Energy Ohio, Inc*
  - a. does not endorse any particular manufacturer, product or system design within the program;
  - b. will not be responsible for any tax liability imposed on the customer as a result of the payment of incentives;
  - c. does not expressly or implicitly warrant the performance of installed equipment. (Contact your contractor for details regarding equipment warranties.);
  - d. is not responsible for the proper disposal/recycling of any waste generated or obsolete or old equipment as a result of this project;
  - e. is not liable for any damage caused by the installation of the equipment nor for any damage caused by the malfunction of the installed equipment; and
  - f. reserves the right to change or discontinue this program at any time. The acceptance of program applications is determined solely by *Duke Energy Ohio, Inc*.



The General Worksheet is part 2 of the application. Do not submit this file without submitting a completed Part1 Custom Application document file, which can be found at [www.duke-energy.com](http://www.duke-energy.com). This worksheet is for all projects that are not easily submitted through one of the other worksheets

Before you complete this application, please note the following important criteria:

- Submitting this application does not guarantee an incentive will be approved.
- Incentive already decided to proceed.
- Electric demand and/or energy reductions must be well documented with auditable calculations.
- Incomplete applications will not be reviewed; all fields are required.

Refer to the complete list of Instructions and Disclaimers, found in the Mercantile Self Direct Custom Application Part 1 document.

**Please enter your information and data into the cells that are shaded.  
Cells in white are locked and cannot be written over.**

**Duke Energy Customer Contact Information (Match the information in Application Part 1):**

Name	Don Elbe
Company	Cinicinnati Public Schools

**Equipment Vendor / Project Engineer Contact Information**

Name	Lucas Dixon
Company	Plug Smart

Before proceeding with the custom application, please verify that your project is not on the Self-Direct Prescriptive application.

The prescriptive incentive applications can be found at:

<http://www.duke-energy.com/ohio-large-business/smart-saver/mercantile-self-direct.asp>

Prescriptive rebate amounts are pre-approved.





For each project, answer the following questions (use one worksheet per project)

App No.	0
Rev.	0

Project Name: **Heat Recovery Wheel**

How would you classify this project? (Place an x in all boxes that apply.)

Lighting		Heating/Cooling	X	Air Compressor		Energy Management System	
VFD		Motors/Pumps		Process Equipment		Other, describe below:	

**Brief Project Description**

Describe the Baseline (see note 3)	Equipment/System	Describe the Proposed High Efficiency Project
Air handler without heat recovery		Aid handler with heat recovery

If Existing Equipment is the Baseline, how many years of useful life remain or how many years until scheduled replacement?

Detailed Project Description Attached?  Yes (Required)

**Operating Hours (see note 4)**

24 x 7	Weekday		Saturday		Sunday		Weeks of Use in Year (see note 5)	Total Annual Hours of Use
	Start Hour	End Hour	Start Hour	End Hour	Start Hour	End Hour		
No	7:00 AM	3:00 PM					14	700

**Energy Savings**

	Baseline (see Note 3)	Proposed	Savings	Describe how energy numbers were calculated
Annual Electric Energy	18,759 kWh	0 kWh	18,759 kWh	None is listed as the savings with proposed at 0 kWh. See attached DUKE.CincPublic_Evar
Electric Demand	0 kW	0 kW	0 kW	
Calculations attached	Yes	Yes	(Required)	

**Simple Payback**

Average electric rate (\$/kWh) on the applicable accounts (see note 6)	\$0.10
Estimated annual electric savings	\$1,876
Other annual savings in addition to electric savings, such as operations, maintenance, other fuels	
Incremental cost to implement the project (equipment & installation) (see note 7)	
Copy of vendor proposal is attached (see note 8)	Yes
Simple Electric Payback in years (see note 9)	0
Total Payback in years	0

**3 Baseline**

Retrofit projects: the existing equipment is the baseline.  
 New construction projects: the baseline is the standard option in today's market, taking into account any applicable organizational, local, state or federal codes or standards currently in effect.

**4 Operating Hours**

Describe when the equipment is typically used. If the project is proposed for more than one site, provide any variations in operating hours between the sites on a separate sheet.

**5 Weeks of Use in Year**

If the equipment is not in use 52 weeks during the year (for example, during holiday or summer break), provide an explanation of when usage is not expected and why: **Used year round but savings are only claimed during summer heating season**

**6 Average electric rate (\$/kWh)**

If you do not know your average electric rate, use \$0.10/kWh.

**7 Incremental cost to implement the project**

Costs exclude self installation costs. Retrofit projects, incremental cost is the total cost of the proposed project. New construction or where the existing equipment must be replaced anyway, then incremental cost is the premium of the proposed high efficiency project over baseline.

**8 Copy of vendor invoice is attached**

Vendor invoices detailing costs of the project are always required.  
 New construction projects or where the existing equipment must be replaced anyway, vendor proposal of baseline must also be attached.

**9 Simple Electric Payback**

If the simple electric payback is less than 1 year, the rebate structure is affected. Double check average electric rate for correct payback.

March 2, 2012



To whom it may concern:

This letter is to confirm that for the renovation to **Bond Hill Academy (1510 California Ave)**, for the **custom** rebate application, an energy conservation wheel was installed with a minimum unit cost listed below.

DESCRIPTION	QUANTITY	PRICE/FIXTURE	AMOUNT
NovelAire ECW 844 Energy Conservation Wheel	1	\$8,000.00	\$8,000.00

This is also to confirm that for the renovation to **Bond Hill Academy (1510 California Ave)**, for the **prescriptive** rebate application, an energy conservation wheel was installed with a minimum unit cost listed below.

DESCRIPTION	QUANTITY	PRICE/FIXTURE	AMOUNT
Sensor Switch OccSensors - WSD PDT 2P, CM PDT 10, & WV PDT 16	172	\$117.89	\$20,277.08

Thank you for your attention to this matter,

A handwritten signature in cursive script that reads "Don Elbe".

Don Elbe  
Utility Management Coordinator

**APPLICATION AND CERTIFICATE FOR PAYMENT**

TO OWNER: CINCINNATI PUBLIC SCHOOLS

PROJECT:

BOND HILL ACADEMY

APPLICATION No:

PAY APP 18  
COMPLETION

FROM CONTRACTOR: ATKINS & STANG

VIA ARCHITECT:

STEED HAMOND PAUL

PERIOD TO:  
PROJECT NOS:  
CONTRACT DATE:

CONTRACT FOR: ELECTRICAL/TELECOMMUNICATIONS

**CONTRACTOR'S APPLICATION FOR PAYMENT**

Application is made for payment as shown below, in connection with the Contract  
Continuation sheet is attached.

- 1. ORIGINAL CONTRACT SUM.....\$ 1,700,000.00
- 2. Net Change by Change Orders.....\$ 79,122.00
- 3. CONTRACT SUM TO DATE.....\$ 1,779,122.00
- 4. TOTAL COMPLETED & STORED TO DATE.....\$ 1,779,122.00
- 5. RETAINAGE
  - a. 8-60% of Completed Labor.....\$ Retainer Inv 0.00
  - b. 8% of Stored Material.....\$ 0.00
  - Total Retainage.....\$ 0.00
- 6. TOTAL EARNED LESS RETAINAGE.....\$ 1,779,122.00
- 7. LESS PREVIOUS CERTIFICATES FOR PAYMENT.....\$ 1,754,546.68
- 8. CURRENT PAYMENT DUE.....\$ 24,575.32
- 9. BALANCE TO FINISH, INCLUDING RETAINAGE.....\$ 0.00

Change Order/Contract	ADDITIONS	DEDUCTIONS
Total Changes approved in Previous months by Owner	38384.00	0.00
Total approved this month	40734.00	0.00
<b>TOTALS</b>	<b>79122.00</b>	<b>0.00</b>
<b>NET CHANGES by Change Order</b>	<b>79122.00</b>	<b>0.00</b>

The Contractor certifies that the work covered by this pay request has been completed in accordance with the Contract Documents and that all progress payments previously paid by the State have been applied by the Contractor to discharge in full all of Contractor's obligations incurred in connection with the work covered by all prior pay requests.

Contractor: Atkins & Stang, Inc. Date: 2-24-09

Based upon on-site observations, the firm affirms that the work has progressed to the percentage of completeness indicated on the pay request.

State of: OHIO County of: HAMILTON  
 Subscribed and sworn to before me this 24th day of February, 2009 at Cincinnati, Ohio  
 Notary Public: Shirley Ann McCormick  
 My Commission expires: Mar. 30, 2013

**ARCHITECT'S CERTIFICATE FOR PAYMENT**  
 In accordance with the Contract Documents, based on on-site observations and the data comprising the application, the Architect certifies to the Owner that to the best of the Architect's knowledge, information and belief the Work has progressed as indicated, the quality of the Work is in accordance with the Contract Documents, and the Contractor is entitled to payment of the AMOUNT CERTIFIED.

AMOUNT CERTIFIED.....\$ 24,575.32  
 (Attach explanation if amount certified differs from the amount applied. Initial all figures on this Application and on the Continuation Sheet that are changed to conform with the amount certified.)  
 Architect: [Signature] Date: 2-4-09  
 Construction Manager: [Signature] Date: 2/19/09  
 Approved: \_\_\_\_\_

# CONTINUATION SHEET

AIA DOCUMENT G703

PAGE 1 OF 3 PAGES

AIA Document G702, APPLICATION AND CERTIFICATION FOR PAYMENT, containing Contractor's signed certification is attached. In tabulations below, amounts are stated to the nearest dollar. Use Column I on Contracts where variable retainage for line items may apply.

APPLICATION NO: C3352-16  
 APPLICATION DATE: 1/24/09  
 PERIOD TO: COMPLETION  
 ARCHITECT'S PROJECT NO:

A ITEM NO.	B DESCRIPTION OF WORK	C SCHEDULED VALUE	D WORK COMPLETED		E THIS PERIOD	F MATERIALS PRESENTLY STORED (NOT IN D OR E)	G TOTAL COMPLETED AND STORED TO DATE (D+E+F)	H % (G+C)	I BALANCE TO FINISH (C-G)	J RETAINAGE (IF VARIABLE RATE)
			FROM PREVIOUS APPLICATION (D+E)	THIS PERIOD						
	BOND	\$17,000.00	\$17,000.00				\$17,000.00	100.00%		\$0.00
	MOBILIZATION	\$5,000.00	\$5,000.00				\$5,000.00	100.00%		\$0.00
	GENERAL ALLOWANCE	\$15,000.00	\$15,000.00				\$15,000.00	100.00%		\$0.00
	DSL LINES ALLOWANCE	\$9,000.00	\$9,000.00				\$9,000.00	100.00%		\$0.00
	SUPERVISION	\$20,000.00	\$20,000.00				\$20,000.00	100.00%		\$0.00
	PRIMARY ELECTRIC LABOR	\$6,000.00	\$6,000.00				\$6,000.00	100.00%		\$0.00
	PRIMARY ELECTRIC MAT	\$16,000.00	\$16,000.00				\$16,000.00	100.00%		\$0.00
	SITE ELECTRIC LABOR	\$15,000.00	\$15,000.00				\$15,000.00	100.00%		\$0.00
	SITE ELECTRIC MATERIAL	\$3,000.00	\$5,000.00				\$5,000.00	100.00%		\$0.00
	BRANCH CONDUIT LABOR	\$125,000.00	\$125,000.00				\$125,000.00	100.00%		\$0.00
	BRANCH CONDUIT MAT.	\$37,500.00	\$37,500.00				\$37,500.00	100.00%		\$0.00
	FEEDER CONDUIT LABOR	\$15,000.00	\$15,000.00				\$15,000.00	100.00%		\$0.00
	FEEDER CONDUIT MAT.	\$12,000.00	\$12,000.00				\$12,000.00	100.00%		\$0.00
	BRANCH WIRING LABOR	\$22,300.00	\$22,300.00				\$22,300.00	100.00%		\$0.00
	BRANCH WIRING MATERIAL	\$45,000.00	\$45,000.00				\$45,000.00	100.00%		\$0.00
	FEEDER WIRING LABOR	\$18,000.00	\$18,000.00				\$18,000.00	100.00%		\$0.00
	FEEDER WIRING MATERIAL	\$133,700.00	\$133,700.00				\$133,700.00	100.00%		\$0.00
	SWITCHGEAR, PANELS, TRANSFORMERS LABOR	\$30,000.00	\$30,000.00				\$30,000.00	100.00%		\$0.00
	SWITCHGEAR, PANELS, TRANSFORMERS MATERIAL	\$90,000.00	\$90,000.00				\$90,000.00	100.00%		\$0.00
	FIRE ALARM LABOR	\$14,000.00	\$14,000.00				\$14,000.00	100.00%		\$0.00
	FIRE ALARM MATERIAL	\$23,000.00	\$23,000.00				\$23,000.00	100.00%		\$0.00
	EMERGENCY GEN. LABOR	\$3,000.00	\$3,000.00				\$3,000.00	100.00%		\$0.00
	EMERGENCY GEN. MAT.	\$25,000.00	\$25,000.00				\$25,000.00	100.00%		\$0.00
	CABLE TRAY LABOR	\$12,000.00	\$12,000.00				\$12,000.00	100.00%		\$0.00
	CABLE TRAY MATERIAL	\$20,000.00	\$20,000.00				\$20,000.00	100.00%		\$0.00

Users may obtain validation of this document by requesting of the license a completed AIA Document D401 - Certification of Documents Authenticity

# CONTINUATION SHEET

AIA DOCUMENT G703

PAGE 2 OF 3 PAGES

AIA Document G702, APPLICATION AND CERTIFICATION FOR PAYMENT, containing Contractor's signed certification is attached.

In tabulations below, amounts are stated to the nearest dollar.

Use Column I on Contracts where variable retainage for line items may apply.

APPLICATION NO: C3352-16

APPLICATION DATE: 01/24/09

PERIOD TO: COMPLETION

ARCHITECT'S PROJECT NO:

A ITEM NO.	B DESCRIPTION OF WORK	C SCHEDULED VALUE	D WORK COMPLETED		E THIS PERIOD	F MATERIALS PRESENTLY STORED (NOT IN D OR E)	G TOTAL COMPLETED AND STORED TO DATE (D+E+F)	H % (G+C)	I BALANCE TO FINISH (C-G)	J RETAINAGE (IF VARIABLE RATE)
			FROM PREVIOUS APPLICATION (D+E)	THIS PERIOD						
	LIGHTING CONTROL LABOR	\$15,000.00	\$15,000.00				\$15,000.00	100.00%	\$0.00	\$0.00
	LIGHTING CONTROL MATERIAL	\$35,000.00	\$35,000.00				\$35,000.00	100.00%	\$0.00	\$0.00
	STAGE LIGHTING LABOR	\$3,000.00	\$3,000.00				\$3,000.00	100.00%	\$0.00	\$0.00
	STAGE LIGHTING MATERIAL	\$20,000.00	\$20,000.00				\$20,000.00	100.00%	\$0.00	\$0.00
	SCOREBOARD LABOR	\$700.00	\$700.00				\$700.00	100.00%	\$0.00	\$0.00
	SCOREBOARD MATERIAL	\$4,300.00	\$4,300.00				\$4,300.00	100.00%	\$0.00	\$0.00
	EQUIPMENT & HVAC, KITCHEN, ETC. LABOR	\$18,000.00	\$18,000.00				\$18,000.00	100.00%	\$0.00	\$0.00
	EQUIPMENT & HVAC, KITCHEN, ETC. MATERIAL	\$5,000.00	\$5,000.00				\$5,000.00	100.00%	\$0.00	\$0.00
	LIGHT FIXTURES LABOR	\$30,000.00	\$30,000.00				\$30,000.00	100.00%	\$0.00	\$0.00
	LIGHT FIXTURES MATERIAL	\$140,000.00	\$140,000.00				\$140,000.00	100.00%	\$0.00	\$0.00
	DEVICES LABOR	\$9,000.00	\$9,000.00				\$9,000.00	100.00%	\$0.00	\$0.00
	DEVICES MATERIAL	\$8,000.00	\$8,000.00				\$8,000.00	100.00%	\$0.00	\$0.00
	TEMPORARY ELECTRIC LABOR	\$7,000.00	\$7,000.00				\$7,000.00	100.00%	\$0.00	\$0.00
	TEMPORARY ELECTRIC MATERIAL	\$4,500.00	\$4,500.00				\$4,500.00	100.00%	\$0.00	\$0.00
	TELECOMMUNICATIONS CABLING LABOR	\$60,337.00	\$60,337.00				\$60,337.00	100.00%	\$0.00	\$0.00
	TELECOMMUNICATIONS CABLING MATERIAL	\$140,788.00	\$140,788.00				\$140,788.00	100.00%	\$0.00	\$0.00
	NETWORK ELECTRONICS LABOR	\$20,100.00	\$20,100.00				\$20,100.00	100.00%	\$0.00	\$0.00
	NETWORK ELECTRONICS MAT	\$46,900.00	\$46,900.00				\$46,900.00	100.00%	\$0.00	\$0.00
	MUSIC ROOM SOUND LABOR	\$3,870.00	\$3,870.00				\$3,870.00	100.00%	\$0.00	\$0.00
	MUSIC ROOM SOUND MAT.	\$9,030.00	\$9,030.00				\$9,030.00	100.00%	\$0.00	\$0.00
	CAFETERIUM SOUND LABOR	\$8,280.00	\$8,280.00				\$8,280.00	100.00%	\$0.00	\$0.00
	CAFETERIUM SOUND MAT.	\$19,320.00	\$19,320.00				\$19,320.00	100.00%	\$0.00	\$0.00
	<b>PAGE SUBTOTALS</b>	\$608,125.00	\$608,125.00		\$0.00	\$0.00	\$608,125.00	100.00%	\$0.00	\$0.00
	<b>SUB TOTALS</b>	\$1,341,625.00	\$1,341,625.00		\$0.00	\$0.00	\$1,341,625.00	100.00%	\$0.00	\$0.00

Users may obtain validation of this document by requesting of the IIA

# CONTINUATION SHEET

AIA DOCUMENT G703

PAGE 3 OF 3 PAGES

AIA Document G702, APPLICATION AND CERTIFICATION FOR PAYMENT, containing Contractor's signed certification is attached. In tabulations below, amounts are stated to the nearest dollar. Use Column I on Contracts where variable retainage for line items may apply.

APPLICATION NO: C3352-16  
 APPLICATION DATE: 01/24/09  
 PERIOD TO: COMPLETION  
 ARCHITECT'S PROJECT NO:

A	B	C	D	E	F	G	H	I	
ITEM NO.	DESCRIPTION OF WORK	SCHEDULED VALUE	WORK COMPLETED FROM PREVIOUS APPLICATION (D + E)	THIS PERIOD	MATERIALS PRESENTLY STORED (NOT IN D OR E)	TOTAL COMPLETED AND STORED TO DATE (D+E+G)	% (G + C)	BALANCE TO FINISH (C - G)	RETAINAGE (IF VARIABLE)
	VIDEO DISTRIBUTION LABOR	\$37,140.00	\$37,140.00			\$37,140.00	100.00%		\$0.00
	GYM SOUND MATERIAL	\$86,660.00	\$86,660.00			\$86,660.00	100.00%		\$0.00
	GYM SOUND LABOR	\$8,272.00	\$8,272.00			\$8,272.00	100.00%		\$0.00
	GYM SOUND MATERIAL	\$19,303.00	\$19,303.00			\$19,303.00	100.00%		\$0.00
	CLASSROOM SOUND LABOR	\$14,700.00	\$14,700.00			\$14,700.00	100.00%		\$0.00
	CLASSROOM SOUND MATERIAL	\$34,300.00	\$34,300.00			\$34,300.00	100.00%		\$0.00
	ALARM & ACCESS CONTROL LABOR	\$12,780.00	\$12,780.00			\$12,780.00	100.00%		\$0.00
	ALARM & ACCESS CONTROL MATERIAL	\$29,820.00	\$29,820.00			\$29,820.00	100.00%		\$0.00
	CCTV LABOR	\$15,570.00	\$15,570.00			\$15,570.00	100.00%		\$0.00
	CCTV MATERIAL	\$36,330.00	\$36,330.00			\$36,330.00	100.00%		\$0.00
	CENTRAL SOUND LABOR	\$13,950.00	\$13,950.00			\$13,950.00	100.00%		\$0.00
	CENTRAL SOUND MATERIAL	\$31,550.00	\$31,550.00			\$31,550.00	100.00%		\$0.00
	PUNCLIST CLOSEOUT	\$3,000.00	\$3,000.00			\$3,000.00	100.00%		\$0.00
	CLOSEOUT DOCUMENTATION	\$15,000.00	\$15,000.00			\$15,000.00	100.00%		\$0.00
CO 1		\$8,819.00	\$8,819.00			\$8,819.00	100.00%		\$0.00
CO 2		\$8,037.00	\$8,037.00			\$8,037.00	100.00%		\$0.00
CO 3		\$8,055.00	\$8,055.00			\$8,055.00	100.00%		\$0.00
CO 4		\$8,908.00	\$8,908.00			\$8,908.00	100.00%		\$0.00
CO 5		\$2,926.00	\$2,926.00			\$2,926.00	100.00%		\$0.00
CO 6		\$1,639.00	\$1,639.00			\$1,639.00	100.00%		\$0.00
CO 7		\$7,244.00	\$7,244.00			\$7,244.00	100.00%		\$0.00
CO 8		(\$3,392.00)	(\$3,392.00)			(\$3,392.00)	100.00%		\$0.00
CO 9		\$6,455.00	\$6,455.00			\$6,455.00	100.00%		\$0.00
CO 10		\$9,404.00	\$9,404.00			\$9,404.00	100.00%		\$0.00
	<b>PAGE SUBTOTALS</b>	\$416,470.00	\$416,470.00	\$0.00	\$0.00	\$416,470.00	100.00%	\$0.00	\$0.00
	<b>SUB TOTALS</b>	\$1,758,095.00	\$1,758,095.00	\$0.00	\$0.00	\$1,758,095.00	100.00%	\$0.00	\$0.00
	TOTAL LABOR for RETAINER	\$0.00							\$0.00
	TOTAL MATERIAL for RETAINER	\$0.00							\$0.00
	<b>TOTAL</b>	<b>\$0.00</b>							<b>\$0.00</b>

Users may obtain validation of this document by requesting of the licensee a completed AIA Document D401 - Certification of Document's Authenticity

# CONTINUATION SHEET

AIA DOCUMENT G703

PAGE 3 OF 3 PAGES

AIA Document G702, APPLICATION AND CERTIFICATION FOR PAYMENT, containing Contractor's signed certification is attached.

In tabulations below, amounts are stated to the nearest dollar.

Use Column 1 on Contracts where variable retainage for line items may apply.

APPLICATION NO: C3352-16  
APPLICATION DATE: 01/24/09

PERIOD TO: COMPLETION  
ARCHITECTS PROJECT NO:

A	B	C	D	E	F	G	H	I	
ITEM NO.	DESCRIPTION OF WORK	SCHEDULED VALUE	WORK COMPLETED FROM PREVIOUS APPLICATION (D+E)	THIS PERIOD	MATERIALS PRESENTLY STORED (NOT IN D OR E)	TOTAL COMPLETED AND STORED TO DATE (D+E+G)	% (G+C)	BALANCE TO FINISH (C-G)	RETAINAGE (IF VARIABLE)
CO 11		\$1,730.00	\$1,730.00			\$1,730.00	100.00%		\$0.00
CO 12		\$1,028.00	\$1,028.00			\$1,028.00	100.00%		\$0.00
CO 13		\$3,838.00	\$3,838.00			\$3,838.00	100.00%		\$0.00
CO 14		\$6,724.00	\$6,724.00			\$6,724.00	100.00%		\$0.00
CO 15		\$2,864.00	\$2,864.00			\$2,864.00	100.00%		\$0.00
CO 16		\$4,359.00	\$4,359.00			\$4,359.00	100.00%		\$0.00
CO 17		\$484.00	\$484.00			\$484.00	100.00%		\$0.00
	<b>PAGE SUBTOTALS</b>	\$21,027.00	\$21,027.00	\$0.00	\$0.00	\$21,027.00	100.00%	\$0.00	\$0.00
	<b>GRAND TOTALS</b>	\$1,779,122.00	\$1,779,122.00	\$0.00	\$0.00	\$1,779,122.00		\$0.00	\$0.00
	<b>TOTAL LABOR for RETAINER</b>								\$0.00
	<b>TOTAL MATERIAL for RETAINER</b>	\$0.00							\$0.00

Users may obtain validation of this document by requesting of the licensee a completed AIA Document D401 - Certification of Document's Authenticity

Contractor's Name: ATKINS & STANG, INC.  
Address: 1031 META DR. CINCINNATI, OH 45237

**Contractor Pay Application Summary**

PO #508759

**Project Name: Bond Hill Elementary**

1	Original Contract Amount	\$	1,700,000.00
2	Net Changes to Date	\$	79,122.00
3	Current Contract Amount	\$	1,779,122.00
4	Labor Completed to Date	\$	0.00
5	Material Completed to Date	\$	1,139,096.00
6	Total Work Completed to Date	\$	1,779,122.00
7	Stored Material to Date	\$	0.00
8	Less Retained to Date	\$	0.00
9	Total Amount Due	\$	1,779,122.00
10	Less Previous Payments	\$	1,576,646.18
11	Less Amount Retained to Cover Lien	\$	0.00
12	Less Amount Retained for Liquidated Damages	\$	0.00
13	Less Other Amounts Withheld	\$	0.00
14	Current Due	\$	24,575.32
15	Balance to Complete	\$	0.00

**\*Owner approval required for the following contract adjustments:**

1. Assessment of liquidated damages
2. Other amounts withheld

\_\_\_\_\_ Date

Comments:


**Turner**  **TYS**  
Rebuilding Cincinnati Public Schools

February 20, 2009

Angie Tolle  
Cincinnati Public Schools  
2315 Iowa Avenue  
Cincinnati, OH 45206


Dear Angie:

Attached are **Pay Applications** for the **Bond Hill Academy**,  
**please process for payment.**

Contractor	Application #	Monthly Billing	Total Billing To Date	Contract Amount to Date
BP#7 Atkins & Stang	#Final	\$ 24,575.32	\$1,779,122.00	\$1,779,122.00

Please call if you have any questions.

Sincerely,  
TURNER/DAG/TYS



James T. DeLage  
Project Executive

/bcs

Attachments

cc: Matt Meibers - SHP  
Manasseh Robinson - Turner/DAG/TYS  
File 0025-10960PB

T:\PROJECTS\BOND HILL\00250 Pay Application\2009-02-20 combined Pay App. Ltr. Doc

**APPLICATION AND CERTIFICATE FOR PAYMENT**

**TO OWNER:**

Cincinnati Public Schools  
2315 Iowa Street  
Cincinnati, Ohio 45206

**PROJECT:**

Bond Hill Academy K-8  
1510 California Avenue  
Cincinnati, Ohio 45237

**FROM CONTRACTOR:**

Feldkamp Enterprises, Inc.  
3642 Muddy Creek Road  
Cincinnati, Ohio 45238

**VIA ARCHITECT:**

Steed Hammond & Paul

APPLICATION No: 21-RET  
PERIOD TO: 08/04/08  
PROJECT NOS:  
CONTRACT DATE: 06/22/06  
INVOICE NO: 1214-20

**CONTRACTOR'S APPLICATION FOR PAYMENT**

Application is made for payment as shown below, in connection with the Contract  
Continuation sheet is attached.

- 1. ORIGINAL CONTRACT SUM..... \$ 1,268,000.00
- 2. Net Change by Change Orders..... \$ 9,619.00
- 3. CONTRACT SUM TO DATE..... \$ 1,267,619.00
- 4. TOTAL COMPLETED & STORED TO DATE..... \$ 1,267,619.00
- 5. RETAINAGE
  - a. 8-50% of Completed Labor..... \$ -
  - b. 8% of Stored Material..... \$ -
  - Total Retainage..... \$ -
- 6. TOTAL EARNED LESS RETAINAGE..... \$ 1,267,619.00
- 7. LESS PREVIOUS CERTIFICATES FOR PAYMENT..... \$ 1,224,369.48
- 8. CURRENT PAYMENT DUE..... \$ 43,249.52
- 9. BALANCE TO FINISH, INCLUDING RETAINAGE..... \$ -

Change Order/Contract	ADDITIONS	DEDUCTIONS
Total Changes approved in Previous months by Owner		
Total approved this month		
<b>TOTALS</b>		
<b>NET CHANGES by Change Order</b>		

The Contractor certified that the work covered by this pay request has been completed in accordance with the Contract Documents and that all progress payments previously paid by Felicity-Franklin have been applied by the Contractor to discharge in full all of Contractor's obligations incurred in connection with the work covered by all prior pay requests.

Contractor:  8/4/08  
Date: PATRICIA A. HICKE  
Notary Public, State of Ohio  
My Commission Expires 01-26-2013 to

Architect:  8-13-08  
Date: 8-13-08

Construction Manager:  8/6/08  
Date: 8/6/08

Approved: \_\_\_\_\_  
School District: \_\_\_\_\_  
Date: \_\_\_\_\_



Steed Hammond Paul Inc.  
 82 Williams Ave  
 Hamilton, OH 45015

Phone: 513-863-5441  
 Fax: 513-863-5441  
 eMail: mmeibers@shpinc.com

RED-NEIGH DEV.

TO: Manasseh Robinson  
 COMPANY: Turner/DAG/TYS  
 2315 Iowa Street  
 Cincinnati, OH 45206

2008 AUG 15 P 2:03

FROM: Matthew E. Meibers  
 RE: Bond Hill Academy K-8

DATE: 8/14/2008

COMM NO.: 2005002.00

We are Sending You the Following Items     Attached     Under a Separate Cover VIA \_\_\_\_\_

- Copy of Letter     Prints     Specifications
- Shop Drawings     Change Order     Pay Application
- Plans     Samples     Other..

COPIES                      DIV. NO.                      DESCRIPTION

COPIES	DIV. NO.	DESCRIPTION
4		HVAC pay application

THESE ARE TRANSMITTED as checked below

- For Approval                       Reviewed as Submitted                       Resubmit                      \_\_\_\_\_ copies for approval
- For Your Use                       Reviewed as Noted                       Submit                      \_\_\_\_\_ copies for approval
- For Review & Comments                       Returned for Corrections                       Return                      \_\_\_\_\_ corrected prints


**REMARKS**

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

IF ENCLOSURES ARE NOT AS NOTED, PLEASE NOTIFY SIGNEE

COPIED TO

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

SIGNED   
 Matthew E. Meibers  
 Field Representative

**Turner**  **TYS**  
Rebuilding Cincinnati Public Schools

August 22, 2008

Angie Tolle  
Cincinnati Public Schools  
2315 Iowa Avenue  
Cincinnati, OH 45206


Dear Angie:

Attached are **Pay Applications** for the **Bond Hill Academy**,  
**please process for payment.**

Contractor	Application #	Monthly Billing	Total Billing To Date	Contract Amount to Date
BP#6 Feldkamp	#21-Retainage	\$ 43,249.52	\$1,267,619.00	\$1,267,619.00

Please call if you have any questions.

Sincerely,  
TURNER/DAG/TYS

  
James T. DeLage  
Project Executive

/bcs

Attachments

cc: Matt Meibers - SHP  
Dave Daniel - Turner/DAG/TYS  
File 0025-10960PO

T:PROJECTS/BOND HILL/00250 Pay Application/2008-08-22 combined Pay App. Ltr. Doc

2315 Iowa Avenue, Cincinnati, OH 45206, Phone 513-363-0875, Fax 513-363-0880

# AIR HANDLING UNITS

- BASIS OF DESIGN: TRANE. REFER TO SPECIFICATIONS FOR LIST OF APPROVED MANUFACTURERS
- WATER TYPE HEATING COIL CAPACITY BASED ON 190°F E.W.T./160°F L.W.T.
- WATER TYPE COOLING COIL CAPACITY BASED ON 44°F E.W.T./58°F L.W.T.
- MOTORS SHALL BE 480/3/60 UNLESS NOTED OTHERWISE.

UNIT NUMBER		AHU-1	AHU-2	AHU-3		
AREA SERVED		ACADEMIC	ADMIN/ MEDIA	GYM/CAFE		
MAXIMUM SYSTEM AIRFLOW (CFM)		36,000	9,000	20,000	(TYPICAL)	
MINIMUM OA (CFM)		14,100	2,600	3,000/12,050		
SUPPLY FAN	CFM	36,000	9,000	20,000		
	S.P. - IN W.G. EXT./TOTAL	2.0/6.0	1.5/5.0	1.5 / 4.06		
	WHEEL DIA. IN./RPM	44.5 / 1202	20 / 1794	39.39 / 1400		
	WHEEL TYPE/ CLASS	AF PLENUM / II	DWDI AF / II	PLENUM AF / II		
	MOTOR BHP / HP	51.1 / 60	10.53 / 15	20.93 / 25		
RETURN/EXHAUST FAN	CFM	32,300	7,800	17,000		
	S.P. - IN W.G. EXT./TOTAL	0.75 / 2.0	0.5 / 0.75	0.75 / 1.22		
	WHEEL DIA. IN./RPM	49 / 615	20 / 495	39.39 / 724		
	WHEEL TYPE/ CLASS	AF PLENUM / I	DWDI AF / I	AF PLENUM / I		
	MOTOR BHP / HP	14.9 / 20	2.79 / 3	4.83 / 7.5		
	VFD / STARTER/DISC. VOLTS/PHASE	Danfoss/Graham 460V/3Ø	Danfoss/Graham 460V/3Ø	Danfoss/Graham 460V/3Ø		
PRE-HEATING COIL	FACE AREA	80.0	14.67	37.75		
	CAPACITY MBH	820.8	195.21	867.6		
	ENT. AIR TEMP.	45	55	25		
	LVG. AIR TEMP.	85	75	65		
	CFM	36,000	9,000	20,000		
	MAX AIR P.D. - IN. W.C.	0.5	0.5	0.5		
	GPM	85	13	57.75		
	MAX WATER P.D.	5	5	5		
		2	1	1		

VFD / STARTER / DISC. VOLTS/PHASE		Danfoss/Graham 460V/3Ø	Danfoss/Graham 460V/3Ø	Danfoss/Graham 460V/3Ø
PRE-HEATING COIL	FACE AREA	80.0	14.67	37.75
	CAPACITY MBH	820.8	195.21	867.6
	ENT. AIR TEMP.	45	55	25
	LVG. AIR TEMP.	65	75	65
	CFM	38,000	9,000	20,000
	MAX. AIR P.D. - IN. W.C.	0.5	0.5	0.5
	GPM	55	13	57.73
	MAX WATER P.D. FT.	5	5	5
	MINIMUM ROWS	2	1	1
COOLING COIL	FACE AREA S.F.	80.0	16.8	39.33
	SENSIBLE CL'G MBH	1098	253	575.4
	TOTAL CL'G MBH	1380	295	818.9
	ENT. AIR TEMP. DB/WB	79.3 / 64.6	80.6 / 65.1	80.0 / 67.0
	LVG. AIR TEMP. DB/WB	53.0 / 52.0	55.0 / 54.17	53.8 / 53.5
	CFM	38,000	9,000	20,000
	MAX. AIR P.D. - IN W.C.	1.0	0.8	1.0
	GPM	203	42	116.6
	MAX. WATER P.D. FT.	10	10	10
MINIMUM ROWS	6	6	6	
FILTER	TYPE - PRE	30	30	30
	TYPE - FINAL	65	65	65
	FACE AREA S.F.	80	40	40
	P.D. IN W.C. PRE- FLTRS. CLN/DIRTY	0.3/0.7	0.3/0.7	0.3/0.7
	P.D. IN W.C. FNL- FLTRS. CLN/DIRTY	0.5/1.0	0.5/1.0	0.5/1.0
OUTSIDE AIR - CFM	14,100	∇	∇	
	9,500			
	95 / 74			
	834 / 67.8			
	770 / 62.8			
EXHAUST AIR - CFM	5 / 2			
SUMMER	O.A. E.A.T. - DB/WB °F			
	O.A. L.A.T. DB/WB °F			
	E.A. E.A.T. - DB/WB °F			

FT.		10	10	10			
MINIMUM ROWS		6	6	6			
FILTER	TYPE - PRE	30	30	30			
	TYPE - FINAL	65	65	65			
	FACE AREA S.F.	80	40	40			
	P.D. IN W.C. PRE-FLTRS. CLN/DIRTY	0.3/0.7	0.3/0.7	0.3/0.7			
	P.D. IN W.C. FINL-FLTRS. CLN/DIRTY	0.5/1.0	0.5/1.0	0.5/1.0			
HEAT RECOVERY	OUTSIDE AIR - CFM	14,100					
	EXHAUST AIR - CFM	9,500					
	SUMMER	O.A. E.A.T. - DB/WB °F	85 / 74				
		O.A. L.A.T. DB/WB °F	85.4 / 67.5				
		E.A. E.A.T. - DB/WB °F	71.0 / 62.5				
	WINTER	O.A. E.A.T. - DB/WB °F	5 / 2				
		O.A. L.A.T. - DB/WB °F	42.2 / 35.7				
		E.A. E.A.T. - DB/WB °F	70 / 54				
	MAX. FACE VEL. - FPM	600					
	MAX. AIR P.D. W.C. O/A	.75					
	MAX. AIR P.D. W.C. EXH	.75					
TOTAL RECOVERY EFFECTIVENESS	80						
UNIT WEIGHT (LBS)	35,000 LBS	6,000 LBS	15,000 LBS				

**REQD ACCESS.**

1. EMS CONTRACTOR SHALL DISABLE WHEEL OPERATION WHEN UNIT ENTERS ECONOMIZER MODE.
2. PACKAGED HEAT RECOVERY UNIT WITH SINGLE POINT POWER CONNECTION PACKAGE AND STOP/JOG ECONOMIZER WHEEL CONTROLS. UNIT SHALL BE 480-3-60. PROVIDE INTEGRAL MOTOR STARTERS.
3. FACTORY PROVIDED HEAT WHEEL 1 HP, W/VP, 460V, 1Ø FOR AHU-1.

**Thybar Corporation AIRX ERC DESIGN POINT ANALYSIS**

<u>DESIGN CONDITIONS</u>	<u>Dry Bulb, F</u>	<u>Wet Bulb, F</u>	<u>Enthalpy, Btu/lb</u>
SUMMER, Outdoor	92.00	74.00	38.15
SUMMER, Indoor	75.00	63.00	28.94
WINTER, Outdoor	.00	-2.00	.31
WINTER, Indoor	70.00	53.00	22.25

<b>Project Unit:</b> ERV-1	<b>Model Number:</b> TV-7490
SUPPLY AIR FLOW RATE, cfm	10010
EXHAUST AIR FLOW RATE, cfm	8010
Latent Effectiveness	75.96%
Sensible Effectiveness	81.67%
Measured Effectiveness (S/W)	79.4%

<u>SUPPLY AIR CONDITIONS</u>	<u>Summer</u>	<u>Winter</u>
Dry Bulb Temperature, F	80.59	44.70
Wet Bulb Temperature, F	67.17	37.04
Enthalpy, Btu/lb	32.19	14.07
Relative Humidity, %	50.6	48.0

<u>DESIGN LOADS, Btu/h</u>	<u>Summer</u>	<u>Winter</u>
Outside Air, Sensible	172,229	765,017
Outside Air, Latent	216,811	233,833
Outside Air, Total	389,040	998,850


<u>RECOVERED LOADS, Btu/h</u>	<u>Summer</u>	<u>Winter</u>
Sensible Recovered	113,884	445,029
Latent Recovered	133,862	169,997
Total Recovered	247,746	615,026

Net OA Load 141,294 383,824


**INSTALLED HVAC REDUCTION**

COOLING, Tons	20.65	615,026
HEATING, Btu/h		

Summer Process Diagram



Winter Process Diagram



Exhaust Air Transfer Ratio: 3.0  
Outdoor Air Correction Factor: 1.01  
Pressure is in in. wc. Flow is in cfm. Temperature is in F.

Exhaust Air Transfer Ratio: 3.0  
Outdoor Air Correction Factor: 1.01  
Pressure is in in. wc. Flow is in cfm. Temperature is in F.

**Thybar Corporation AIRX ERC DESIGN POINT ANALYSIS**

<u>DESIGN CONDITIONS</u>	<u>Dry Bulb, F</u>	<u>Wet Bulb, F</u>	<u>Enthalpy, Btu/lb</u>
SUMMER, Outdoor	92.00	74.00	38.15
SUMMER, Indoor	75.00	63.00	28.94
WINTER, Outdoor	.00	-2.00	.31
WINTER, Indoor	70.00	53.00	22.25

<b>Project Unit:</b> ERV-2	<b>Model Number:</b> TV-7490	
SUPPLY AIR FLOW RATE, cfm	10958	10958
EXHAUST AIR FLOW RATE, cfm	8958	8958
Latent Effectiveness	73.38%	74.14%
Sensible Effectiveness	79.45%	80.34%
Measured Effectiveness (S/W)	77.0%	79.4%

**SUPPLY AIR CONDITIONS**

	<b>Summer</b>	<b>Winter</b>
Dry Bulb Temperature, F	80.67	44.36
Wet Bulb Temperature, F	67.24	36.76
Enthalpy, Btu/lb	32.25	13.94
Relative Humidity, %	50.7	48.0

**DESIGN LOADS, Btu/h**

	<b>Summer</b>	<b>Winter</b>
Outside Air, Sensible	188,512	837,978
Outside Air, Latent	237,310	256,134
Outside Air, Total	425,822	1,094,113

**RECOVERED LOADS, Btu/h**

	<b>Summer</b>	<b>Winter</b>
Sensible Recovered	123,898	483,833
Latent Recovered	144,652	184,275
Total Recovered	268,550	668,108

**Net OA Load**



	157,271	426,005
--	---------	---------

**INSTALLED HVAC REDUCTION**

COOLING, Tons	22.38	
HEATING, Btu/h		668,108

Summer Process Diagram

Winter Process Diagram



Exhaust Air Transfer Ratio: 2.8  
Outdoor Air Correction Factor: 1.01

Exhaust Air Transfer Ratio: 2.8  
Outdoor Air Correction Factor: 1.01

Pressure is in in. wc. Flow is in cfm. Temperature is in F.



# **Air-Cooled Series R™ Helical-Rotary Liquid Chiller**

---

**Model RTAC 120 to 200  
(400 to 760kw - 50 Hz)  
Built for the Industrial and  
Commercial Markets**



---

**RLC-PRC005-E4**

# Performance Data

## SI Units

**Table P-49 — ARI Part-Load Values RTAC Standard  
(along with ARI 550/590-98)**

Unit	% Load	kW cooling	PL kW	COP (kW/kW)	IPLV (kW/kW)
140	100	505.9	159.0	2.90	4.09
	75	372.0	85.8	3.67	
	50	247.9	47.3	4.47	
	25	124.1	21.0	4.25	
155	100	554.3	175.6	2.87	3.98
	75	407.6	94.7	3.63	
	50	271.9	52.2	4.36	
	25	135.7	24.8	3.89	
170	100	603.4	192.4	2.85	3.98
	75	443.8	103.7	3.60	
	50	295.8	58.4	4.32	
	25	148.1	26.0	4.11	
185	100	669.7	212.5	2.86	3.98
	75	491.7	114.6	3.62	
	50	328.1	62.6	4.40	
	25	164.2	31.1	3.81	
200	100	737.6	232.9	2.88	4.00
	75	542.3	125.8	3.64	
	50	361.5	71.3	4.34	
	25	180.8	32.7	4.05	

**Table P-50 — ARI Part-Load Values RTAC High-Efficiency  
(along with ARI 550/590-98)**

Unit	% Load	kW cooling	PL kW	COP (kW/kW)	IPLV (kW/kW)
120	100	434.8	126.3	3.06	4.17
	75	320.0	70.5	3.71	
	50	213.1	38.3	4.58	
	25	106.6	16.3	4.34	
130	100	480.3	138.9	3.07	4.14
	75	353.5	76.9	3.74	
	50	235.3	41.2	4.59	
	25	117.8	19.6	3.97	
140	100	526.6	151.6	3.08	4.18
	75	387.2	83.4	3.76	
	50	258.1	46.2	4.59	
	25	129.1	20.6	4.21	
155	100	574.0	167.5	3.04	4.08
	75	423.4	92.1	3.73	
	50	281.4	50.7	4.49	
	25	140.7	24.2	3.89	
170	100	622.0	183.6	3.01	4.08
	75	456.9	100.1	3.70	
	50	304.9	56.5	4.45	
	25	152.3	25.4	4.07	
185	100	693.1	203.9	3.03	4.08
	75	510.3	111.9	3.72	
	50	339.7	61.7	4.50	
	25	169.9	30.6	3.82	
200	100	765.9	224.4	3.05	4.10
	75	561.7	122.8	3.75	
	50	375.6	70.6	4.45	
	25	187.8	32.2	4.08	

## English Units

**Table P-51 — ARI Part-Load Values RTAC Standard  
(along with ARI 550/590-98)**

Unit	% Load	tons	PL kW	EER	IPLV
140	100	143.9	159.0	9.88	13.95
	75	105.8	85.8	12.51	
	50	70.5	47.3	15.24	
	25	35.3	21.0	14.51	
155	100	157.6	175.6	9.79	13.59
	75	115.9	94.7	12.39	
	50	77.3	52.2	14.89	
	25	38.6	24.8	13.29	
170	100	171.6	192.4	9.72	13.58
	75	126.2	103.7	12.29	
	50	84.1	58.4	14.74	
	25	42.1	26.0	14.02	
185	100	190.4	212.5	9.77	13.60
	75	139.8	114.6	12.34	
	50	93.3	62.6	15.02	
	25	46.7	31.1	13.00	
200	100	209.7	232.9	9.83	13.64
	75	154.2	125.8	12.42	
	50	102.8	71.3	14.81	
	25	51.4	32.7	13.81	

**Table P-52 — ARI Part-Load Values RTAC High-Efficiency  
(along with ARI 550/590-98)**

Unit	% Load	tons	PL kW	EER	IPLV
120	100	434.8	126.3	10.45	14.23
	75	320.0	70.5	12.66	
	50	213.1	38.3	15.63	
	25	106.6	16.3	14.82	
130	100	480.3	138.9	10.47	14.14
	75	353.5	76.9	12.76	
	50	235.3	41.2	15.66	
	25	117.8	19.6	13.55	
140	100	526.6	151.6	10.50	14.27
	75	387.2	83.4	12.84	
	50	258.1	46.2	15.65	
	25	129.1	20.6	14.37	
155	100	574.0	167.5	10.37	13.93
	75	423.4	92.1	12.73	
	50	281.4	50.7	15.31	
	25	140.7	24.2	13.26	
170	100	622.0	183.6	10.26	13.92
	75	456.9	100.1	12.64	
	50	304.9	56.5	15.20	
	25	152.3	25.4	13.90	
185	100	693.1	203.9	10.33	13.91
	75	510.3	111.9	12.71	
	50	339.7	61.7	15.35	
	25	169.9	30.6	13.04	
200	100	765.9	224.4	10.40	13.98
	75	561.7	122.8	12.80	
	50	375.6	70.6	15.17	
	25	187.8	32.2	13.93	

## CHILLERS

TAG	DESCRIPTION	E.W.T.	L.W.T.	GPM	FOULING FACTOR	MAX EVAP PD (FT. HD.)	TONS	MIN. CAPACITY	EER	ELECTRICAL DATA				MFR. **	MODEL	REQ'D ACCESS.
										VOLTS	PHASE	MCA	MCOF			
CH-1	AIR COOLED SCREW	56	44	330	0.0001	10	187.9	10%	9.6	460	3	418	500	TRANE	RTAC200	ALL

### REQ'D ACCESS:

1. FACTORY MOUNTED & WIRED DISCONNECT
2. VIBRATION PADS
3. SINGLE POINT POWER CONNECTION
4. WATER FLOW SWITCH
5. HEAT TRACE FOR ALL EXTERIOR PIPING
6. HFC-134A REFRIGERANT
7. UNIT SHALL MEET ASHRAE 90.3-1999 FOR FULL LOAD CAPACITY AT ALL CONDITIONS.

8. WEIGHT OF UNIT IS 14,200 LBS, WITH REFRIGERANT.
9. UNIT DIMENSIONS: 232" O"L x 89" W x 98" H
10. GAS CHARGE 1 & 2 = 215 LB EACH
11. UNIT POWER 247.8 KW, COMPRESSOR POWER 229.60 KW, FAN MOTOR POWER 17.5 KW, 12 CONDENSER FANS, WYE-DELTA CLOSED COMPRESSOR STARTER TYPE.
12. FLA - CONDENSER FANS EACH 3.00A; FLA - COMPRESSOR A 168.00 A & FLA COMPRESSOR B 168.00 A

\*\* - REFER TO SPECIFICATIONS FOR LIST OF APPROVED MANUFACTURERS (CARRIER MODEL 30GR-024 ACCEPTABLE MODEL#)

## GAS FIRED BOILERS

TAG	DESCRIPTION	E.W.T.	L.W.T.	GPM	MAX. P.D. FT.	MDH		BURNER			OPER. GAS PRESS. IN. WC.	MFR. **	MODEL	REQ'D ACCESS.
						INPUT	OUTPUT	H.P.	VOLTS	PHASE				
B-1	FLEXIBLE TUBE FORCED DRAFT	160	190	110	10	2,000	1,670	3	460	3	14"	BRYAN	AB200	ALL
B-2	FLEXIBLE TUBE FORCED DRAFT	160	190	110	10	2,000	1,670	3	460	3	14"	BRYAN	AB200	ALL

# Dynamix Engineering Ltd.

Facility Engineering Consultants

1108 City Park Avenue, 3rd Floor  
Phone (614) 443-1178

Fax (614) 443-1594

Columbus, Ohio 43206  
www.dynamix-ltd.com

## Shop Drawing Submittal Comments

**Project:** 050003 Bond Hill Academy  
**In regard to:** 15855 - Custom AHU #1

REVIEW IS FOR GENERAL COMPLIANCE WITH CONTRACT DOCUMENTS. NO RESPONSIBILITY IS ASSUMED FOR CORRECTNESS OF DIMENSIONS OR DETAILS.	
NO EXCEPTIONS TAKEN	<input type="checkbox"/>
MAKE CORRECTIONS NOTED	<input checked="" type="checkbox"/>
AMEND & RESUBMIT	<input type="checkbox"/>
REJECTED-SEE REMARKS	<input type="checkbox"/>
DYNAMIX ENGINEERING LTD.	
DATE RECEIVED BY DYNAMIX: 8/11/06	
DATE RETURNED: 9/29/06	
BY: MEO	

### REMARKS

- 1) The Hot Water Coils, Chilled Water Coils, and The Energy Recovery Wheel in the original submittal were not correct. The manufacturer has submitted Supplemental Information regarding these items. See Attached Sheets.
- 2) Energy Recovery Wheel submitted in Supplemental Information is acceptable.

# Ventrol



Ventrol Air Handling Systems Inc

## Bond Hill Academy

### STATIC PRESSURE SUMMARY


air pressure drops at 0 feet above sea level (inches w.g.)

septembre 15, 2006

Job Tag	Supply	Return
	AHU-1	AHU-1
Serial Number	11406-01	11329-01
Intake Section	0.10	0.01
2" Pre-Filters 25-30%	0.60	0.60
Heat Wheel	1.27	0.86
Return Fan System Effect	-	0.14
Exhaust damper	-	0.10
2" Pre-Filters 25-30%	0.60	
Cooling Coils	0.83	-
Heating Coils	0.06	-
12" Cartridge Filters 60-65%	1.00	-
Supply Fan System Effect	0.17	-
Discharge Section	0.01	-
Internal Static Pressure	4.64	1.71
Available External Static Pressure	2.00 ✓	0.75 ✓
Total Static Pressure	6.64	2.46

\* Filters estimated at 50% Dirty.

# Bond Hill Academy 11406-01 Revision : 2



## Certified Performance Data Sheet

### UNIT DETAILS

Unit TAG : AHU-1  
CFM : 38000 ✓  
TSP : 6.55" WG ✓  
Unit Type : Indoor  
Unit Exterior : Air dried enamel CES sandstone color coated exterior liner  
Unit Roof Curb : N/A  
Unit Roof Curb Serial : N/A  
Unit Floor Type : Standard flat floor  
Auxillary Floor Drains : 1 1/4" Dia. Galvanized Drain Connection  
Unit Floor Insulation : 4", 3 lbs / cu.ft. density insulation  
Unit Floor Liner : 12 Ga. Galvanized steel checkered plate  
Unit Under Floor Liner : 22 Ga. Galvanized steel (Ventrol standard)  
Unit Wall And Roof Insulation : 2", 3 lbs/cu.ft density  
Unit Exterior Liner : 16 Ga G-90 galvanized steel (Ventrol standard)  
Interior Liner : SEE UNIT DRAWING  
Fastners : Zinc coated screws on interior and exterior liners (Ventrol Standard Interior Unit)  
ETL : YES

### Dampers Louvers

Damper Louver Number : 1  
Damper Model : Ventrol VCD-60  
Damper Louver Duty : Return air  
Damper Actuator Model : None

### Pre-Filter

Filter Duty : E/A  
Filter Number : 1  
Filter Loading : Front loading  
Filter Type : 2" AAF Perfect Pleat 25-30% efficiency (MERV 7), UL Class II ✓  
Total Media Sets : 2 sets supplied by Ventrol, 1 set installed by Ventrol & 1 set extra  
Filter Gage Type : Dwyer 2002  
Filter Frame Type Material : AAF Universal Holding Frame (angular, front loading)  
Filter Qty 24 X 24 : 20  
Filter Qty 12 X 24 : 0  
Blanking Material : Galvanized

### Dampers Louvers

Damper Louver Number : 2  
Damper Model : Ventrol VCD-60  
Damper Louver Duty : Return Bypass Damper  
Damper Actuator Model : None

### Dampers Louvers

# Bond Hill Academy 11406-01 Revision : 2

Ventrol



## Certified Performance Data Sheet

Damper Louver Number : 3  
Damper Model : Ventrol VCD-60  
Damper Louver Duty : Exhaust Bypass air  
Damper Actuator Model : None

### Return Fan(s)

Return Fan Number : 1  
Fan Model Number : PF-49  
Class Construction : II  
Rotation : CW  
Fan Discharge Arrangement : axial  
Fan Arrangement Type : 3  
Motor manufacturer : Weg  
Motor Model # : 02018T3E256T  
Enclosure/Hp/RPM/Frame/Eff. : ODP - 20 - 1800 - 256T - PREMIUM ✓  
Vac/Ph/Hz : 460/3/60 ✓  
Belt Guard : OSHA  
Drive Sheaves : Fixed pitch 1.2 safety factor  
Safety Lock On Fan Door : OSHA approved tool operated latch  
Fan Bearings : 200 000 hrs L-50 with heavy duty nylon tubing & grease fittings to common internal location  
Septum Wall : 2" Double Wall  
Fan Accessories 1 : Inertia base (concrete by others in the field)  
Fan Accessories 2 : Inlet screen  
Fan Accessories 3 : Fan enclosure screen

### Dampers Louvers

Damper Louver Number : 4  
Damper Model : Ventrol VCD-60  
Damper Louver Duty : Exhaust air  
Damper Actuator Model : None

### Dampers Louvers

Damper Louver Number : 5  
Damper Model : Ventrol VCD-60  
Damper Louver Duty : Outside air  
Damper Actuator Model : None

### Pre-Filter

Filter Duty : O/A  
Filter Number : 2  
Filter Loading : Front loading  
Filter Type : 2" AAF Perfect Pleat 25-30% efficiency (MERV 7), UL Class II ✓  
Total Media Sets : 2 sets supplied by Ventrol, 1 set installed by Ventrol & 1 set extra ✓  
Filter Gage Type : Dwyer 2002  
Filter Frame Type Material : Type 8 Galvanized steel  
Filter Qty 24 X 24 : 20  
Filter Qty 12 X 24 : 0

# Bond Hill Academy 11406-01 Revision : 2



## Certified Performance Data Sheet

Blanking Material : Galvanized

### Dampers Louvers

Damper Louver Number : 6  
Damper Model : Ventrol VCD-80  
Damper Louver Duty : Outside Bypass air  
Damper Actuator Model : None

### Combo-Filter

Filter Duty : S/A  
Filter Number : 1  
Filter Loading : Front loading  
Filter Type : 2" AAF Perfect Pleat 25-30% efficiency (MERV 7), UL Class II ✓  
Total Media Sets : 2 sets supplied by Ventrol, 1 set installed by Ventrol & 1 set extra ✓  
Pre-Filter Gage Type : Dwyer 2002  
Final Filter Type : 12" AAF Varicel, Type SH, 60-65%, UL Class I ✓  
Final Filter Total Media Sets : 2 sets supplied by Ventrol, 1 set installed by Ventrol & 1 set extra ✓  
Final Filter Gage Type : Dwyer 2002  
Final Filter Frame Type Material: Type 8 Galvanized steel  
Filter Qty 24 X 24 : 20  
Filter Qty 12 X 24 : 0  
Blanking Material : Galvanized

### Heating Coil(s)

Coil Casing Material : Galvanized Steel  
Blanking Material : Galvanized  
Coil Rack : 304 Stainless Steel Coil Rack  
Special Coating : None  
Piping : No

### Cooling Coil(s)


Coil Casing Material : Galvanized Steel  
Blanking Material : Galvanized  
Coil Rack : 304 Stainless Steel Coil Rack  
Drain Pan : IAQ 304 (18 Ga.) Stainless Steel Drain Pan With (18 Ga.) Intermediate Drain Pan  
Drain Pan Connection : 1 1/4" Dia. Stainless Steel Drain Connection  
Special Coating : None  
Piping : No

### Supply Fan(s)

Supply Fan Number : 1  
Fan Model Number : PF-49  
Class Construction : II  
Rotation : CW  
Fan Discharge Arrangement : Radial  
Fan Arrangement Type : 3

# Bond Hill Academy 11406-01 Revision : 2

Ventrol



## Certified Performance Data Sheet

Motor manufacturer :	Weg
Motor Model # :	06018OT3E364T
Enclosure/Hp/RPM/Frame/Eff. :	ODP - 60 - 1800 - 364T - PREMIUM
Vac/Ph/Hz :	460/3/60
Belt Guard :	OSHA
Drive Sheaves :	Fixed pitch 1.2 safety factor
Safety Lock On Fan Door :	OSHA approved tool operated latch
Fan Bearings :	200 000 hrs L-50 with heavy duty nylon tubing & grease fittings to common internal location
Septum Wall:	2" Double Wall
Fan Accessories 1 :	Inertia base (concrete by others in the field)
Fan Accessories 2 :	Inlet screen
Fan Accessories 3 :	Fan enclosure screen

### Others Components

Other Component - 1 :

Note :




Novel Aire Heat Wheel (ECW<sup>844</sup>) c/w VFD & Frost Control (motor is 460V) ✓  
See Heatwheel selection for more info. Frost control is c/w one E/A temperature sensor (see electrical drawing for more info).

### Production Notes

- 1- S/A floor opening c/w grating.
- 2- Galvanized auxilliary drains provided downstream of the heatwheel for both tunnels (see drawing)
- 3- Short radius bellmouths provided on S/A openings. See drawing for more details.
- 4- All doors are c/w ADH-50 handles and stainless steel butt hinges.

### Electrical Notes


- 1- Each fan motor is wired to a junction box (460V).
- 2- Heatwheel motor is wired to the VFD/Frost control enclosure.
- 3- Frost Control is c/w one temperature sensor installed in exhaust air tunnel.
- 4- All compact fluorescent lights in S/A tunnel are wired to a light switch (c/w pilot light) and GFI at supply fan section.
- 5- All compact fluorescent lights in R/A tunnel are wired to a light switch (c/w pilot light) and GFI at return fan section.
- 6- VFDs provided, installed and wired by others.



ALL MATERIALS SHOWN ARE GENERAL AND FOR ILLUSTRATION PURPOSES ONLY. REFER TO COMPANY'S SPECIFICATIONS FOR DETAILED INFORMATION.

06/08/00 CHANGE SUBMITTAL	02		JOB NAME: <b>Bond Hill Academy</b>		TYPE OF DRAWING	DRAWING NUMBER
07/31/00 SEE REVISION TABLE IN SUBMITTAL	01		ENGINEER:	SCALE: <b>N.E.S.</b>	REFERENCE DRAWINGS	
07/14/08			PREPARED BY / APPLICATION ENGINEER	DATE: <b>11-4-05</b>	SHOP ORDER NO.:	UNIT TAG
EXTD.			REP: <b>Stidley-Anderson</b>		<b>01</b>	<b>AHU-1</b>

PLANS, SPECIFICATIONS AND ENGINEERING DATA SUBMITTED HEREIN ARE THE PROPERTY OF VENTROL AIR HANDLING SYSTEMS INC. AND SHALL NOT BE REPRODUCED OR ALTERED OR USED IN WHOLE OR PART AS THE BASIS FOR MANUFACTURING WITHOUT EXPRESS CONSENT OF VENTROL AIR HANDLING SYSTEMS INC. TRADEMARKS SHOWN HEREON ARE COVERED BY PATENTS OWNED OR PENDING. ALL WEIGHTS SHOWN ON THIS DRAWING ARE DRY WEIGHTS UNLESS OTHERWISE SPECIFIED.



# PF02-49 NYB 12 Blade Plenum

### JOB INFORMATION:

**Job Name:** Bond Hill Academy  
**Job Tag:** AHU-1 (Return Fan)  
**Rep Firm:** Stoermer-Anderson  
**Serial No:** 11406-01  
**Date:** 09-15-2006

### WHEEL SPECIFICATIONS:

**Class / Max RPM:** Class II / 1,105 ✓  
**Diameter:** 49.0 In.  
**Width:** 100%  
**Tip Speed:** 8,980 FPM  
**Shaft / Bearing Dia.:** 2 7/16", 2 7/16"  
**Inertia:** 143 WR<sup>2</sup>

### OPERATING CONDITIONS:

**Required Air Flow:** 32,300 CFM ✓  
**Static Pressure:** 2.32 in. Wg. ✓  
**Unducted Axial Disch.:** 0.04 in. Wg.  
**Inlet Screen:** 0.10 in. Wg.  
**Total Adjusted Static:** 2.46 in. Wg.  
**Site Elevation:** Sea Level  
**TSP @ Sea Level:** 2.46 in. Wg.

### MOTOR SELECTION:

**Rated HP:** 20.0 ✓  
**Frame Size:** 256T  
**Nominal RPM:** 1750  
**VAC / PH / HZ:** 460/3/60 ✓  
**Efficiency:** Premium ✓  
**Enclosure Type:** ODP ✓  
**Max Inertial Load:** 236 WR<sup>2</sup>

### FAN PERFORMANCE:


**RPM:** 700  
**BHP / BHP with Belt Loss:** 18.86 / 19.44  
**Static / Mech. Efficiency:** 66.3% / 71.5%  
**Inlet / Outlet Velocity:** 1976 / 1764 FPM  
**Plenum Outlet Velocity:** 500 FPM

### SOUND POWER: (Inlet / Outlet)

**Octave Band: (Re 10<sup>-12</sup> watts)**  

1	2	3	4	5	6	7	8
89	96	88	84	83	81	81	77
91	96	92	90	87	84	82	79

**Sound Power A-Weighted: 89 / 93 db**



Version 2003.100



# PF02-49 NYB 12 Blade Plenum

### JOB INFORMATION:

**Job Name:** Bond Hill Academy  
**Job Tag:** AHU-1 (Supply Fan)  
**Rep Firm:** Stoermer-Anderson  
**Serial No:** 11406-01  
**Date:** 09-15-2006

### WHEEL SPECIFICATIONS:

**Class / Max RPM:** Class II / 1,105 ✓  
**Diameter:** 49.0 in.  
**Width:** 100%  
**Tip Speed:** 12,584 FPM  
**Shaft / Bearing Dia.:** 2 7/16", 2 7/16"  
**Inertia:** 280 WR<sup>2</sup>

### OPERATING CONDITIONS:

**Required Air Flow:** 38,000 CFM ✓  
**Static Pressure:** 6.47 in. Wg. ✓  
**Unducted Radial Disch.:** 0.03 in. Wg.  
**Inlet Screen:** 0.14 in. Wg.  
**Total Adjusted Static:** 6.64 in. Wg.  
**Site Elevation:** Sea Level  
**TSP @ Sea Level:** 6.64 in. Wg.

### MOTOR SELECTION:

**Rated HP:** 60.0 ✓  
**Frame Size:** 364T  
**Nominal RPM:** 1750  
**VAC / PH / HZ:** 460/3/60 ✓  
**Efficiency:** Premium ✓  
**Enclosure Type:** ODP ✓  
**Max Inertial Load:** 637 WR<sup>2</sup>

### FAN PERFORMANCE:


**RPM:** 981  
**BHP / BHP with Belt Loss:** 55.70 / 57.26  
**Static / Mech. Efficiency:** 71.3% / 74.2%  
**Inlet / Outlet Velocity:** 2324 / 2075 FPM  
**Plenum Outlet Velocity:** 500 FPM


### SOUND POWER: (Inlet / Outlet)

**Octave Band:** (Re 10<sup>-12</sup> watts)  

1	2	3	4	5	6	7	8
92	98	96	92	89	87	87	82
97	99	102	100	95	90	88	83

**Sound Power A-Weighted:** 96 / 101 db



**Ventrol**

# Coil Selection / Rating 2006.100


Job Name: Bond Hill Academy  
 Tag: AHU-1 EC

Entered By: User Name

Date: 09/08/06  
 Serial #: 11406-01

Hot Water		5WC - 2 - 48 x 115 x 1 - 6 AL
Individual Coil Construction	Entering Conditions	Leaving Conditions
(Qty) FH x FL : (2) 48.00 x 115.00 Rows - FPI : 1 - 6 Serpentine : 0.500 Total Face Area : 76.67 sq.ft Fin Thick / Mat. : 0.008" / AL Tube O.D. / Wall : 5/8" / 0.020" Tube Material : CU Case Material : 16 GA GALV Conn Location : LH Same Sup.Conn - Qty / Size : (1) 1-1/2" Ret.Conn - Qty / Size : (1) 1-1/2"	ACFM : 38,000 ✓ SCFM : 38,000 ✓ Altd : 0 ft EDB : 45.0°F  EWT : 180.0°F - PD Fluid : Water GPM : 55.00 ✓	Total Heat : 938,734 Btu/Hr ✓ Sensible Heat : 938,734 Btu/Hr  LDB : 67.8°F  LWT : 141.1°F Actual FV : 495.7 ft/min APD : 0.06 in.WG ✓ Water Velocity : 1.91 ft/s Water PD : 2.53 ft ✓
ARI CERTIFIED 'Rated in Accordance with ARI Standard 410'		

1. Hot water velocity is below recommended minimum of 2.5 fps



Coil Selection / Rating 2006.100

Job Name: Bond Hill Academy  
 Tag: AHU-1 CC

Entered By: User Name

Date: 09/08/06

Serial #: 11406-01

Chilled Water		SWC - 4 - 48 x 115 x 6 - 11 AL	
Individual Coil Construction	Entering Conditions	Leaving Conditions	
(Qty) FH x FL : (2) 48.00 x 115.00	ACFM : 38,000 ✓	Total Heat : 1,367,474 Btu/Hr ✓	
Rows - FPI : 6 - 11	SCFM : 38,000	Sensible Heat : 1,103,715 Btu/Hr ✓	
Serpentine : 1.500	Altd : 0 ft	LDB : 52.8°F	
Total Face Area : 76.67 sq.ft	EDB : 79.3°F	LWB : 52.6°F	
Fin Thick / Mat. : 0.008" / AL	EWB : 64.8°F	LWT : 57.4°F	
Tube O.D. / Wall : 5/8" / 0.020"	EWT : 44.0°F ✓	Actual FV : 495.7 ft/min	
Tube Material : CU	Fluid : Water	APD : 0.83 in.WG ✓	
Case Material : 16 GA GALV	GPM : 203.00 ✓	Water Velocity : 2.35 ft/s	
Conn Location : LH Same		Water PD : 8.2 ft ✓	
Sup.Conn - Qty / Size : (1) 2-1/2"			
Ret.Conn - Qty / Size : (1) 2-1/2"			
<b>ARI CERTIFIED 'Rated in Accordance with ARI Standard 410'</b>			

1. Chilled water velocity is below recommended minimum of 2.5 fps


# NOVELAIRE TECHNOLOGIES

## Energy Conservation Wheel Summer Operation



Title: AHU 1-Bond Academy  
Date: 9/11/2006

### Model Number: ECW 844



<b>Wheel Parameters</b>		<b>Face Velocity, sfpm</b>	
Wheel Diam., in.	84.0	Supply Side	721
Wheel Depth, in.	4.0	Exhaust Side	489
Purge Angle, °	2.0	<b>Pressures, in. WC</b>	
Purge Vol., scfm	48	OA Static	0.40
Wheel Speed, RPM	45	RA Static	0.00
Hub Diam. in.	10.0	Supply Delta P	1.27
		Exhaust Delta P	0.86
<b>Cassette Parameters</b>		<b>Effectiveness Balanced</b>	
Drive Motor, HP	1.5	Sensible, %	77.2
Height, in.	90.0	Latent, %	73.9
Width, in.	90.0	<b>Effectiveness Unbalanced</b>	
Depth, in.	9.0	Sensible, %	85.8
<b>Energy Conserved, BTU/h</b>		Latent, %	82.1
Sensible	135,448	Total, %	83.8
Latent	178,677		
Total	314,124		

	Volume scfm	Volume acfm	°FDB	°F WB	gr/lb	RH%	Enthalpy BTU / lb
Outdoor	13,607	14,518	93.0	74.0	95.7	41.2	37.39
Supply	13,497	14,100	83.7	68.0	77.3	44.8	32.22
Return	9,229	9,500	77.0	62.8	62.6	45.3	28.27
Exhaust	9,277	9,852	90.7	72.3	89.6	41.5	35.86

(Elevation: 0 ft. above Sea Level)

#### WHEEL

**WHEEL:** Unitary rotor design with 12 galvanized spokes equally spaced, 10 in. diameter aluminum center hub, 2.19 in. diameter shaft, 12 ga. outer band

**MEDIA:** Total energy transfer type (sensible and latent), corrugated synthetic fibrous matrix with molecular sieve desiccant

#### CASSETTE

**FRAME:** Galvanized 10 ga. steel with two (2) removable side panels

**BEARINGS:** Internal sealed roller bearing

**AIR SEALS:** Non-contact inner and outer bulb seals

**PURGE:** Adjustable Purge

**DRIVE:** Perimeter driven belt drive

NovelAire Technologies, 10132 Mammoth Drive, Baton Rouge, LA 70814  
Telephone: 800-762-1320 / 225-924-0427 Fax: 225-930-0340  
www.novelaire.com



3042 Muddy Creek Road  
Cincinnati, Ohio 45238  
Phone: (513) 347-4500  
Fax: (513) 347-4506  
Website: www.feldkampvac.com

## ***SUBMITTAL DATA***

Project: Bond Hill Academy K-8  
Project / P.O.# 1214  
Specification Section 15855  
Architect/Engineer: Steed Hammond Paul  
Submittal For: Air Handling Unit #1  
Manufacturer: Ventrol  
Supplier: Stoermer-Anderson, Inc.  
Contact Name & Phone #: George Mayer - (513) 527-2300

**Comments:**

**Wesley B. Goodyear**


**8/8/2006**

**RECEIVED BY**  
FELDKAMP ENTERPRISES, INC.

- APPROVED
- APPROVED AS NOTED
- NOT APPROVED
- RESUBMIT
- REVISION NOTED

SPEC SECTION \_\_\_\_\_ 15855

**MECHANICAL CONTRACTORS**  
INDUSTRIAL AND COMMERCIAL SHEET METAL FABRICATORS



## **Stoermer-Anderson, Inc.**

*Manufactures Representative \* Heating / A.C. \* Industrial / Power Equipment*

3818 Red Bank Road, Cincinnati, Ohio 45227  
t:513-527-2300 f:531-527-2306  
www.stoermer-anderson.com



### **EQUIPMENT SUBMITTAL**

**PROJECT:** Bond Hill Academy K-8  
1510 California Avenue  
Cincinnati, Ohio 45237

**ENGINEER:** Steed Hammond Paul  
1014 Vine Street, Suite 2100  
Cincinnati, Ohio 45202

**CONTRACTOR:** Feldkamp Enterprises, Inc.  
3642 Muddy Creek Rd.  
Cincinnati, OH 45238

**BY:** Stoermer-Anderson, Inc.  
3818 Red Bank Road  
Cincinnati, Ohio 45227

**MANUFACTURER:** Ventrol

**EQUIPMENT:** Air Handling Unit #1

**DATE:** August 1, 2006

---

*Below this line reserved for approval stamps*

Ventrol



Ventrol Air Handling Systems Inc.

# SUBMITTAL

## SUBMITTAL DRAWINGS & PERFORMANCE

PROJECT NAME: BOND HILL ACADEMY

VENTROL REP: STOERMER ANDERSON

SERIAL NUMBER:	11406-01
REVISION:	01
CUSTOMER:	-
ENGINEER FIRM:	-
PROJECT MANAGER:	Mauro Catavolo
DATE:	JULY 31 <sup>st</sup> , 2006

SUBMISSION FOR APPROVAL

FOR RECORD PURPOSES ONLY  
(NO DRAWINGS TO BE RETURNED)

# Ventrol



Ventrol Air Handling Systems Inc

## GENERAL:

- o Factory fabricated (ITF) indoor air handling units).
- o Right and left is determined by facing in the direction of the airflow with the air hitting the back of your neck.
- o All dimensions are in inches, unless otherwise indicated on drawings.
- o All unit dimensions are nominal, they do not include lifting lugs, light switches, convenience outlets, variable frequency drives, coil connections or any other accessory or component.
- o Multiple section units are shipped in modular sections. Units are shipped with sufficient gasket, mending plates, caulking and screws for field reassembly by OTHERS.
- o Multiple piece units with factory furnished lights or electrical conduit will require reconstructions at each demount. Field furnished electrical connections will be required after the unit is reassembled and set in place.
- o Units shall be ETL listed in accordance to UL Standard 1995 except for units with gas-fired heater, electric coils over 252 kW or shipped knocked down.

## UNIT BASE / FLOOR / FRAMEWORK:

The unit base frame is manufactured with rectangular structural tubing and fitted with C-Channel cross support members and "Double Bottom" base. The base rails are fitted with lifting lugs at each corner and midpoints as required.

## LINERS:

- o Liners are as per each Certified Performance Data Sheet (CPDS).
- o Panels are secured with 1/4" hex head, zinc plated fasteners.
- o If specified in the submittal, exterior panels are painted with industrial air-dried (alkyd) enamel (Standard CES Sandstone color). Salt Spray Resistance 5% salt fog at 95 °F passes 1000 hrs (ASTM B-117). Humidity Resistance 100% salt fog at 95 °F passes 1000 hrs (ASTM D-2247). If customer requires special color, please furnish factory with paint chip and/or paint color number before or at time of release.

## INSULATION:

The fiberglass insulation has an effective thermal conductivity (C) of 24 (BTU in. / hr sq.ft. °F) and a noise reduction coefficient (NRC) of 0.70 per inch thick (based on a type "A" mounting). Coefficients meet or exceed a 3.0 lb/ft<sup>3</sup> density material rating, unless otherwise indicated in CPDS. The insulation meets erosion requirements of UL 181 facing the air stream and fire hazard classification of 25/50 (per ASTM-84 and UL 723).

## ACCESS DOORS:

Access doors are double wall construction with an extruded aluminum frame, stainless steel butt hinges and heavy duty ADH-50 handles on 2" walls and Allegis handles on 4" wall units. The doorframe features a built-in no-through-metal and a perimeter gasket.

## CONDENSATE PAN:

Condensate pan is 16-ga TYPE 304 stainless steel. All pans have a dual slope and "Double Bottom" construction with welded corners. Drain connections are standard stainless steel 1/4" MPT.

## FANS:

Specific fan information can be found in CPDS and fan selection print out. The fan shaft is turned, ground and polished solid steel rated at a maximum RPM below the critical speed. The fan wheel and sheaves are keyed to the shaft. Prior to shipment, the fan is balanced at the design RPM. Fans are rated in accordance with AMCA 210 for performance and/or AMCA 300 for sound (See fan selection print out for more details). All fans are provided with high-pressure plastic lube lines internally located on the drive side unless otherwise indicated in CPDS. Fans, motors and drives are internally spring isolated on a welded structural steel base complete with flex connections. Isolators are Amber Booth (or equal) seismically restrained type with 2" deflection for all fans, except for AF wheels 18" or smaller and FC wheels 27" or smaller which will have 1" isolators, unless otherwise indicated in CPDS.

## MOTORS:

NEMA Design B T-FRAME motors are mounted on an adjustable base. The motors are tested to IEEE standard 112 test method B and NEMA MG 12.58.2 and 12.59 table 12-10. The motors meet energy policy act (EPA) regulations unless otherwise indicated in CPDS. See performance data and accessories sheet for voltage, rpm, efficiencies, and motor type.

## DRIVES:

VP "Variable Pitch" drive sheaves are furnished on motors up to 10 HP and fixed pitch on 15 HP and above. "Fixed pitch" sheaves are provided on all fans in excess of 2,000 RPM. See the air unit performance data and accessories sheet for the motor / fan sheave model numbers. V-Belt drives are selected at 120% to 150% of the motor nameplate horsepower.

## COILS:

All coil assemblies are leak tested under water at 315 PSIG. PERFORMANCE is CERTIFIED under ARI Standard 410. Coils exceeding the range of ARI standard rating conditions will be as noted on the coil computer printout. Coils are constructed of seamless copper tubing mechanically expanded into fin collars. Fins are die formed plate type. Headers are seamless copper with die formed tube holes. Intermediate tube supports are supplied on coils over 44" fin length with an additional support every 42" multiple thereafter.

## OTHERS:

- o All electrical and automatic control devices not called out in this submittal are to be furnished and installed in the field by OTHERS.
- o Dampers, louvers and/or other accessories are furnished and/or installed by Ventrol as indicated in each CPDS.

Ventrol



Ventrol Air Handling Systems Inc

AHU - 1

Ventrol



Ventrol Air Handling Systems Inc

**STATIC PRESSURE SUMMARY**



Ventrol Air Handling Systems Inc

## Bond Hill Academy

### STATIC PRESSURE SUMMARY


air pressure drops at 0 feet above sea level (inches w.g.)

juillet 13, 2006

Job Tag	Supply	Return
	AHU-1	AHU-1
Serial Number	11406-01	11329-01
Intake Section	0.10	0.01
2" Pre-Filters 25-30%	0.60	0.60
Heat Wheel	0.92	0.56
Return Fan System Effect	-	0.31
Exhaust damper	-	0.10
2" Pre-Filters 25-30%	0.60	
Cooling Coils	0.76	-
Heating Coils	0.06	-
12" Cartridge Filters 60-65%	1.00	-
Supply Fan System Effect	0.32	-
Discharge Section	0.01	-
Internal Static Pressure	4.37	1.58
Available External Static Pressure	2.00	0.75
Total Static Pressure	6.37	2.33

\* Filters estimated at 50% Dirty.

**Ventrol**



Ventrol Air Handling Systems Inc

**CERTIFIED PERFORMANCE DATA**



## Certified Performance Data Sheet

---

### UNIT DETAILS

Unit TAG : AHU-1  
CFM : 38000  
TSP : 6.37" WG  
Unit Type : Indoor  
Unit Exterior : Air dried enamel CES sandstone color coated exterior liner  
Unit Roof Curb : N/A  
Unit Roof Curb Serial : N/A  
Unit Floor Type : Standard flat floor  
Auxiliary Floor Drains : 1 1/4" Dia. Galvanized Drain Connection  
Unit Floor Insulation : 4", 3 lbs / cu.ft. density insulation  
Unit Floor Liner : 12 Ga. Galvanized steel checkered plate  
Unit Under Floor Liner : 22 Ga. Galvanized steel (Ventrol standard)  
Unit Wall And Roof Insulation : 2", 3 lbs/cu.ft density  
Unit Exterior Liner : 16 Ga G-90 galvanized steel (Ventrol standard)  
Interior Liner : SEE UNIT DRAWING  
Fastners : Zinc coated screws on interior and exterior liners (Ventrol Standard Interior Unit)  
ETL : YES

### Dampers Louvers

Damper Louver Number : 1  
Damper Model : Ventrol VCD-60  
Damper Louver Duty : Return air  
Damper Actuator Model : None

### Pre-Filter

Filter Duty : E/A  
Filter Number : 1  
Filter Loading : Front loading  
Filter Type : 2" AAF Perfect Pleat 25-30% efficiency (MERV 7), UL Class II  
Total Media Sets : 2 sets supplied by Ventrol, 1 set installed by Ventrol & 1 set extra  
Filter Gage Type : Dwyer 2002  
Filter Frame Type Material : AAF Universal Holding Frame (angular, front loading)  
Filter Qty 24 X 24 : 20  
Filter Qty 12 X 24 : 0  
Blanking Material : Galvanized

### Dampers Louvers

Damper Louver Number : 2  
Damper Model : Ventrol VCD-60  
Damper Louver Duty : Return Bypass Damper  
Damper Actuator Model : None

### Dampers Louvers

# Bond Hill Academy 11406-01 Revision : 1



## Certified Performance Data Sheet

---

Damper Louver Number : 3  
Damper Model : Ventrol VCD-60  
Damper Louver Duty : Exhaust Bypass air  
Damper Actuator Model : None

### Return Fan(s)

Return Fan Number : 1  
Fan Model Number : PF-49  
Class Construction : II  
Rotation : CW  
Fan Discharge Arrangement : axial  
Fan Arrangement Type : 3  
Motor manufacturer : Weg  
Motor Model # : 02018T3E256T  
Enclosure/Hp/RPM/Frame/Eff. : ODP - 20 - 1800 - 256T - PREMIUM  
Vac/Ph/Hz : 460/3/60  
Belt Guard : OSHA  
Drive Sheaves : Fixed pitch 1.2 safety factor  
Safety Lock On Fan Door : OSHA approved tool operated latch  
Fan Bearings : 200 000 hrs L-50 with heavy duty nylon tubing & grease fittings to common internal location  
Septum Wall : 2" Double Wall  
Fan Accessories 1 : Inertia base (concrete by others in the field)  
Fan Accessories 2 : Inlet screen  
Fan Accessories 3 : Fan enclosure screen

### Dampers Louvers

Damper Louver Number : 4  
Damper Model : Ventrol VCD-60  
Damper Louver Duty : Exhaust air  
Damper Actuator Model : None

### Dampers Louvers

Damper Louver Number : 5  
Damper Model : Ventrol VCD-60  
Damper Louver Duty : Outside air  
Damper Actuator Model : None

### Pre-Filter

Filter Duty : O/A  
Filter Number : 2  
Filter Loading : Front loading  
Filter Type : 2" AAF Perfect Pleat 25-30% efficiency (MERV 7), UL Class II  
Total Media Sets : 2 sets supplied by Ventrol, 1 set installed by Ventrol & 1 set extra  
Filter Gage Type : Dwyer 2002  
Filter Frame Type Material : Type 8 Galvanized steel  
Filter Qty 24 X 24 : 20  
Filter Qty 12 X 24 : 0

---

# Bond Hill Academy 11406-01 Revision : 1



## Certified Performance Data Sheet

---

Blanking Material : Galvanized

### Dampers Louvers

Damper Louver Number : 6  
Damper Model : Ventrol VCD-60  
Damper Louver Duty : Outside Bypass air  
Damper Actuator Model : None

### Combo-Filter

Filter Duty : S/A  
Filter Number : 1  
Filter Loading : Front loading  
Filter Type : 2" AAF Perfect Pleat 25-30% efficiency (MERV 7), UL Class II  
Total Media Sets : 2 sets supplied by Ventrol, 1 set installed by Ventrol & 1 set extra  
Pre-Filter Gage Type : Dwyer 2002  
Final Filter Type : 12" AAF Varicel, Type SH, 60-65%, UL Class I  
Final Filter Total Media Sets : 2 sets supplied by Ventrol, 1 set installed by Ventrol & 1 set extra  
Final Filter Gage Type : Dwyer 2002  
Final Filter Frame Type Material: Type 8 Galvanized steel  
Filter Qty 24 X 24 : 20  
Filter Qty 12 X 24 : 0  
Blanking Material : Galvanized

### Heating Coil(s)

Coil Casing Material : Galvanized Steel  
Blanking Material : Galvanized  
Coil Rack : 304 Stainless Steel Coil Rack  
Special Coating : None  
Piping : No

### Cooling Coil(s)

Coil Casing Material : Galvanized Steel  
Blanking Material : Galvanized  
Coil Rack : 304 Stainless Steel Coil Rack  
Drain Pan : IAQ 304 (18 Ga.) Stainless Steel Drain Pan With (18 Ga.) Intermediate Drain Pan  
Drain Pan Connection : 1½" Dia. Stainless Steel Drain Connection  
Special Coating : None  
Piping : No

### Supply Fan(s)

Supply Fan Number : 1  
Fan Model Number : PF-49  
Class Construction : II  
Rotation : CW  
Fan Discharge Arrangement : Radial  
Fan Arrangement Type : 3

---

# Bond Hill Academy 11406-01 Revision : 1



## Certified Performance Data Sheet

---

Motor manufacturer :	Weg
Motor Model # :	06018OT3E364T
Enclosure/Hp/RPM/Frame/Eff. :	ODP - 60 - 1800 - 364T - PREMIUM
Vac/Ph/Hz :	460/3/60
Belt Guard :	OSHA
Drive Sheaves :	Fixed pitch 1.2 safety factor
Safety Lock On Fan Door :	OSHA approved tool operated latch
Fan Bearings :	200 000 hrs L-50 with heavy duty nylon tubing & grease fittings to common internal location
Septum Wall:	2" Double Wall
Fan Accessories 1 :	Inertia base (concrete by others in the field)
Fan Accessories 2 :	Inlet screen
Fan Accessories 3 :	Fan enclosure screen

### Others Components

Other Component - 1 : Innergy tech Heat Wheel (ERW3000-T-88) c/w VFD & Frost Control (motor is 460V)  
Note : See Heatwheel selection for more info. Frost control is c/w one E/A temperature sensor (see electrical drawing for more info).

### Production Notes

- 1- S/A floor opening c/w grating.
- 2- Galvanized auxilliary drains provided downstream of the heatwheel for both tunnels (see drawing)
- 3- Short radius bellmouths provided on S/A openings. See drawing for more details.
- 4- All doors are c/w ADH-50 handles and stainless steel butt hinges.

### Electrical Notes


- 1- Each fan motor is wired to a junction box (460V).
  - 2- Heatwheel motor is wired to the VFD/Frost control enclosure.
  - 3- Frost Control is c/w one temperature sensor installed in exhaust air tunnel.
  - 4- All compact fluorescent lights in S/A tunnel are wired to a light switch (c/w pilot light) and GFI at supply fan section.
  - 5- All compact fluorescent lights in R/A tunnel are wired to a light switch (c/w pilot light) and GFI at return fan section.
  - 6- VFDs provided, installed and wired by others.
-

Ventrol




Ventrol Air Handling Systems Inc


**DRAWINGS**



ELEVATION SECTION A-A



PLAN VIEW



ELEVATION VIEW

ALL INTERNAL COMPONENTS ARE GENERIC AND FOR ILLUSTRATION PURPOSES ONLY. REFER TO COMPONENT SELECTION FOR SPECIFIED INFORMATION.



JOB NAME: Bond Hill Academy		TYPE OF DRAWING: REFERENCE DRAWINGS	DRAWING NUMBER: ---
ENGINEER: ---	SCALE: N.T.S.	REFERENCE DRAWINGS	
PREPARED BY / APPLICATION ENGINEER: FST/ vep/ MC	SERIAL NO.: 114C6	SHOP ORDER NO.: 01	UNIT TAG: AHU-1
8100 Ave. de Paroisse, Amite, Louisiana 70401		EST. NO.: 38,000	DATE: ---
REV. 1: Stewart-Angerson		DATE: ---	

07/31/08	SEE REVISION TABLE IN SUBMITTAL	01
07/14/08	---	---
DATE	DESCRIPTION	REVISION TABLE


VENTROL, VENTROL LOGO, VENTROL AIR HANDLING SYSTEMS, INC. AND SHALL NOT BE REPRODUCED OR ALTERED OR USED IN WHOLE OR PART AS THE BASIS FOR ANY OTHER DRAWING OR DOCUMENTATION WITHOUT THE WRITTEN PERMISSION OF VENTROL AIR HANDLING SYSTEMS, INC.

Ventrol



Ventrol Air Handling Systems Inc

**FAN SELECTION**



# PF02-49 NYB 12 Blade Plenum

### JOB INFORMATION:

Job Name: Bond Hill Academy  
 Job Tag: AHU-1 (Return Fan)  
 Rep Firm: -  
 Serial No: -  
 Date: 07-13-2006

### WHEEL SPECIFICATIONS:

Class / Max RPM: Class II / 1,105  
 Diameter: 49.0 in.  
 Width: 100%  
 Tip Speed: 8,864 FPM  
 Shaft / Bearing Dia.: 2 7/16", 2 7/16"  
 Inertia: 139 WR<sup>2</sup>

### OPERATING CONDITIONS:

Required Air Flow: 32,300 CFM  
 Static Pressure: 2.02 in. Wg.  
 Unducted Axial Disch.: 0.21 in. Wg.  
 Inlet Screen: 0.10 in. Wg.  
 Total Adjusted Static: 2.30 in. Wg.  
 Site Elevation: Sea Level  
 TSP @ Sea Level: 2.30 in. Wg.

### MOTOR SELECTION:

Rated HP: 20.0  
 Frame Size: 256T  
 Nominal RPM: 1750  
 VAC / PH / HZ: 460/3/60  
 Efficiency: Premium  
 Enclosure Type: ODP  
 Max Inertial Load: 236 WR<sup>2</sup>

### FAN PERFORMANCE:


RPM: 691  
 BHP / BHP with Belt Loss: 17.93 / 18.49  
 Static / Mech. Efficiency: 65.2% / 70.7%  
 Inlet / Outlet Velocity: 1976 / 1764 FPM  
 Plenum Outlet Velocity: 1200 FPM

### SOUND POWER: (Inlet / Outlet)

Octave Band: (Re 10<sup>-12</sup> watts)  

1	2	3	4	5	6	7	8
89	96	88	83	83	81	80	77
91	96	92	90	87	84	81	79

 Sound Power A-Weighted: 89 / 93 db





# PF02-49 NYB 12 Blade Plenum

### JOB INFORMATION:

Job Name: Bond Hill Academy  
 Job Tag: AHU-1 (Supply Fan)  
 Rep Firm: -  
 Serial No: -  
 Date: 07-13-2006

### WHEEL SPECIFICATIONS:

Class / Max RPM: Class II / 1,105  
 Diameter: 49.0 in.  
 Width: 100%  
 Tip Speed: 12,418 FPM  
 Shaft / Bearing Dia.: 2 7/16", 2 7/16"  
 Inertia: 273 WR<sup>2</sup>

### OPERATING CONDITIONS:

Required Air Flow: 38,000 CFM  
 Static Pressure: 6.05 in. Wg.  
 Unducted Radial Disch.: 0.18 in. Wg.  
 Inlet Screen: 0.14 in. Wg.  
 Total Adjusted Static: 6.37 in. Wg.  
 Site Elevation: Sea Level  
 TSP @ Sea Level: 6.37 in. Wg.

### MOTOR SELECTION:

Rated HP: 60.0  
 Frame Size: 364T  
 Nominal RPM: 1750  
 VAC / PH / HZ: 460/3/60  
 Efficiency: Premium  
 Enclosure Type: ODP  
 Max Inertial Load: 637 WR<sup>2</sup>


### FAN PERFORMANCE:

RPM: 968  
 BHP / BHP with Belt Loss: 53.42 / 54.91  
 Static / Mech. Efficiency: 71.3% / 74.3%  
 Inlet / Outlet Velocity: 2324 / 2075 FPM  
 Plenum Outlet Velocity: 1200 FPM


### SOUND POWER: (Inlet / Outlet)

Octave Band: (Re 10 <sup>-12</sup> watts)							
1	2	3	4	5	6	7	8
92	97	95	92	89	86	86	81
96	99	101	100	95	90	87	82

Sound Power A-Weighted: 95 / 101 db




**Ventrol**



Ventrol Air Handling Systems Inc

**COIL SELECTION**



Coil Selection / Rating 2006.100

Job Name: Bond Hill Academy  
 Tag: CC-1

Entered By: User Name

Date: 07/13/06  
 Serial #: 0

Chilled Water		5WC - 6 - 48 x 115 x 6 - 10 AL
Individual Coil Construction	Entering Conditions	Leaving Conditions
(Qty) FH x FL : (2) 48.00 x 115.00	ACFM : 38,000	Total Heat : 1,402,762 Btu/Hr
Rows - FPI : 6 - 10	SCFM : 38,000	Sensible Heat : 1,113,445 Btu/Hr
Serpentine : 1.000	Ald : 0 ft	LDB : 52.6°F
Total Face Area : 76.67 sq.ft	EDB : 79.3°F	LWB : 52.2°F
Fin Thick / Mat. : 0.008" / AL	EWB : 64.8°F	LWT : 57.8°F
Tube O.D. / Wall : 5/8" / 0.020"	EWT : 44.0°F	Actual FV : 495.7 ft/min
Tube Material : CU	Fluid : Water	APD : 0.76 in.WG
Case Material : 16 GA GALV	GPM : 203.00	Water Velocity : 3.52 ft/s
Conn Location : LH Same		Water PD : 13.25 ft
Sup.Conn - Qty / Size : (1) 2-1/2"		
Ret.Conn - Qty / Size : (1) 2-1/2"		
ARI CERTIFIED 'Rated in Accordance with ARI Standard 410'		



Coil Selection / Rating 2006.100

Job Name: Bond Hill Academy  
 Tag: HC-1

Date: 07/13/06  
 Entered By: User Name  
 Serial #: 0

Hot Water		5WC - 4 - 48 x 115 x 1 - 6 AL
Individual Coil Construction	Entering Conditions	Leaving Conditions
(Qty) FH x FL : (2) 48.00 x 115.00	ACFM : 38,000	Total Heat : 976,068 Btu/Hr
Rows - FPI : 1 - 6	SCFM : 38,000	Sensible Heat : 976,068 Btu/Hr
Serpentine : 0.250	Altd : 0 ft	LDB : 68.7°F
Total Face Area : 76.67 sq.ft	EDB : 45.0°F	
Fin Thick / Mat. : 0.008" / AL	EWT : 180.0°F	LWT : 139.5°F
Tube O.D. / Wall : 5/8" / 0.020"	Fluid : Water	Actual FV : 495.7 ft/min
Tube Material : CU	GPM : 55.00	APD : 0.06 in.WG
Case Material : 16 GA GALV		Water Velocity : 3.81 ft/s
Conn Location : LH Same		Water PD : 6.69 ft
Sup.Conn - Qty / Size : (1) 1-1/2"		
Ret.Conn - Qty / Size : (1) 1-1/2"		
ARI CERTIFIED 'Rated in Accordance with ARI Standard 410'		

**Ventrol**



Ventrol Air Handling Systems Inc

**HEAT WHEEL SELECTION**



**Innergy tech inc.**  
 389 Notre-Dame,  
 Notre-Dame-du-Bon-Conseil,  
 QC Canada J0C 1A0 Tel.:  
 (800) 203-9015 Fax:  
 (819) 336-2283

Project name: Bond Hill Academy  
 Location:  
 Engineer/Customer:  
 Date: 07/13/08  
 Unit Tag: AHU-1  
 Quote #:-

**Engineering submittal data**

Summer

**ERW3000 Total energy wheel**

**ROTARY AIR-TO-AIR**

**TOTAL ENERGY RECOVERY WHEEL PERFORMANCE**

Rated in Accordance with ASHRAE Standard 84-91  
 HWL is a UL recognize component, construction only.  
 Application ratings based on ARI 1060-2001 certification program



Wheel model:	ERW3000-T-88
Face area (sq. ft):	20
Motor power (hp):	1/2
<b>Dimensions (in):</b>	
Depth (D):	16
Width (W):	95
Height (H):	95
Weight (lb):	1398
Wheel speed (rpm):	20
Purge static pressure (in wg):	0
Purge Airflow (cfm):	0
Purge angle (deg):	0
Face velocity of supply air (ft/min):	668
Face velocity of return air (ft/min):	450
Altitude (ft):	0



**Performance**

	Effectiveness	Capacity
<i>Sensible</i>	84.6 %	138894 Btu/hr
<i>Latent</i>	78.0 %	173291 Btu/hr
<i>Total</i>	81.0 %	312185 Btu/hr

**Entering supply air (T1)**


37.39 Btu/lb  
 14100 cfm  
 93 DB °F  
 74 WB °F  
 95.7 gr/lb  
 41.2 RH %

**Leaving supply air (T2)**

32.42 Btu/lb  
 14100 cfm  
 83.9 DB °F  
 68.2 WB °F  
 78.3 gr/lb  
 45.1 RH %  
 0.92 A.P.D.  
 668 fpm

**Leaving exhaust air (T4)**

34.31 Btu/lb  
 9500 cfm  
 90.5 DB °F  
 70.6 WB °F  
 80 gr/lb  
 37.3 RH %  
 0.56 A.P.D.  
 450 fpm



**Entering exhaust air (T3)**

28.27 Btu/lb  
 9500 cfm  
 77 DB °F  
 62.8 WB °F  
 62.6 gr/lb  
 45.3 RH %

**Innergy tech inc.**

389 Notre-Dame,  
Notre-Dame-du-Bon-Conseil,  
QC Canada J0C 1A0 Tel.:  
(800) 203-9015 Fax:  
(819) 336-2283

Project name: Bond Hill Academy  
Location:  
Engineer/Customer:  
Date: 07/13/06  
Unit Tag: AHU-1  
Quote #:

## General Notes

- 1- Heat exchanger must permit drainage of condensate.
- 2- Air filters should be installed in front of both entering air flows sides of the unit to reduce wheel media fouling.
- 3- Air streams composition should be compatible with wheel media material.
- 4- If the enthalpy wheel will be used at -34F (-37C) or below, please consult Innergy tech for recommendations on how to maintain the speed reducer at an acceptable working temperature.
- 5- The energy saving estimation does not consider the effect of the frost control system.
- 6- For more information contact the manufacturer or his distributor.
- 7- All prices are unitary prices, some set-up charges may be applied. Contact Innergy tech inc for volume discount.

## Warranty

This rotary Air-to-Air exchanger is a high quality product, built and packed with care. All systems are guaranteed for one (1) year from the shipment date against any operational defects due to parts and/or manufacturing. The warranty applies to all cases where damage is not a result of poor installation, improper use, improper AHU design, mistreatment or negligence, acts of Gods or any other circumstances beyond the control of Innergy tech inc. Also, Innergy tech inc. will not be held responsible for any bodily injuries or damages to personal property or real estate and shall not be liable for any consequential loss or damages.

The sole liability of Innergy tech inc. shall be, at its option: A) to refund the purchase price of the equipment, B) to repair any defective parts, or C) to supply replacement parts EXW the factory where parts are manufactured with all freight costs paid by customer.

This warranty supersedes all prior warranties.



**Innergy tech inc.**  
 389 Notre-Dame,  
 Notre-Dame-du-Bon-Conseil,  
 QC Canada J0C 1A0 Tel.:  
 (800) 203-9015 Fax:  
 (819) 336-2283

Project name: Bond Hill Academy  
 Location:  
 Engineer/Customer:  
 Date: 07/13/06  
 Unit Tag: AHU-1  
 Quote #:

**Engineering submittal data**

Winter

**ERW3000 Total energy wheel**

**ROTARY AIR-TO-AIR**

**TOTAL ENERGY RECOVERY WHEEL PERFORMANCE**

Rated in Accordance with ASHRAE Standard 84-91  
 HWL is a UL recognize component, construction only.  
 Application ratings based on ARI 1060-2001 certification program



Wheel model:	ERW3000-T-88
Face area (sq. ft):	20
Motor power (hp):	1/2
<b>Dimensions (in):</b>	
Depth (D):	16
Width (W):	95
Height (H):	95
Weight (lb):	1398
Wheel speed (rpm):	20
Purge static pressure (in wg):	0
Purge Airflow (cfm):	0
Purge angle (deg):	0
Face velocity of supply air (ft/min):	668
Face velocity of return air (ft/min):	450
Altitude (ft):	0



**Performance**

	Effectiveness	Capacity
Sensible	84.6 %	564255 Btu/hr
Latent	83.5 %	184560 Btu/hr
Total	84.1 %	748815 Btu/hr

**Entering supply air (T1)**

1.42 Btu/lb  
 14100 cfm  
 5 DB °F  
 2 WB °F  
 1.5 gr/lb  
 20.7 RH %

**Leaving exhaust air (T4)**


5.4 Btu/lb  
 9500 cfm  
 15 DB °F  
 15 WB °F  
 11.8 gr/lb  
 100 RH %  
 0.56 A.P.D.  
 450 fpm


**Leaving supply air (T2)**

13.36 Btu/lb  
 14100 cfm  
 42.1 DB °F  
 35.9 WB °F  
 21.2 gr/lb  
 53.9 RH %  
 0.92 A.P.D.  
 668 fpm

**Entering exhaust air (T3)**

22.49 Btu/lb  
 9500 cfm  
 70 DB °F  
 54 WB °F  
 36.5 gr/lb  
 33.6 RH %





## Innergy tech inc.

389 Notre-Dame,  
Notre-Dame-du-Bon-Conseil,  
QC Canada J0C 1A0 Tel.:  
(800) 203-9015 Fax:  
(819) 336-2283

Project name: Bond Hill Academy  
Location:  
Engineer/Customer:  
Date: 07/13/06  
Unit Tag: AHU-1  
Quote #:

## General Notes

- 1- Heat exchanger must permit drainage of condensate.
- 2- Air filters should be installed in front of both entering air flows sides of the unit to reduce wheel media fouling.
- 3- Air streams composition should be compatible with wheel media material.
- 4- If the enthalpy wheel will be used at -34F (-37C) or below, please consult Innergy tech for recommendations on how to maintain the speed reducer at an acceptable working temperature.
- 5- The energy saving estimation does not consider the effect of the frost control system.
- 6- For more information contact the manufacturer or his distributor.
- 7- All prices are unitary prices, some set-up charges may be applied. Contact Innergy tech inc for volume discount.

## Warranty

This rotary Air-to-Air exchanger is a high quality product, built and packed with care. All systems are guaranteed for one (1) year from the shipment date against any operational defects due to parts and/or manufacturing. The warranty applies to all cases where damage is not a result of poor installation, improper use, improper AHU design, mistreatment or negligence, acts of Gods or any other circumstances beyond the control of Innergy tech inc. Also, Innergy tech inc. will not be held responsible for any bodily injuries or damages to personal property or real estate and shall not be liable for any consequential loss or damages.

The sole liability of Innergy tech inc. shall be, at its option: A) to refund the purchase price of the equipment, B) to repair any defective parts, or C) to supply replacement parts EXW the factory where parts are manufactured with all freight costs paid by customer.

This warranty supersedes all prior warranties.

**Ventrol**




Ventrol Air Handling Systems Inc

**HEAT WHEEL VFD & FROST CONTROL**

# ERW3000 SERIES

## Energy Recovery Wheels



### VFD and controller system specifications for enthalpy wheel series ERW3000

- 1) The wheel manufacturer shall provide the entire control system for the wheel, including but not limited to the variable frequency drive, a disconnect switch and a sensor for the exhaust leaving air temperature.
- 2) The VFD and controller system shall be specifically designed to prevent frost build-up in an enthalpy wheel.
- 3) The controller shall include a sequence of operation to avoid frost build-up in the enthalpy wheel.
- 4) The VFD and controller shall include a sensor in the leaving exhaust air to vary the wheel speed between full speed and zero in order to maintain the leaving exhaust temperature set point.
- 5) The VFD and controller system shall be ETL listed to UL 508C Power Conservation Equipment and CSA C22.2 No. 14 Industrial Control Equipment.
- 6) The VFD and controller system components, except the temperature sensor, shall be assembled in a Nema 4/12 enclosure.
- 7) The VFD and controller system shall include a fusible disconnect switch and a motor overload protection.
- 8) The VFD shall be able to send a fault signal to a building management system.
- 9) The VFD and controller system shall permit to stop and start the rotation of the wheel by a dry contact.
- 10) The VFD and controller system shall enable soft-starts of the wheel, taking approximately 30 seconds to ramp up the wheel to maximum speed.

#### Options

- Ambient temperature actuates ON-OFF control to facilitate a summer-winter changeover cycle. Unwanted heat pick-up in the make-up air stream in the 55°F to 75°F ambient temperature range will be eliminated.
- GFI utility outlet, service light and heater.
- Rotation fault sensor.



Innergytech, Inc.

**Carson School**  
**Supporting Documentation**

# Ohio Mercantile Self Direct Program

## Application Guide & Cover Sheet

Questions? Call 1-866-380-9580 or visit [www.duke-energy.com](http://www.duke-energy.com).

Email this form along with completed Mercantile Self Direct Prescriptive or Custom applications, proof of payment, energy savings calculations and spec sheets to [SelfDirect@Duke-Energy.com](mailto:SelfDirect@Duke-Energy.com). You may also fax to 1-513-419-5572.

Mercantile customers, defined as using at least 700,000 kWh annually are eligible for the Mercantile Self Direct program. Please indicate mercantile qualification:

- a single Duke Energy Ohio account  
 multiple accounts in Ohio (energy usage with other utilities may be counted toward the total)

Please list Duke Energy account numbers below (attach listing of multiple accounts an/or billing history for other utilities as required):

Account Number	Annual Usage	Account Number	Annual Usage
4620-3671-01			

Self Direct rebates are available for completed Custom projects that have not previously received a Duke Energy Smart \$aver® Custom Incentive. Self Direct incentives are applicable to Prescriptive measures that were installed more than 90 days prior to submission to Duke Energy and have not previously received a Duke Energy Prescriptive rebate.

Self Direct Program requirements dictate that certain projects that may be Prescriptive in nature under the Smart \$aver program must be evaluated using the Custom process. Use the table on page two as a guide to determine which Self Direct program fits your project(s). Apply for Self Direct projects using the appropriate application forms in conjunction with this cover sheet. Where Mercantile Self Direct Prescriptive applications are listed, please refer to the measure list on that application. If your measure is not listed, you may be eligible for a Self Direct Custom rebate. Self Direct Custom applications, like Smart \$aver Custom applications, should include detailed analysis of pre-project and post-project energy usage and project costs. Please indicate which type of rebate applications are included in the table provided on page two.

Please check each box to indicate completion of the following program requirements:

<input type="checkbox"/> All sections of appropriate application(s) are completed	<input type="checkbox"/> Proof of payment.*	<input type="checkbox"/> Manufacturer's Spec sheets	<input type="checkbox"/> Energy model/calculations and detailed inputs for Custom applications
---	---	---	--

\* If a single payment record is intended to demonstrate the costs of both Prescriptive & Custom projects, please include an additional document with an estimated breakout of costs for each Prescriptive and Custom energy conservation measure.

Application Type	Replaced equipment at end of lifetime or because equipment failed**	Replaced fully operational equipment to improve efficiency***	New Construction
Lighting	MSD Custom Part 1 <input type="checkbox"/> Custom Lighting Worksheet <input type="checkbox"/>	MSD Prescriptive Lighting <input type="checkbox"/>	MSD Prescriptive Lighting <input type="checkbox"/>
		MSD Custom Part 1 <input type="checkbox"/> Custom Lighting Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> Custom Lighting Worksheet <input type="checkbox"/>
Heating & Cooling	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Heating & Cooling <input type="checkbox"/>
			MSD Custom Part 1 <input checked="" type="checkbox"/> MSD Custom General Worksheet <input checked="" type="checkbox"/>
Window Films, Programmable Thermostats, & Guest Room Energy Management Systems	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General and/or EMS Worksheet(s) <input type="checkbox"/>	MSD Prescriptive Heating & Cooling <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General and/or EMS Worksheet(s) <input type="checkbox"/>
Chillers & Thermal Storage	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Chillers & Thermal Storage <input type="checkbox"/>
			MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>
Motors & Pumps	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Motors, Pumps & Drives <input type="checkbox"/>
			MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>
VFDs	Not Applicable	MSD Prescriptive Motors, Pumps & Drives <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom VFD Worksheet <input type="checkbox"/>
		MSD Custom Part 1 <input type="checkbox"/> MSD Custom VFD Worksheet <input type="checkbox"/>	
Food Service	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Food Service <input type="checkbox"/>
			MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>
Process	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Process <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>
		MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	
Energy Management Systems	MSD Custom Part 1 <input type="checkbox"/> MSD Custom EMS Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom EMS Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom EMS Worksheet <input type="checkbox"/>
Behavioral*** & No/Low Cost	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>		

\*\* Under the Self Direct program, failed equipment and equipment at the end of its useful life are evaluated differently than early replacement of fully functioning equipment. **All equipment replacements due to failure or old age will be evaluated via the Custom program.**

\*\*\* Please ensure that you include the age of the replaced equipment for measures classified as "Early Replacement" in your application as well as the estimated date that you would have otherwise replaced the existing equipment if you had not chosen a more energy efficient option.

\*\*\*\* Behavioral energy efficiency and demand reduction projects must be both measurable and verifiable. Provide justification with your application.

# Mercantile Self Direct Nonresidential Custom Rebate Application PART 1



Proposed energy efficiency measures may be eligible for Self-Direct Custom rebates if they clearly reduce electrical consumption and/or demand as compared to the appropriate baseline.

Before you complete this application, please note the following important criteria:

- Submitting this application does not guarantee a rebate will be approved.
- Rebates are based on electricity conservation only.
- Electric demand and/or energy reductions must be well documented with auditable calculations.
- Incomplete applications cannot be reviewed; all fields are required.

Refer to the complete list of Instructions and Disclaimers, beginning on page 6.

## Notes on the Application Process

If you have any questions concerning how to complete any portion of the application or what supplementary information is required, please contact your Duke Energy Ohio, Inc account manager or the Duke Energy Smart \$aver® team at 1-866-380-9580.

Every application must include calculations of the baseline electrical usage and the electrical usage of the proposed high-efficiency equipment/system. Monthly calculations are best. You, the Duke Energy Ohio customer, or your equipment vendor / engineer should perform these calculations and submit them to Duke Energy for review. *We strongly encourage the use of modeling software (such as eQuest or comparable) for complex projects.*

Upon receipt of your application, an acknowledgement email will be sent to you with an estimated response time based on an initial assessment of your application. The application review may include some communication to resolve any questions about the project or to request additional information. Applications that are received complete without missing information have a faster review time.

There are two ways to submit your completed application.

Email your scanned form to: [SelfDirect@duke-energy.com](mailto:SelfDirect@duke-energy.com)

Or, fax your form to 513-419-5572

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



**1. Contact Information (Required)**

Duke Energy Customer Contact Information					
Company Name	Cincinnati Public Schools				
Address	2651 Burnett Ave				
Project Contact	Don Elbe				
City	Cincinnati	State	OH	Zip Code	45219
Title	Utility Management Coordinator				
Office Phone	614-580-3352	Mobile Phone		Fax	
E-mail Address	elbedon@cpsboe.k12.oh.us				

Equipment Vendor / Contractor / Architect / Engineer Contact Information					
Company Name	Plug Smart				
Address	1275 Kinnear Road Suite 229				
City	Columbus	State	OH	Zip Code	43212
Project Contact	Lucas Dixon				
Title	Operations Manager				
Office Phone	614-580-3352	Mobile Phone		Fax	1-800-518-5576
E-mail Address	lucas.dixon@plugsmart.com				
Describe Role	Ensures rebate is correctly applied for				

Payment Information					
Payee Legal Company Name (as shown on Federal income tax return):	Cincinnati Public Schools				
Mailing Address	2651 Burnett Ave				
City	Cincinnati	State	OH	Zip Code	45219
Type of organization (check one) <input type="checkbox"/> Individual/Sole Proprietor <input type="checkbox"/> Corporation <input type="checkbox"/> Partnership <input type="checkbox"/> Unit of Government <input type="checkbox"/> Non-Profit (non-corporation)					
Payee Federal Tax ID # of Legal Company Name Above:	31-6000758				
Who should receive incentive payment? (select one) <input checked="" type="checkbox"/> Customer <input type="checkbox"/> Vendor (Customer must sign below)					
If the vendor is to receive payment, please sign below: I hereby authorize payment of incentive directly to vendor:					
Customer Signature _____ Date ____/____/____ (mm/dd/yyyy)					

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



**2. Project Information (Required)**

- A. Please indicate project type:
- New Construction
  - Expansion at an existing facility
  - Replacing equipment due to equipment failure
  - Replacing equipment that is estimated to have remaining useful life of 2 years or less
  - Replacing equipment that is estimated to have remaining useful life of more than 2 years
  - Behavioral, operational and/or procedural programs/projects
- B. Please describe your project, or attach a detailed project description that describes the project.  
New public pre kindergarten - 8<sup>th</sup> grade school.
- C. When did you start and complete implementation?  
Start date / (mm/yyyy) End date / 2008 (mm/yyyy)
- D. Are you also applying for Self-Direct Prescriptive incentives and, if so, which one(s)<sup>1</sup>?  
Lighting Controls
- E. Please indicate which worksheet(s) you are submitting for this application (check all that apply):
- Lighting
  - Variable Frequency Drive (VFD)
  - Compressed Air
  - Energy Management System (EMS)
  - General (for projects not easily submitted using one of the above worksheets)
- F. Please tell us if there is anything about your electrical energy projections (either for the baseline or the proposed project) that you are either unsure about or for which you have made significant assumptions. Attach additional sheets as needed.

Required: Attach a supplier or contractor invoice or other equivalent information documenting the Implementation Cost for each project listed in your application. (Note: self-install costs cannot be included in the Implementation Cost)

---

<sup>1</sup> If your project involves some equipment that is eligible for prescriptive incentives and some equipment that is likely eligible for custom incentives, and if it is feasible to separate the equipment for the energy analysis, then the equipment will be evaluated separately. If it is not feasible to separate the equipment for analysis, then the equipment will be evaluated together in the custom application.

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



**3. Signature** (Required – must be signed by Duke Energy customer)

**Customer Consent to Release of Personal Information**

I, (insert name) Don Elbe, do hereby consent to Duke Energy disclosing my Duke Energy Ohio, Inc Account Number and Federal Tax ID Number to its subcontractors solely for the purpose of administering Duke Energy Ohio's Mercantile Self-Direct Program. I understand that such subcontractors are contractually bound to otherwise maintain my Duke Energy Ohio, Inc Account Number and Federal Tax ID Number in the strictest of confidence.

I realize that under the rules and regulations of the public utilities commission, I may refuse to allow Duke Energy Ohio, Inc to release the information set forth above. By my signature, I freely give Duke Energy Ohio, Inc permission to release the information designated above.

**Application Signature**

I certify that I meet the eligibility requirements of the Duke Energy Ohio, Inc Mercantile Self Direct Custom Incentives Program and that all information provided within this application is correct to the best of my knowledge. I agree to the terms and conditions set forth for this program. I certify that the numbers, energy savings, and responses shown on this form are correct. Further, I certify that the taxpayer identification number is current and correct. I am not subject to backup withholding because: (a) I am exempt from backup withholding; or (b) I have not been notified by the IRS that I am subject to backup withholding as a result of a failure to report all interest or dividends; or (c) the IRS has notified me that I am no longer subject to backup withholding. I am a U.S. citizen (includes a U.S. resident alien).

\_\_\_\_\_  
Duke Energy Ohio, Inc Customer Signature

Print Name Don Elbe

Date 12/30/2011

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



**Checklist for completing the Application**

INCOMPLETE APPLICATIONS WILL RESULT IN DELAYS IN DUKE ENERGY PROCESSING YOUR APPLICATION AND NOTIFYING YOU CONCERNING ANY REBATES. Before submitting the application and the required supplementary information, use the following checklist to ensure that your application is complete and the information in the application is accurate. (Note: this checklist is for your use only – do not submit this checklist with your application)

Section No. & Title	Have You:
1. Contact Information	<input type="checkbox"/> Completed the contact information for the Duke Energy customer? <input type="checkbox"/> Completed the contact information for the equipment vendor / project engineer that can answer questions about the technical aspects of the project, if that is a different person than above?
2. Project Information	<input type="checkbox"/> Answered the questions A-E, including providing a description of your project. <input type="checkbox"/> Completed and attached the lighting, compressed air, VFD, EMS and/or General worksheet(s)?
3. Signature	<input type="checkbox"/> Signed your name? <input type="checkbox"/> Printed your name? <input type="checkbox"/> Entered the date?
Supplementary information (Required)	<input type="checkbox"/> Attached a supplier or contractor's invoice or other equivalent information documenting the Implementation Cost for projects listed in your application? (Note: self-install costs cannot be included in the Implementation Cost) <input type="checkbox"/> (If submitting the General Worksheet) attached calculations documenting the energy usage and energy savings for <b>each</b> project listed in your application?

If you have any questions concerning how to complete any portion of the application or what supplementary information is required, please contact:

- your Duke Energy account manager
- or,
- the Duke Energy Smart \$aver® team at 1-866-380-9580.

# Mercantile Self Direct Nonresidential Custom Rebate Application PART 1



## Instructions/Terms/Conditions

Note: Please keep for your records- do not submit with the application

1. Energy service companies or contractors may assist in preparing the application, but an authorized representative of the customer must sign this application to be eligible to participate in the Mercantile Self Direct Program. Completion of this application does not guarantee the approval of a Self Direct Custom Rebate.
2. Once all documentation requested in this application is received by *Duke Energy Ohio, Inc*, and any follow-up information requested by *Duke Energy* is received, the rebate amount for each Energy Conservation Measure (ECM) will be communicated to the customer. The rebate amount will be based on ECM energy savings and ECM incremental installation cost.
3. All rebates require approval by the Public Utilities Commission of Ohio. *Duke Energy Ohio, Inc* will submit an application for rebate on the customer's behalf upon customer attestation to program terms, conditions and requirements as outlined in the rebate offer letter and upon customer completion of attestation documents required by the Public Utilities Commission of Ohio.
4. *Duke Energy Ohio, Inc* will issue a Self Direct Custom Rebate check, based on the approved rebate amount for each ECM, upon receiving approval from the Public Utilities Commission of Ohio. *Duke Energy Ohio, Inc* does not guarantee PUCO approval.
5. With the application, the customer must provide a list of all sites where the ECMs were installed. *Duke Energy Ohio, Inc* requests that sites of similar size, hours of operation and energy consuming characteristics be grouped together in one application for the determination of the rebate amount. The application should identify the site where each unique ECM was installed.
6. Based on the information submitted with the application and the information gathered both before and after the initial installation of the ECM, *Duke Energy Ohio, Inc* will calculate the rebate amount for each ECM.
7. *Duke Energy Ohio, Inc* may conduct random site inspections of a sample of the locations where the ECMs are installed to verify installation and operability of the ECMs and to obtain information needed to calculate the Approved Incentive Amount.
8. Customers are encouraged to retain copies of all forms, invoices and supporting documentation for their records.
9. Approved rebates are valid for 6 months from the date communicated to the customer by *Duke Energy Ohio, Inc*, subject to the expiration of measure eligibility based on project completion dates and application submission deadlines as defined by PUCO. Customers are encouraged to execute their rebate offer contracts and PUCO-required affidavits promptly to ensure eligibility is not forfeited.
10. *Duke Energy Ohio, Inc* reserves the right to recover all unrecoverable costs associated with the project approval if the customer decides not to execute the rebate contract, after the project is approved by *Duke Energy Ohio, Inc*.
11. Projects financially supported by other funding sources will be evaluated on a case-by-case basis for potential partial funding from *Duke Energy Ohio, Inc*.
12. Participants must be *Duke Energy Ohio, Inc* nonresidential, mercantile customers with the project sites in the *Duke Energy Ohio, Inc* service territory.

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



13. Customers or trade allies may not use any *Duke Energy* logo without prior written permission.
14. Only trade allies registered with *Duke Energy* are eligible to participate.
15. All equipment must be new. Used or rebuilt equipment is not eligible for incentives. All old existing equipment must be removed on retrofit projects.
16. Disclaimers: *Duke Energy Ohio, Inc*
  - a. does not endorse any particular manufacturer, product or system design within the program;
  - b. will not be responsible for any tax liability imposed on the customer as a result of the payment of incentives;
  - c. does not expressly or implicitly warrant the performance of installed equipment. (Contact your contractor for details regarding equipment warranties.);
  - d. is not responsible for the proper disposal/recycling of any waste generated or obsolete or old equipment as a result of this project;
  - e. is not liable for any damage caused by the installation of the equipment nor for any damage caused by the malfunction of the installed equipment; and
  - f. reserves the right to change or discontinue this program at any time. The acceptance of program applications is determined solely by *Duke Energy Ohio, Inc*.



The General Worksheet is part 2 of the application. Do not submit this file without submitting a completed Part1 Custom Application document file, which can be found at [www.duke-energy.com](http://www.duke-energy.com). This worksheet is for all projects that are not easily submitted through one of the other worksheets

Before you complete this application, please note the following important criteria:

- Incentive approval is required PRIOR to equipment purchase, or any other activity which would indicate that the Duke Energy customer has already decided to proceed.
- Submitting this application does not guarantee an incentive will be approved.
- Incentives are based on electricity conservation only.
- Electric demand and/or energy reductions must be well documented with auditable calculations.
- Simple payback without incentive must be greater than 1 year.
- Incomplete applications will not be reviewed; all fields are required.

Refer to the complete list of Instructions and Disclaimers, found in the Custom Application Part 1 document.

**Please enter your information and data into the cells that are shaded.  
Cells in white are locked and cannot be written over.**

**Duke Energy Customer Contact Information (Match the information in Application Part 1):**

Name	Michael Burson
Company	Cincinnati Public Schools

**Equipment Vendor / Project Engineer Contact Information**

Name	Lucas Dixon
Company	Plug Smart

Before proceeding with the custom application, please verify that your project is not on the prescriptive incentive application.

The prescriptive incentive applications can be found at:

- KY <http://www.duke-energy.com/kentucky-business/energy-management/energy-efficiency-incentives.asp>  
Kentucky only: custom incentives only available to K-12 school facilities; prescriptive incentives available for those not on rate TT.
- OH <http://www.duke-energy.com/ohio-business/energy-management/energy-efficiency-incentives.asp>
- NC <http://www.duke-energy.com/north-carolina-business/energy-management/energy-efficiency-incentives.asp>
- SC <http://www.duke-energy.com/south-carolina-business/energy-management/energy-efficiency-incentives.asp>

Prescriptive incentives are already pre-approved and the application is submitted after project implementation.  
Take note of the equipment eligibility on the prescriptive application before planning to utilize the prescriptive application.





For each project, answer the following questions (use one worksheet per project)

App No.	0
Rev.	0

Project Name: **Heat recovery wheels**

How would you classify this project? (Place an x in all boxes that apply.)

Lighting		Heating/Cooling	X	Air Compressor		Energy Management System	
VFD		Motors/Pumps		Process Equipment		Other, describe below:	

**Brief Project Description**

Describe the Baseline (see note 3)	Equipment/System	Describe the Proposed High Efficiency Project
No heat recovery wheels installed		Heat recovery wheels installed.

If Existing Equipment is the Baseline, how many years of useful life remain or how many years until replacement?

Detailed Project Description Attached?  (Required)

**Operating Hours (see note 4)**

24 x 7	Weekday		Saturday		Sunday		Weeks of Use in Year (see note 5)	Total Annual Hours of Use
	Start Hour	End Hour	Start Hour	End Hour	Start Hour	End Hour		
No	7:00 AM	3:30 PM					14	700

**Energy Savings**

	Baseline (see Note 3)	Proposed	Savings	Describe how energy numbers were calculated
Annual Electric Energy	23,435 kWh	0 kWh	23,435 kWh	
Electric Demand	0 kW	0 kW	0 kW	
Calculations attached	Yes	Yes	(Required)	

**Simple Payback**

Average electric rate (\$/kWh) on the applicable accounts (see note 6)	\$0.10
Estimated annual electric savings	\$2,344
Other annual savings in addition to electric savings, such as operations, maintenance, other fuels	
Incremental cost to implement the project (equipment & installation) (see note 7)	
Copy of vendor proposal is attached (see note 8)	Yes
Simple Electric Payback in years (see note 9)	0
Total Payback in years	0

**3 Baseline**

Retrofit projects: the existing equipment is the baseline unless that equipment must be replaced for some reason anyway.  
 New construction projects or where the existing equipment must be replaced anyway: the baseline is the standard option in today's market, taking into account any applicable organizational, local, state or federal codes or standards currently in effect.

**4 Operating Hours**

Describe when the equipment is typically used. If the project is proposed for more than one site, provide any variations in operating hours between the sites on a separate sheet.

**5 Weeks of Use in Year**

If the equipment is not in use 52 weeks during the year (for example, during holiday or summer break), provide an explanation of when usage is not expected and why:

**6 Average electric rate (\$/kWh)**

If you do not know your average electric rate, use \$0.10/kWh.

**7 Incremental cost to implement the project**

Costs exclude self installation costs. Retrofit projects, incremental cost is the total cost of the proposed project. New construction or where the existing equipment must be replaced anyway, then incremental cost is the premium of the proposed high efficiency project over baseline.

**8 Copy of vendor proposal is attached**

Vendor proposal of proposed system is always required.  
 New construction projects or where the existing equipment must be replaced anyway, vendor proposal of baseline must also be attached.

**9 Simple Electric Payback**

If the simple electric payback is less than 1 year, then no incentive can be approved. Double check average electric rate for correct payback.

March 13, 2012



To whom it may concern:

This letter is to confirm that for the renovation to Cincinnati Public school **Carson Elementary (4323 Glenway Ave)**, for the **custom** rebate application, the energy recovery project was installed with a minimum unit cost listed below.

Thybar TV7490 Energy Recovery Units	2	\$8,000.00	\$16,000.00
-------------------------------------	---	------------	-------------

<b>TOTAL</b>	<b>\$16,000.00</b>
--------------	--------------------

This is also to confirm that for the renovation to **Carson Elementary (4323 Glenway Ave)**, for the **prescriptive** rebate application, occupancy sensors and a chiller was installed with a minimum unit cost listed below.

DESCRIPTION	Model Number	QUANTITY	Nominal Size (Tons)	PRICE/FIXTURE	AMOUNT
SelfDirect Occupancy Sensor	DT-200, WS-200, WT-600, WT-2200	165	-	\$117.89	\$19,451.85
SelfDirect Chiller - Air - Screw	Trane Chiller RTAA125	2	60	\$72,000.00	\$144,000.00

<b>TOTAL</b>	<b>\$163,451.85</b>
--------------	---------------------

Thank you for your attention to this matter,

A handwritten signature in cursive script that reads "Don Elbe".

Don Elbe  
Utility Management Coordinator

# APPLICATION AND CERTIFICATE FOR PAYMENT

TO OWNER:

PROJECT:

Carson Elementary  
4323 Glenway Avenue  
Cincinnati, OH 45205

APPLICATION NO:

18

PERIOD TO:

02/20/09

PROJECT NO:

CONTRACT DATE:

FROM CONTRACTOR:

Hilvert & Pope Electric, Inc.  
11070 Southland Road  
Cincinnati, OH 45240

VIA ARCHITECT:

CONTRACT FOR: ELECTRICAL

## CONTRACTOR'S APPLICATION FOR PAYMENT

Application is made for Payment, as shown below, in connection with the Contract. Continuation Sheet, AIA Document G703, is attached.

1. ORIGINAL CONTRACT SUM.....	\$	1736800	
2. Net change by Change Orders.....	\$	45895	
3. CONTRACT SUM TO DATE.....	\$	1782695	
4. TOTAL COMPLETED & STORED TO DATE.....	\$	1,782,695	
5. RETAINAGE:			
a. 8-50% of Completed Labor \$	\$		
b. 8% of Stored Material \$	\$		
Total Retainage	\$	0	
6. TOTAL EARNED LESS RETAINAGE.....	\$	1782695	
7. LESS PREVIOUS CERTIFICATES FOR PAYMENT (Line 6 from prior Certificate).....	\$	1781779	
8. CURRENT PAYMENT DUE.....	\$	916	
9. BALANCE TO FINISH, PLUS RETAINAGE.....	\$	0	

The Contractor certified that the work covered by this pay request has been completed in accordance with the Contract Document and that all progress payments previously paid by the State have been applied by the Contractor to discharge in full all Contractor's obligations incurred in connection with the work covered by all prior pay requests.

*Ken Hill*  
Contractor

2-20-09  
Date

Based upon on-site observations, the firm affirms that the work has progressed to the percentage of completeness indicated on the pay request.

*Paul P. St...*  
Construction Manager

2/23/09  
Date

*Architect*

Date

Approved:

School District Treasurer

Date

CHANGE ORDER SUMMARY	ADDITIONS	DEDUCTIONS
Total change orders approved in previous months by Owner	44599	
Total approved this Month	1296	
<b>TOTALS</b>	45895	0
Net change by Change Orders	45895	

ITEM NO.	DESCRIPTION OF WORK	SCHEDULED VALUE	WORK COMPLETED		MATERIALS PRESENTLY STORED (NOT IN D OR E)	COMPLETED AND STORED TO DATE (D+E+F)	% (G/C)	BALANCE TO FINISH (C-G)	RETAINAGE
			FROM PREVIOUS APPLICATION (D+E)	THIS PERIOD					
1	BONDING	21,000	21,000	0		21,000	100%	0	0
2	MOBILIZATION	5,000	5,000	0		5,000	100%	0	400
3	DEMobilIZATION	2,000	2,000	0		2,000	100%	0	160
4	REGULAR CLEAN-UP	3,000	3,000	0		3,000	100%	0	240
5	PUNCH LIST	6,000	6,000	0		6,000	100%	0	480
6	CLOSE OUT ITEMS	4,000	4,000	0		4,000	100%	0	320
7	SUBMITTALS	3,000	3,000	0		3,000	100%	0	240
8	COORDINATION	4,000	4,000	0		4,000	100%	0	320
9	FIELD SUPERVISION	80,000	80,000	0		80,000	100%	0	6,400
10	TEMP POWER	20,000	20,000	0		20,000	100%	0	1,600
11	DEMOLITION	4,000	4,000	0		4,000	100%	0	320
12	SITE CONDUIT & WIRE - LAB	30,000	30,000	0		30,000	100%	0	2,400
13	SITE CONDUIT & WIRE - MAT	40,000	40,000	0		40,000	100%	0	0
14	LIGHT FIXTURES - LABOR	50,000	50,000	0		50,000	100%	0	4,000
15	LIGHT FIXTURES - MATERIAL	140,000	140,000	0		140,000	100%	0	2,800
16	CONDUIT - LABOR	90,000	90,000	0		90,000	100%	0	7,200
17	CONDUIT - MATERIAL	110,000	110,000	0		110,000	100%	0	0
18	WIRE/CABLE - LABOR	50,000	50,000	0		50,000	100%	0	4,000
19	WIRE/CABLE - MATERIAL	80,000	80,000	0		80,000	100%	0	0
20	DEVICES - LABOR	6,000	6,000	0		6,000	100%	0	480
21	DEVICES - MATERIAL	8,000	8,000	0		8,000	100%	0	160
22	F/A - LABOR	10,000	10,000	0		10,000	100%	0	800
23	F/A - MATERIAL	18,000	18,000	0		18,000	100%	0	360
24	AUDIO VISUAL - LABOR	30,000	30,000	0		30,000	100%	0	2,400
25	AUDIO VISUAL - MATERIAL	140,000	140,000	0		140,000	100%	0	2,800
26	CLOCKS - LABOR	10,000	10,000	0		10,000	100%	0	800
27	CLOCKS - MATERIAL	48,000	48,000	0		48,000	100%	0	960
28	BROADBAND - LABOR	10,000	10,000	0		10,000	100%	0	800
29	BROADBAND - MATERIAL	49,000	49,000	0		49,000	100%	0	980
30	WATTSTOPPER - LAB	15,000	15,000	0		15,000	100%	0	1,200
31	WATTSTOPPER - MAT	25,000	25,000	0		25,000	100%	0	500
32	POWER PACKAGE - LAB	35,000	35,000	0		35,000	100%	0	2,800
33	POWER PACKAGE - MAT	90,000	90,000	0		90,000	100%	0	1,800
34	TECHNOLOGY - LABOR	20,000	20,000	0		20,000	100%	0	1,600
35	TECHNOLOGY - MATERIAL	129,000	129,000	0		129,000	100%	0	2,580
36	GENERATOR & A.T.S - LAB	8,000	8,000	0		8,000	100%	0	640
37	GENERATOR & A.T.S - MAT	30,000	30,000	0		30,000	100%	0	600
38	NETWORK ELECTRONICS -L	10,000	10,000	0		10,000	100%	0	800
39	NETWORK ELECTRONICS -M	70,000	70,000	0		70,000	100%	0	1,400
40	SECURITY SYSTEM - LABOR	30,000	30,000	0		30,000	100%	0	2,400
41	SECURITY SYSTEM - MATERIAL	170,000	170,000	0		170,000	100%	0	3,400
42	OWNER TRAINING - LABOR	2,000	2,000	0		2,000	100%	0	160
43	ALLOWANCE	15,000	15,000	0		15,000	100%	0	1,200
44	FINAL CLEAN-UP	2,800	2,800	0		2,800	100%	0	224
45	TRAILER TELEPHONES	9,000	8,084	916		9,000	100%	0	162
46	UPS - LABOR	1,000	1,000	0		1,000	100%	0	80
47	UPS - MATERIAL	4,000	4,000	0		4,000	100%	0	80
48	CHANGE ORDER #1	6,831	6,831	0		6,831	100%	0	137
49	CHANGE ORDER #2	6,167	6,167	0		6,167	100%	0	123
50	CHANGE ORDER #3	14,582	14,582	0		14,582	100%	0	292
51	CHANGE ORDER #4	1,729	1,729	0		1,729	100%	0	35
52	CHANGE ORDER #5	9,911	9,911	0		9,911	100%	0	198
53	CHANGE ORDER #6	404	404	0		404	100%	0	8
54	CHANGE ORDER #7	4,975	4,975	0		4,975	100%	0	100
55	CHANGE ORDER #8	616	616	0		616	100%	0	12
56	CHANGE ORDER #9	680	680	0		680	100%	0	14
	TOTAL	1,782,695	1,781,779	916	0	1,782,695	100%	0	63,965

**The Ohio School Facilities Commission**

10 West Broad Street  
 Suite 1400  
 Columbus, Ohio 43215

Contractor's Name: Feldkamp Enterprises, Inc.  
 Address: 3642 Muddy Creek Road, Cincinnati, Ohio 45238

**Contractor Pay Application Summary**

Project Name: CARSON

Bid Package No.:

1	Original Contract Amount	\$	1,463,000.00
2	Net Changes to Date	\$	242.00
3	Current Contract Amount	\$	1,463,242.00
4	Labor Completed to Date	\$	671,000.00
5	Material Completed to Date	\$	792,242.00
6	Total Work Completed to Date	\$	1,463,242.00
7	Store Material to Date	\$	0.00
8	Less Retained to Date	\$	0.00
9	Total Amount Due	\$	1,463,242.00
10	Less Previous Payments	\$	1,462,136.00
11	Less Amount Retained to Cover Lien	\$	0.00
12	Less Amount Retained for Liquidated Damages	\$	0.00
13	Less Other Amounts Withheld	\$	0.00
14	Current Due	\$	1,106.00
15	Balance to Complete	\$	0.00

**The Ohio School Facilities Commission approval required for the following contract adjustments:**

1. Assessment of liquidated damages
2. Other amounts withheld

The Ohio School Facilities Commission	Date _____
Comments:	

**APPLICATION AND CERTIFICATE FOR PAYMENT**

**TO OWNER:**

Cincinnati Public Schools  
2315 Iowa Street  
Cincinnati, Ohio 45206

**PROJECT:**

Carson Elementary  
4323 Glenway Avenue  
Cincinnati, Ohio 45205

**FROM CONTRACTOR:**

Feldkamp Enterprises, Inc.  
3642 Muddy Creek Road  
Cincinnati, Ohio 45238

**VIA ARCHITECT:**

APPLICATION No: 16  
PERIOD TO: 10/31/08  
PROJECT NOS:  
CONTRACT DATE:  
INVOICE NO: 1230-16

**CONTRACT FOR:** HVAC & PIPING

**CONTRACTOR'S APPLICATION FOR PAYMENT**

Application is made for payment as shown below, in connection with the Contract  
Continuation sheet is attached.

- 1. ORIGINAL CONTRACT SUM.....\$ 1,463,000.00
- 2. Net Change by Change Orders.....\$ 242.00
- 3. CONTRACT SUM TO DATE.....\$ 1,463,242.00
- 4. TOTAL COMPLETED & STORED TO DATE.....\$ 1,463,242.00
- 5. RETAINAGE
  - a. 8-50% of Completed Labor.....\$ -
  - b. 8% of Stored Material.....\$ -
  - Total Retainage.....\$ -
- 6. TOTAL EARNED LESS RETAINAGE.....\$ 1,463,242.00
- 7. LESS PREVIOUS CERTIFICATES FOR PAYMENT.....\$ 1,462,136.00
- 8. CURRENT PAYMENT DUE.....\$ 1,106.00
- 9. BALANCE TO FINISH, INCLUDING RETAINAGE.....\$ -

Change Order/Contract	ADDITIONS	DEDUCTIONS
Total Changes approved in Previous months by Owner	3634.00	
Total approved this month	1106.00	-4498.00
<b>TOTALS</b>	<b>4740.00</b>	<b>-4498.00</b>
<b>NET CHANGES by Change Order</b>	<b>242.00</b>	

The Contractor certified that the work covered by this pay request has been completed in accordance with the Contract Documents and that all progress payments previously paid by CPS have been applied by the Contractor to discharge in full all of Contractor's obligations incurred in connection with the work covered by all prior pay requests.

Contractor Brett Meyer 10/31/2008

Based upon on-site observations, I certify that the Commission Expresses to the point indicated on the pay request.

 Brett Meyer  
Notary Public, State of Ohio

Architect Ray Meade Date 11/4/08

Construction Manager [Signature] Date 11/4/08

Approved:

School District \_\_\_\_\_ Date \_\_\_\_\_

ITEM NUMBER	DESCRIPTION OF WORK	SCHEDULED VALUE	WORK COMPLETED		MATERIALS PRESENTLY STORED	TOTAL COMPLETED & STORED TO DATE	%	BALANCE TO FINISH	RETAINAGE
			PREVIOUS APPS.	THIS PERIOD					
1	BOND	16,000.00	18,000.00	0.00	0.00	18,000.00	100%	0.00	0.00
2	SUBMITTALS	5,000.00	5,000.00	0.00	0.00	5,000.00	100%	0.00	0.00
3	CLEAN UP	5,000.00	5,000.00	0.00	0.00	5,000.00	100%	0.00	0.00
4	PUNCH LIST	3,000.00	3,000.00	0.00	0.00	3,000.00	100%	0.00	0.00
5	ALLOWANCE	10,000.00	10,000.00	0.00	0.00	10,000.00	100%	0.00	0.00
6	MHVAC Equipment	332,000.00	332,000.00	0.00	0.00	332,000.00	100%	0.00	0.00
7	L HVAC Equipment	50,000.00	50,000.00	0.00	0.00	50,000.00	100%	0.00	0.00
8	MHydronic Equipment	26,000.00	26,000.00	0.00	0.00	26,000.00	100%	0.00	0.00
9	L Hydronic Equipment	10,000.00	10,000.00	0.00	0.00	10,000.00	100%	0.00	0.00
10	M Boilers	65,000.00	65,000.00	0.00	0.00	65,000.00	100%	0.00	0.00
11	L Boilers	10,000.00	10,000.00	0.00	0.00	10,000.00	100%	0.00	0.00
12	M HW/CW Piping	115,000.00	115,000.00	0.00	0.00	115,000.00	100%	0.00	0.00
13	L HW/CW Piping	222,000.00	222,000.00	0.00	0.00	222,000.00	100%	0.00	0.00
14	SUBCONTRACTORS	30,000.00	30,000.00	0.00	0.00	30,000.00	100%	0.00	0.00
15	M Insulation	55,000.00	55,000.00	0.00	0.00	55,000.00	100%	0.00	0.00
16	L Insulation	52,000.00	52,000.00	0.00	0.00	52,000.00	100%	0.00	0.00
17	M Temp Control	78,000.00	78,000.00	0.00	0.00	78,000.00	100%	0.00	0.00
18	L Temp Control	10,000.00	10,000.00	0.00	0.00	10,000.00	100%	0.00	0.00
19	L Temp Engineering	12,000.00	12,000.00	0.00	0.00	12,000.00	100%	0.00	0.00
20	L Air/Water Balance	35,000.00	35,000.00	0.00	0.00	35,000.00	100%	0.00	0.00
21	SHEETMETAL	2,000.00	2,000.00	0.00	0.00	2,000.00	100%	0.00	0.00
22	L Coordination Drawing	2,000.00	2,000.00	0.00	0.00	2,000.00	100%	0.00	0.00
23	M Coordination Drawing	12,000.00	12,000.00	0.00	0.00	12,000.00	100%	0.00	0.00
24	L VAV Boxes	2,000.00	2,000.00	0.00	0.00	2,000.00	100%	0.00	0.00
25	M VAV Boxes	4,000.00	4,000.00	0.00	0.00	4,000.00	100%	0.00	0.00
26	L Curbs	2,000.00	2,000.00	0.00	0.00	2,000.00	100%	0.00	0.00
27	M Curbs	2,000.00	2,000.00	0.00	0.00	2,000.00	100%	0.00	0.00
28	L Fans & Vents	4,000.00	4,000.00	0.00	0.00	4,000.00	100%	0.00	0.00
29	M Fans & Vents	22,000.00	22,000.00	0.00	0.00	22,000.00	100%	0.00	0.00
30	L Kitchen Hood System	4,000.00	4,000.00	0.00	0.00	4,000.00	100%	0.00	0.00
31	M Kitchen Hood System	17,000.00	17,000.00	0.00	0.00	17,000.00	100%	0.00	0.00
32	L Duct	115,000.00	115,000.00	0.00	0.00	115,000.00	100%	0.00	0.00
33	M Duct	8,000.00	8,000.00	0.00	0.00	8,000.00	100%	0.00	0.00
34	L Air Devices	8,000.00	8,000.00	0.00	0.00	8,000.00	100%	0.00	0.00
35	M Air Devices	3,000.00	3,000.00	0.00	0.00	3,000.00	100%	0.00	0.00
36	L Boiler Flue	4,000.00	4,000.00	0.00	0.00	4,000.00	100%	0.00	0.00
37	M Boiler Flue	2,705.00	2,705.00	0.00	0.00	2,705.00	100%	0.00	0.00
38	CO#1 Bulletin #7	929.00	929.00	0.00	0.00	929.00	100%	0.00	0.00
39	CO#2 Pads & Valves	(4,498.00)	(4,498.00)	0.00	0.00	(4,498.00)	100%	0.00	0.00
40	CO#3 Unused Allowance	1,106.00	1,106.00	0.00	0.00	1,106.00	100%	0.00	0.00
41	CO#4 Dyer Vents	1,483,242.00	1,483,242.00	0.00	0.00	1,483,242.00	100%	0.00	0.00
	Total		1,482,136.00	1,106.00	0.00	1,483,242.00	100%	0.00	0.00



The Ohio School Facilities Commission  
 10 West Broad Street  
 14th Floor  
 Columbus, Ohio 43215  
 Phone: 614-466-6290 Fax: 614-466-7749

**CHANGE ORDER**

ADD  DEDUCT  
 Contract Reference No. **38-01962-005025-B132X - 520970**

Change Order No. 5 - 004 Contract Days Changed 0  
 BP# CO# Revised Completion Date No change

Change Order Date 9/29/2008  
 Contractor Name: Feldkamp Enterprises  
 Project: **Cincinnati Public Schools  
 CPS - Carson Elementary School  
 4323 Glenway Ave.  
 Cincinnati, Ohio 45205  
 #10960PA-3**

Reason for Change Order:  
 \*Design Clarification  
 Local Funded Initiative (List breakdown % below)  
97.9 2.1  
 % Project Construction Fund % Local Initiative

PCO	Item	Description/Justification	Amount
122	001	CB-11: Added Dryer Vent (Co-Fund)	\$1,083.00
122	002	CB-11: Added Dryer Vent (LFI)	\$23.00
Per Bulletin 11 dated 7/28/08, Feldkamp installed the added dryer vent for Locker Room 2017A. It was surface mounted and painted to match the wall.			

Original Contract	\$1,463,000.00
Previous Changes	
This Change	(\$864.00)
Revised Contract	\$1,106.00
	\$1,463,242.00

The compensation or time extension provided by this Change Order constitutes full and complete satisfaction for all direct and indirect costs, and interest related thereto, which has been or may be incurred in connection with this change to the work, including but not limited to, any delays, inefficiencies, disruption, extended overhead, acceleration, and the cumulative impact of this and other change orders issues as of this date.

**CONTRACTOR'S ACCEPTANCE**  
 Feldkamp Enterprises  
 3642 Muddy Creek  
 Cincinnati, OH 45238  
 \_\_\_\_\_  
 Authorized Signature Date 10/2/08

**ARCHITECT'S RECOMMENDATION**  
 GBBN Architects Inc.  
 332 East 8th Street  
 Cincinnati, OH 45202  
 \_\_\_\_\_  
 Authorized Signature Date

**SCHOOL DISTRICT ACCEPTANCE**  
 Cincinnati Public Schools  
 2651 Burnet Avenue  
 Cincinnati, OH 45219  
 \_\_\_\_\_  
 Board Authorized Signature Date

**CHANGE ORDER RECOMMENDED**  
 \_\_\_\_\_  
 Construction Manager Date  
 Turner/DAG/TYS

**Thybar Corporation AIRX ERC DESIGN POINT ANALYSIS**

<u>DESIGN CONDITIONS</u>	<u>Dry Bulb, F</u>	<u>Wet Bulb, F</u>	<u>Enthalpy, Btu/lb</u>
SUMMER, Outdoor	92.00	74.00	38.15
SUMMER, Indoor	75.00	63.00	28.94
WINTER, Outdoor	.00	-2.00	.31
WINTER, Indoor	70.00	53.00	22.25

<b>Project Unit:</b> ERV-1	<b>Model Number:</b> TV-7490	
SUPPLY AIR FLOW RATE, cfm	10010	10010
EXHAUST AIR FLOW RATE, cfm	8010	8010
Latent Effectiveness	75.96%	76.75%
Sensible Effectiveness	81.67%	82.58%
Measured Effectiveness (S/W)	79.4%	81.7%

<u>SUPPLY AIR CONDITIONS</u>	<u>Summer</u>	<u>Winter</u>
Dry Bulb Temperature, F	80.59	44.70
Wet Bulb Temperature, F	67.17	37.04
Enthalpy, Btu/lb	32.19	14.07
Relative Humidity, %	50.6	48.0

<u>DESIGN LOADS, Btu/h</u>	<u>Summer</u>	<u>Winter</u>
Outside Air, Sensible	172,229	765,017
Outside Air, Latent	216,811	233,833
Outside Air, Total	389,040	998,850


<u>RECOVERED LOADS, Btu/h</u>	<u>Summer</u>	<u>Winter</u>
Sensible Recovered	113,884	445,029
Latent Recovered	133,862	169,997
Total Recovered	247,746	615,026

Net OA Load 141,294 383,824


**INSTALLED HVAC REDUCTION**

COOLING, Tons	20.65	
HEATING, Btu/h		615,026

Summer Process Diagram



Winter Process Diagram



Exhaust Air Transfer Ratio 3.0  
 Outdoor Air Correction Factor 1.01  
 Pressure is in in. wc. Flow is in cfm. Temperature is in F.

Exhaust Air Transfer Ratio 3.0  
 Outdoor Air Correction Factor 1.01  
 Pressure is in in. wc. Flow is in cfm. Temperature is in F.

**Thybar Corporation AIRX ERC DESIGN POINT ANALYSIS**

<u>DESIGN CONDITIONS</u>	<u>Dry Bulb, F</u>	<u>Wet Bulb, F</u>	<u>Enthalpy, Btu/lb</u>
SUMMER, Outdoor	92.00	74.00	38.15
SUMMER, Indoor	75.00	63.00	28.94
WINTER, Outdoor	.00	-2.00	.31
WINTER, Indoor	70.00	53.00	22.25

<b>Project Unit:</b> ERV-2	<b>Model Number:</b> TV-7490	
SUPPLY AIR FLOW RATE, cfm	10958	10958
EXHAUST AIR FLOW RATE, cfm	8958	8958
Latent Effectiveness	73.38%	74.14%
Sensible Effectiveness	79.45%	80.34%
Measured Effectiveness (S/W)	77.0%	79.4%

**SUPPLY AIR CONDITIONS**

	<b>Summer</b>	<b>Winter</b>
Dry Bulb Temperature, F	80.67	44.36
Wet Bulb Temperature, F	67.24	36.76
Enthalpy, Btu/lb	32.25	13.94
Relative Humidity, %	50.7	48.0

**DESIGN LOADS, Btu/h**

	<b>Summer</b>	<b>Winter</b>
Outside Air, Sensible	188,512	837,978
Outside Air, Latent	237,310	256,134
Outside Air, Total	425,822	1,094,113

**RECOVERED LOADS, Btu/h**

	<b>Summer</b>	<b>Winter</b>
Sensible Recovered	123,898	483,833
Latent Recovered	144,652	184,275
Total Recovered	268,550	668,108

**Net OA Load**



	157,271	426,005
--	---------	---------

**INSTALLED HVAC REDUCTION**

COOLING, Tons	22.38	
HEATING, Btu/h		668,108

**Summer Process Diagram**

**Winter Process Diagram**



Exhaust Air Transfer Ratio: 2.8  
 Outdoor Air Correction Factor: 1.01  
 Pressure is in in. wc. Flow is in cfm. Temperature is in F.

Exhaust Air Transfer Ratio: 2.8  
 Outdoor Air Correction Factor: 1.01  
 Pressure is in in. wc. Flow is in cfm. Temperature is in F.

**Tag Data - Water Cooled Helical Rotary Chillers (Duplex) (Qty: 2)**

Item	Tag(s)	Qty	Description	Model Number
A1	C-1, C-2	2	125 Ton Series R w/Remote Cond	RTUA125

**Product Data - Water Cooled Helical Rotary Chillers (Duplex)****Item: A1 Qty: 2 Tag(s): C-1, C-2**

Series R(TM) Compressor Chiller  
Factory Assigned  
125 Nominal Tons  
460 Volt/60 Hertz/3 Phase  
Y-delta Closed Transition Starter  
Standard Cooling 40 to 65 degrees F  
UL/CUL Listing  
Not ASHRAE 90.1/CSA compliant  
Outside ARI certification  
LonTalk communication interface module  
Power Disconnect Switch  
Elastomeric Isolators (Fld)  
Low Ambient Lockout Sensor (Fld)  
Ship with skid (flat bed truck)  
Sound Attenuator - Field Installed (Fld)  
150 psi NEMA 1 Flow Switch x 1 (Fld)  
2nd - 5th Year Replacement Compressor Parts Warranty



**TRANE®**

# Series R® Rotary Liquid Chiller

---

**70 to 125 Tons**

**Water-Cooled and Condenserless**

*Built For the Industrial and Commercial Markets*



---

November 1999

**RLC-DS-4**

# Performance Data

**Table P-20 – ARI Part-Load Performance**

Unit Size	% Load	Tons	EER	IPLV
RTUA 70	100	68.4	10.2	13.5
	75	51.3	12.0	
	50	34.2	14.6	
	25	17.1	15.2	
RTUA 80	100	78.3	10.1	13.1
	75	58.7	11.7	
	50	39.2	14.9	
	25	19.6	11.7	
RTUA 90	100	87.2	9.6	11.7
	75	65.4	10.2	
	50	43.6	12.9	
	25	21.8	12.6	
RTUA 100	100	95.0	9.2	11.9
	75	71.3	10.4	
	50	47.5	12.8	
	25	23.8	14.0	
RTUA 110	100	102.4	9.2	12.0
	75	76.8	10.4	
	50	51.2	13.1	
	25	25.6	13.9	
RTUA125	100	111.0	9.2	11.9
	75	83.3	10.5	
	50	55.5	12.9	
	25	27.8	13.3	



**Table P-21 – Performance Data Adjustment Factors**

Fouling Factor	Chilled Water Temp. Drop	Altitude											
		Sea Level			2000 Feet			4000 Feet			6000 Feet		
		CAP	GPM	kW									
0.00010	8	1.000	1.249	1.000	0.996	1.245	1.004	0.991	1.240	1.007	0.987	1.234	1.014
	10	1.000	1.000	1.000	0.997	0.996	1.004	0.993	0.992	1.007	0.988	0.988	1.015
	12	1.001	0.835	1.001	0.997	0.832	1.004	0.993	0.828	1.009	0.988	0.824	1.015
	14	1.003	0.716	1.001	0.999	0.714	1.004	0.994	0.711	1.009	0.990	0.708	1.015
	16	1.004	0.628	1.001	1.000	0.626	1.005	0.997	0.623	1.009	0.991	0.620	1.016
0.00025	8	0.988	1.235	0.996	0.984	1.230	1.000	0.980	1.225	1.004	0.975	1.220	1.010
	10	0.988	0.989	0.998	0.986	0.985	1.000	0.981	0.981	1.004	0.977	0.976	1.011
	12	0.990	0.825	0.998	0.987	0.822	1.000	0.983	0.819	1.005	0.978	0.815	1.011
	14	0.991	0.708	0.998	0.988	0.706	1.001	0.984	0.703	1.005	0.980	0.700	1.011
	16	0.993	0.621	0.999	0.990	0.619	1.001	0.986	0.617	1.006	0.981	0.614	1.012

**Fairview School**  
**Supporting Documentation**

# Ohio Mercantile Self Direct Program

## Application Guide & Cover Sheet

Questions? Call 1-866-380-9580 or visit [www.duke-energy.com](http://www.duke-energy.com).

Email this form along with completed Mercantile Self Direct Prescriptive or Custom applications, proof of payment, energy savings calculations and spec sheets to [SelfDirect@Duke-Energy.com](mailto:SelfDirect@Duke-Energy.com). You may also fax to 1-513-419-5572.

Mercantile customers, defined as using at least 700,000 kWh annually are eligible for the Mercantile Self Direct program. Please indicate mercantile qualification:

- a single Duke Energy Ohio account
- multiple accounts in Ohio (energy usage with other utilities may be counted toward the total)

Please list Duke Energy account numbers below (attach listing of multiple accounts an/or billing history for other utilities as required):

Account Number	Annual Usage	Account Number	Annual Usage
3880-3662-01			

Self Direct rebates are available for completed Custom projects that have not previously received a Duke Energy Smart \$aver® Custom Incentive. Self Direct incentives are applicable to Prescriptive measures that were installed more than 90 days prior to submission to Duke Energy and have not previously received a Duke Energy Prescriptive rebate.

Self Direct Program requirements dictate that certain projects that may be Prescriptive in nature under the Smart \$aver program must be evaluated using the Custom process. Use the table on page two as a guide to determine which Self Direct program fits your project(s). Apply for Self Direct projects using the appropriate application forms in conjunction with this cover sheet. Where Mercantile Self Direct Prescriptive applications are listed, please refer to the measure list on that application. If your measure is not listed, you may be eligible for a Self Direct Custom rebate. Self Direct Custom applications, like Smart \$aver Custom applications, should include detailed analysis of pre-project and post-project energy usage and project costs. Please indicate which type of rebate applications are included in the table provided on page two.

Please check each box to indicate completion of the following program requirements:

<input type="checkbox"/> All sections of appropriate application(s) are completed	<input type="checkbox"/> Proof of payment.*	<input type="checkbox"/> Manufacturer's Spec sheets	<input type="checkbox"/> Energy model/calculations and detailed inputs for Custom applications
---	---	---	--

\* If a single payment record is intended to demonstrate the costs of both Prescriptive & Custom projects, please include an additional document with an estimated breakout of costs for each Prescriptive and Custom energy conservation measure.

Application Type	Replaced equipment at end of lifetime or because equipment failed**	Replaced fully operational equipment to improve efficiency***	New Construction
Lighting	MSD Custom Part 1 <input type="checkbox"/> Custom Lighting Worksheet <input type="checkbox"/>	MSD Prescriptive Lighting <input type="checkbox"/>	MSD Prescriptive Lighting <input type="checkbox"/>
		MSD Custom Part 1 <input type="checkbox"/> Custom Lighting Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input checked="" type="checkbox"/> Custom Lighting Worksheet <input type="checkbox"/>
Heating & Cooling	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Heating & Cooling <input type="checkbox"/>
			MSD Custom Part 1 <input checked="" type="checkbox"/> MSD Custom General Worksheet <input checked="" type="checkbox"/>
Window Films, Programmable Thermostats, & Guest Room Energy Management Systems	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General and/or EMS Worksheet(s) <input type="checkbox"/>	MSD Prescriptive Heating & Cooling <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General and/or EMS Worksheet(s) <input type="checkbox"/>
Chillers & Thermal Storage	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Chillers & Thermal Storage <input type="checkbox"/>
			MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>
Motors & Pumps	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Motors, Pumps & Drives <input type="checkbox"/>
			MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>
VFDs	Not Applicable	MSD Prescriptive Motors, Pumps & Drives <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom VFD Worksheet <input type="checkbox"/>
		MSD Custom Part 1 <input type="checkbox"/> MSD Custom VFD Worksheet <input type="checkbox"/>	
Food Service	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Food Service <input type="checkbox"/>
			MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>
Process	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Process <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>
		MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	
Energy Management Systems	MSD Custom Part 1 <input type="checkbox"/> MSD Custom EMS Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom EMS Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom EMS Worksheet <input type="checkbox"/>
Behavioral*** & No/Low Cost	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>		

\*\* Under the Self Direct program, failed equipment and equipment at the end of its useful life are evaluated differently than early replacement of fully functioning equipment. **All equipment replacements due to failure or old age will be evaluated via the Custom program.**

\*\*\* Please ensure that you include the age of the replaced equipment for measures classified as "Early Replacement" in your application as well as the estimated date that you would have otherwise replaced the existing equipment if you had not chosen a more energy efficient option.

\*\*\*\* Behavioral energy efficiency and demand reduction projects must be both measurable and verifiable. Provide justification with your application.

# Mercantile Self Direct Nonresidential Custom Rebate Application PART 1



Proposed energy efficiency measures may be eligible for Self-Direct Custom rebates if they clearly reduce electrical consumption and/or demand as compared to the appropriate baseline.

Before you complete this application, please note the following important criteria:

- Submitting this application does not guarantee a rebate will be approved.
- Rebates are based on electricity conservation only.
- Electric demand and/or energy reductions must be well documented with auditable calculations.
- Incomplete applications cannot be reviewed; all fields are required.

Refer to the complete list of Instructions and Disclaimers, beginning on page 6.

## Notes on the Application Process

If you have any questions concerning how to complete any portion of the application or what supplementary information is required, please contact your Duke Energy Ohio, Inc account manager or the Duke Energy Smart \$aver® team at 1-866-380-9580.

Every application must include calculations of the baseline electrical usage and the electrical usage of the proposed high-efficiency equipment/system. Monthly calculations are best. You, the Duke Energy Ohio customer, or your equipment vendor / engineer should perform these calculations and submit them to Duke Energy for review. *We strongly encourage the use of modeling software (such as eQuest or comparable) for complex projects.*

Upon receipt of your application, an acknowledgement email will be sent to you with an estimated response time based on an initial assessment of your application. The application review may include some communication to resolve any questions about the project or to request additional information. Applications that are received complete without missing information have a faster review time.

There are two ways to submit your completed application.

Email your scanned form to: [SelfDirect@duke-energy.com](mailto:SelfDirect@duke-energy.com)

Or, fax your form to 513-419-5572

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



**1. Contact Information (Required)**

Duke Energy Customer Contact Information					
Company Name	Cincinnati Public Schools				
Address	2651 Burnett Ave				
Project Contact	Don Elbe				
City	Cincinnati	State	OH	Zip Code	45219
Title	Utility Management Coordinator				
Office Phone	513-363-0754	Mobile Phone		Fax	
E-mail Address	elbedon@cpsboe.k12.oh.us				

Equipment Vendor / Contractor / Architect / Engineer Contact Information					
Company Name	Plug Smart				
Address	1275 Kinnear Road Suite 229				
City	Columbus	State	OH	Zip Code	43212
Project Contact	Lucas Dixon				
Title	Operations Manager				
Office Phone	614-580-3352	Mobile Phone		Fax	1-800-518-5576
E-mail Address	lucas.dixon@plugsmart.com				
Describe Role	Ensures rebate is correctly applied for				

Payment Information					
Payee Legal Company Name (as shown on Federal income tax return):	Cincinnati Public Schools				
Mailing Address	2651 Burnett Ave				
City	Cincinnati	State	OH	Zip Code	45219
Type of organization (check one) <input type="checkbox"/> Individual/Sole Proprietor <input type="checkbox"/> Corporation <input type="checkbox"/> Partnership <input checked="" type="checkbox"/> Unit of Government <input type="checkbox"/> Non-Profit (non-corporation)					
Payee Federal Tax ID # of Legal Company Name Above:	31-6000758				
Who should receive incentive payment? (select one) <input checked="" type="checkbox"/> Customer <input type="checkbox"/> Vendor (Customer must sign below)					
If the vendor is to receive payment, please sign below: I hereby authorize payment of incentive directly to vendor:					
Customer Signature _____ Date ____/____/____ (mm/dd/yyyy)					

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



**2. Project Information (Required)**

- A. Please indicate project type:
- New Construction
  - Expansion at an existing facility
  - Replacing equipment due to equipment failure
  - Replacing equipment that is estimated to have remaining useful life of 2 years or less
  - Replacing equipment that is estimated to have remaining useful life of more than 2 years
  - Behavioral, operational and/or procedural programs/projects
- B. Please describe your project, or attach a detailed project description that describes the project.  
New K-6 magnet schools with a focus on learning the German language.
- C. When did you start and complete implementation?  
Start date / (mm/yyyy) End date 08/2008 (mm/yyyy)
- D. Are you also applying for Self-Direct Prescriptive incentives and, if so, which one(s)<sup>1</sup>?  
Lighting Controls
- E. Please indicate which worksheet(s) you are submitting for this application (check all that apply):
- Lighting
  - Variable Frequency Drive (VFD)
  - Compressed Air
  - Energy Management System (EMS)
  - General (for projects not easily submitted using one of the above worksheets)
- F. Please tell us if there is anything about your electrical energy projections (either for the baseline or the proposed project) that you are either unsure about or for which you have made significant assumptions. Attach additional sheets as needed.

Required: Attach a supplier or contractor invoice or other equivalent information documenting the Implementation Cost for each project listed in your application. (Note: self-install costs cannot be included in the Implementation Cost)

---

<sup>1</sup> If your project involves some equipment that is eligible for prescriptive incentives and some equipment that is likely eligible for custom incentives, and if it is feasible to separate the equipment for the energy analysis, then the equipment will be evaluated separately. If it is not feasible to separate the equipment for analysis, then the equipment will be evaluated together in the custom application.

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



**3. Signature** (Required – must be signed by Duke Energy customer)

**Customer Consent to Release of Personal Information**

I, (insert name) Don Elbe, do hereby consent to Duke Energy disclosing my Duke Energy Ohio, Inc Account Number and Federal Tax ID Number to its subcontractors solely for the purpose of administering Duke Energy Ohio's Mercantile Self-Direct Program. I understand that such subcontractors are contractually bound to otherwise maintain my Duke Energy Ohio, Inc Account Number and Federal Tax ID Number in the strictest of confidence.

I realize that under the rules and regulations of the public utilities commission, I may refuse to allow Duke Energy Ohio, Inc to release the information set forth above. By my signature, I freely give Duke Energy Ohio, Inc permission to release the information designated above.

**Application Signature**

I certify that I meet the eligibility requirements of the Duke Energy Ohio, Inc Mercantile Self Direct Custom Incentives Program and that all information provided within this application is correct to the best of my knowledge. I agree to the terms and conditions set forth for this program. I certify that the numbers, energy savings, and responses shown on this form are correct. Further, I certify that the taxpayer identification number is current and correct. I am not subject to backup withholding because: (a) I am exempt from backup withholding; or (b) I have not been notified by the IRS that I am subject to backup withholding as a result of a failure to report all interest or dividends; or (c) the IRS has notified me that I am no longer subject to backup withholding. I am a U.S. citizen (includes a U.S. resident alien).

\_\_\_\_\_  
Duke Energy Ohio, Inc Customer Signature

Print Name Don Elbe

Date 12/30/2011

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



**Checklist for completing the Application**

INCOMPLETE APPLICATIONS WILL RESULT IN DELAYS IN DUKE ENERGY PROCESSING YOUR APPLICATION AND NOTIFYING YOU CONCERNING ANY REBATES. Before submitting the application and the required supplementary information, use the following checklist to ensure that your application is complete and the information in the application is accurate. (Note: this checklist is for your use only – do not submit this checklist with your application)

Section No. & Title	Have You:
1. Contact Information	<input type="checkbox"/> Completed the contact information for the Duke Energy customer? <input type="checkbox"/> Completed the contact information for the equipment vendor / project engineer that can answer questions about the technical aspects of the project, if that is a different person than above?
2. Project Information	<input type="checkbox"/> Answered the questions A-E, including providing a description of your project. <input type="checkbox"/> Completed and attached the lighting, compressed air, VFD, EMS and/or General worksheet(s)?
3. Signature	<input type="checkbox"/> Signed your name? <input type="checkbox"/> Printed your name? <input type="checkbox"/> Entered the date?
Supplementary information (Required)	<input type="checkbox"/> Attached a supplier or contractor's invoice or other equivalent information documenting the Implementation Cost for projects listed in your application? (Note: self-install costs cannot be included in the Implementation Cost) <input type="checkbox"/> (If submitting the General Worksheet) attached calculations documenting the energy usage and energy savings for <b>each</b> project listed in your application?

If you have any questions concerning how to complete any portion of the application or what supplementary information is required, please contact:

- your Duke Energy account manager
- or,
- the Duke Energy Smart \$aver® team at 1-866-380-9580.

# Mercantile Self Direct Nonresidential Custom Rebate Application PART 1



## Instructions/Terms/Conditions

Note: Please keep for your records- do not submit with the application

1. Energy service companies or contractors may assist in preparing the application, but an authorized representative of the customer must sign this application to be eligible to participate in the Mercantile Self Direct Program. Completion of this application does not guarantee the approval of a Self Direct Custom Rebate.
2. Once all documentation requested in this application is received by *Duke Energy Ohio, Inc*, and any follow-up information requested by *Duke Energy* is received, the rebate amount for each Energy Conservation Measure (ECM) will be communicated to the customer. The rebate amount will be based on ECM energy savings and ECM incremental installation cost.
3. All rebates require approval by the Public Utilities Commission of Ohio. *Duke Energy Ohio, Inc* will submit an application for rebate on the customer's behalf upon customer attestation to program terms, conditions and requirements as outlined in the rebate offer letter and upon customer completion of attestation documents required by the Public Utilities Commission of Ohio.
4. *Duke Energy Ohio, Inc* will issue a Self Direct Custom Rebate check, based on the approved rebate amount for each ECM, upon receiving approval from the Public Utilities Commission of Ohio. *Duke Energy Ohio, Inc* does not guarantee PUCO approval.
5. With the application, the customer must provide a list of all sites where the ECMs were installed. *Duke Energy Ohio, Inc* requests that sites of similar size, hours of operation and energy consuming characteristics be grouped together in one application for the determination of the rebate amount. The application should identify the site where each unique ECM was installed.
6. Based on the information submitted with the application and the information gathered both before and after the initial installation of the ECM, *Duke Energy Ohio, Inc* will calculate the rebate amount for each ECM.
7. *Duke Energy Ohio, Inc* may conduct random site inspections of a sample of the locations where the ECMs are installed to verify installation and operability of the ECMs and to obtain information needed to calculate the Approved Incentive Amount.
8. Customers are encouraged to retain copies of all forms, invoices and supporting documentation for their records.
9. Approved rebates are valid for 6 months from the date communicated to the customer by *Duke Energy Ohio, Inc*, subject to the expiration of measure eligibility based on project completion dates and application submission deadlines as defined by PUCO. Customers are encouraged to execute their rebate offer contracts and PUCO-required affidavits promptly to ensure eligibility is not forfeited.
10. *Duke Energy Ohio, Inc* reserves the right to recover all unrecoverable costs associated with the project approval if the customer decides not to execute the rebate contract, after the project is approved by *Duke Energy Ohio, Inc*.
11. Projects financially supported by other funding sources will be evaluated on a case-by-case basis for potential partial funding from *Duke Energy Ohio, Inc*.
12. Participants must be *Duke Energy Ohio, Inc* nonresidential, mercantile customers with the project sites in the *Duke Energy Ohio, Inc* service territory.

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



13. Customers or trade allies may not use any *Duke Energy* logo without prior written permission.
14. Only trade allies registered with *Duke Energy* are eligible to participate.
15. All equipment must be new. Used or rebuilt equipment is not eligible for incentives. All old existing equipment must be removed on retrofit projects.
16. Disclaimers: *Duke Energy Ohio, Inc*
  - a. does not endorse any particular manufacturer, product or system design within the program;
  - b. will not be responsible for any tax liability imposed on the customer as a result of the payment of incentives;
  - c. does not expressly or implicitly warrant the performance of installed equipment. (Contact your contractor for details regarding equipment warranties.);
  - d. is not responsible for the proper disposal/recycling of any waste generated or obsolete or old equipment as a result of this project;
  - e. is not liable for any damage caused by the installation of the equipment nor for any damage caused by the malfunction of the installed equipment; and
  - f. reserves the right to change or discontinue this program at any time. The acceptance of program applications is determined solely by *Duke Energy Ohio, Inc*.



The General Worksheet is part 2 of the application. Do not submit this file without submitting a completed Part1 Custom Application document file, which can be found at [www.duke-energy.com](http://www.duke-energy.com). This worksheet is for all projects that are not easily submitted through one of the other worksheets

Before you complete this application, please note the following important criteria:

- Submitting this application does not guarantee an incentive will be approved.
- Incentive already decided to proceed.
- Electric demand and/or energy reductions must be well documented with auditable calculations.
- Incomplete applications will not be reviewed; all fields are required.

Refer to the complete list of Instructions and Disclaimers, found in the Mercantile Self Direct Custom Application Part 1 document.

Please enter your information and data into the cells that are shaded.  
Cells in white are locked and cannot be written over.

**Duke Energy Customer Contact Information (Match the information in Application Part 1):**

Name	Don Elbe
Company	Cincinnati Public Schools

**Equipment Vendor / Project Engineer Contact Information**

Name	Lucas Dixon
Company	Plug Smart

Before proceeding with the custom application, please verify that your project is not on the Self-Direct Prescriptive application.

The prescriptive incentive applications can be found at:

<http://www.duke-energy.com/ohio-large-business/smart-saver/mercantile-self-direct.asp>

Prescriptive rebate amounts are pre-approved.





For each project, answer the following questions (use one worksheet per project)

App No.	0
Rev.	0

Project Name: **Heat Recovery Units**

How would you classify this project? (Place an x in all boxes that apply.)

Lighting		Heating/Cooling	X	Air Compressor		Energy Management System	
VFD		Motors/Pumps		Process Equipment		Other, describe below:	

**Brief Project Description**

Describe the Baseline (see note 3)	Equipment/System	Describe the Proposed High Efficiency Project
No heat recovery units installed on air handlers		Heat recovery units installed on air handlers.

If Existing Equipment is the Baseline, how many years of useful life remain or how many years until scheduled replacement?

Detailed Project Description Attached?  Yes (Required)

**Operating Hours (see note 4)**

24 x 7	Weekday		Saturday		Sunday		Weeks of Use in Year (see note 5)	Total Annual Hours of Use
	Start Hour	End Hour	Start Hour	End Hour	Start Hour	End Hour		
	7:00 AM	3:00 PM					29	1,225

**Energy Savings**

	Baseline (see Note 3)	Proposed	Savings	Describe how energy numbers were calculated
Annual Electric Energy	34,653 kWh	0 kWh	34,653 kWh	
Electric Demand	0 kW	0 kW	0 kW	
Calculations attached	Yes	Yes	(Required)	

**Simple Payback**

Average electric rate (\$/kWh) on the applicable accounts (see note 6)	\$0.10
Estimated annual electric savings	\$3,465
Other annual savings in addition to electric savings, such as operations, maintenance, other fuels	
Incremental cost to implement the project (equipment & installation) (see note 7)	
Copy of vendor proposal is attached (see note 8)	Yes
Simple Electric Payback in years (see note 9)	0
Total Payback in years	0

**3 Baseline**

Retrofit projects: the existing equipment is the baseline.  
 New construction projects: the baseline is the standard option in today's market, taking into account any applicable organizational, local, state or federal codes or standards currently in effect.

**4 Operating Hours**

Describe when the equipment is typically used. If the project is proposed for more than one site, provide any variations in operating hours between the sites on a separate sheet.

**5 Weeks of Use in Year**

If the equipment is not in use 52 weeks during the year (for example, during holiday or summer break), provide an explanation of when usage is not expected and why: Savings only calculated for summer hours, gas heating systems are used during the winter.

**6 Average electric rate (\$/kWh)**

If you do not know your average electric rate, use \$0.10/kWh.

**7 Incremental cost to implement the project**

Costs exclude self installation costs. Retrofit projects, incremental cost is the total cost of the proposed project. New construction or where the existing equipment must be replaced anyway, then incremental cost is the premium of the proposed high efficiency project over baseline.

**8 Copy of vendor invoice is attached**

Vendor invoices detailing costs of the project are always required.  
 New construction projects or where the existing equipment must be replaced anyway, vendor proposal of baseline must also be attached.

**9 Simple Electric Payback**

If the simple electric payback is less than 1 year, the rebate structure is affected. Double check average electric rate for correct payback.

March 2, 2012



To whom it may concern:

This letter is to confirm that for the renovation to Cincinnati Public school Fairview Elementary (3645 Clifton Ave), for the custom rebate application, the lighting project was installed with a minimum unit cost listed below.

DESCRIPTION	QUANTITY	PRICE/FIXTURE	AMOUNT
R1 - Metalux 2GC8-332A	513	\$95.00	\$48,735.00
R6 - Portfolio C6142E	8	\$60.00	\$480.00
R12 - Metalux 2GC8-232A125	37	\$90.00	\$3,330.00
W7 - Metalux BAU-232	6	\$60.00	\$360.00
CL4 - Metalux W-332A	8	\$55.00	\$440.00
R9 - Halo H800E277	3	\$75.00	\$225.00
CL3 - Metalux W-332A	14	\$55.00	\$770.00
R5 - Portfolio C6152E	32	\$60.00	\$1,920.00
R10 - Portfolio M7600TQF	3	\$163.00	\$489.00
W2 - Elliptipar F113-H242	13	\$126.00	\$1,638.00
52 - Shaper 482-10-CFL	10	\$153.00	\$1,530.00
R7 - Metalux GC8-232A125	151	\$80.00	\$12,080.00
R11 - Metalux 2GC8-332A125	84	\$95.00	\$7,980.00
CL6 - Fail-Safe FWS-332	2	\$109.00	\$218.00
CH1 - Metalux DIM-232	36	\$94.00	\$3,384.00
W5 - Metalux BC-232	7	\$78.00	\$546.00
W6 - Lumark ICVW1G	2	\$32.00	\$64.00
R3 - Metalux 2EP3GX-332S36I	28	\$105.00	\$2,940.00
S1 - Lumark MH SE ENGR 21 C	31	\$189.00	\$5,859.00
R8 - Metalux 2GC8FA-432A125	5	\$56.00	\$280.00
W4 - Steplyte RSC2 F13	4	\$179.00	\$716.00
CL5 - Fail-Safe FWS-332	23	\$109.00	\$2,507.00
NovelAire ECW 844 Energy Conservation Wheel	3	\$8,000.00	\$24,000

<b>TOTAL</b>	<b>\$120,491</b>
--------------	------------------

This is also to confirm that for the renovation to Fairview Elementary (3645 Clifton Ave), for the prescriptive rebate application, occupancy sensors were installed with a minimum unit cost listed below.

DESCRIPTION	QUANTITY	PRICE/FIXTURE	AMOUNT
Occupancy Sensors - WT 11 CM-PDT-10	45	\$117.89	\$5,305.05

<b>TOTAL</b>	<b>\$5,305.05</b>
--------------	-------------------

Thank you for your attention to this matter,

Don Elbe  
Utility Management Coordinator

**APPLICATION AND CERTIFICATE FOR PAYMENT**

**TO OWNER:**

CINCINNATI PUBLIC SCHOOLS  
 2315 IOWA AVENUE  
 CINCINNATI, OHIO 45208

**PROJECT:**  
 FAIRVIEW ELEMENTARY SCHOOL  
 3645 CLIFTON AVENUE  
 CINCINNATI, OHIO 45220

**FROM CONTRACTOR:**

BEACON ELECTRIC COMPANY  
 7815 REDSKY DRIVE  
 CINCINNATI, OHIO 45249

**VIA ARCHITECT:**  
 GLASERWORKS  
 304 EAST EIGHT  
 CINCINNATI, OHIO 45202-2231

**APPLICATION No:** 21  
**PERIOD TO:** 10/31/08  
**PROJECT NOS:** 04026  
**CONTRACT DATE:**

**MELISSA M. LAWSON**  
 Notary Public, State of Ohio  
 My Commission Expires August 13, 2013


**CONTRACTOR'S APPLICATION FOR PAYMENT**

Application is made for payment as shown below. In connection with the Contract Continuation sheet is attached.


1. ORIGINAL CONTRACT SUM.....\$ 1,675,000.00
2. Net Change by Change Orders.....\$ 83,221.00
3. CONTRACT SUM TO DATE.....\$ 1,758,221.00
4. TOTAL COMPLETED & STORED TO DATE.....\$ 1,758,221.00
5. RETAINAGE
  - a. 8-50% of Completed Labor.....\$
  - b. 8% of Stored Material.....\$
  - Total Retainage.....\$
6. TOTAL EARNED LESS RETAINAGE.....\$ 1,758,221.00
7. LESS PREVIOUS CERTIFICATES FOR PAYMENT.....\$ 1,749,245.00
8. CURRENT PAYMENT DUE.....\$ 9,976.00
9. BALANCE TO FINISH, INCLUDING RETAINAGE.....\$

Change Order/Contract	ADDITIONS	DEDUCTIONS
Total Changes approved in Previous months by Owner	\$ 74,245.00	
Total approved this month	\$ 8,976.00	
<b>TOTALS</b>	<b>\$ 83,221.00</b>	
<b>NET CHANGES by Change Order</b>	<b>\$ 83,221.00</b>	

The Contractor certifies that the work covered by this pay request has been completed in accordance with the Contract Documents and that all progress payments previously paid by the State have been applied by the Contractor to discharge in full all of Contractor's obligations incurred in connection with the work covered by all prior pay requests.

Contractor:  Date: 10-20-08

Based upon on-site observations, the firm affirms that the work has progressed to the percentage of completeness indicated on the pay request.

Architect:  Date: 10/28/08

Construction Manager:  Date: 10/27/08

Approved:

School District Treasurer

Date

CONTINUATION SHEET

APPLICATION NUMBER 21

PERIOD TO:

10/31/2008

ITEM NUMBER	DESCRIPTION OF WORK GENERAL CONDITIONS		SCHEDULED VALUE	WORK COMPLETED		MATERIALS PRESENTLY STORED	TOTAL COMPLETED & STORED TO DATE	%	BALANCE TO FINISH	RETAINAGE 0%
				PREVIOUS APPS.	THIS PERIOD					
1	BOND/INSURANCE		35,275.00	35,275.00	\$	0.00	35,275.00	100.00%	0.00	\$
2	PERMITS & FEES		25,500.00	25,500.00	\$	0.00	25,500.00	100.00%	0.00	\$
3	GC-SUBMITTALS	LABOR	8,300.00	8,300.00	\$	0.00	8,300.00	100.00%	0.00	\$
4	GC-CLEANUP	MATERIAL	4,150.00	4,150.00	\$	0.00	4,150.00	100.00%	0.00	\$
5	GC-CLEANUP	LABOR	9,980.00	9,980.00	\$	0.00	9,980.00	100.00%	0.00	\$
6	PUNCHLIST	MATERIAL	2,490.00	2,490.00	\$	0.00	2,490.00	100.00%	0.00	\$
6	PUNCHLIST	LABOR	2,490.00	2,490.00	\$	0.00	2,490.00	100.00%	0.00	\$
6	TEMPORARY POWER	MATERIAL	1,680.00	1,680.00	\$	0.00	1,680.00	100.00%	0.00	\$
6	TEMPORARY POWER	LABOR	33,200.00	33,200.00	\$	0.00	33,200.00	100.00%	0.00	\$
7	ALLOWANCES GENERAL	MATERIAL	37,350.00	37,350.00	\$	0.00	37,350.00	100.00%	0.00	\$
7	ALLOWANCES DSL / TELE	MATERIAL	15,000.00	15,000.00	\$	0.00	15,000.00	100.00%	0.00	\$
8	CLOSE-OUT		5,000.00	5,000.00	\$	0.00	5,000.00	100.00%	0.00	\$
9	ATTIC STOCK TO OWNER		2,075.00	2,075.00	\$	0.00	2,075.00	100.00%	0.00	\$
10	TRAINING		1,680.00	1,680.00	\$	0.00	1,680.00	100.00%	0.00	\$
11	SITE WORK									
11	BRCH/FEEDER-CONDUIT	LABOR	20,750.00	20,750.00	\$	0.00	20,750.00	100.00%	0.00	\$
12	BRCH/FEEDER-CONDUIT	MATERIAL	17,015.00	17,015.00	\$	0.00	17,015.00	100.00%	0.00	\$
13	BRANCH/FEEDER-WIRE	LABOR	7,885.00	7,885.00	\$	0.00	7,885.00	100.00%	0.00	\$
14	BRANCH/FEEDER-WIRE	MATERIAL	7,470.00	7,470.00	\$	0.00	7,470.00	100.00%	0.00	\$
15	LIGHT FIXTURES	LABOR	14,940.00	14,940.00	\$	0.00	14,940.00	100.00%	0.00	\$
16	LIGHT FIXTURES	MATERIAL	20,750.00	20,750.00	\$	0.00	20,750.00	100.00%	0.00	\$
17	TRENCHING/BACKFILL	LABOR	28,560.00	28,560.00	\$	0.00	28,560.00	100.00%	0.00	\$
18	TRENCHING/BACKFILL	MATERIAL	53,950.00	53,950.00	\$	0.00	53,950.00	100.00%	0.00	\$
19	ELECTRICAL EQUIPMENT 1st Floor North	LABOR	37,350.00	37,350.00	\$	0.00	37,350.00	100.00%	0.00	\$
20	ELECTRICAL EQUIPMENT	MATERIAL	124,500.00	124,500.00	\$	0.00	124,500.00	100.00%	0.00	\$
21	BRCH/FEEDER-CONDUIT	LABOR	70,550.00	70,550.00	\$	0.00	70,550.00	100.00%	0.00	\$
22	BRCH/FEEDER-CONDUIT	MATERIAL	45,650.00	45,650.00	\$	0.00	45,650.00	100.00%	0.00	\$
23	BRANCH/FEEDER-WIRE	LABOR	9,980.00	9,980.00	\$	0.00	9,980.00	100.00%	0.00	\$
24	BRANCH/FEEDER-WIRE	MATERIAL	62,250.00	62,250.00	\$	0.00	62,250.00	100.00%	0.00	\$
	TOTAL		712,690.00	712,690.00		0.00	712,690.00	100.00%	0.00	0.00

00400-3

Contractor Pay Application

CONTINUATION SHEET

APPLICATION NUMBER 21

PERIOD TO:

1/23/2008

ITEM NUMBER	DESCRIPTION OF WORK	SCHEDULED VALUE	WORK COMPLETED		MATERIALS PRESENTLY STORED	TOTAL COMPLETED & STORED TO DATE	%	BALANCE TO FINISH	RETAINAGE
			PREVIOUS APPS.	THIS PERIOD					
25	LIGHT FIXTURES	16,800.00	16,800.00	\$	0.00	\$ 16,800.00	100.00%	0.00	\$ -
26	LIGHT FIXTURES	63,950.00	53,950.00	\$	0.00	\$ 53,950.00	100.00%	0.00	\$ -
27	DEVICES/EQUIPMENT	12,450.00	12,450.00	\$	0.00	\$ 12,450.00	100.00%	0.00	\$ -
28	DEVICES/EQUIPMENT	9,980.00	9,980.00	\$	0.00	\$ 9,980.00	100.00%	0.00	\$ -
28	1st Floor South ELECTRICAL EQUIPMENT	8,300.00	8,300.00	\$	0.00	\$ 8,300.00	100.00%	0.00	\$ -
30	ELECTRICAL EQUIPMENT	20,750.00	20,750.00	\$	0.00	\$ 20,750.00	100.00%	0.00	\$ -
31	BRCH/FEEDER-CONDUIT	14,940.00	14,940.00	\$	0.00	\$ 14,940.00	100.00%	0.00	\$ -
32	BRCH/FEEDER-CONDUIT	15,770.00	15,770.00	\$	0.00	\$ 15,770.00	100.00%	0.00	\$ -
33	BRANCH/FEEDER-WIRE	8,300.00	8,300.00	\$	0.00	\$ 8,300.00	100.00%	0.00	\$ -
34	BRANCH/FEEDER-WIRE	9,130.00	9,130.00	\$	0.00	\$ 9,130.00	100.00%	0.00	\$ -
35	LIGHT FIXTURES	6,840.00	6,840.00	\$	0.00	\$ 6,840.00	100.00%	0.00	\$ -
36	LIGHT FIXTURES	16,600.00	16,600.00	\$	0.00	\$ 16,600.00	100.00%	0.00	\$ -
37	DEVICES/EQUIPMENT	4,665.00	4,665.00	\$	0.00	\$ 4,665.00	100.00%	0.00	\$ -
36	DEVICES/EQUIPMENT	4,150.00	4,150.00	\$	0.00	\$ 4,150.00	100.00%	0.00	\$ -
39	2nd Floor South ELECTRICAL EQUIPMENT	8,300.00	8,300.00	\$	0.00	\$ 8,300.00	100.00%	0.00	\$ -
40	ELECTRICAL EQUIPMENT	20,750.00	20,750.00	\$	0.00	\$ 20,750.00	100.00%	0.00	\$ -
41	BRCH/FEEDER-CONDUIT	9,980.00	9,980.00	\$	0.00	\$ 9,980.00	100.00%	0.00	\$ -
42	BRCH/FEEDER-CONDUIT	12,450.00	12,450.00	\$	0.00	\$ 12,450.00	100.00%	0.00	\$ -
43	BRANCH/FEEDER-WIRE	8,300.00	8,300.00	\$	0.00	\$ 8,300.00	100.00%	0.00	\$ -
44	BRANCH/FEEDER-WIRE	9,130.00	9,130.00	\$	0.00	\$ 9,130.00	100.00%	0.00	\$ -
45	LIGHT FIXTURES	5,810.00	5,810.00	\$	0.00	\$ 5,810.00	100.00%	0.00	\$ -
46	LIGHT FIXTURES	12,450.00	12,450.00	\$	0.00	\$ 12,450.00	100.00%	0.00	\$ -
47	DEVICES/EQUIPMENT	4,150.00	4,150.00	\$	0.00	\$ 4,150.00	100.00%	0.00	\$ -
48	DEVICES/EQUIPMENT	3,320.00	3,320.00	\$	0.00	\$ 3,320.00	100.00%	0.00	\$ -
<b>TOTAL</b>		<b>1,009,415.00</b>	<b>1,009,415.00</b>	<b>0.00</b>	<b>0.00</b>	<b>1,009,415.00</b>	<b>100.00%</b>	<b>0.00</b>	<b>0.00</b>

00408-J

Contractor Pay Application

CONTINUATION SHEET

APPLICATION NUMBER 21

PERIOD TO:

10/31/2003

ITEM NUMBER	DESCRIPTION OF WORK	SCHEDULED VALUE	WORK COMPLETED		MATERIALS PRESENTLY STORED	TOTAL COMPLETED & STORED TO DATE	%	BALANCE TO FINISH	RETAINAGE
			PREVIOUS APPS.	THIS PERIOD					
49	ELECTRICAL EQUIPMENT 3rd Floor South	LABOR 4,150.00	\$ 4,150.00	\$ -	0.00	\$ 4,150.00	100.00%	0.00	-
50	ELECTRICAL EQUIPMENT	MATERIAL 20,750.00	\$ 20,750.00	\$ -	0.00	\$ 20,750.00	100.00%	0.00	-
51	BROCH/FEEDER-CONDUIT	LABOR 4,565.00	\$ 4,565.00	\$ -	0.00	\$ 4,565.00	100.00%	0.00	-
62	BROCH/FEEDER-CONDUIT	MATERIAL 4,150.00	\$ 4,150.00	\$ -	0.00	\$ 4,150.00	100.00%	0.00	-
53	BRANCH/FEEDER-WIRE	LABOR 4,565.00	\$ 4,565.00	\$ -	0.00	\$ 4,565.00	100.00%	0.00	-
54	BRANCH/FEEDER-WIRE	MATERIAL 8,300.00	\$ 8,300.00	\$ -	0.00	\$ 8,300.00	100.00%	0.00	-
55	LIGHT FIXTURES	LABOR 4,565.00	\$ 4,565.00	\$ -	0.00	\$ 4,565.00	100.00%	0.00	-
56	LIGHT FIXTURES	MATERIAL 8,300.00	\$ 8,300.00	\$ -	0.00	\$ 8,300.00	100.00%	0.00	-
57	DEVICES/EQUIPMENT	LABOR 3,320.00	\$ 3,320.00	\$ -	0.00	\$ 3,320.00	100.00%	0.00	-
58	DEVICES/EQUIPMENT	MATERIAL 3,320.00	\$ 3,320.00	\$ -	0.00	\$ 3,320.00	100.00%	0.00	-
	<b>Equip &amp; Systems</b>								
59	GENERATOR/RATS 16622	LABOR 8,225.00	\$ 8,225.00	\$ -	0.00	\$ 8,225.00	100.00%	0.00	-
60	GENERATOR/RATS 16622	MATERIAL 32,370.00	\$ 32,370.00	\$ -	0.00	\$ 32,370.00	100.00%	0.00	-
61	WIRE BASKET TRAY 16136	LABOR 9,960.00	\$ 9,960.00	\$ -	0.00	\$ 9,960.00	100.00%	0.00	-
62	WIRE BASKET TRAY 16136	MATERIAL 12,450.00	\$ 12,450.00	\$ -	0.00	\$ 12,450.00	100.00%	0.00	-
63	FIRE ALARM 16721	LABOR 10,375.00	\$ 10,375.00	\$ -	0.00	\$ 10,375.00	100.00%	0.00	-
64	FIRE ALARM 16721	MATERIAL 16,600.00	\$ 16,600.00	\$ -	0.00	\$ 16,600.00	100.00%	0.00	-
65	SECURITY 17910	LABOR 7,055.00	\$ 7,055.00	\$ -	0.00	\$ 7,055.00	100.00%	0.00	-
66	SECURITY 17910	MATERIAL 29,050.00	\$ 29,050.00	\$ -	0.00	\$ 29,050.00	100.00%	0.00	-
67	CCTV 17930	LABOR 9,130.00	\$ 9,130.00	\$ -	0.00	\$ 9,130.00	100.00%	0.00	-
68	CCTV 17930	MATERIAL 42,330.00	\$ 42,330.00	\$ -	0.00	\$ 42,330.00	100.00%	0.00	-
69	VOICEDATA 17150	LABOR 29,050.00	\$ 29,050.00	\$ -	0.00	\$ 29,050.00	100.00%	0.00	-
70	VOICEDATA 17150	MATERIAL 123,360.00	\$ 123,360.00	\$ -	0.00	\$ 123,360.00	100.00%	0.00	-
71	PA SYSTEM 17760	LABOR 8,715.00	\$ 8,715.00	\$ -	0.00	\$ 8,715.00	100.00%	0.00	-
72	PA SYSTEM 17760	MATERIAL 20,750.00	\$ 20,750.00	\$ -	0.00	\$ 20,750.00	100.00%	0.00	-
	<b>TOTAL</b>		1,432,820.00	1,432,820.00	0.00	1,432,820.00	100.00%	0.00	0.00

CONTINUATION SHEET

APPLICATION NUMBER: 21

PERIOD TO:

10/31/2008

ITEM NUMBER	DESCRIPTION OF WORK	SCHEDULED VALUE	WORK COMPLETED		MATERIALS PRESENTLY STORED	TOTAL COMPLETED & STORED TO DATE	%	BALANCE TO FINISH	RETAINAGE
			PREVIOUS APPS.	THIS PERIOD					
73	CLASSROOM REINFORCEMENT 17890	2,075.00	2,075.00	-	0.00	2,075.00	100.00%	0.00	-
74	CLASSROOM REINFORCEMENT 17890	6,850.00	6,850.00	-	0.00	6,850.00	100.00%	0.00	-
75	VOCAL RM SOUND 16821	2,075.00	2,075.00	-	0.00	2,075.00	100.00%	0.00	-
76	VOCAL RM SOUND 16821	3,320.00	3,320.00	-	0.00	3,320.00	100.00%	0.00	-
77	GYM SOUND 17824	4,565.00	4,565.00	-	0.00	4,565.00	100.00%	0.00	-
78	GYM SOUND 17824	12,450.00	12,450.00	-	0.00	12,450.00	100.00%	0.00	-
79	CAFETERIA SOUND SYSTEM 17821	3,320.00	3,320.00	-	0.00	3,320.00	100.00%	0.00	-
80	CAFETERIA SOUND SYSTEM 17821	8,130.00	8,130.00	-	0.00	8,130.00	100.00%	0.00	-
81	MUSIC ROOM SND 17827	2,490.00	2,490.00	-	0.00	2,490.00	100.00%	0.00	-
82	MUSIC ROOM SND 17827	6,640.00	6,640.00	-	0.00	6,640.00	100.00%	0.00	-
83	VIDEO DISTRIBUTION 17410	4,565.00	4,565.00	-	0.00	4,565.00	100.00%	0.00	-
84	VIDEO DISTRIBUTION 17410	9,980.00	9,980.00	-	0.00	9,980.00	100.00%	0.00	-
85	VIDEO PLAYBACK PROJECTION 17430	9,980.00	9,980.00	-	0.00	9,980.00	100.00%	0.00	-
86	VIDEO PLAYBACK PROJECTION 17430	82,000.00	82,000.00	-	0.00	82,000.00	100.00%	0.00	-
87	NETWORK EQUIP 17210	4,565.00	4,565.00	-	0.00	4,565.00	100.00%	0.00	-
88	NETWORK EQUIP 17210	65,400.00	65,400.00	-	0.00	65,400.00	100.00%	0.00	-
89	SCOREBOARD 16660	1,875.00	1,875.00	-	0.00	1,875.00	100.00%	0.00	-
90	SCOREBOARD 16660	5,465.00	5,465.00	-	0.00	5,465.00	100.00%	0.00	-
91	UPS 17280	675.00	675.00	-	0.00	675.00	100.00%	0.00	-
92	UPS 17280	4,800.00	4,800.00	-	0.00	4,800.00	100.00%	0.00	-
93	CHANGE ORDER # 1	2,701.00	2,701.00	-	0.00	2,701.00	100.00%	0.00	-
94	CHANGE ORDER # 2	16,998.00	16,998.00	-	0.00	16,998.00	100.00%	0.00	-
95	CHANGE ORDER # 3	3,446.00	3,446.00	-	0.00	3,446.00	100.00%	0.00	-
96	CHANGE ORDER # 4	6,267.00	6,267.00	-	0.00	6,267.00	100.00%	0.00	-
97	CHANGE ORDER # 5	1,551.00	1,551.00	-	0.00	1,551.00	100.00%	0.00	-
98	CHANGE ORDER # 6	22,005.00	22,005.00	-	0.00	22,005.00	100.00%	0.00	-
99	CHANGE ORDER # 7	3,658.00	3,658.00	-	0.00	3,658.00	100.00%	0.00	-
100	CHANGE ORDER # 8	8,883.00	8,883.00	-	0.00	8,883.00	100.00%	0.00	-
101	CHANGE ORDER # 9	7,011.00	7,011.00	-	0.00	7,011.00	100.00%	0.00	-
102	CHANGE ORDER # 10	1,745.00	1,745.00	-	0.00	1,745.00	100.00%	0.00	-
103	CHANGE ORDER # 11	389.00	389.00	-	0.00	389.00	100.00%	0.00	-
104	CHANGE ORDER # 12	8,167.00	8,167.00	-	0.00	8,167.00	100.00%	0.00	-
	CHANGE ORDER # 13	420.00	420.00	-	0.00	420.00	100.00%	0.00	-
	CHANGE ORDER # 14			-					
	TOTAL	1,758,221.00	1,749,245.00	8,976.00	0.00	1,758,221.00	100.00%	0.00	0.00

00406-V

Continuator Pay Application

**LABOR**

Said affiant further says that the following shows the names and addresses of every unpaid laborer in the employ of Beacon Electric Company furnishing labor under said contract, giving the amount, if any, which is due, or to become due, for labor done to date hereof.

NOTE-If the fact is that every laborer has been paid in full, then recite: "Every laborer has been paid in full." If not, then give each unpaid laborer's name and address and the amount due or to become due.

NAME	ADDRESS	HOURS	Amount Due or to Become Due for Labor Furnished to Date Hereof
EVERY LABORER HAS BEEN PAID IN FULL			

Affiant further states that there is due or to become due to Beacon Electric Company for work performed or machinery, material or fuel furnished to Cincinnati Public School to date hereof under said contracts, the sum of \$ 8,976.00 (Owner or Contractor)

That the amounts due or to become due to said sub-contractors, material men and laborers, for work done or machinery, material or fuel furnished to the date hereof, to Beacon Electric Company are fully and correctly set forth opposite their names, respectively, in the aforesaid statements, and further evidenced by certificates of every person furnishing machinery, material or fuel, hereto attached, and made a part hereof.

Affiant further says that Beacon Electric Company has not employed or purchased or procured machinery, material or fuel from, or sub-contracted with any person, firm or corporation, other than

NOTE-The above must be accompanied by "Certificate of Materialman." In lieu of such certificate, there may be furnished a written waiver of lien, a written release or receipt.

NAME	ADDRESS	Kind of Machinery, Material or Fuel	Amount Due or to Become Due for Material Furnished to Date Hereof
ALL MATERIAL HAS BEEN PAID IN FULL			

Beacon Electric Company giving the amount, if any, which is due, or to become due, to them, or any of them, for machinery, material or fuel furnished to date hereof, under said contracts.

RECEIVED

OCT 28 2008

glaserworks

Cincinnati Public Schools

2315 Iowa Avenue  
Cincinnati, Ohio 45206

RECEIVED

OCT 25 2008

glaserworks

Contractor's Name: BEACON ELECTRIC COMPANY  
Address: 7815 REDSKY DRIVE, CINCINNATI, OHIO 45249

Date: October 25, 2008

Application # 21

**Contractor Pay Application Summary**

Project Name FAIRVIEW ELEMENTARY SCHOOL  
Bid Package No. # 7

1	Original Contract Amount	\$ 1,675,000.00
2	Net Changes to Date	\$ 83,221.00
3	Current Contract Amount	\$ 1,758,221.00
4	Labor Completed to Date	\$ -
5	Material Completed to Date	\$ -
6	Total Work Completed to Date	\$ 1,758,221.00
7	Store Material to Date	\$ -
8	Less Retained to Date	\$ -
9	Total Amount Due	\$ 1,758,221.00
10	Less Previous Payments	\$ 1,749,245.00
11	Less Amount Retained to Cover Lien	\$ -
12	Less Amount Retained for Liquidated Damages	\$ -
13	Less Other Amounts Withheld	\$ -
14	Current Due	\$ 8,976.00
15	Balance to Complete	\$ -

**OSFC approval required for the following contract adjustments:**

1. Assessment of liquidated damages
2. Other amounts withheld

Ohio School Facilities Commission \_\_\_\_\_

Date \_\_\_\_\_

Comments:


**Turner  TYS**  
Rebuilding Cincinnati Public Schools

October 31, 2008

Angie Tolle  
Cincinnati Public Schools  
2315 Iowa Avenue  
Cincinnati, OH 45206

Dear Angie:

Attached is **Pay Application** for the **Fairview School**, please  
**process for payment.**

Contractor	Application #	Monthly Billing	Total Billing To Date	Contract Amount to Date
<del>BP#4 Ken Rogers</del>	<del>#20</del>	<del>\$ 15,128.00</del>	<del>\$ 817,766.00</del>	<del>\$ 817,766.00</del>
BP#6 Feldkamp	#22	\$ 30,321.20	\$1,442,872.00	\$1,442,872.00
BP#7 Beacon	#21	\$ 8,976.00	\$1,758,221.00	\$1,758,221.00

Please call if you have any questions.

Sincerely,  
TURNER/DAG/TYS

  
James T. De Lage  
Project Executive

/bcs

Attachments

cc: Paul Duffy - Glaserworks  
Manasseh Robinson - Turner/DAG/TYS  
File 0025 -10960PA

T:PROJECTS/FAIRVIEW/00250 Pay Application/2008-10-31 Combined pay app.doc

2315 Iowa Avenue, Cincinnati, OH 45206, Phone 513-363-0875, Fax 513-363-0880

**APPLICATION AND CERTIFICATE FOR PAYMENT**

TO OWNER: Cincinnati Public Schools

PROJECT: Fairview Elementary

3645 Clifton Avenue  
Cincinnati, Ohio 45220

FROM CONTRACTOR:

Feldkamp Enterprises, Inc.  
3642 Muddy Creek Road  
Cincinnati, Ohio 45238

VIA ARCHITECT:

APPLICATION No: 22  
PERIOD TO: 10/31/08  
PROJECT NOS:  
CONTRACT DATE: 08/11/06  
INVOICE NO: 1219-RET

CONTRACT FOR: HVAC & PIPING

**CONTRACTOR'S APPLICATION FOR PAYMENT**

Application is made for payment as shown below, in connection with the Contract  
Continuation sheet is attached:


1. ORIGINAL CONTRACT SUM..... \$ 1,463,000.00
2. Net Change by Change Orders..... \$ (20,128.00)
3. CONTRACT SUM TO DATE..... \$ 1,442,872.00
4. TOTAL COMPLETED & STORED TO DATE..... \$ 1,442,872.00
5. RETAINAGE
  - a. 8-50% of Completed Labor..... \$ -
  - b. 8% of Stored Material..... \$ -
  - Total Retainage..... \$ -
6. TOTAL EARNED LESS RETAINAGE..... \$ 1,442,872.00
7. LESS PREVIOUS CERTIFICATES FOR PAYMENT..... \$ 1,412,550.80
8. CURRENT PAYMENT DUE..... \$ 30,321.20
9. BALANCE TO FINISH, INCLUDING RETAINAGE..... \$ -

Change Order/Contract	ADDITIONS	DEDUCTIONS
Total Changes approved in Previous months by Owner	16136.00	-36264.00
Total approved this month	0.00	0.00
<b>TOTALS</b>	16136.00	-36264.00
<b>NET CHANGES by Change Order</b>		<b>-20128.00</b>

The Contractor certified that the work covered by this pay request has been completed in accordance with the Contract Documents and that all progress payments previously paid by GPS have been applied by the Contract to discharge in full all of Contractor's obligations incurred in connection with the work covered by all prior pay requests.

Contractor Chad J. Feldkamp 10/31/2008

Based upon on-site observations, the State of Ohio  
the point indicated on the pay request.



Brett Meyer

Architect [Signature] 10/28/08

Construction Manager [Signature] 10/27/08

Approved:

School District \_\_\_\_\_ Date \_\_\_\_\_

ITEM NUMBER	DESCRIPTION OF WORK	SCHEDULED VALUE	WORK COMPLETED		MATERIALS PRESENTLY STORED	TOTAL COMPLETED & STORED TO DATE	%	BALANCE TO FINISH	RETAINAGE
			PREVIOUS AP'S.	THIS PERIOD					
1	SHEETMETAL								
2	L Coordination Drawings	LABOR 50,000.00	50,000.00	0.00	0.00	50,000.00	100.00%	0.00	0.00
3	M COORDINATION DRAWINGS	MATERIAL 2,000.00	2,000.00	0.00	0.00	2,000.00	100.00%	0.00	0.00
4	M MOBILIZATION	LABOR 2,000.00	2,000.00	0.00	0.00	2,000.00	100.00%	0.00	0.00
5	M MOBILIZATION	MATERIAL 2,000.00	2,000.00	0.00	0.00	2,000.00	100.00%	0.00	0.00
6	L VAV Boxes	LABOR 10,000.00	10,000.00	0.00	0.00	10,000.00	100.00%	0.00	0.00
7	M VAV Boxes	MATERIAL 20,000.00	20,000.00	0.00	0.00	20,000.00	100.00%	0.00	0.00
8	L Fans	LABOR 3,000.00	3,000.00	0.00	0.00	3,000.00	100.00%	0.00	0.00
9	M Fans	MATERIAL 6,000.00	6,000.00	0.00	0.00	6,000.00	100.00%	0.00	0.00
10	L Double Wall Flue	LABOR 2,500.00	2,500.00	0.00	0.00	2,500.00	100.00%	0.00	0.00
11	M Double Wall Flue	MATERIAL 9,000.00	9,000.00	0.00	0.00	9,000.00	100.00%	0.00	0.00
12	L Ductwork	LABOR 141,750.00	141,750.00	0.00	0.00	141,750.00	100.00%	0.00	0.00
13	M Ductwork	MATERIAL 141,750.00	141,750.00	0.00	0.00	141,750.00	100.00%	0.00	0.00
14	BOND	LABOR 15,000.00	15,000.00	0.00	0.00	15,000.00	100.00%	0.00	0.00
15	SUBMITTALS	LABOR 5,000.00	5,000.00	0.00	0.00	5,000.00	100.00%	0.00	0.00
16	MOBILIZATION	LABOR 5,000.00	5,000.00	0.00	0.00	5,000.00	100.00%	0.00	0.00
17	CLEAN-UP	LABOR 3,500.00	3,500.00	0.00	0.00	3,500.00	100.00%	0.00	0.00
18	PUNCHLIST	LABOR 3,000.00	3,000.00	0.00	0.00	3,000.00	100.00%	0.00	0.00
19	ALLOWANCE	LABOR 10,000.00	10,000.00	0.00	0.00	10,000.00	100.00%	0.00	0.00
20	M HVAC Equipment	MATERIAL 310,000.00	310,000.00	0.00	0.00	310,000.00	100.00%	0.00	0.00
21	L HVAC Equipment	LABOR 28,200.00	28,200.00	0.00	0.00	28,200.00	100.00%	0.00	0.00
22	M Hydronic Equipment	MATERIAL 20,000.00	20,000.00	0.00	0.00	20,000.00	100.00%	0.00	0.00
23	L Hydronic Equipment	LABOR 5,500.00	5,500.00	0.00	0.00	5,500.00	100.00%	0.00	0.00
24	M Boilers	MATERIAL 40,000.00	40,000.00	0.00	0.00	40,000.00	100.00%	0.00	0.00
25	L Boilers	LABOR 8,000.00	8,000.00	0.00	0.00	8,000.00	100.00%	0.00	0.00
26	M HW/CW Piping	MATERIAL 94,000.00	94,000.00	0.00	0.00	94,000.00	100.00%	0.00	0.00
27	L HW/CW Piping	LABOR 175,000.00	175,000.00	0.00	0.00	175,000.00	100.00%	0.00	0.00
28	SUBCONTRACTORS								
29	M Insulation	MATERIAL 75,000.00	75,000.00	0.00	0.00	75,000.00	100.00%	0.00	0.00
30	L Insulation	LABOR 120,000.00	120,000.00	0.00	0.00	120,000.00	100.00%	0.00	0.00
31	M Temp Controls	MATERIAL 40,000.00	40,000.00	0.00	0.00	40,000.00	100.00%	0.00	0.00
32	L Temp Controls	LABOR 80,000.00	80,000.00	0.00	0.00	80,000.00	100.00%	0.00	0.00
33	L Engineering	LABOR 20,000.00	20,000.00	0.00	0.00	20,000.00	100.00%	0.00	0.00
34	L Air/Water Balance	LABOR 12,800.00	12,800.00	0.00	0.00	12,800.00	100.00%	0.00	0.00
35	Close-out Documents	LABOR 5,000.00	5,000.00	0.00	0.00	5,000.00	100.00%	0.00	0.00
36	CO#1 Ductwork/Insulation	LABOR (36,264.00)	(36,264.00)	0.00	0.00	(36,264.00)	100.00%	0.00	0.00
37	CO#2 Sound Blanket	LABOR 9,882.00	9,882.00	0.00	0.00	9,882.00	100.00%	0.00	0.00
38	CO#3 Modify Return Air	LABOR 6,254.00	6,254.00	0.00	0.00	6,254.00	100.00%	0.00	0.00
	Total Labor	678,122.00	678,122.00	0.00	0.00	678,122.00	100.00%	0.00	0.00
	Total Material	764,750.00	764,750.00	0.00	0.00	764,750.00	100.00%	0.00	0.00
		1,442,872.00	1,432,980.00	0.00	0.00	1,442,872.00	100.00%	0.00	0.00

Fairview Elementary

HVAC

**The Ohio School Facilities Commission**  
 10 West Broad Street  
 Suite 1400  
 Columbus, Ohio 43215

Contractor's Name: Feldkamp Enterprises, Inc.  
 Address: 3642 Muddy Creek Road, Cincinnati, Ohio 45238

**Contractor Pay Application Summary**

Project Name: Fairview Elementary  
 Bid Package No.:

1	Original Contract Amount	\$	1,463,000.00
2	Net Changes to Date	\$	-20,128.00
3	Current Contract Amount	\$	1,442,872.00
4	Labor Completed to Date	\$	678,122.00
5	Material Completed to Date	\$	764,750.00
6	Total Work Completed to Date	\$	1,442,872.00
7	Store Material to Date	\$	0.00
8	Less Retained to Date	\$	0.00
9	Total Amount Due	\$	1,442,872.00
10	Less Previous Payments	\$	1,412,550.80
11	Less Amount Retained to Cover Lien	\$	0.00
12	Less Amount Retained for Liquidated Damages	\$	0.00
13	Less Other Amounts Withheld	\$	0.00
14	Current Due	\$	30,321.20
15	Balance to Complete	\$	0.00

**The Ohio School Facilities Commission approval required for the following contract adjustments:**

1. Assessment of liquidated damages
2. Other amounts withheld

The Ohio School Facilities Commission	Date
Comments:	



## Performance Data

**Table 9. AHRI and Part Load Performance - 60 Hz - I-P units**

Standard efficiency				High efficiency			
Unit Size	Full Load Tons	Full Load EER	IPLV	Unit Size	Full Load Tons	Full Load EER	IPLV
<b>140</b>	138.3	9.7	<b>13.6</b>	<b>140</b>	142.0	10.2	<b>13.8</b>
<b>155</b>	151.8	9.8	<b>14.0</b>	<b>155</b>	157.3	10.4	<b>14.5</b>
<b>170</b>	166.1	9.9	<b>14.0</b>	<b>170</b>	171.3	10.5	<b>14.5</b>
<b>185</b>	182.0	9.8	<b>13.9</b>	<b>185</b>	188.1	10.4	<b>14.3</b>
<b>200</b>	198.9	9.7	<b>13.6</b>	<b>200</b>	206.1	10.3	<b>14.0</b>
<b>225</b>	218.6	9.7	<b>13.9</b>	<b>225</b>	223.1	10.1	<b>14.1</b>
<b>250</b>	240.0	9.7	<b>13.7</b>	<b>250</b>	246.3	10.2	<b>14.0</b>
<b>275</b>	266.2	9.8	<b>14.6</b>	<b>275</b>	275.5	10.5	<b>14.8</b>
<b>300</b>	298.9	9.7	<b>14.2</b>	<b>300</b>	308.8	10.3	<b>14.4</b>
<b>350</b>	340.0	9.6	<b>14.3</b>	<b>350</b>	346.5	10.5	<b>15.4</b>
<b>400</b>	401.2	9.7	<b>14.7</b>	<b>400</b>	415.6	10.2	<b>14.7</b>
<b>450</b>	441.8	9.6	<b>15.0</b>				
<b>500</b>	483.9	9.6	<b>15.0</b>				

1. IPLV values are rated in accordance with AHRI Standard 550/590.
2. EER and IPLV values include compressors, condenser fans, and control kW.

**Table 10. AHRI and Part Load Performance - 50 Hz - I-P units**

Standard Efficiency				High Efficiency			
Unit Size	Full Load Tons	Full Load EER	IPLV	Unit Size	Full Load Tons	Full Load EER	IPLV
<b>140</b>	133.7	9.4	<b>14.4</b>	<b>120</b>	114.4	10.0	<b>14.8</b>
<b>155</b>	146.3	9.3	<b>14.4</b>	<b>130</b>	127.1	10.2	<b>15.2</b>
<b>170</b>	159.6	9.3	<b>14.1</b>	<b>140</b>	140.6	10.3	<b>15.1</b>
<b>185</b>	175.9	9.4	<b>14.5</b>	<b>155</b>	152.9	10.2	<b>15.1</b>
<b>200</b>	193.4	9.5	<b>14.2</b>	<b>170</b>	166.0	10.1	<b>14.8</b>
<b>250</b>	230.1	9.4	<b>16.1</b>	<b>185</b>	183.4	10.2	<b>15.2</b>
<b>275</b>	256.8	9.3	<b>15.7</b>	<b>200</b>	201.8	10.3	<b>14.9</b>
<b>300</b>	290.7	9.4	<b>15.7</b>	<b>250</b>	238.6	10.0	<b>16.0</b>
<b>350</b>	322.7	9.3	<b>16.2</b>	<b>275</b>	267.9	10.1	<b>16.1</b>
<b>375</b>	356.7	9.4	<b>16.4</b>	<b>300</b>	302.5	10.2	<b>16.2</b>
<b>400</b>	390.1	9.4	<b>16.4</b>	<b>350</b>	335.7	10.0	<b>16.4</b>
				<b>375</b>	370.9	10.1	<b>16.6</b>
				<b>400</b>	406.9	10.2	<b>16.6</b>

1. IPLV values are rated in accordance with AHRI Standard 550/590.
2. EER and IPLV values include compressors, condenser fans, and control kW.

# ***SUBMITTAL DATA***

Project: Fairview Elementary School  
Project / P.O.# 1219  
Specification Section: 15855  
Architect/Engineer: Glaserworks  
Submittal For: Air Handling Units  
Manufacturer: Trane  
Supplier: Trane  
Contact Name & Phone #: Stephanie Myers: (513) 771-8884

Comments:

**Mollie Lane**

**1/29/2007**

**RECEIVED BY**

FELDKAMP ENTERPRISES, INC.

- APPROVED
- APPROVED AS NOTED
- NOT APPROVED
- RESUBMIT
- REVISION NOTED

SPEC SECTION \_\_\_\_\_ 15855



# Record Submittal

Trane  
A Division of American Standard Inc.

**Prepared For:**  
Feldkamp Enterprises Inc

**Date:** January 23, 2007

**Sold To:**  
Feldkamp Enterprises Inc  
3642 Muddy Creek  
CINCINNATI, OH 45238

**Job Name:**  
Fairview Elementary School

Trane is pleased to provide the enclosed submittal for your review and approval.

## Product Summary

Qty	Product	Tag:
3	Indoor Central Station Air Handler Units	AHU-1, AHU-2 & AHU-3

Reference: Section 15682

## Submittal Notes:

Supply and Return Fan Motors are inverter balanced. The VFD's are to be field installed.

### AHU-1

- Provided 56KW Electric Heat Output per Specs.
- Added a Small Access Module downstream of the Electric Heat Module
- Changed Access Module upstream from Electric Heat Module from Medium to Small Size Module
- Changed Electric Heat Module to 11,788 CFM per Specs.
- Changed Energy Wheel to 12500 Nominal CFM
- Please Note: Unit Length is now 314.50

### AHU-2

- Changed Cooling Coil to 130 Fin Spacing per Specs.
- Added a Small Access Module downstream of the Electric Heat Module
- Changed Access Module upstream from Electric Heat Module from Extended Medium to Small Size Module
- Please Note: Unit Length is now 364.50

### AHU-3

- Changed Heating Coil to 2 Row coil which corrected the MBH to 1042 MBH & 66.83 GPM
- Changed Supply Fan Motor External Static Pressure to 4.25 per Specs.
- Added a Small Access Module downstream of the Electric Heat Module
- Changed Access Module upstream from Electric Heat Module from Extended Medium to Small Size Module
- Please Note: Unit Length is now 364.50

The attached information describes the equipment we propose to furnish for this project, and is submitted for your approval.

## Stephanie Myers

Trane  
10300 Springfield Pike  
Cincinnati, OH 45215  
Phone: (513) 771-8884  
Fax: (513) 772-7281

## Performance Data - Indoor Central Station Air Handler Units

Tags	AHU-2			AHU-3		
<b>Unit level selections</b>						
Actual airflow (cfm)	23253			23849		
Length (in)	364.500			364.500		
Rigging unit weight (lb)	15909.7			15817.9		
Installed unit weight (lb)	16334.6			16277.9		
<b>Fan module</b>						
<b>Position</b>	<b>#1</b>	<b>#12</b>		<b>#1</b>	<b>#12</b>	
Fan airflow (cfm)	23253	23253		23849	23849	
External static pressure (in H2O)	2.25	4.25		2.25	4.25	
Total static pressure (in H2O)	3.92	7.92		4.02	7.49	
Fan module pressure drop (in H2O)	2.25	4.25		2.25	4.25	
Design temperature (F)	70.00	70.00		70.00	70.00	
Minimum temperature (F)	10.00	10.00		10.00	10.00	
Speed (rpm)	1074	1645		1093	1629	
Brake horsepower (hp)	20.206	39.617		21.333	38.891	
Width (in)	120.000	120.000		120.000	120.000	
Height (in)	75.000	75.000		75.000	75.000	
Weight (lb)	2623.6	3218.5		2623.6	3218.5	
<b>Access/turning module</b>						
<b>Position</b>	<b>#3,#5</b>		<b>#9,#11</b>	<b>#3,#5</b>		<b>#9,#11</b>
Module length (in)	14.500		20.000	14.500		20.000
Module weight (lb)	318.7		392.0	318.7		392.0
Module width (in)	120.000		120.000	120.000		120.000
Module height (in)	75.000		75.000	75.000		75.000
<b>Coil module</b>						
<b>Position</b>	<b>#4</b>	<b>#8</b>	<b>#10</b>	<b>#4</b>	<b>#8</b>	<b>#10</b>
Coil design airflow (cfm)	13449	23253	23253	12862	23849	23849
Total capacity (MBh)	218.56	1013.67	1006.52	208.40	1042.81	943.57
Dry coil weight (lb)	-	272.7	982.5	-	374.9	967.5
Entering dry bulb (F)	0.00	60.89	77.30	0.00	60.98	77.30
Entering wet bulb (F)	-	-	65.50	-	-	65.50
Fluid temperature rise (F)	-	-	14.23	-	-	13.93
Fluid temperature drop (F)	-	32.68	-	-	31.18	-
Sensible capacity (MBh)	-	-	677.34	-	-	656.69
Fluid volume (gal)	-	11.15	39.71	-	15.37	39.71
Leaving dry bulb (F)	15.04	101.08	50.85	15.00	101.30	52.30
Leaving wet bulb (F)	-	-	50.75	-	-	52.20
Entering fluid temperature (F)	-	180.00	44.00	-	180.00	44.00
Leaving fluid temperature (F)	-	147.32	58.23	-	148.82	57.93
Standard fluid flow rate (gpm)	-	62.00	141.00	-	66.83	135.00
Fluid pressure drop (ft H2O)	-	1.75	10.36	-	0.86	4.07
Air pressure drop (in H2O)	0.04	0.12	0.84	0.03	0.12	0.99
Face velocity (ft/min)	-	470	470	-	500	483
Face area (sq ft)	48.76	49.43	49.43	48.76	47.69	49.43
Wet coil weight (lb)	-	365.6	1314.5	-	502.9	1299.5
Coil fouling factor (hr-sq ft-deg F/Btu)	-	0.00050	0.00000	-	0.00050	0.00000
Fluid velocity (ft/sec)	-	2.13	2.42	-	1.76	2.32
Coil module pressure drop (in H2O)	0.04	0.12	0.84	0.03	0.12	0.99
Fluid type	-	Water	Water	-	Water	Water
Module length (in)	48.000	14.500	20.000	48.000	14.500	20.000
Module weight (lb)	1611.6	701.5	1725.8	1611.6	838.8	1710.8
Amp draw (A)	77.07	-	-	73.49	-	-
Module width (in)	120.000	120.000	120.000	120.000	120.000	120.000
Module height (in)	75.000	75.000	75.000	75.000	75.000	75.000

Tags	AHU-2		AHU-3			
Low limit interlock wiring	No LLT wired to starter,vfd					
<b>Energy recovery module</b>						
<b>Position</b>	<b>#6</b>			<b>#6</b>		
Leaving supply airflow (cfm)	23253			23849		
Min ventilation airflow (cfm)	13449			12862		
Exhaust airflow (cfm)	13449			12862		
Re-circulating damper airflow (cfm)	9448			10654		
OACF (%)	101.00			100.92		
EATR (%)	2.58			2.52		
OATR airflow (cfm)	495			455		
EATR airflow (cfm)	356			333		
Supply air wheel PD (in H2O)	1.04			1.13		
Supply air wheel PD - economizing (in H2O)	0.53			0.58		
Exhaust air wheel PD (in H2O)	1.03			1.12		
Exhaust air wheel PD - economizing (in H2O)	0.53			0.58		
Max supply level module PD (in H2O)	1.04			1.13		
Max exhaust level module PD (in H2O)	1.67			1.77		
Re-circulating damper area (sq ft)	10.77			10.77		
Re-circulating damper PD (in H2O)	0.17			0.21		
Exhaust air bypass damper area (sq ft)	7.29			6.32		
Exhaust air bypass damper PD (in H2O)	0.53			0.66		
Outside air bypass damper area (sq ft)	7.29			6.32		
Outside air bypass damper PD (in H2O)	0.53			0.66		
Outside air ESP (in H2O)	1.00			1.00		
Return air ESP (in H2O)	1.00			1.00		
Total eff -winter (%)	72.62			71.05		
Sensible eff -winter (%)	73.30			71.66		
Latent eff -winter (%)	71.88			70.45		
Total eff -summer (%)	72.63			71.11		
Sensible eff -summer (%)	73.30			71.66		
Latent eff -summer (%)	71.88			70.45		
Winter return EDB (F)	70.00			70.00		
Winter return EWB (F)	58.00			58.00		
Winter outside EDB (F)	11.00			11.00		
Winter outside EWB (F)	-2.00			-2.00		
Winter ventilation DB (F)	54.24			53.28		
Winter ventilation WB (F)	47.67			47.01		
Winter ventilation RH (%)	61.71			62.75		
Winter supply LDB (F)	60.89			60.98		
Winter supply LWB (F)	52.27			52.36		
Winter supply RH (%)	56.06			56.08		
Winter exhaust LDB (F)	29.07			29.83		
Winter exhaust LWB (F)	27.10			27.77		
Summer return EDB (F)	75.00			75.00		
Summer return EWB (F)	63.50			63.50		
Summer outside EDB (F)	92.00			92.00		
Summer outside EWB (F)	74.00			74.00		
Summer ventilation DB (F)	79.75			80.01		
Summer ventilation WB (F)	66.76			66.91		
Summer ventilation RH (%)	50.97			50.78		
Summer supply LDB (F)	77.75			77.70		
Summer supply LWB (F)	65.41			65.37		
Summer supply RH (%)	52.02			52.01		
Summer exhaust LDB (F)	87.46			87.18		
Summer exhaust LWB (F)	71.35			71.20		

Tags	AHU-2		AHU-3	
Filter pressure drop (in H2O)	0.64		0.65	
Total energy saved -summer (MBh)	386.08		361.39	
Latent energy saved -summer (MBh)	204.51		191.66	
Sensible energy saved -summer (MBh)	187.90		175.65	
Humidity recovered -winter (lb/hr)	351.22		329.81	
Sensible energy saved -winter (MBh)	663.29		619.29	
Width (in)	120.000		120.000	
Height (in)	150.000		150.000	
Length (in)	67.000		67.000	
Weight (lb)	2734.0		2555.0	
<b>Filter module</b>				
<b>Position</b>	<b>#7</b>		<b>#7</b>	
Filter airflow (cfm)	23253		23849	
Filter area (sq ft)	51.60		51.60	
Filter pressure drop (in H2O)	0.77		0.34	
Filter module pressure drop (in H2O)	0.77		0.34	
Module length (in)	29.500		29.500	
Module weight (lb)	976.2		976.2	
Module width (in)	120.000		120.000	
Module height (in)	75.000		75.000	
<b>Air mixing module</b>				
<b>Position</b>	<b>#2</b>		<b>#2</b>	
Back opening airflow (cfm)	23255		12862	
Back entry pressure drop (in H2O)	0.22		0.07	
Front opening airflow (cfm)	23255		12862	
Filter airflow (cfm)	23255		12862	
Filter pressure drop (in H2O)	0.64		0.56	
Total filter pressure drop (in H2O)	0.64		0.56	
Module total pressure drop (in H2O)	0.86		0.63	
Module length (in)	48.000		48.000	
Module weight (lb)	1322.1		1322.1	
Module width (in)	120.000		120.000	
Module height (in)	75.000		75.000	

Tags	AHU-1		
<b>Unit level selections</b>			
Actual airflow (cfm)	14096		
Length (in)	314.500		
Rigging unit weight (lb)	9199.7		
Installed unit weight (lb)	9393.0		
<b>Fan module</b>			
<b>Position</b>	<b>#1</b>	<b>#12</b>	
Fan airflow (cfm)	14096	14096	
External static pressure (in H2O)	1.75	2.25	
Total static pressure (in H2O)	3.43	5.93	
Fan module pressure drop (in H2O)	1.75	2.25	
Design temperature (F)	70.00	70.00	
Minimum temperature (F)	10.00	10.00	
Speed (rpm)	1332	1931	
Brake horsepower (hp)	12.237	20.765	
Width (in)	91.000	91.000	
Height (in)	56.500	56.500	
Weight (lb)	1315.5	1655.5	

Tags	AHU-1		
<b>Access/turning module</b>			
Position	#3,#5		#9,#11
Module length (in)	11.000		15.500
Module weight (lb)	190.7		239.3
Module width (in)	91.000		91.000
Module height (in)	56.500		56.500
<b>Coil module</b>			
Position	#4	#8	#10
Coil design airflow (cfm)	11788	14096	14096
Total capacity (MBh)	192.00	639.02	534.65
Dry coil weight (lb)	-	139.1	460.4
Entering dry bulb (F)	0.00	56.84	76.40
Entering wet bulb (F)	-	-	64.90
Fluid temperature rise (F)	-	-	14.02
Fluid temperature drop (F)	-	27.76	-
Sensible capacity (MBh)	-	-	374.81
Fluid volume (gal)	-	4.33	18.81
Leaving dry bulb (F)	15.08	98.64	52.25
Leaving wet bulb (F)	-	-	52.04
Entering fluid temperature (F)	-	180.00	44.00
Leaving fluid temperature (F)	-	152.24	58.02
Standard fluid flow rate (gpm)	-	46.00	76.00
Fluid pressure drop (ft H2O)	-	4.59	18.77
Air pressure drop (in H2O)	0.11	0.15	0.68
Face velocity (ft/min)	-	522	486
Face area (sq ft)	24.96	27.00	29.01
Wet coil weight (lb)	-	175.1	617.7
Coil fouling factor (hr-sq ft-deg F/Btu)	-	0.00050	0.00000
Fluid velocity (ft/sec)	-	3.18	3.26
Coil module pressure drop (in H2O)	0.11	0.15	0.68
Fluid type	-	Water	Water
Module length (in)	40.000	11.000	15.500
Module weight (lb)	984.0	378.2	871.9
Amp draw (A)	67.71	-	-
Module width (in)	91.000	91.000	91.000
Module height (in)	56.500	56.500	56.500
Low limit interlock wiring	No LLT wired to starter,vfd	No LLT wired to starter,vfd	No LLT wired to starter,vfd
<b>Energy recovery module</b>			
Position	#6		
Leaving supply airflow (cfm)	14096		
Min ventilation airflow (cfm)	11788		
Exhaust airflow (cfm)	11788		
Re-circulating damper airflow (cfm)	2019		
OACF (%)	101.44		
EATR (%)	2.39		
OATR airflow (cfm)	463		
EATR airflow (cfm)	289		
Supply air wheel PD (in H2O)	1.04		
Supply air wheel PD - economizing (in H2O)	0.67		
Exhaust air wheel PD (in H2O)	1.02		
Exhaust air wheel PD - economizing (in H2O)	0.67		
Max supply level module PD (in H2O)	1.04		
Max exhaust level module PD (in H2O)	1.68		
Re-circulating damper area (sq ft)	8.05		
Re-circulating damper PD (in H2O)	0.01		

Tags	AHU-1		
Exhaust air bypass damper area (sq ft)	6.32		
Exhaust air bypass damper PD (in H2O)	0.55		
Outside air bypass damper area (sq ft)	6.32		
Outside air bypass damper PD (in H2O)	0.55		
Outside air ESP (in H2O)	1.00		
Return air ESP (in H2O)	1.00		
Total eff -winter (%)	72.65		
Sensible eff -winter (%)	73.32		
Latent eff -winter (%)	71.90		
Total eff -summer (%)	72.65		
Sensible eff -summer (%)	73.32		
Latent eff -summer (%)	71.90		
Winter return EDB (F)	70.00		
Winter return EWB (F)	58.00		
Winter outside EDB (F)	11.00		
Winter outside EWB (F)	-2.00		
Winter ventilation DB (F)	54.26		
Winter ventilation WB (F)	47.67		
Winter ventilation RH (%)	61.70		
Winter supply LDB (F)	56.84		
Winter supply LWB (F)	49.51		
Winter supply RH (%)	59.54		
Winter exhaust LDB (F)	29.06		
Winter exhaust LWB (F)	27.09		
Summer return EDB (F)	75.00		
Summer return EWB (F)	63.50		
Summer outside EDB (F)	92.00		
Summer outside EWB (F)	74.00		
Summer ventilation DB (F)	79.75		
Summer ventilation WB (F)	66.76		
Summer ventilation RH (%)	50.97		
Summer supply LDB (F)	78.97		
Summer supply LWB (F)	66.24		
Summer supply RH (%)	51.39		
Summer exhaust LDB (F)	87.46		
Summer exhaust LWB (F)	71.35		
Filter pressure drop (in H2O)	0.65		
Total energy saved -summer (MBh)	339.31		
Latent energy saved -summer (MBh)	179.73		
Sensible energy saved -summer (MBh)	165.14		
Humidity recovered -winter (lb/hr)	308.66		
Sensible energy saved -winter (MBh)	582.95		
Width (in)	91.000		
Height (in)	113.000		
Length (in)	57.500		
Weight (lb)	1830.0		
<b>Filter module</b>			
<b>Position</b>	<b>#7</b>		
Filter airflow (cfm)	14096		
Filter area (sq ft)	28.00		
Filter pressure drop (in H2O)	0.80		
Filter module pressure drop (in H2O)	0.80		
Module length (in)	24.500		
Module weight (lb)	568.7		
Module width (in)	91.000		
Module height (in)	56.500		

<b>Tags</b>	AHU-1		
<b>Air mixing module</b>			
<b>Position</b>	#2		
Back opening airflow (cfm)	14096		
Back entry pressure drop (in H2O)	0.25		
Front opening airflow (cfm)	14096		
Filter airflow (cfm)	14096		
Filter pressure drop (in H2O)	0.65		
Total filter pressure drop (in H2O)	0.65		
Module total pressure drop (in H2O)	0.91		
Module length (in)	56.500		
Module weight (lb)	929.1		
Module width (in)	91.000		
Module height (in)	56.500		

**Kilgour School**  
**Supporting Documentation**

# Ohio Mercantile Self Direct Program

## Application Guide & Cover Sheet

Questions? Call 1-866-380-9580 or visit [www.duke-energy.com](http://www.duke-energy.com).

Email this form along with completed Mercantile Self Direct Prescriptive or Custom applications, proof of payment, energy savings calculations and spec sheets to [SelfDirect@Duke-Energy.com](mailto:SelfDirect@Duke-Energy.com). You may also fax to 1-513-419-5572.

Mercantile customers, defined as using at least 700,000 kWh annually are eligible for the Mercantile Self Direct program. Please indicate mercantile qualification:

- a single Duke Energy Ohio account
- multiple accounts in Ohio (energy usage with other utilities may be counted toward the total)

Please list Duke Energy account numbers below (attach listing of multiple accounts an/or billing history for other utilities as required):

Account Number	Annual Usage	Account Number	Annual Usage
2730-3614-01			

Self Direct rebates are available for completed Custom projects that have not previously received a Duke Energy Smart \$aver® Custom Incentive. Self Direct incentives are applicable to Prescriptive measures that were installed more than 90 days prior to submission to Duke Energy and have not previously received a Duke Energy Prescriptive rebate.

Self Direct Program requirements dictate that certain projects that may be Prescriptive in nature under the Smart \$aver program must be evaluated using the Custom process. Use the table on page two as a guide to determine which Self Direct program fits your project(s). Apply for Self Direct projects using the appropriate application forms in conjunction with this cover sheet. Where Mercantile Self Direct Prescriptive applications are listed, please refer to the measure list on that application. If your measure is not listed, you may be eligible for a Self Direct Custom rebate. Self Direct Custom applications, like Smart \$aver Custom applications, should include detailed analysis of pre-project and post-project energy usage and project costs. Please indicate which type of rebate applications are included in the table provided on page two.

Please check each box to indicate completion of the following program requirements:

<input type="checkbox"/> All sections of appropriate application(s) are completed	<input type="checkbox"/> Proof of payment.*	<input type="checkbox"/> Manufacturer's Spec sheets	<input type="checkbox"/> Energy model/calculations and detailed inputs for Custom applications
---	---	---	--

\* If a single payment record is intended to demonstrate the costs of both Prescriptive & Custom projects, please include an additional document with an estimated breakout of costs for each Prescriptive and Custom energy conservation measure.

Application Type	Replaced equipment at end of lifetime or because equipment failed**	Replaced fully operational equipment to improve efficiency***	New Construction
Lighting	MSD Custom Part 1 <input type="checkbox"/> Custom Lighting Worksheet <input type="checkbox"/>	MSD Prescriptive Lighting <input type="checkbox"/>	MSD Prescriptive Lighting <input type="checkbox"/>
		MSD Custom Part 1 <input type="checkbox"/> Custom Lighting Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input checked="" type="checkbox"/> Custom Lighting Worksheet <input type="checkbox"/>
Heating & Cooling	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Heating & Cooling <input type="checkbox"/>
			MSD Custom Part 1 <input checked="" type="checkbox"/> MSD Custom General Worksheet <input checked="" type="checkbox"/>
Window Films, Programmable Thermostats, & Guest Room Energy Management Systems	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General and/or EMS Worksheet(s) <input type="checkbox"/>	MSD Prescriptive Heating & Cooling <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General and/or EMS Worksheet(s) <input type="checkbox"/>
Chillers & Thermal Storage	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Chillers & Thermal Storage <input type="checkbox"/>
			MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>
Motors & Pumps	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Motors, Pumps & Drives <input type="checkbox"/>
			MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>
VFDs	Not Applicable	MSD Prescriptive Motors, Pumps & Drives <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom VFD Worksheet <input type="checkbox"/>
		MSD Custom Part 1 <input type="checkbox"/> MSD Custom VFD Worksheet <input type="checkbox"/>	
Food Service	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Food Service <input type="checkbox"/>
			MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>
Process	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	MSD Prescriptive Process <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>
		MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>	
Energy Management Systems	MSD Custom Part 1 <input type="checkbox"/> MSD Custom EMS Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom EMS Worksheet <input type="checkbox"/>	MSD Custom Part 1 <input type="checkbox"/> MSD Custom EMS Worksheet <input type="checkbox"/>
Behavioral*** & No/Low Cost	MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/>		

\*\* Under the Self Direct program, failed equipment and equipment at the end of its useful life are evaluated differently than early replacement of fully functioning equipment. **All equipment replacements due to failure or old age will be evaluated via the Custom program.**

\*\*\* Please ensure that you include the age of the replaced equipment for measures classified as "Early Replacement" in your application as well as the estimated date that you would have otherwise replaced the existing equipment if you had not chosen a more energy efficient option.

\*\*\*\* Behavioral energy efficiency and demand reduction projects must be both measurable and verifiable. Provide justification with your application.

# Mercantile Self Direct Nonresidential Custom Rebate Application PART 1



Proposed energy efficiency measures may be eligible for Self-Direct Custom rebates if they clearly reduce electrical consumption and/or demand as compared to the appropriate baseline.

Before you complete this application, please note the following important criteria:

- Submitting this application does not guarantee a rebate will be approved.
- Rebates are based on electricity conservation only.
- Electric demand and/or energy reductions must be well documented with auditable calculations.
- Incomplete applications cannot be reviewed; all fields are required.

Refer to the complete list of Instructions and Disclaimers, beginning on page 6.

## Notes on the Application Process

If you have any questions concerning how to complete any portion of the application or what supplementary information is required, please contact your Duke Energy Ohio, Inc account manager or the Duke Energy Smart \$aver® team at 1-866-380-9580.

Every application must include calculations of the baseline electrical usage and the electrical usage of the proposed high-efficiency equipment/system. Monthly calculations are best. You, the Duke Energy Ohio customer, or your equipment vendor / engineer should perform these calculations and submit them to Duke Energy for review. *We strongly encourage the use of modeling software (such as eQuest or comparable) for complex projects.*

Upon receipt of your application, an acknowledgement email will be sent to you with an estimated response time based on an initial assessment of your application. The application review may include some communication to resolve any questions about the project or to request additional information. Applications that are received complete without missing information have a faster review time.

There are two ways to submit your completed application.

Email your scanned form to: [SelfDirect@duke-energy.com](mailto:SelfDirect@duke-energy.com)

Or, fax your form to 513-419-5572

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



**1. Contact Information (Required)**

Duke Energy Customer Contact Information					
Company Name	Cincinnati Public Schools				
Address	2651 Burnett Ave				
Project Contact	Don Elbe				
City	Cincinnati	State	OH	Zip Code	45219
Title	Utility Management Coordinator				
Office Phone	513-363-0754	Mobile Phone		Fax	
E-mail Address	elbedon@cpsboe.k12.oh.us				

Equipment Vendor / Contractor / Architect / Engineer Contact Information					
Company Name	Plug Smart				
Address	1275 Kinnear Road Suite 229				
City	Columbus	State	OH	Zip Code	43212
Project Contact	Lucas Dixon				
Title	Operations Manager				
Office Phone	614-580-3352	Mobile Phone		Fax	1-800-518-5576
E-mail Address	lucas.dixon@plugsmart.com				
Describe Role	Ensures rebate is correctly applied for				

Payment Information					
Payee Legal Company Name (as shown on Federal income tax return):	Cincinnati Public Schools				
Mailing Address	2651 Burnett Ave				
City	Cincinnati	State	OH	Zip Code	45219
Type of organization (check one) <input type="checkbox"/> Individual/Sole Proprietor <input type="checkbox"/> Corporation <input type="checkbox"/> Partnership <input checked="" type="checkbox"/> Unit of Government <input type="checkbox"/> Non-Profit (non-corporation)					
Payee Federal Tax ID # of Legal Company Name Above:	31-6000758				
Who should receive incentive payment? (select one) <input checked="" type="checkbox"/> Customer <input type="checkbox"/> Vendor (Customer must sign below)					
If the vendor is to receive payment, please sign below: I hereby authorize payment of incentive directly to vendor:					
Customer Signature _____ Date ____/____/____ (mm/dd/yyyy)					

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



**2. Project Information (Required)**

- A. Please indicate project type:
- New Construction
  - Expansion at an existing facility
  - Replacing equipment due to equipment failure
  - Replacing equipment that is estimated to have remaining useful life of 2 years or less
  - Replacing equipment that is estimated to have remaining useful life of more than 2 years
  - Behavioral, operational and/or procedural programs/projects
- B. Please describe your project, or attach a detailed project description that describes the project.  
New elementary school in the CPS district
- C. When did you start and complete implementation?  
Start date / (mm/yyyy) End date 08/2008 (mm/yyyy)
- D. Are you also applying for Self-Direct Prescriptive incentives and, if so, which one(s)<sup>1</sup>?
- E. Please indicate which worksheet(s) you are submitting for this application (check all that apply):
- Lighting
  - Variable Frequency Drive (VFD)
  - Compressed Air
  - Energy Management System (EMS)
  - General (for projects not easily submitted using one of the above worksheets)
- F. Please tell us if there is anything about your electrical energy projections (either for the baseline or the proposed project) that you are either unsure about or for which you have made significant assumptions. Attach additional sheets as needed.

Required: Attach a supplier or contractor invoice or other equivalent information documenting the Implementation Cost for each project listed in your application. (Note: self-install costs cannot be included in the Implementation Cost)

---

<sup>1</sup> If your project involves some equipment that is eligible for prescriptive incentives and some equipment that is likely eligible for custom incentives, and if it is feasible to separate the equipment for the energy analysis, then the equipment will be evaluated separately. If it is not feasible to separate the equipment for analysis, then the equipment will be evaluated together in the custom application.

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



**3. Signature** (Required – must be signed by Duke Energy customer)

**Customer Consent to Release of Personal Information**

I, (insert name) Don Elbe, do hereby consent to Duke Energy disclosing my Duke Energy Ohio, Inc Account Number and Federal Tax ID Number to its subcontractors solely for the purpose of administering Duke Energy Ohio's Mercantile Self-Direct Program. I understand that such subcontractors are contractually bound to otherwise maintain my Duke Energy Ohio, Inc Account Number and Federal Tax ID Number in the strictest of confidence.

I realize that under the rules and regulations of the public utilities commission, I may refuse to allow Duke Energy Ohio, Inc to release the information set forth above. By my signature, I freely give Duke Energy Ohio, Inc permission to release the information designated above.

**Application Signature**

I certify that I meet the eligibility requirements of the Duke Energy Ohio, Inc Mercantile Self Direct Custom Incentives Program and that all information provided within this application is correct to the best of my knowledge. I agree to the terms and conditions set forth for this program. I certify that the numbers, energy savings, and responses shown on this form are correct. Further, I certify that the taxpayer identification number is current and correct. I am not subject to backup withholding because: (a) I am exempt from backup withholding; or (b) I have not been notified by the IRS that I am subject to backup withholding as a result of a failure to report all interest or dividends; or (c) the IRS has notified me that I am no longer subject to backup withholding. I am a U.S. citizen (includes a U.S. resident alien).

\_\_\_\_\_  
Duke Energy Ohio, Inc Customer Signature

Print Name Don Elbe

Date 12/30/2011

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



**Checklist for completing the Application**

INCOMPLETE APPLICATIONS WILL RESULT IN DELAYS IN DUKE ENERGY PROCESSING YOUR APPLICATION AND NOTIFYING YOU CONCERNING ANY REBATES. Before submitting the application and the required supplementary information, use the following checklist to ensure that your application is complete and the information in the application is accurate. (Note: this checklist is for your use only – do not submit this checklist with your application)

Section No. & Title	Have You:
1. Contact Information	<input type="checkbox"/> Completed the contact information for the Duke Energy customer? <input type="checkbox"/> Completed the contact information for the equipment vendor / project engineer that can answer questions about the technical aspects of the project, if that is a different person than above?
2. Project Information	<input type="checkbox"/> Answered the questions A-E, including providing a description of your project. <input type="checkbox"/> Completed and attached the lighting, compressed air, VFD, EMS and/or General worksheet(s)?
3. Signature	<input type="checkbox"/> Signed your name? <input type="checkbox"/> Printed your name? <input type="checkbox"/> Entered the date?
Supplementary information (Required)	<input type="checkbox"/> Attached a supplier or contractor's invoice or other equivalent information documenting the Implementation Cost for projects listed in your application? (Note: self-install costs cannot be included in the Implementation Cost) <input type="checkbox"/> (If submitting the General Worksheet) attached calculations documenting the energy usage and energy savings for <b>each</b> project listed in your application?

If you have any questions concerning how to complete any portion of the application or what supplementary information is required, please contact:

- your Duke Energy account manager
- or,
- the Duke Energy Smart \$aver® team at 1-866-380-9580.

# Mercantile Self Direct Nonresidential Custom Rebate Application PART 1



## Instructions/Terms/Conditions

Note: Please keep for your records- do not submit with the application

1. Energy service companies or contractors may assist in preparing the application, but an authorized representative of the customer must sign this application to be eligible to participate in the Mercantile Self Direct Program. Completion of this application does not guarantee the approval of a Self Direct Custom Rebate.
2. Once all documentation requested in this application is received by *Duke Energy Ohio, Inc*, and any follow-up information requested by *Duke Energy* is received, the rebate amount for each Energy Conservation Measure (ECM) will be communicated to the customer. The rebate amount will be based on ECM energy savings and ECM incremental installation cost.
3. All rebates require approval by the Public Utilities Commission of Ohio. *Duke Energy Ohio, Inc* will submit an application for rebate on the customer's behalf upon customer attestation to program terms, conditions and requirements as outlined in the rebate offer letter and upon customer completion of attestation documents required by the Public Utilities Commission of Ohio.
4. *Duke Energy Ohio, Inc* will issue a Self Direct Custom Rebate check, based on the approved rebate amount for each ECM, upon receiving approval from the Public Utilities Commission of Ohio. *Duke Energy Ohio, Inc* does not guarantee PUCO approval.
5. With the application, the customer must provide a list of all sites where the ECMs were installed. *Duke Energy Ohio, Inc* requests that sites of similar size, hours of operation and energy consuming characteristics be grouped together in one application for the determination of the rebate amount. The application should identify the site where each unique ECM was installed.
6. Based on the information submitted with the application and the information gathered both before and after the initial installation of the ECM, *Duke Energy Ohio, Inc* will calculate the rebate amount for each ECM.
7. *Duke Energy Ohio, Inc* may conduct random site inspections of a sample of the locations where the ECMs are installed to verify installation and operability of the ECMs and to obtain information needed to calculate the Approved Incentive Amount.
8. Customers are encouraged to retain copies of all forms, invoices and supporting documentation for their records.
9. Approved rebates are valid for 6 months from the date communicated to the customer by *Duke Energy Ohio, Inc*, subject to the expiration of measure eligibility based on project completion dates and application submission deadlines as defined by PUCO. Customers are encouraged to execute their rebate offer contracts and PUCO-required affidavits promptly to ensure eligibility is not forfeited.
10. *Duke Energy Ohio, Inc* reserves the right to recover all unrecoverable costs associated with the project approval if the customer decides not to execute the rebate contract, after the project is approved by *Duke Energy Ohio, Inc*.
11. Projects financially supported by other funding sources will be evaluated on a case-by-case basis for potential partial funding from *Duke Energy Ohio, Inc*.
12. Participants must be *Duke Energy Ohio, Inc* nonresidential, mercantile customers with the project sites in the *Duke Energy Ohio, Inc* service territory.

**Mercantile Self Direct  
Nonresidential Custom Rebate Application  
PART 1**



13. Customers or trade allies may not use any *Duke Energy* logo without prior written permission.
14. Only trade allies registered with *Duke Energy* are eligible to participate.
15. All equipment must be new. Used or rebuilt equipment is not eligible for incentives. All old existing equipment must be removed on retrofit projects.
16. Disclaimers: *Duke Energy Ohio, Inc*
  - a. does not endorse any particular manufacturer, product or system design within the program;
  - b. will not be responsible for any tax liability imposed on the customer as a result of the payment of incentives;
  - c. does not expressly or implicitly warrant the performance of installed equipment. (Contact your contractor for details regarding equipment warranties.);
  - d. is not responsible for the proper disposal/recycling of any waste generated or obsolete or old equipment as a result of this project;
  - e. is not liable for any damage caused by the installation of the equipment nor for any damage caused by the malfunction of the installed equipment; and
  - f. reserves the right to change or discontinue this program at any time. The acceptance of program applications is determined solely by *Duke Energy Ohio, Inc*.



The Lighting Worksheet is part 2 of the application. Do not submit this file without submitting a completed Part1 Custom Application document file, which can be found at [www.duke-energy.com](http://www.duke-energy.com).

Before you complete this application, please note the following important criteria:

- Incentive approval is required PRIOR to equipment purchase, or any other activity which would indicate that the Duke Energy customer has already decided to proceed.
- Submitting this application does not guarantee an incentive will be approved.
- Incentives are based on electricity conservation only.
- Electric demand and/or energy reductions must be well documented with auditable calculations.
- Simple payback without incentive must be greater than 1 year.
- Incomplete applications will not be reviewed; all fields are required.

Refer to the complete list of Instructions and Disclaimers, found in the Custom Application Part 1 document.

Please enter your information and data into the cells that are shaded.  
Cells in white are locked and cannot be written over.

**Duke Energy Customer Contact Information (Match the information in Application Part 1):**

Name	Don Elbe
Company	Cincinnati Public Schools

**Equipment Vendor / Project Engineer Contact Information**

Name	Lucas Dixon
Company	Plug Smart

Before proceeding with the custom application, please verify that your project is not on the prescriptive incentive application.

The prescriptive incentive applications can be found at:

KY <http://www.duke-energy.com/kentucky-business/energy-management/energy-efficiency-incentives.asp>

Kentucky only: custom incentives only available to K-12 school facilities; prescriptive incentives available for those not on rate TT.

OH <http://www.duke-energy.com/ohio-business/energy-management/energy-efficiency-incentives.asp>

NC <http://www.duke-energy.com/north-carolina-business/energy-management/energy-efficiency-incentives.asp>

SC <http://www.duke-energy.com/south-carolina-business/energy-management/energy-efficiency-incentives.asp>

Prescriptive incentives are already pre-approved and the application is submitted after project implementation.

Take note of the equipment eligibility on the prescriptive application before planning to utilize the prescriptive application.



Please enter your information and data into the cells that are shaded.

Cells in white are locked and cannot be written over.

**List of Sites (Required)**

Project/ Site (see note 1)	Site Name	Electric Account Number(s) (see note 2)	Site Address	Area (sq ft)	Location within Facility	Location Type	Indoor or Outdoor?
<i>Example</i>	<i>Distribution Center</i>	<i>12345678 01</i>	<i>Example: 123 Main Street, Anywhere USA 12345</i>	<i>1000</i>	<i>Warehouse</i>	<i>Industrial</i>	<i>Indoor</i>
1	Kilgour	2730-3614-01	1339 Herschel Ave Cincinatti Ohio 45208	67,232	Classroom	K-12	Indoor
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							

If your application involves more than 20 lighting projects, please check here and use multiple worksheets.

**1 Project/Site**

You can write over the default project/site number with a store #, building identifier, or other reference that distinguishes one project/location from another.

**2 Electric Account Number(s)**

If there are multiple meters at a site, only include the Duke Energy account numbers that pertain to the project.

Currently active account number(s) are required for an existing facility. For new construction, write in "new construction."



Project/ Site	Hours of Use (see note 3)								Controls (see note 5)				
	24 x 7	Weekday		Saturday		Sunday		Weeks of Use in Year (see note 4)	Total Annual Hours of Use	Existing		Proposed	Description
		Start Hour	End Hour	Start Hour	End Hour	Start Hour	End Hour			Type of Control	Hours Reduction	Type of Control	
<i>Example</i>	<i>No</i>	<i>8:00 AM</i>	<i>7:00 PM</i>	<i>10:00 AM</i>	<i>6:00 PM</i>	<i>1:00 PM</i>	<i>6:00 PM</i>	<i>52</i>	<i>3,536</i>	<i>None</i>	<i>0%</i>	<i>Occupancy</i>	<i>Applying for Prescriptive Incentive</i>
1	No	6:30:00 AM	5:00:00 PM					52	2,730	None		Occupancy	Applying for Prescriptive Incentive
2													
3													
4													
5													
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													
16													
17													
18													
19													
20													

**3 Hours of Use**

For unoccupied times, leave applicable cells blank.

**4 Weeks of Use in Year**

If the lighting fixtures are not in use 52 weeks during the year (for example, during holiday or summer break), provide an explanation of when they are not expected to be in use and why:

**5 Controls**

Please attach more description of existing and/or proposed controls if more space is needed. If sufficient description is not provided, then controls portion of project will not be evaluated. Attach assumptions and calculations to support estimated reduction in hours that result from the controls.

New occupancy sensors should be applied for through the prescriptive application unless ineligible for prescriptive.

New or upgraded EMS/building controls require a separate application part 2. Without the separate application, EMS portion of the project will not be evaluated for an incentive.



Project/ Site	Existing Fixture(s)								
	Existing Fixture Installation Year (see note 6)	Fixture Type	Fixture Manufacturer (see note 6)	Fixture Model Number (see note 6)	Lamps per Fixture	Fixture Size	Fixture Input Power (watts) (see note 7)	Quantity of Fixtures	Total Demand (kW)
<i>Example</i>	1995	High Pressure Sodium	Manufacturer	Model #	1		190	175	33
1	2008	Other (enter by typing)	COMcheck		1	1	78,538	1	79
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15									
16									
17									
18									
19									
20									

**Application Total** **1** **79**

**6 Information on Existing Fixture(s)**

Optional - please provide as much information as you can.

For new construction projects, provide information on the light fixture(s) that would meet the building code in your location.

**7 Fixture Input Power (watts)**

Provide actual input power (in watts), not nominal power rating. For example, a 400 watt (nominal) metal halide fixture has a typical input power of approximately 459 watts.



Project/ Site	Proposed Fixture(s)										Projected Savings			Incremental Project Cost \$ (see note 11)
	Fixture Type	Fixture Manufacturer (see note 8)	Fixture Model Number (see note 8)	Warranty of Proposed Fixtures (years)	Lamps per Fixture	Fixture Input Power (watts) (see note 9)	Quantity of Fixtures	Total Demand (kW)	Lumen Output per Fixture	Lumen/ Sq Ft	Demand (kW)	Annual Energy (kWh)	Other Annual Savings \$ (see note 10)	
<i>Example</i>	<i>T8 Fluorescent</i>	<i>Manufacturer</i>	<i>Model #</i>	<i>5.0</i>	<i>1.0</i>	<i>78</i>	<i>225</i>	<i>18</i>		<i>0</i>		<i>55,515</i>	<i>\$1,265</i>	<i>\$29,215</i>
1	COMcheck		1	1	5.0	1.0	69,221	1	69	0	9	25,435		
2														
3														
4														
5														
6														
7														
8														
9														
10														
11														
12														
13														
14														
15														
16														
17														
18														
19														
20														

Application Total 1 69 9 25,435 \$0 \$0  
 Average Electric Rate \$/kWh \$0.10 Project Simple Electric Payback (see note 12)   years

**8 Fixture Manufacturer and Model Number**

Attach a scanned copy of a spec sheet for each fixture that includes the input power (watts), lumen output and other relevant information. For eligible LED fixtures, refer to the FAQs for Custom Incentives found at [www.duke-energy.com](http://www.duke-energy.com) and attach required documents if necessary.

**9 Fixture Input Power (watts)**

Provide actual input power (in watts), not nominal power rating. For example, a 400 watt (nominal) metal halide fixture has a typical input power of approximately 459 watts.

**10 Other Annual Savings \$**

Optional. Estimate other annual savings in addition to electric (for example operations/maintenance savings).

**11 Incremental Project Cost \$**

Attach a copy of a formal proposal with the projected project costs. For new construction projects, a formal proposal is also required with the projected costs for the light fixture(s) that would meet the building code in your location.

**12 Project Simple Electric Payback**

If the simple payback on the project is less than 1 year, then the project is not eligible for a custom incentive. Please check that the electric rate is accurate based on history.

March 2, 2012



To whom it may concern:

This letter is to confirm that for the renovation to Cincinnati Public school Kilgour Elementary (1339 Herschel), for the custom rebate application, the lighting project was installed with a minimum unit cost listed below.

DESCRIPTION	QUANTITY	PRICE/FIXTURE	AMOUNT
R3A - Metalux 2EP3GX-332S361	23	\$105.00	\$2,415.00
W5 - Metalux BAU-217	16	\$60.00	\$960.00
R1 - Metalux 2GC-332A	147	\$95.00	\$13,965.00
S2 - Centris 9506T03RN	151	\$306.00	\$46,206.00
R4A - Metalux 2GC-332A	19	\$95.00	\$1,805.00
R4 - Metalux 2GC-332A	66	\$95.00	\$6,270.00
R3 - Metalux 2EP3GX-332S361	96	\$105.00	\$10,080.00
R7 - Portfolio C6132	14	\$213.00	\$2,982.00
W1 - Lumark IP	1	\$189.00	\$189.00
CH1 - Metalux DIM-232	32	\$94.00	\$3,008.00
S3 - Corelite IPW P-2 8'	18	\$639.00	\$11,502.00
S6 - Corelite IPW P-2 4'	4	\$639.00	\$2,556.00
W4 - Metalux BC-232	17	\$78.00	\$1,326.00
R2 - Metalux 2EP3GX-332S361	7	\$105.00	\$735.00
W7 - Portfolio M8605	1	\$163.00	\$163.00
S5 - Corelite IQWB 12'	2	\$639.00	\$1,278.00
S4 - Spectrum SP6VF132EX	7	\$153.00	\$1,071.00
R9 - Cooper Halo H800	3	\$75.00	\$225.00
W2 - Prescolite ALCFQ13EB	6	\$51.00	\$306.00
S1 - Lithonia TPGE	25	\$210.00	\$5,250.00
CL3 - Fail Safe FWS-332	12	\$109.00	\$1,308.00
R5 - Lithonia 2SPG-432FW	14	\$119.00	\$1,666.00
R8 - Lithonia 2AV-G-332	29	\$266.00	\$7,714.00


<b>TOTAL</b>	<b>\$122,980.00</b>
--------------	---------------------

This is also to confirm that for the renovation to **Kilgour Elementary (1339 Herschel)**, for the prescriptive rebate application, occupancy sensors, motors, and chillers were installed with a minimum unit cost listed below.

DESCRIPTION	Model Number	QUANTITY	Nominal Size (Tons)	PRICE/FIXTURE	AMOUNT
SelfDirect Occupancy Sensor	01-110, 01-300-BAS	35	-	\$117.89	\$4,126.15
SelfDirect Motor	US Motors D15P2D	1	-	\$2,158.00	\$2,158.00
SelfDirect Motor	US Motors D30P2D	1	-	\$3,615.00	\$3,615.00
SelfDirect Chiller - Air - Reciprocal	York YCAL0124EC	2	124	\$148,800.00	\$297,600.00

<b>TOTAL</b>	<b>\$307,499.15</b>
--------------	---------------------

Thank you for your attention to this matter,



Don Elbe  
Utility Management Coordinator

**APPLICATION AND CERTIFICATE FOR PAYMENT**

**TO OWNER:**  
 CINCINNATI PUBLIC SCHOOLS  
 2315 KOWA ST  
 CINCINNATI, OHIO 45206

**PROJECT:**  
 KILGOUR ELEMENTARY SCHOOL  
 1339 HERSHEL AVENUE  
 CINCINNATI, OHIO 45208

**APPLICATION No:** RETAINAGE  
**PERIOD TO:** 9/30/2008  
**PROJECT NOS:**  
**CONTRACT DATE:** 1/1/2007

**FROM CONTRACTOR:**  
 STAPLETON ELECTRIC CO  
 4845 STATE ROUTE 128  
 CLEVELAND, OHIO 45002-9752  
**CONTRACT FOR:** ELECTRICAL

**VIA ARCHITECT:**  
 CHASE BUILDING INC  
 141 EAST POLK STREET  
 CINCINNATI, OHIO 45202

INVENTORY

**CONTRACTOR'S APPLICATION FOR PAYMENT**

Application is made for payment as shown below. In connection with the Contract  
 Continuation Sheet is attached.

1. ORIGINAL CONTRACT SUM..... \$ 1,626,000.00
2. Net Change by Change Orders..... \$ 122,313.00
3. CONTRACT SUM TO DATE..... \$ 1,751,313.00
4. TOTAL COMPLETED & STORED TO DATE..... \$ 1,751,313.00
5. RETAINAGE..... \$ 0.00
  - a. 8.50% of Completed Labor..... \$ 0.00
  - b. 8% of Stored Material..... \$ 0.00
 Total Retainage..... \$ 0.00
6. TOTAL EARNED LESS RETAINAGE..... \$ 1,751,313.00
7. LESS PREVIOUS CERTIFICATES FOR PAYMENT..... \$ 1,728,289.76
8. CURRENT PAYMENT DUE..... \$ 26,043.22
9. BALANCE TO FINISH, INCLUDING RETAINAGE..... \$ 0.00

Change Order/Contract	ADDITIONS	DEDUCTIONS
Total Changes approved in Previous months by Owner	122313.00	
Total approved this month		
<b>TOTALS</b>	<b>122313.00</b>	
<b>NET CHANGES by Change Order</b>	<b>122313.00</b>	

The Contractor certifies that the work covered by this pay request has been completed in accordance with the Contract Documents and that all progress payments previously paid by the State have been applied by the Contractor to discharge in full all of Contractor's obligations incurred in connection with the work covered by all prior pay requests.

Contractor *David J. Szymon* Date 9/24/2008  
 Based upon on-site observations, the firm affirms that the work has progressed to the percentage of completion(s) indicated on the pay request.

Architect *Black* Date 7/16/08

Construction Manager *E. Stewart* Date 6-5-09

Approved:

School District Treasurer \_\_\_\_\_ Date \_\_\_\_\_

AIA Type Document  
Application and Certification for Payment

TO: CINCINNATI PUBLIC SCHOOLS  
2315 IOWA ST  
CINCINNATI, OH 45206

FROM (CONTRACTOR): STABLETON ELECTRIC CO.  
4845 STATE ROUTE 128  
CLEVES, OH 45002-9152

PROJECT: KILGOUR ELEMENTARY SCHOOL  
1339 HERSCHEL AVENUE  
CINCINNATI, OHIO 45208

VIA (ARCHITECT): CHAMPLIN/HAIPL, INC  
424 EAST FOURTH STREET  
CINCINNATI, OHIO 45202

APPLICATION NO: 19  
PERIOD TO: 09/30/08  
JOB NO: C06962  
INVOICE NO: 18881  
APP. DATE: 09/24/08  
ARCHITECTS  
PROJECT NO: PO# 515477

DISTRIBUTION  
TO: OWNER  
ARCHITECT  
CONTRACTOR

CONTRACT FOR: ELECTRICAL PO# 515477  
CONTRACT DATE: 01/12/07

ITEM	DESCRIPTION	SCHEDULED		PREVIOUS APPLICATIONS	COMPLETED THIS PERIOD	STORED MATERIAL	COMPLETED		%	BALANCE	RETAINAGE
		VALUE	VALUE				+STORED				
100010	JOB START UP	15,000.00	15,000.00	0.00	0.00	0.00	15,000.00	100.00	0.00	0.00	
100020	DEMO	14,000.00	14,000.00	0.00	0.00	0.00	14,000.00	100.00	0.00	0.00	
100030	PERF BOND	16,000.00	16,000.00	0.00	0.00	0.00	16,000.00	100.00	0.00	0.00	
100040	TEMPORARY ELECTRIC	9,000.00	9,000.00	0.00	0.00	0.00	9,000.00	100.00	0.00	0.00	
100050	TEMPORARY ELECTRIC	9,000.00	9,000.00	0.00	0.00	0.00	9,000.00	100.00	0.00	0.00	
100060	EXT POLES & LIGHTS	4,000.00	4,000.00	0.00	0.00	0.00	4,000.00	100.00	0.00	0.00	
100070	EXT POLES & LIGHTS	12,000.00	12,000.00	0.00	0.00	0.00	12,000.00	100.00	0.00	0.00	
100080	EXT. POLES & LIGHTS ROUGH	10,000.00	10,000.00	0.00	0.00	0.00	10,000.00	100.00	0.00	0.00	
100090	EXT. POLES & LIGHTS ROUGH	12,000.00	12,000.00	0.00	0.00	0.00	12,000.00	100.00	0.00	0.00	
100100	ROUGH IN RENOV	137,750.00	137,750.00	0.00	0.00	0.00	137,750.00	100.00	0.00	0.00	
100110	ROUGH IN RENOV	40,000.00	40,000.00	0.00	0.00	0.00	40,000.00	100.00	0.00	0.00	
100120	ROUGH IN NEW ADD	40,000.00	40,000.00	0.00	0.00	0.00	40,000.00	100.00	0.00	0.00	
100130	ROUGH IN NEW ADD	40,000.00	40,000.00	0.00	0.00	0.00	40,000.00	100.00	0.00	0.00	
100140	LIGHTING RENOV	80,000.00	80,000.00	0.00	0.00	0.00	80,000.00	100.00	0.00	0.00	
100150	LIGHTING RENOV	15,000.00	15,000.00	0.00	0.00	0.00	15,000.00	100.00	0.00	0.00	
100160	LIGHTING NEW ADD	35,000.00	35,000.00	0.00	0.00	0.00	35,000.00	100.00	0.00	0.00	
100170	LIGHTING NEW ADD	4,000.00	4,000.00	0.00	0.00	0.00	4,000.00	100.00	0.00	0.00	
100180	WIRING DEVICES	6,000.00	6,000.00	0.00	0.00	0.00	6,000.00	100.00	0.00	0.00	
100190	FIRE ALARM	26,000.00	26,000.00	0.00	0.00	0.00	26,000.00	100.00	0.00	0.00	
100200	FIRE ALARM	10,000.00	10,000.00	0.00	0.00	0.00	10,000.00	100.00	0.00	0.00	
100210	CABLE TRAY	10,000.00	10,000.00	0.00	0.00	0.00	10,000.00	100.00	0.00	0.00	
100220	CABLE TRAY	10,000.00	10,000.00	0.00	0.00	0.00	10,000.00	100.00	0.00	0.00	
100230	CABLE TRAY	10,000.00	10,000.00	0.00	0.00	0.00	10,000.00	100.00	0.00	0.00	
100240	SCOREBOARD	1,000.00	1,000.00	0.00	0.00	0.00	1,000.00	100.00	0.00	0.00	
100250	SCOREBOARD	4,000.00	4,000.00	0.00	0.00	0.00	4,000.00	100.00	0.00	0.00	
100260	GENERATOR	2,500.00	2,500.00	0.00	0.00	0.00	2,500.00	100.00	0.00	0.00	
100270	GENERATOR	17,000.00	17,000.00	0.00	0.00	0.00	17,000.00	100.00	0.00	0.00	
100280	SWITCH GEAR	20,000.00	20,000.00	0.00	0.00	0.00	20,000.00	100.00	0.00	0.00	
100290	SWITCH GEAR	68,000.00	68,000.00	0.00	0.00	0.00	68,000.00	100.00	0.00	0.00	
100300	FEEDERS	85,000.00	85,000.00	0.00	0.00	0.00	85,000.00	100.00	0.00	0.00	
100310	FEEDERS	120,000.00	120,000.00	0.00	0.00	0.00	120,000.00	100.00	0.00	0.00	
100318	AA#11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
100319	AA#10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	

ITEM	DESCRIPTION	SCHEDULED VALUE	PREVIOUS APPLICATIONS	COMPLETED THIS PERIOD	STORED MATERIAL	COMPLETED +STORED	%	BALANCE	RETAINAGE
100320	GENERAL ALLOW	15,000.00	15,000.00	0.00	0.00	15,000.00	100.00	0.00	0.00
100321	AA#1 1492.00 PCO#086	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
100322	AA#2 1978.00 PCO#076	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
100323	AA#3 2880.00 PCO#090	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
100324	AA#4 360.00 PCO#095	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
100325	AA#5 1415.00 PCO#122	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
100326	AA#6 \$1726.00 PCO#083	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
100327	AA#7 \$913.00 PCO#123	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
100328	AA#8 \$1121.00 PCO#151	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
100329	AA#9 \$2202.00 PCO#159	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
100330	17150 COMMUN CONN	52,778.00	52,778.00	0.00	0.00	52,778.00	100.00	0.00	0.00
100340	17150 COMMUN CONN	109,223.00	109,223.00	0.00	0.00	109,223.00	100.00	0.00	0.00
100350	17210 DATA NETWORK	4,200.00	4,200.00	0.00	0.00	4,200.00	100.00	0.00	0.00
100360	17210 DATA NETWORK	41,798.00	41,798.00	0.00	0.00	41,798.00	100.00	0.00	0.00
100370	17260 UPS	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
100380	17260 UPS	3,975.00	3,975.00	0.00	0.00	3,975.00	100.00	0.00	0.00
100390	17410-17430 VIDEO	17,600.00	17,600.00	0.00	0.00	17,600.00	100.00	0.00	0.00
100400	17410-17430 VIDEO	124,049.00	124,049.00	0.00	0.00	124,049.00	100.00	0.00	0.00
100410	17750 PA SYSTEM	14,552.00	14,552.00	0.00	0.00	14,552.00	100.00	0.00	0.00
100420	17550 PA SYSTEM	29,504.00	29,504.00	0.00	0.00	29,504.00	100.00	0.00	0.00
100430	17821 STUDENT DINE	3,200.00	3,200.00	0.00	0.00	3,200.00	100.00	0.00	0.00
100440	17821 STUDENT DINE	17,218.00	17,218.00	0.00	0.00	17,218.00	100.00	0.00	0.00
100450	17824 GYM SOUND	4,000.00	4,000.00	0.00	0.00	4,000.00	100.00	0.00	0.00
100460	17824 GYM SOUND	17,847.00	17,847.00	0.00	0.00	17,847.00	100.00	0.00	0.00
100470	17827 MUSIC	880.00	880.00	0.00	0.00	880.00	100.00	0.00	0.00
100480	17827 MUSIC ROOM	5,769.00	5,769.00	0.00	0.00	5,769.00	100.00	0.00	0.00
100490	7830 CLASS RM SOUND	4,400.00	4,400.00	0.00	0.00	4,400.00	100.00	0.00	0.00
100500	17830 CLASS RM SOUND	38,771.00	38,771.00	0.00	0.00	38,771.00	100.00	0.00	0.00
100510	17910 ACCESS CONT	8,800.00	8,800.00	0.00	0.00	8,800.00	100.00	0.00	0.00
100520	17910 ACCESS CONT	29,116.00	29,116.00	0.00	0.00	29,116.00	100.00	0.00	0.00
100530	17930 CCTV	7,600.00	7,600.00	0.00	0.00	7,600.00	100.00	0.00	0.00
100540	17930 CCTV	59,540.00	59,540.00	0.00	0.00	59,540.00	100.00	0.00	0.00
100550	17730 CLOCKS	1,120.00	1,120.00	0.00	0.00	1,120.00	100.00	0.00	0.00
100560	17730 CLOCKS	14,060.00	14,060.00	0.00	0.00	14,060.00	100.00	0.00	0.00
100570	AA#12 PCO #206	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
901010	CO# 1, CO#001 PCO#021	-5,896.00	-5,896.00	0.00	0.00	-5,896.00	100.00	0.00	0.00
901020	CO# 2, CO#002 FWO#059	2,174.00	2,174.00	0.00	0.00	2,174.00	100.00	0.00	0.00
901030	CO# 3, CO#3 PCO#060	8,814.00	8,814.00	0.00	0.00	8,814.00	100.00	0.00	0.00
901040	CO# 6, CO#6 BULL #005	4,206.00	4,206.00	0.00	0.00	4,206.00	100.00	0.00	0.00
901050	CO# 4, CO#4 PCO #037	11,880.00	11,880.00	0.00	0.00	11,880.00	100.00	0.00	0.00
901060	CO# 7, CO#7 PCO #112	2,023.00	2,023.00	0.00	0.00	2,023.00	100.00	0.00	0.00
901070	CO# 8, CO#8 PCO#124	1,784.00	1,784.00	0.00	0.00	1,784.00	100.00	0.00	0.00
901080	CO# 10, CO#010 PCO#138	1,917.00	1,917.00	0.00	0.00	1,917.00	100.00	0.00	0.00
901090	CO# 5, CO# 5 BULLETIN #07	14,507.00	14,507.00	0.00	0.00	14,507.00	100.00	0.00	0.00
901100	CO# 11 PCO#182 OTIME	3,605.00	3,605.00	0.00	0.00	3,605.00	100.00	0.00	0.00
901110	CO# 14, PCO# 152	7,391.00	7,391.00	0.00	0.00	7,391.00	100.00	0.00	0.00

ITEM	DESCRIPTION	SCHEDULED VALUE	PREVIOUS APPLICATIONS	COMPLETED THIS PERIOD	STORED MATERIAL	COMPLETED + STORED	%	BALANCE	RETAINAGE
901120	CO# 12, CO#012 PCO#177	1,030.00	1,030.00	0.00	0.00	1,030.00	100.00	0.00	0.00
901130	CO# 09, CO# 009BULLETIN #29	21,524.00	21,524.00	0.00	0.00	21,524.00	100.00	0.00	0.00
901140	CO# 19, CO# 019	4,594.00	4,594.00	0.00	0.00	4,594.00	100.00	0.00	0.00
901150	CO# 17, CO# 17 PCO #34, #143	8,861.00	8,861.00	0.00	0.00	8,861.00	100.00	0.00	0.00
901170	CO# 16, CO#16	6,456.00	6,456.00	0.00	0.00	6,456.00	100.00	0.00	0.00
901180	CO# 15, CO#15	6,393.00	6,393.00	0.00	0.00	6,393.00	100.00	0.00	0.00
901190	CO# 13, CO #13 PCO #178, 181	2,232.00	2,232.00	0.00	0.00	2,232.00	100.00	0.00	0.00
901210	CO# 18, CO#18	3,181.00	3,181.00	0.00	0.00	3,181.00	100.00	0.00	0.00
901220	CO# 21, CO#021	3,095.00	3,095.00	0.00	0.00	3,095.00	100.00	0.00	0.00
901230	CO# 20, CO#020	3,146.00	3,146.00	0.00	0.00	3,146.00	100.00	0.00	0.00
901240	CO# 22, CO#022	2,047.00	2,047.00	0.00	0.00	2,047.00	100.00	0.00	0.00
901250	CO# 23, CO# 023	2,123.00	2,123.00	0.00	0.00	2,123.00	100.00	0.00	0.00
901260	CO# 24, CO# 024 PCO 209, 220,	1,769.00	1,769.00	0.00	0.00	1,769.00	100.00	0.00	0.00
901270	CO# 25, CO# 025 PCO 244, 249	1,737.00	1,737.00	0.00	0.00	1,737.00	100.00	0.00	0.00
901280	CO# 27, PCO #252, 256	271.00	271.00	0.00	0.00	271.00	100.00	0.00	0.00
901290	CO# 28, PCO #253, 255	710.00	710.00	0.00	0.00	710.00	100.00	0.00	0.00
901300	CO# 26, CO#026 PCO #248	1,739.00	1,739.00	0.00	0.00	1,739.00	100.00	0.00	0.00

REPORT TOTALS      1,751,313.00      1,749,574.00      0.00      0.00      1,749,574.00      99.90      1,739.00      0.00

## Affidavit of Prime Contractor

State of Ohio )

County of Hamilton )

September 23, 2008

David J. Stapleton being first duly sworn, says that he is (1) President of (2) Stapleton Electric Co. 4845 State Route 128, Cleves, OH 45002 the contractor having a contract with CINCINNATI PUBLIC SCHOOLS, the CONTRACTOR for (3) KILGOUR ELEMENTARY SCHOOL, situated on or around or in front of the following described property at 1339 HERSHEL AVE known as: KILGOUR ELEMENTARY SCHOOL whereof (4) CINCINNATI PUBLIC SCHOOL DISTRICT was the owner, part owner or lessee.

### SUBCONTRACTORS

Affidavit further says that the following shows the names and addresses of every subcontractor in its employ, giving the amount, if any, which is due, or to become due to them, or any of them, for work done or machinery, material or fuel furnished to the date hereof under said contract.

NAME	ADDRESS	TRADE	AMOUNT DUE OR TO BECOME DUE FROM THIS DRAW FOR WORK AND MATERIALS	
			\$	

### MATERIALMEN

Affiant further says that the following shows the names and addresses of every person furnishing machinery, material or fuel to it, giving the amount, if any, which is due, or to become due to them, or any of them, for machinery, material or fuel furnished to date hereof under said contract.

NAME	ADDRESS	KIND OF MACHINERY, MATERIAL OR FUEL	AMOUNT DUE OR TO BECOME DUE FROM THIS DRAW FOR MATERIAL	
NONE				

**LABORERS**

Affiant further says that the following shows the names and addresses of every unpaid laborer in its employ furnishing labor under said contract, giving the amount, if any, which is due, or to become due, for labor done to date hereof.


Note- if the fact is that every laborer has been paid in full and then recites: Every laborer has been paid in full". If not, then give each unpaid laborer's name and address and the amount due or to become due.

NAME	ADDRESS	HOURS	AMOUNT DUE OR TO BECOME DUE FROM THIS DRAW FOR LABOR FURNISHED
Every Laborer has been Paid in Full			

Affidavit further states that there is due or to become due to (2) Stapleton Electric Co., 4845 State Route 128, Cleves, OH 45002 for work performed or machinery, material or fuel furnished to **CINCINNATI PUBLIC SCHOOL DISTRICT**. To date hereof under said contracts, the sum of \$1736,612.00.


That the amounts due or to become due to said subcontractors, materialmen and laborers for work done or machinery, material or fuel furnished to the date hereof to (2) Stapleton Electric Co., 4845 State Route 128, Cleves, OH 45002 Are fully and correctly set forth opposite their names, respectively, in the aforesaid statements, and further evidenced by certificates of every person furnishing machinery, material or fuel, attached hereto and made a part hereof.

Affiant further says that (2) Stapleton Electric Co., 4845 State Route 128, Cleves, OH 45002 has not employed or purchased or procured machinery, material or fuel from, or subcontracted with any person, firm or corporation, other than those above mentioned, and owes for no labor performed, or machinery, material or fuel furnished, under said contracts, other than above set forth.

  
 \_\_\_\_\_  
 CONTRACTOR SIGNATURE                      David J. Stapleton/President

SWORN TO BEFORE ME AND SUBSCRIBED IN MY PRESENCE, at Cleves, Ohio,

This 23rd day of September, 2008

  
 Kathleen A. Leopold, Notary Public  
**KATHLEEN A. LEOPOLD**  
 Notary Public, State of Ohio  
 My Commission Expires November 7, 2008

1. Pres., Treas., Owner, or authorized agent, as case may be.
2. Name and address of Subcontractor
3. Brief description of project.
4. Name of project owner from page 1 of Subcontract Agreement

**Cincinnati Public Schools**  
 2315 Iowa Avenue  
 Cincinnati, Ohio 45206

STAPLETON ELECTRIC CO.  
 4845 STATE ROUTE 128  
 CLEVELAND, OHIO 45002

**Contractor Pay Application Summary**      RETAINAGE

**Project No:** KILGOUR ELEMENTARY SCHOOL PO# 515477  
**Bid Package No.**

1	Original Contract Amount	\$	1,629,000.00
2	Net Changes to Date	\$	122,313.00
3	Current Contract Amount	\$	1,751,313.00
4	Labor Completed to Date	\$	\$674,962.25
5	Material Completed to Date	\$	797,390.75
6	Total Work Completed to Date	\$	1,751,313.00
7	Store Material to Date	\$	278,960.00
8	Less Retained to Date	\$	0.00
9	Total Amount Due	\$	1,736,612.00
10	Less Previous Payments	\$	1,725,269.78
11	Less Amount Retained to Cover Lien	\$	
12	Less Amount Retained for Liquidated Damages	\$	
13	Less Other Amounts Withheld	\$	
14	Current Due	\$	26,043.22
15	Balance to Complete including retainage	\$	0.00

<b>OSFC approval required for the following contract adjustments:</b>	
1. Assessment of liquidated damages	
2. Other amounts withheld	
Ohio School Facilities Commission	Date
Comments:	

**Turner**  **TYS**  
Rebuilding Cincinnati Public Schools

December 11, 2009

Angie Tolle  
Cincinnati Public Schools  
2315 Iowa Avenue  
Cincinnati, OH 45206


Dear Angie:

Attached are **Pay Applications** for the Kilgour School, please **process payment for the January 8, 2009 check distribution.**

Contractor	Application #	Monthly Billing	Total Billing To Date	Contract Amount to Date
BP#3&5 Feldkamp	#18	\$ 61,804.00.00	\$2,680,995.00	\$2,680,995.00

Please call if you have any questions.

Sincerely,  
TURNER/DAG/TYS



James T. DeLage  
Project Executive

/bcs

**Attachments**

cc: Jay Darental – Champlin/Haupt  
Rob Marks – Turner/DAG/TYS  
File 0025 – 10960PA

T:PROJECTS/Kilgour/00250 Pay Application/2008-12-11 Feldkamp Pay App. Ltr. Doc

# APPLICATION AND CERTIFICATE FOR PAYMENT

AIA DOCUMENT G702 (Instructions on reverse side) PAGE ONE OF TWO

**TO OWNER:** Cincinnati Public Schools  
 2315 Iowa Avenue  
 Cincinnati, OH 45206

**PROJECT:** Kilgour Elementary  
 1339 Herschel Avenue  
 Cincinnati, OH 45208

**FROM CONTRACTOR:** Feldkamp Enterprises, Inc.  
 3642 Muddy Creek  
 Cincinnati, OH 45238

**VIA ARCHITECT:** Kilgour Elementary  
 1339 Herschel Avenue  
 Cincinnati, OH 45208

## CONTRACTOR'S APPLICATION FOR PAYMENT

Application is made for payment, as shown below, in connection with the Contract, Continuation Sheet, AIA Document G703, is attached.

1. ORIGINAL CONTRACT SUM	\$	2,542,000.00
2. Net change by Change Orders	\$	138,995.00
3. CONTRACT SUM TO DATE (Line 1 + 2)	\$	2,680,995.00
4. TOTAL COMPLETED & STORED TO DATE (Column F on G703)	\$	2,680,995.00
5. RETAINAGE:		
a. % of Completed Work (Columns D + E on G703)	\$	0.00
b. % of Stored Material (Column F on G703)	\$	0.00
Total Retainage (Line 5a + 5b or Total in Column I of G703)	\$	0.00
6. TOTAL EARNED LESS RETAINAGE (Line 4 less Line 5 Total)	\$	2,680,995.00
7. LESS PREVIOUS CERTIFICATES FOR PAYMENT (Line 6 from prior Certificate)	\$	2,619,191.00
8. CURRENT PAYMENT DUE	\$	61,804.00
9. BALANCE TO FINISH, INCLUDING RETAINAGE (Line 3 less Line 6)	\$	0.00

CHANGE ORDER SUMMARY	ADDITIONS	DEDUCTIONS
Total changes approved in previous months by Owner	155,484.00	11,227.00
Total approved this month	0.00	5,262.00
<b>TOTALS</b>	<b>155,484.00</b>	<b>16,489.00</b>
NET CHANGES by Change Order	138,995.00	


**CAUTION:** You should use an original AIA document which has this caution printed in red. An original assures that changes will not be obscured as they occur when documents are reproduced.

The undersigned Contractor certifies that to the best of the Contractor's knowledge, information and belief the work covered by this Application for Payment has been completed in accordance with the Contract Documents, that all amounts have been paid by the Contractor for work for which previous Certificates for Payment were issued and payments received from the Owner, and that current payment shown herein is now due.

**CONTRACTOR:** Feldkamp Enterprises, Inc.  
 By: *[Signature]* Date: 2/4/2009

State of: Ohio  
 County of: Hamilton  
 Subscribed and signed to before me this 10th day of Feb-09

Notary Public: *[Signature]*  
 My Commission expires: 11/18/12



## ARCHITECT'S CERTIFICATE FOR PAYMENT

In accordance with the Contract Documents, based on on-site observations and the data comprising this application, the Architect certifies to the Owner that to the best of the Architect's knowledge, information and belief the Work has progressed as indicated, the quality of the Work is in accordance with the Contract Documents, and the Contractor is entitled to payment of the AMOUNT CERTIFIED.

**AMOUNT CERTIFIED:** \$ 61,804.00

*(Attach explanation if amount certified differs from the amount applied for initial all figures on this Application and on the Continuation Sheet that are changed to conform to the amount certified.)*

By: *[Signature]* Date: 12/9/09

This Certificate is not negotiable. The AMOUNT CERTIFIED is payable only to the Contractor named herein. Issuance, payment and acceptance of payment are without prejudice to any rights of the Owner or Contractor under this Contract.

AIA DOCUMENT G702 • APPLICATION AND CERTIFICATE FOR PAYMENT • 1992 EDITION • AIA® • 1515 N. MICHIGAN AVENUE, N.W., WASHINGTON, D.C. 20006-5292 • WARNING: Unlicensed photocopying violates U.S. copyright laws and will subject the violator to legal prosecution.

12/4/09  
 G702-1992

# CONTINUATION SHEET

AIA DOCUMENT G703 (Instructions on reverse side)

AIA Document G702, APPLICATION AND CERTIFICATE FOR PAYMENT, containing Contractor's signed Certification, is attached.  
 In tabulations below, amounts are stated to the nearest dollar.  
 Use Column I on Contracts where variable retainage for line items may apply.

APPLICATION NO.: 18  
 APPLICATION DATE: 11/30/2008  
 PERIOD TO: 11/30/2008  
 ARCHITECT'S PROJECT NO.:

A ITEM NO.	B DESCRIPTION OF WORK	C SCHEDULED VALUE	D WORK COMPLETED		E THIS PERIOD	F MATERIALS PRESENTLY STORED (NOT IN D OR E)	G TOTAL COMPLETED AND STORED TO DATE (D+E+H)		H BALANCE TO FINISH (C-G)	I RETAINAGE (IF VARIABLE RATE)
			PROM PREVIOUS APPLICATION (D + H)	THIS PERIOD			COMPLETED AND STORED TO DATE (D+E+H)	% (G ÷ C)		
1	HVAC	0	0	0	0	0	0	0	0	0
2	L Coordination Draw.	50,000	50,000	0	0	0	50,000	100	0	0
3	M Coordination Draw.	2,000	2,000	0	0	0	2,000	100	0	0
4	L Mobilization	3,000	3,000	0	0	0	3,000	100	0	0
5	M Mobilization	3,000	3,000	0	0	0	3,000	100	0	0
6	L Attic Hole Cutting	61,000	61,000	0	0	0	61,000	100	0	0
7	M Attic Hole Cutting	2,000	2,000	0	0	0	2,000	100	0	0
8	L Attic Exist Bldg Duct	84,000	84,000	0	0	0	84,000	100	0	0
9	M Attic Exist Bldg Duct	70,000	70,000	0	0	0	70,000	100	0	0
10	L 1st Fir Exist-Bldg Duct	30,000	30,000	0	0	0	30,000	100	0	0
11	M 1st Fir Exist-Bldg Duct	23,000	23,000	0	0	0	23,000	100	0	0
12	L Base-Exist Bldg Duct	27,000	27,000	0	0	0	27,000	100	0	0
13	M Base-Exist Bldg Duct	22,000	22,000	0	0	0	22,000	100	0	0
14	L Exist-Bldg Air Devices	8,000	8,000	0	0	0	8,000	100	0	0
15	M Exist-Bldg Air Devices	8,000	8,000	0	0	0	8,000	100	0	0
16	L Fans	10,000	10,000	0	0	0	10,000	100	0	0
17	M Fans	20,000	20,000	0	0	0	20,000	100	0	0
18	L VAV Boxes	2,000	2,000	0	0	0	2,000	100	0	0
19	M VAV Boxes	3,000	3,000	0	0	0	3,000	100	0	0
20	L Flue	2,000	2,000	0	0	0	2,000	100	0	0
21	M Flue	6,000	6,000	0	0	0	6,000	100	0	0
22	L Addition Gym Duct	11,000	11,000	0	0	0	11,000	100	0	0
23	M Addition Gym Duct	6,000	6,000	0	0	0	6,000	100	0	0
24	L 1st Fir Add-Duct	14,000	14,000	0	0	0	14,000	100	0	0
25	M 1st Fir Add-Duct	10,000	10,000	0	0	0	10,000	100	0	0



AIA DOCUMENT G703 • CONTINUATION SHEET FOR G702 • 1992 EDITION • AIA® • ©1992 • THE AMERICAN INSTITUTE OF ARCHITECTS, 1735 NEW YORK AVENUE, N.W., WASHINGTON, D.C. 20006-5292 • WARNING: Unlicensed photocopying violates U.S. copyright laws and will subject the violator to legal prosecution.

G703-1992

CAUTION: You should use an original AIA document which has this caution printed in red. An original assures that changes will not be obscured as may occur when documents are reproduced.


# CONTINUATION SHEET

AIA DOCUMENT G703 (Instructions on reverse side)

AIA Document G702, APPLICATION AND CERTIFICATE FOR PAYMENT, containing Contractor's signed Certification, is attached.  
 In tabulations below, amounts are stated to the nearest dollar.  
 Use Column I on Contracts where variable retainage for line items may apply.

APPLICATION NO.: 18  
 APPLICATION DATE: 11/30/2008  
 PERIOD TO: 11/30/2008  
 ARCHITECT'S PROJECT NO.:

A ITEM NO.	B DESCRIPTION OF WORK	C SCHEDULED VALUE	D WORK COMPLETED		F MATERIALS PRESENTLY STORED (NOT IN D OR E)	G TOTAL COMPLETED AND STORED TO DATE (D+E+F)		H BALANCE TO FINISH (G - G)	I RETAINAGE (IF VARIABLE) (F RATED)
			E THIS PERIOD	D + E		% (G ÷ C)			
26	L 2nd Flr Add-Duct	9,000	9,000	0	0	9,000	100	0	0
27	M 2nd Flr Add-Duct	6,000	6,000	0	0	6,000	100	0	0
28	L Addition Air Devices	4,000	4,000	0	0	4,000	100	0	0
29	M Addition Air Devices	4,000	4,000	0	0	4,000	100	0	0
30	PLUMBING	0	0	0	0	0	***	0	0
31	COORDINATION	10,000	10,000	0	0	10,000	100	0	0
32	MOBILIZATION	5,000	5,000	0	0	5,000	100	0	0
33	PLUMBING PERMIT	6,000	6,000	0	0	6,000	100	0	0
34	BOND	10,000	10,000	0	0	10,000	100	0	0
35	SUBMITTALS	5,000	5,000	0	0	5,000	100	0	0
36	SUPERVISION	15,000	15,000	0	0	15,000	100	0	0
37	ALLOWANCE	10,000	10,000	0	0	10,000	100	0	0
38	L Blwgrd Sant & Strm-Exist	25,000	25,000	0	0	25,000	100	0	0
39	M Blwgrd Sant & Strm-Exist	12,000	12,000	0	0	12,000	100	0	0
40	L Blwgrd Sant & Strm New Bidg	9,000	9,000	0	0	9,000	100	0	0
41	M Blwgrd Sant & Strm New Bidg	8,000	8,000	0	0	8,000	100	0	0
42	L Abovegrd Sant & Strm Exist	57,000	57,000	0	0	57,000	100	0	0
43	M Abovegrd Sant & Strm Exist	31,000	31,000	0	0	31,000	100	0	0
44	L Abovegrd Sant New Bidg	8,000	8,000	0	0	8,000	100	0	0
45	M Abovegrd Sant New Bidg	5,000	5,000	0	0	5,000	100	0	0
46	L Abovegrd Strm Exist Bidg	18,000	18,000	0	0	18,000	100	0	0



AIA DOCUMENT G703 • CONTINUATION SHEET FOR G702 • 1992 EDITION • AIA® • ©1992 • THE AMERICAN INSTITUTE OF ARCHITECTS, 1735 NEW YORK AVENUE, N.W., WASHINGTON, D.C. 20005-2929 • WARNING: Unlicensed photocopying violates U.S. copyright laws and will subject the violator to legal prosecution.

G703-1992

CAUTION: You should use an original AIA document which has this caution printed in red. An original assures that changes will not be obscured as may occur when documents are reproduced.

# CONTINUATION SHEET

AIA DOCUMENT G703 (Instructions on reverse side)

PAGE **3** OF **3** PAGES

AIA Document G702, APPLICATION AND CERTIFICATE FOR PAYMENT, containing Contractor's signed Certification, is attached.  
 In tabulations below, amounts are stated to the nearest dollar.  
 Use Column I on Contracts where variable retainage for line items may apply.

APPLICATION NO.: **18**  
 APPLICATION DATE: **11/30/2008**  
 PERIOD TO: **11/30/2008**  
 ARCHITECT'S PROJECT NO.:

A ITEM NO.	B DESCRIPTION OF WORK	C SCHEDULED VALUE	D WORK COMPLETED		E THIS PERIOD	F MATERIALS PRESENTLY STORED (NOT IN D OR E)	G TOTAL COMPLETED AND STORED TO DATE (D+E+F)		H BALANCE TO FINISH (C-G)	I RETAINAGE (IF VARIABLE RATE)
			FROM PREVIOUS APPLICATION (D + E)				% (G ÷ C)			
47	M Abovegrd Strm Exist Bldg	9,000	9,000	0	0	0	9,000	100	0	0
48	L Abovegrd Strm New Bldg	8,000	8,000	0	0	0	8,000	100	0	0
49	M Abovegrd Strm New Bldg	5,000	5,000	0	0	0	5,000	100	0	0
50	L Domestic Water Exist Bldg	64,000	64,000	0	0	0	64,000	100	0	0
51	M Domestic Water Exist Bldg	39,000	39,000	0	0	0	39,000	100	0	0
52	L Domestic Water New Bldg	29,000	29,000	0	0	0	29,000	100	0	0
53	M Domestic Water New Bldg	18,000	18,000	0	0	0	18,000	100	0	0
54	L Gas Piping	17,000	17,000	0	0	0	17,000	100	0	0
55	M Gas Piping	8,000	8,000	0	0	0	8,000	100	0	0
56	L Air Piping	3,000	3,000	0	0	0	3,000	100	0	0
57	M Air Piping	2,000	2,000	0	0	0	2,000	100	0	0
58	L Cutting & Patching	18,000	18,000	0	0	0	18,000	100	0	0
59	M Cutting & Patching	15,000	15,000	0	0	0	15,000	100	0	0
60	L Clean Up	6,000	6,000	0	0	0	6,000	100	0	0
61	M Clean Up	2,000	2,000	0	0	0	2,000	100	0	0
62	L Drain Carriers Cleanouts	12,000	12,000	0	0	0	12,000	100	0	0
63	M Drain Carriers Cleanouts	15,000	15,000	0	0	0	15,000	100	0	0
64	L Water Heater	8,000	8,000	0	0	0	8,000	100	0	0
65	M Water Heater	18,000	18,000	0	0	0	18,000	100	0	0
66	L Plumbing Fixtures	22,000	22,000	0	0	0	22,000	100	0	0
67	M Plumbing Fixtures	38,000	38,000	0	0	0	38,000	100	0	0
68	L Insulation	14,000	14,000	0	0	0	14,000	100	0	0



AIA DOCUMENT G703 • CONTINUATION SHEET FOR G702 • 1992 EDITION • AIA® • ©1992 • THE AMERICAN INSTITUTE OF ARCHITECTS, 1735 NEW YORK AVENUE, N.W., WASHINGTON, D.C. 20006-4292 • WARNING: Unlicensed photocopying violates U.S. copyright laws and will subject the violator to legal prosecution.

G703-1992

CAUTION: You should use an original AIA document which has this caution printed in red. An original assures that changes will not be obscured as may occur when documents are reproduced.

# CONTINUATION SHEET

AIA DOCUMENT G703 (Instructions on reverse side)

AIA Document G702, APPLICATION AND CERTIFICATE FOR PAYMENT, containing Contractor's signed Certification, is attached. In tabulations below, amounts are stated to the nearest dollar. Use Column I on Contracts where variable retainage for line items may apply.

APPLICATION NO.: 18  
 APPLICATION DATE: 11/30/2008  
 PERIOD TO: 11/30/2008  
 ARCHITECT'S PROJECT NO.:

A ITEM NO.	B DESCRIPTION OF WORK	C SCHEDULED VALUE	D WORK COMPLETED		F MATERIALS PRESENTLY STORED (NOT IN D OR E)	G TOTAL COMPLETED AND STORED TO DATE (D+E+F)	H BALANCE TO FINISH (C-G)	I RETAINAGE (IF VARIABLE) RATE
			FROM PREVIOUS APPLICATION (D + E)	THIS PERIOD				
69	M Insulation	22,000	22,000	0	0	22,000	100	0
70	L Site Water	25,000	25,000	0	0	25,000	100	0
71	M Site Water	31,000	31,000	0	0	31,000	100	0
72	WATER TAP FEE	14,000	14,000	0	0	14,000	100	0
73	CIVIL LAYOUT	4,000	4,000	0	0	4,000	100	0
74	SEWER TAP FEE	51,000	51,000	0	0	51,000	100	0
75	L Site Storm	75,000	75,000	0	0	75,000	100	0
76	M Site Storm	94,000	94,000	0	0	94,000	100	0
77	L Site Sanitary	14,000	14,000	0	0	14,000	100	0
78	M Site Sanitary	11,000	11,000	0	0	11,000	100	0
79	L Street Cutting & Restoration	2,000	2,000	0	0	2,000	100	0
80	M Street Cutting & Restoration	1,000	1,000	0	0	1,000	100	0
81	L Punchlist	3,000	3,000	0	0	3,000	100	0
82	M Punchlist	1,000	1,000	0	0	1,000	100	0
83	L Closeout	2,000	2,000	0	0	2,000	100	0
84	M Closeout	1,000	1,000	0	0	1,000	100	0
85	PIPING	0	0	0	0	0	***	0
86	BOND	20,000	20,000	0	0	20,000	100	0
87	SUBMITTALS	10,000	10,000	0	0	10,000	100	0
88	PUNCHLIST	8,000	8,000	0	0	8,000	100	0
89	ALLOWANCE	10,000	10,000	0	0	10,000	100	0
90	CLOSEOUT DOCUMENTS	5,000	5,000	0	0	5,000	100	0
91	M HVAC Equipment	260,000	260,000	0	0	260,000	100	0

AIA DOCUMENT G703 • CONTINUATION SHEET FOR G702 • 1992 EDITION • AIA® • ©1992 • THE AMERICAN INSTITUTE OF ARCHITECTS, 1735 NEW YORK AVENUE, N.W., WASHINGTON, D.C. 20006-5292 • WARNING: Unlicensed photocopying violates U.S. copyright laws and will subject the violator to legal prosecution.

G703-1992

CAUTION: You should use an original AIA document which has this caution printed in red. An original assures that changes will not be obscured as may occur when documents are reproduced.


# CONTINUATION SHEET

AIA DOCUMENT G703 (Instructions on reverse side)

AIA Document G702, APPLICATION AND CERTIFICATE FOR PAYMENT, containing Contractor's signed Certification, is attached. In tabulations below, amounts are stated to the nearest dollar. Use Column I on Contracts where variable retainage for line items may apply.

APPLICATION NO.: 18  
 APPLICATION DATE: 11/30/2008  
 PERIOD TO: 11/30/2008  
 ARCHITECT'S PROJECT NO.:

A ITEM NO.	B DESCRIPTION OF WORK	C SCHEDULED VALUE	D WORK COMPLETED		E THIS PERIOD	F MATERIALS PRESENTLY STORED (NOT IN D OR E)	G TOTAL COMPLETED AND STORED TO DATE (D+E+F)	H % (G ÷ C)	I BALANCE TO FINISH (C - G)	J RETAINAGE (IF VARIABLE RATE)
			FROM PREVIOUS APPLICATION (D + E)							
92	L HVAC Equipment	30,000	30,000		0	0	30,000	100	0	0
93	M Hydronic Equipment	25,000	25,000		0	0	25,000	100	0	0
94	L Hydronic Equipment	6,000	6,000		0	0	6,000	100	0	0
95	M Boilers	40,000	40,000		0	0	40,000	100	0	0
96	L Boilers	7,500	7,500		0	0	7,500	100	0	0
97	M Hot Water Piping	60,000	60,000		0	0	60,000	100	0	0
98	L Hot Water Piping	180,000	180,000		0	0	180,000	100	0	0
99	M Chilled Water Piping	45,000	45,000		0	0	45,000	100	0	0
100	L Chilled Water Piping	110,000	110,000		0	0	110,000	100	0	0
101	SUBCONTRACTORS	0	0		0	0	0	***	0	0
102	M Insulation	48,500	48,500		0	0	48,500	100	0	0
103	L Insulation	70,000	70,000		0	0	70,000	100	0	0
104	M Temp Control	58,000	58,000		0	0	58,000	100	0	0
105	L Temp Control	60,000	60,000		0	0	60,000	100	0	0
106	L Engineering	20,000	20,000		0	0	20,000	100	0	0
107	L Air/Water Balance	14,000	14,000		0	0	14,000	100	0	0
108	CO#1 Saw Cutting Plumbing	7,103	7,103		0	0	7,103	100	0	0
109	CO#2 Grease Interceptor	11,178	11,178		0	0	11,178	100	0	0
110	CO#3 Add Manhole	18,595	18,595		0	0	18,595	100	0	0
111	CO#4 Main Sanitary Drain	24,691	24,691		0	0	24,691	100	0	0
112	CO#5 Roof Sumps	4,264	4,264		0	0	4,264	100	0	0
113	CO#6 New Sinks Rm 101B	3,378	3,378		0	0	3,378	100	0	0
114	CO#7 Sewer Line Replacement	22,440	22,440		0	0	22,440	100	0	0



AIA DOCUMENT G703 • CONTINUATION SHEET FOR G702 • 1992 EDITION • AIA® • ©1992 • THE AMERICAN INSTITUTE OF ARCHITECTS, 1735 NEW YORK AVENUE, N.W., WASHINGTON, DC, 20006-5292 • WARNING: Unlicensed photocopying violates U.S. copyright laws and will subject the violator to legal prosecution.

G703-1992

CAUTION: You should use an original AIA document which has this caution printed in red. An original assures that changes will not be obscured as may occur when documents are reproduced.

# CONTINUATION SHEET

AIA DOCUMENT G703 (Instructions on reverse side)


PAGE OF 6 PAGES

AIA Document G702, APPLICATION AND CERTIFICATE FOR PAYMENT, containing Contractor's signed Certification, is attached.

In tabulations below, amounts are stated to the nearest dollar. Use Column 1 on Contracts where variable retainage for line items may apply.

APPLICATION NO: 18  
 APPLICATION DATE: 11/30/2008  
 PERIOD TO: 11/30/2008  
 ARCHITECT'S PROJECT NO:

A Item NO.	B DESCRIPTION OF WORK	C SCHEDULED VALUE	D WORK COMPLETED		E THIS PERIOD	F MATERIALS PRESENTLY STORED (NOT IN D OR E)	G TOTAL COMPLETED AND STORED TO DATE (D+E+G)		H BALANCE TO FINISH (G - C)	I RETAINAGE (IF VARIABLE RATE)
			FROM PREVIOUS APPLICATION (D + E)	THIS PERIOD			COMPLETED AND STORED TO DATE (D+E+G)	% (G ÷ C)		
115	CO#8 Gas Line Replacement	16,472	16,472	0	0	0	16,472	100	0	0
116	CO#9 Roof Drain/Move Sink	7,309	7,309	0	0	0	7,309	100	0	0
117	CO#10 Ductboard Jacket	16,402	16,402	0	0	0	16,402	100	0	0
118	CO#11 Water Coolers	3,457	3,457	0	0	0	3,457	100	0	0
119	CO#12 Remove Concrete	10,388	10,388	0	0	0	10,388	100	0	0
120	CO#13 Stilework Changes	4,702	4,702	0	0	0	4,702	100	0	0
121	CO#14 North Parking Lot	-10,197	-10,197	0	0	0	-10,197	100	0	0
122	CO#15 Damaged Conduits	-1,030	-1,030	0	0	0	-1,030	100	0	0
123	CO#16 Modify Boiler Louvers	1,770	1,770	0	0	0	1,770	100	0	0
124	CO#17 Elevator Equip Dampers	401	401	0	0	0	401	100	0	0
125	CO#18 Piping Valves	1,830	1,830	0	0	0	1,830	100	0	0
126	CO#19 Kitchen MUA Unit	1,104	1,104	0	0	0	1,104	100	0	0
127	CO#20 Replace Sidewalk	-1,581	0	-1,581	0	0	-1,581	100	0	0
128	CO#21 Replace Ceiling Tiles	-3,681	0	-3,681	0	0	-3,681	100	0	0
		2,680,995	2,686,257	-5,262	0	0	2,680,995	100	0	0



AA DOCUMENT G703 • CONTINUATION SHEET FOR G702 • 1992 EDITION • AIA® • ©1992 • THE AMERICAN INSTITUTE OF ARCHITECTS, 1735 NEW YORK AVENUE, N.W., WASHINGTON, D.C. 20006-5292 • WARNING: Unauthorized photocopying violates U.S. copyright laws and will subject the violator to legal prosecution.

G703-1992

CAUTION: You should use an original AIA document which has this caution printed in red. An original assures that changes will not be obscured as may occur when documents are reproduced.

- Automatic electronic lighting control.
- Sleek styling.
- Full coverage. No gaps.
- Adjustable sensitivity control.
- Replaceable circuit board.
- Convenient and safe for occupants. Silent.
- Combines with a Novitas Switchpack.
- Five-year warranty.

**How It Operates:**

The 01-110 is a motion sensor that controls lighting and other electrical loads automatically based on the presence or absence of people. The Sensor activates a Novitas<sup>®</sup> Switchpack to turn loads on and off.

The Sensor produces a low-intensity, inaudible sound. It detects changes in acoustic waves caused by motion such as reaching for the telephone, turning the pages of a book, walking into a room, etc. The Sensor does not respond to audible sound. When the Sensor detects motion, the relay in the connected Switchpack is closed and the lights are turned on. If no motion occurs within a pre-set period of time, the lights are turned off. To ensure continuous light when people are present, the time delay can be set from 15 seconds (for installer testing) to 30 minutes. The recommended time delay is usually 6-8 minutes. People who remain very still for long periods may need a longer time delay.

**Special Features:**

- Design ensures complete coverage in all corners of a room.
- Fixed angle position makes installation fast and accurate. No swivel to adjust. No accidental change in coverage.
- Manual override switch turns load on easily if Sensor ever fails.
- Snap-out circuit board allows fast, easy replacement without affecting hard wiring or mounting.
- Multiple frequencies can segment space for greater savings.
- Crystal control provides consistent and stable performance. Frequency variations will not exceed  $\pm 0.005$  percent.
- Up to ten Switchpacks can be controlled in a single lighting zone. Up to 20 amps per Switchpack.
- Convenient access to controls under faceplate allows for easy adjustments by installer.
- Teflon-insulated pigtail is fire-rated for ceiling plenums.
- Removable shunt prevents unnecessary "lights on" following power sweeps in facilities with computer control systems.

**Range & Coverage:**

Use in areas from 1,270 to 2,850 square feet. Minor motion coverage up to 1,872 square feet. See Coverage Diagrams. For areas outside the range of coverage, refer to other Novitas technical sheets. Multiple sensors may be wired together for complete coverage of larger areas. If partitions between 49" and 71" are present, see Coverage Diagrams. For greater partition heights, each partitioned area should be treated as an individual space with floor-to-ceiling walls. Range and coverage vary slightly according to room shape and acoustics. In "soft" rooms with carpet and drapes, coverage may be reduced by approximately 15 percent. An adjustable Sensitivity Control permits adaptation to different areas.

The NEMA WD 7 Guide and robotic method were utilized to verify coverage patterns.

**Lighting Sweep Applications:**

When Sensors are used in conjunction with computer systems that "sweep" power off at night and turn power on in the morning, the installer should remove the JP2 shunt from the printed circuit board to avoid a "lights on" following the power-on sweep (see Printed Circuit Board Diagram). In facilities where no computer sweeps are used, leave the shunt in the factory default setting.

**Multiple**
**Frequencies:**

Large open areas can be divided into individually controlled spaces without gaps in coverage. Each adjacent area can be independently controlled by using alternate frequency Sensors. Three frequencies are available:

Frequency A = 25 KHz (Standard)

Frequency B = 27 KHz

Frequency C = 32 KHz

Coverage is slightly reduced with frequencies B and C (refer to Novitas Customer Service for coverage dimensions).

**Mounting:**

The Sensor mounts through a single 3/4" hole in the ceiling tile. All hardware is provided. An adapter plate is available to allow mounting to a standard fixture ring and junction box.

**Wiring:**

Novitas Sensors are provided with Teflon-insulated pigtails. Sensors and Switchpacks are interconnected by 18 AWG Class 2 wiring per NEC 725. Use UL-recognized Teflon-insulated wire approved for plenum areas per NEC 725-7 (a) where required.

**Power Requirements:**

15 VDC from Novitas Switchpack only. Up to five Sensors may be powered from one Switchpack.


**Output:**

Open collector output can switch up to ten Novitas Switchpacks.

**Housing:**

Handsome design. Medium impact injection-molded housing. ABS resin complies with UL 94V0. Off-white color may be easily painted to match custom ceilings. Sensor guard available.


**Size & Weight:**

3-3/4" x 6" x 1" (94mm x 151mm x 24mm). DWH. Approximately 4 oz. (113.6 g).

**Installation Considerations:**

The Sensor must have a clear view of the area to be controlled. It should not be blocked from "seeing" people by high partitions. (For partitioned areas, refer to Coverage Diagrams.) The Sensor will not "see" through glass. Mounting height should be kept below 12 feet. Avoid pointing into hallways. To prevent false activation, the Sensor should be mounted four feet away from the path of strong air turbulence for standard sensitivity settings and at least six feet away for maximum sensitivity settings. Not for use where temperatures fall below 32° F or exceed 100° F. For indoor use only.

Note: The life of some compact fluorescent lamps (CFLs) is shortened by frequent automatic or manual switching. Check with CFL and ballast manufacturer to determine effects of cycling.





U.S. Letters Patent No. Des. 337,942


**Wiring Diagram**

**MODEL 01-110**

**Sensor Controls Under Coverplate**




**Printed Circuit Board Diagram**




**Minor Motion Coverage in Enclosed Rooms (1,872 Sq. Ft. Maximum)**  
(At Maximum Sensitivity)

**NON-PARTITIONED AREAS**  
No partitions or partitions under 49" in height




**PARTITIONED AREAS**  
Partition heights of 49" to 71"




**Coverage In Open Areas - Multiple Sensor Applications**  
(At Maximum Sensitivity)

**NON-PARTITIONED AREAS**  
No partitions or partitions under 49" in height




1/2 Step Walk Coverage

**PARTITIONED AREAS**  
Partition heights of 49" to 71"



Motion-At-Desk Coverage

**MAXIMUM COVERAGE**  
Major Motion





KILGORE SCHOOL

TYPE: CLASSROOM SENSOR  
CAT. #: MODEL 01-300-BAS

SUPER DUAL TECH SENSOR (TWO-WAY)

- Ultrasonic & passive infrared sensors. 360° coverage.
- Real-time self-adjusting sensitivity and time delay.
- Microprocessor-based Airflow Tolerant Technology.
- Manual On/Off switch capability.
- BAS interface with "Zero Time Delay" option.
- Immune to RFI, EMI and voltage fluctuations.
- Five-year warranty.

#### How It Operates:

The Super Dual Tech Sensor provides superior performance in lighting and HVAC control through the most effective combination of passive infrared (PIR) and ultrasonic technologies. This pairing helps eliminate false activation in rooms with heavy airflow while providing full coverage without gaps. Separate, concurrent time delays for each technology avoid inadvertent lights out in occupied rooms. Microprocessor-based Airflow Tolerant Technology™ safeguards against false activation during vacancy by filtering out the portion of the frequency spectrum related to air movement. This advanced dual tech sensor is best used to control lighting and HVAC in classrooms, computer rooms and other challenging applications.

The 01-300-BAS activates a Novitas® Switchpack to turn loads on and off. Lights turn on when the PIR sensor detects motion. In the standard configuration, lights stay on if either technology detects occupancy. When the room is vacated, lights turn off after the time delay elapses. Digital microprocessor-based circuitry allows time delay settings from 15 seconds (for installer testing) to 30 minutes. The Sensor can also be configured to maintain lighting with both technologies.

The 01-300-BAS offers the most versatile connections available. A built-in isolated Form C relay may be configured for either a Building Automation System (BAS) or Alarm system interface, via a DIP switch. When connecting the 01-300-BAS to a BAS, any of the following may be used: (1) Form C relay output, with or without time delay option, (2) open collector output, with or without built-up feature, and (3) direct BAS connection. See Power Requirements and Wiring Diagram.

#### Special Features:

- Self-adjusts sensitivity and time delay in real-time to optimize performance and minimize the need for follow-up adjustments.
- False activation from corridor activity is avoided by the self-adjusting sensitivity feature.
- Coverage remains stable regardless of environmental conditions.
- Separate, concurrent time delays for ultrasonic and infrared sensors avoid inadvertent lights out in occupied rooms.
- Simplifies installation with 10-minute time delay default when potentiometer is left at minimum setting.
- Airflow Tolerant Technology resists false activation in high airflow environments.
- DIP switch selectable lighting sweep option prevents unnecessary "lights on" following power sweeps in facilities with computer control systems.
- Internal pull-up option via shunt simplifies BAS interface.
- "Zero Time Delay" DIP switch is available in both BAS and Alarm modes for building management systems equipped with an internal lighting function.
- Complements existing security system. Alarm function avoids false alarm activation through detection redundancy testing.
- DIP switch permits override should a Sensor ever fail.
- Snap-out circuit board allows fast, easy replacement without affecting hard wiring or mounting.
- Manual On/Off option via a wall switch, BAS relay remains active during occupancy.
- Fully self-resetting; lights turned off manually in Automatic On mode turn off during occupancy. After the room is vacated and the time



Patent Pending



- A 10-second grace period allows lights to be turned on by motion anywhere in the room after being turned off due to inactivity.
- Crystal control provides consistent and stable performance. Frequency variations will not exceed ±0.005 percent.
- Bi-color LED indicates which technology detects motion.

#### Range & Coverage:

Use in areas from 300 to 1,750 square feet. Coverage for normal desktop motion is 900 square feet.

#### Mounting:

Ceiling mount permits optimum location of sensor and reduces tampering. Fixed angle position makes installation fast and accurate. The Sensor mounts through a 3/4" hole in the ceiling tile using provided hardware. An adapter plate is available to allow mounting to a standard fixture ring and junction box.

#### Wiring:

Novitas Sensors are provided with Teflon insulated pigtailed. Sensors and Switchpacks are interconnected using 18 AWG class 2 wiring per NEC 725. Use UL-recognized Teflon insulated wire for plenum areas per NEC 725-2(b) where required.

#### Power Requirements:

15 VDC from Novitas Switchpack. Up to five Sensors may be powered by one Novitas Switchpack. Direct connection to a Building Automation System is possible if the BAS provides between 10 and 30 VDC at 25mA. Sensor circuit includes jumper selectable pull-ups which enable the BAS to recognize the sensor's open collector output.

#### Output:

Up to 16 Novitas Switchpacks may be connected to one Sensor with 20 amps maximum per Switchpack.

#### Housing:

Impact-resistant injection molded housing in off-white ABS resin complies with UL 94V0. Protective sensor guard available.

#### Size & Weight:


1-5/12" x 3-3/4" x 6-1/12" (37mm x 100mm x 154mm) HDW. Approximately 6 oz. (170g).

#### Installation Considerations:


For indoor use only. For best results, mounting height should be kept below 12 feet; temperatures should be above 60°F and below 90°F. Note: The life of some compact fluorescent lamps (CFL) can be shortened by frequent automatic or manual switching.

# MODEL 01-300-BAS

## Wiring Diagram



## Printed Circuit Board Diagram



## Potentiometers




## Dip Switch




### DIP SWITCH CONTROL SIGNALS

- 1 - AUTO ON/MANUAL OFF
- 2 - LIGHTING SWEEP
- 3 - LIGHT SENSITIVITY
- 4 - US SELF-ADJUST
- 5 - IR SELF-ADJUST
- 6 - CASUALARM
- 7 - ZERO TIME DELAY
- 8 - MANUAL OVERRIDE

## Coverage in Open Areas



## Coverage in Enclosed Areas



- ULTRASONIC 1/2 STEP WALK COVERAGE
- ULTRASONIC MOTION-AT-DESK COVERAGE

# FAIL-SAFE®

## DESCRIPTION

Designed to retain the aesthetics of a commercial wraparound, Fail-Safe's FWS Series assures owners an unbreakable, maintenance free, one time installation. Ideally suited for high abuse areas that must maintain a clean, well lighted appearance, Fail-Safe's FWS comes as ceiling or wall mounted, unit to four lamp units to provide general ambient illumination.

## APPLICATION

The FWS Series is specifically designed for use in public access areas where vandalism may occur and for areas that must maintain a clean, well-lighted appearance. Ideal for schools, dormitories, hallways, locker rooms, shower facilities, and restrooms.

## SPECIFICATION FEATURES

### A - Lens

Nominal, 1/8" UV stabilized, clear K12, impact resistant, prismatic polycarbonate refractor for high efficiency, low surface brightness and maximum strength.

### B - Fasteners

Captive, stainless steel tamperproof torx-head screws prevent unauthorized access.

### C - Housing

Die-formed, 16 ga. CRS with welded end ground ends and internal weld bands for added strength. Standard white high reflectance polyester

powder coat finish. Glass: 85%; Reflectance: 93%; Hardness: Minimum: 2H; Salt Spray: 500 hours.

### D - Lamps

(By Choice)

### E - Lens Retention

Double wall lens channel captivates lens to prevent unauthorized fixture penetration.

### F - Gasket

Concealed, polyurethane end gaskets inhibit the entrance of environmental contaminants.

### G - Ballast

Copper wound HPF, rapid start, Class P, CBME™ L ballast is standard.

### Labels

U.L. listed, C.S.A. certified, standard wet label.


Catalog #	FWS-332-277V-DLS1/DLS-WS-1/GTD-VRSD	Type	CL3-GTD
Project	KILGORE SCHOOL		
Comments			
Prepared by		Date	




**FWS**

**17W - 120W**  
Fluorescent




**POLYCARBONATE**  
**HIGH ABUSE LUMINAIRE**  
Clear Prismatic or White  
1 and 3 Lamp



## SIDE DIMENSIONS



## MOUNTING DIMENSIONS




## ENERGY DATA

For Energy Management related technical data to support the performance of this fixture series, refer to the ordering information for input wattage.

PHOTOMETRICS

Candlepower Distribution



Test No. 487C  
**FWS-340-120**  
 Lamp=(1) F40T12RS/  
 WW  
 Lumens=3200  
 Spacing Criteria  
 I=1.4 II=1.2  
 Efficiency=85.0%



Candlepower

Deg.	I	II
0	2167	2167
5	2111	2167
15	2123	2044
25	2105	1975
35	1929	1867
45	1290	912
55	705	595
65	438	298
75	381	138
85	359	71
90	283	7

Zonal Lumen Summary

Zone	Lumens	%Lamp	%Luminaire
0-30	1641	17.1	31.3
0-45	2765	28.8	57.8
0-60	4137	43.7	79.0
0-80	4933	51.4	94.4
90-180	307	3.2	5.9
0-180	5240	54.8	100.0


Coefficient of Utilization

rc	80%				70%			50%		30%		10%		0%
	rw	70	50	30	10	50	30	10	50	30	50	30	10	0
RCR														
0	47	47	47	47	46	46	46	43	43	41	41	39	39	38
1	44	42	40	38	41	39	38	39	38	37	35	35	34	33
2	40	37	35	31	36	34	32	35	31	33	30	32	29	28
3	37	34	31	29	33	30	28	31	27	30	27	29	25	25
4	35	31	27	25	30	27	25	29	24	27	24	26	23	22
5	32	28	24	22	27	24	22	26	21	25	21	24	21	20
6	30	25	21	20	25	22	20	24	19	23	19	22	19	18
7	28	23	20	18	23	20	18	22	17	21	17	20	17	16
8	26	21	18	16	21	18	16	20	15	19	15	19	15	14
9	24	19	16	14	19	16	14	18	14	18	14	17	13	13
10	22	18	15	13	17	14	13	17	12	18	12	16	12	11

rc=Ceiling reflectance, rw=Wall reflectance, RCR=Room cavity ratio  
 CU Data Based on 20% Effective Floor Cavity Reflectance.

ORDERING INFORMATION

SAMPLE NUMBER: FWS-340-120-LE3-GLR



\*Data for additional options details. Color, Input & Power/Output Specifications and Dimensions subject to change without notice.  
 †For quantities other than indicated, consult branch and ordering number.  
 ‡Electronics follow ANSI standards unless noted otherwise.  
 §Products also available in non-UL508 packages and for 50/60Hz environments in metric (Consult your Cooper Lighting Representative for availability and ordering information).

# METALUX®

## DESCRIPTION

GCB is a premium grade specification troffer series. This innovative, high quality luminaire is dedicated to the latest T8 lamp and micro electronic ballast technology for optimal performance and energy efficiency. The GCB is compatible with all of today's popular ceiling systems and is available with a number of options and accessories for application versatility.

## APPLICATION

The GCB Series features efficiency, quality and performance. The series is an excellent choice for commercial office spaces, schools, hospitals or retail merchandising areas.

## SPECIFICATION FEATURES

### A - Construction

Rigid housing is die formed of code gauge prime cold rolled steel and features full length die-formed stiffeners for added strength. Side flanges are hemmed. Innovative design provides superior lens brightness uniformity and visual comfort. Micro ballast cover\*\* reduces ballast shadow for superior lens brightness uniformity and is easily removed without tools. Die formed captive lampholder brackets fully enclose lampholder wiring permitting easy lampholder replacement. Heavy endplates are securely attached with interlocking tabs and screws. Four auxiliary fixture end suspension points provided. KO's for continuous row wiring. Endplates have integral Grid-lock feature for safety and convenience.

### B - Electrical

Ballasts are CBM/ETL Class "B" and are positively secured by mounting bolts. Pressure lock lampholders, UL/CUL listed. Suitable for damp locations.\*\*

### C - Finish

Multistage, iron phosphate pretreatment ensures maximum bonding and rust inhibition. Housing and ballast cover finished with new 90% reflective white enamel for superior performance. "PAF" Painted After Fabrication nation also available.

### D - Hinging/Latching

Positive cam action spring loaded steel latches with baked white enamel finish. Safety-lock T-hinges allow hinging and latching either side.

### E - Frame/Shielding

Die formed, heavy gauge, flat steel door with reinforced mitered corners and baked white enamel finish. Flat and regressed aluminum doors also available. Positive light seals. Light stabilized 100% virgin acrylic prismatic lens. Standard #12 pattern. Numerous additional shielding options available.


Catalog #	2GC-332A125-UNV-1.8735-ER82-	Type	
	GTD		R1-GTD
Project	KILGORE SCHOOL		
Comments			
Prepared by			Date



**2GC8332**

2' X 4' TROFFER  
3 LAMP

Specification T8 Troffer



Temperature overall nominal depth

## ENERGY DATA

Input Watts:  
EB Ballast & STD Lamps  
332 (91)

ES Ballast & STD Lamps  
337 (108)

## Luminaire Efficacy Rating

LER = 81-89  
Catalog Number 2GCB-332A


Yearly Cost of 1000 lumens,  
3000 hrs. at 65 KW/h = \$31.45

\*Reference the lampballast data in the Technical Section for specific lamp/ballast requirements.

\*\* Contact The Sales Technical Support.

\*\*\* For steel ballast cover for listed lamps and appropriate wiring.

## MOUNTING DATA



## DOOR FRAMES



## LAMP CONFIGURATIONS



## CEILING COMPATIBILITY

B	G	E	F	C	Ceiling Type	Troffer Type
Grid Only - Standard	Recessed T	Steel Grid	Hinged T-Tray With Supporting Overlays	Modular Tray With Supporting Swing Gates	Exposed Grid Concealed T Steel Grid	B C A

PHOTOMETRICS



**2GC8-332A-PAF**  
Electronic Ballast  
(3) F032/35K lamps  
2800 lumens  
Spacing criterion:  
JL 1.2 x mounting  
height, (L) 1.3 x  
mounting height  
Efficiency 83.0%  
Test Report  
2GC8332A-PAF-HPPIES  
LER = FL-73  
Yearly Cost of 1000  
lumens, 3000 hrs at  
.08 KWH = \$3.29

Angle	Along B	45	Across L
0	2998	2988	2988
5	2979	2979	2982
10	2961	2961	2975
15	2946	2942	2962
20	2934	2940	2957
25	2925	2942	2952
30	2920	2937	2947
35	2919	2933	2943
40	2921	2930	2940
45	2925	2927	2938
50	2931	2925	2937
55	2938	2924	2936
60	2946	2923	2935
65	2954	2922	2934
70	2961	2921	2933
75	2967	2920	2932
80	2972	2919	2931
85	2976	2918	2930
90	2979	2917	2929
95	2980	2916	2928
100	2980	2915	2927

Coefficients of Utilization

H/W	Effective floor cavity reflectance					
	80%	70%	50%	30%	10%	0%
0	95	88	80	69	57	42
1	81	67	59	48	37	23
2	63	51	43	32	21	10
3	51	40	32	21	10	5
4	42	31	23	12	6	3
5	35	24	16	8	4	2
6	30	20	13	6	3	1
7	26	17	10	4	2	0
8	23	15	8	3	1	0
9	21	13	6	2	0	0
10	20	12	5	1	0	0

Zonal Lumen Summary


Zone	Lumens	Slamp	Sfactors
0-20	3124	25.3	12.5
0-40	3484	27.5	14.1
0-60	3817	30.9	15.6
0-80	4119	33.5	16.9
0-100	4395	35.5	18.0

Typical VCP Percentages

Room Size (Ft <sup>2</sup> )	Height Along	Height Across
20 x 20	8.5	10.0
30 x 30	8.5	10.0
40 x 40	8.5	10.0
50 x 50	8.5	10.0
60 x 60	8.5	10.0
80 x 80	8.5	10.0
100 x 100	8.5	10.0

ORDERING INFORMATION

SAMPLE NUMBER: 2GC8-332A-120V-EB81-D



<sup>1</sup>0% to 10% of total lumens. <sup>2</sup>Acyl<sup>3</sup> is a registered trademark of Acyl<sup>3</sup> Lighting Systems. <sup>3</sup>Standard of acrylic values are given in feet. <sup>4</sup>For details on available voltages, visit our website. <sup>5</sup>Not available for use in California. <sup>6</sup>Not available for use in California. <sup>7</sup>Not available for use in California.

See website & accessories for more information. Contact your local lighting distributor.



**2GC8-332A**  
Electronic Ballast  
(3) F032/35K lamps  
2800 lumens  
Spacing criterion:  
JL 1.2 x mounting  
height, (L) 1.3 x  
mounting height  
Efficiency 81.3%  
Test Report  
2GC8332A-JFS  
LER = FL-69  
Yearly Cost of 1000  
lumens, 3000 hrs at  
.08 KWH = \$3.45

Angle	Along B	45	Across L
0	2821	2834	2834
5	2802	2825	2824
10	2783	2816	2813
15	2766	2807	2801
20	2751	2800	2791
25	2738	2793	2781
30	2727	2787	2771
35	2718	2782	2761
40	2711	2777	2751
45	2706	2773	2741
50	2703	2770	2731
55	2701	2767	2721
60	2700	2764	2711
65	2700	2761	2701
70	2700	2758	2691
75	2700	2755	2681
80	2700	2752	2671
85	2700	2749	2661
90	2700	2746	2651
95	2700	2743	2641
100	2700	2740	2631

Coefficients of Utilization

H/W	Effective floor cavity reflectance					
	80%	70%	50%	30%	10%	0%
0	95	88	80	69	57	42
1	81	67	59	48	37	23
2	63	51	43	32	21	10
3	51	40	32	21	10	5
4	42	31	23	12	6	3
5	35	24	16	8	4	2
6	30	20	13	6	3	1
7	26	17	10	4	2	0
8	23	15	8	3	1	0
9	21	13	6	2	0	0
10	20	12	5	1	0	0

Zonal Lumen Summary

Zone	Lumens	Slamp	Sfactors
0-20	2928	24.9	11.5
0-40	3270	27.0	13.0
0-60	3570	29.2	14.5
0-80	3828	31.5	15.8
0-100	4055	33.6	16.9

Typical VCP Percentages

Room Size (Ft <sup>2</sup> )	Height Along	Height Across
20 x 20	8.5	10.0
30 x 30	8.5	10.0
40 x 40	8.5	10.0
50 x 50	8.5	10.0
60 x 60	8.5	10.0
80 x 80	8.5	10.0
100 x 100	8.5	10.0

# METALUX®

## DESCRIPTION

GCB is a premium grade specification lamp troffer series. This innovative, high quality luminaire is dedicated to the latest T8 lamp and micro electronic ballast technology for optimal performance and energy efficiency. The GCB is compatible with all of today's popular ceiling systems and is available with a number of options and accessories for application versatility.

## APPLICATION

The GCB Series features efficiency, quality and performance. The series is an excellent choice for commercial office spaces, schools, hospitals or retail merchandising areas.

## SPECIFICATION FEATURES

### A - Construction

Rigid housing is die formed of code gauge prime cold rolled steel and features full length die-formed stiffeners for added strength. Side flanges are hemmed. Innovative design provides superior lens brightness uniformity and visual comfort. Micro ballast cover<sup>1,2</sup> reduces ballast shadow for superior lens brightness uniformity and is easily removed without tools. Die formed captive lampholder brackets fully enclose lampholder wiring permitting easy lampholder replacement. Heavy endplates are securely attached with interlocking tabs and screws. Four auxiliary fixture and suspension points provided. KOs for continuous mw wiring. Endplates have integral Grid-lock feature for safety and convenience.

### B - Electrical

Ballasts are CBM/ETL Class "P" and are positively secured by mounting bolts. Pressure lock lampholders, UL/CUL listed. Suitable for damp locations.<sup>3,4</sup>

### C - Finish

Multistage, iron phosphate pretreatment ensures maximum bonding and rust inhibition. Housing and ballast cover finished with new 90% reflective white enamel for superior performance. "PAP" Painted After Fabrication option also available.

### D - Hinging/Latching

Positive cam action spring loaded steel latches with baked white enamel finish. Safety-lock T-linges allow hinging and latching either side.

### E - Frame/Shielding

Die formed, heavy gauge, flat steel door with reinforced mitered corners and baked white enamel finish. Flat and regressed aluminum doors also available. Positive light seal. Light stabilized 100% virgin acrylic prismatic lens. Standard #12 pattern. Numerous additional shielding options available.


Catalog #	2GC-332A125-UNV L8735-ER82	Type	
Project	KILGORE SCHOOL		R1
Comments			
Prepared by		Date	



**2GC8332**

2' X 4' TROFFER  
3 LAMP

Specification T8 Troffer



Maximum overall mounting depth

## ENERGY DATA

Input Watts  
FF Ballast & STD Lamps  
332 (911)

ES Ballast & STD Lamps  
332 (103)

## Luminaire Efficiency Rating

LER = TL-69

Catalog Number 2GC8332A

Yearly Cost of 1000 Hours,  
3000 hrs. at .08 KWH = \$3.45

<sup>1</sup>Reference the lamp/ballast data in the Technical Section for specific lamp/ballast requirements.

<sup>2</sup>Consult Pre-Sales Technical Support.

<sup>3</sup>Full sized ballast cover for dual lamps and emergency option.

## MOUNTING DATA



## DOOR FRAMES

DLR  
Flat, 30-30  
Text

COFPA  
Flat, Enamel  
White, 2 years

FLRMC  
Flat, Regressed,  
Enamel, 2 years, 2 years



## LAMP CONFIGURATIONS



## CEILING COMPATIBILITY

G	G	G	F	C	Ceiling Type	Trim Type
Grid/Lay-in Standard	Grid/Lay-in Standard	Slot Grid	Flange Trim With Supporting Swing Gates	Module Trim With Supporting Swing Gates	Exposed Grid	G
					Exposed T	G
					Sec Grid	G
					Flange	F
					Metal Pins	E

For full compatibility, consult





## DESCRIPTION

The Paralux III Series features recessed aesthetics and the latest in energy efficient technology. The luminaire incorporates a true 3" deep precision cell louver into a nominal 5-1/2" deep para-contoured fixture housing. This combination creates a total high performance parabolic optical assembly for optimum performance. The series is compatible with all of today's popular ceiling systems and is available with a number of options and accessories for application versatility.

## APPLICATION

The high performance luminaire is designed to offer maximum efficiency and performance for today's unique interior specifications. The Paralux III series is an excellent choice for commercial office spaces, schools, hospitals or retail merchandising areas.

## SPECIFICATION FEATURES

### A - Construction

Nominal 5-1/2" deep, para-contoured housing, die formed of code gauge, prime cold rolled steel. Die embossed housing has full length die formed stiffeners for added strength. Contoured ballast/wireway cover is easily removed without tools. Die formed captive lampholder bracket fully encloses lampholder wiring permitting easy lampholder replacement. Heavy end plates are securely attached with interlocking tabs and screws. Four auxiliary fixture end suspension points provided, KOs for continuous row wiring. End plates have label saving integral Grid-Lock feature for safety and convenience. Housing features enable fixture to be converted from Grid to T-top or vice versa in the field.\*

### B - Electrical\*\*

Ballasts are CBMETL Class "P" and are positively secured by mounting bolts. Pressure lock lampholders. UL/CUL listed. Suitable for damp locations.

### C - Finish


Lighting grade, baked white enamel finish. Multistage, iron phosphate pretreatment ensures maximum bonding and rust inhibition.

### D - Hinging/Latching

Positive cam action spring loaded, self locking, black steel latches. Safety lock T-hinges allow hinging and latching either side.

### E - Louver

Die formed of low iridescent, vertical grain anodized aluminum. Finish is Anodic oxide coating. Accurate precision parabolic cells are held in place with interlocking feature. True-cut mitered corners. Black reveal with integral mechanical light seal around entire perimeter of louver. Louver protected from construction contaminants by polyethylene cover.



**2EP3GAX340**  
**332**

**18 Cell**

**2' X 4' PARABOLIC  
3 LAMP  
SEMI-SPECULAR OR  
SPECULAR LOUVER**

Paralux III  
Recessed Static or  
Air Supply Troffer



## ENERGY DATA

Input Watts  
EB Ballast & STD Lamps  
340 (110)  
332 (97)

ES Ballast & STD Lamps  
340 (110)  
332 (100)

Luminaire Efficacy Rating

LER = FP-60

Catalog Number: 2EP3GAX-332


Yearly Cost of 1000 lumens,  
3000 hrs. at .08 KWH = \$4.00

\*Conversion available in housing only. Approximate at adding third assemblies must be allowed.


\*\*Theoretical maximum ballast data in the Technical Data on our specific ballast rated for only.



## MOUNTING DATA



## LAMP CONFIGURATIONS



## CEILING COMPATIBILITY

G	I	T	F	M2	Ceiling Type	Trim Type
Grid-Layer Standard	Concealed T	Slot Grid	Frope Trim With Supporting Swing Gates	M2 Modular Trim With Supporting Swing Gates	Exposed Grid Concealed T Slot Grid Frope Concealed Spine Metal Pan	Grid T-top T-top T-top M2 M2
Verify compatibility / consult the Sales Technical Support.						



PHOTOMETRICS



**2EP3GAX-332S36I**  
Electronic Ballast  
F32/35K Lamps  
2800 Lumens

Spacing criterion  
(III) 1.2 x mounting  
height, (I) 1.6 x  
mounting height  
Efficiency 69.4%

Test Report:  
2EP3GAX332S36IES  
LER - FP-60

Yearly Cost of 1000  
lumens, 3000 hrs at  
.38 kWh = \$4.00

Coefficients of Utilization

RCR	Effective floor cavity reflectance																							
	80%				70%				50%				30%				10%				0%			
	rc	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0		
0	63	53	33	23	81	71	51	31	77	67	47	74	64	44	71	61	41	69						
1	78	71	73	77	78	73	71	70	71	68	58	69	67	65	68	65	64	62						
2	77	68	64	61	71	67	63	60	64	62	60	62	60	58	60	58	57	55						
3	67	61	67	63	66	60	56	53	58	55	52	56	52	51	55	52	50	49						
4	62	55	50	46	61	54	50	46	53	48	45	51	48	45	50	47	44	43						
5	57	48	44	40	55	49	44	40	47	43	39	45	42	39	45	41	39	37						
6	53	45	39	35	52	44	38	35	43	38	35	42	38	34	41	37	34	33						
7	49	40	35	31	48	40	34	31	39	34	30	38	33	30	37	33	30	29						
8	45	38	30	27	44	35	30	26	35	30	26	34	29	26	33	29	26	25						
9	41	32	27	23	40	32	26	22	31	26	22	30	25	23	29	25	22	21						
10	38	29	24	20	37	29	24	20	28	23	20	27	23	20	27	23	20	19						

Candela

Angle	Along II	45°	Across
0	2712	2312	2312
5	2295	2300	2324
10	2251	2289	2347
15	2189	2274	2368
20	2108	2258	2451
25	2067	2236	2506
30	1991	2208	2638
35	1932	2173	2769
40	1817	2153	2880
45	1449	2001	1423
50	1267	1460	980
55	1043	885	807
60	782	571	656
65	443	325	243
70	142	106	79
75	46	38	35
80	18	16	15
85	6	5	4
90	0	0	0

Zonal Lumen Summary


Zone	Lumens	% Lamp	% Fixture
0-30	1935	22.7	22.6
3-40	3995	45.7	45.0
4-50	5425	64.0	63.0
0-90	3834	44.4	100.0
0-180	5834	68.4	100.0

Typical VCP Percentages

Room Size (ft)	Height Along		Height Across	
	8.5'	10.0'	8.5'	10.0'
70 x 20	76	73	39	26
30 x 36	84	78	87	89
22 x 61	36	33	89	86
66 x 23	89	82	88	88
60 x 60	88	85	90	89

ORDERING INFORMATION

SAMPLE NUMBER: 2EP3GAX-332S36I-120V-LD81-U



LEOCB<sup>®</sup> type and placement of lamp are available in heat removal<sup>2</sup> An EM ballast is recommended for all EM lighting systems.<sup>3</sup> Convertible applies to mounting only, accessory mounting not a assembly mounting ballast.<sup>4</sup> Standard electronic ballast on starting failure.<sup>5</sup> Product not available in all US voltage and frequency for intensity of market. \* Not available when mounting fluorescent ballast on fixture.<sup>6</sup>

SHIPPING INFORMATION

Catalog No.	Wt.
2EP3GAX-332S36I	62 lbs

## DESCRIPTION

The Paralux III Series features recessed aesthetics and the latest in energy efficient technology. The luminaire incorporates a true 3" deep precision cell louver into a nominal 5-1/2" deep para-contoured fixture housing. This combination creates a total high performance parabolic optical assembly for optimum performance. The series is compatible with all of today's popular ceiling systems and is available with a number of options and accessories for application versatility.

## APPLICATION

The high performance luminaire is designed to offer maximum efficiency and performance for today's unique interior specifications. The Paralux III series is an excellent choice for commercial office spaces, schools, hospitals or retail merchandising areas.

## SPECIFICATION FEATURES

### A - Construction

Nominal 5-1/2" deep, para-contoured housing, die formed of code gauge, prime cold rolled steel. Die embossed housing has full length die formed stiffeners for added strength. Contoured ballast/wireway cover is easily removed without tools. Die formed captive lampholder bracket fully encloses lampholder wiring permitting easy lampholder replacement. Heavy end plates are securely attached with interlocking tabs and screws. Four auxiliary fixture end suspension points provided, KQs for continuous row wiring. End plates have labor saving integral GridLock feature for safety and convenience. Housing features enable fixture to be converted from Grid to T-option or vice versa in the field.\*

### B - Electrical\*\*

Ballasts are CBM/ETL Class "P" and are positively secured by mounting bolts. Pressure lock lampholders. UL/CUL listed. Suitable for damp locations.

### C - Finish


Lighting grade, baked white enamel finish. Multistage, iron phosphate pretreatment ensures maximum bonding and rust inhibition.

### D - Hinging/Latching


Positive cam action spring loaded, self locking, blank steel latches. Safety lock hinges allow hinging and latching either side.

### E - Louver


Die formed of low iron descent, vertical grain anodized aluminum. Finish is Anodic oxide coating. Accurate precision parabolic cells are held in place with interlocking feature. True-cut mitered corners. Black reveal with integral mechanical light seal around entire perimeter of louver. Louver protected from construction contaminants by polyethylene cover.



## MOUNTING DATA



## LAMP CONFIGURATIONS



## CEILING COMPATIBILITY

D	T	T	F	M2	Ceiling Type	Trim Type
Grid/Lay In Standard	Concealed T	Slot Grid	Large Trim With Supporting Spring Clips	Modular Trim With Supporting Swing Gates	Exposed Grid	G
					Concealed T	G or T
					Slot Grid	Slot T
					Plano	F
					Concealed Splice	M2
					Modular	M2

\*Verify compatibility (convert) Pre Sales Technical Support.

Catalog #	2EP3GX-332S36I-UNV-LB735-ER82-2BC	Type	
Project	KILGORE SCHOOL		R2/R3
Comments			
Prepared by		Date	



**2EP3GAX340  
332**

18 Cell

2' X 4' PARABOLIC  
1 LAMP  
SEMI-SPECULAR OR  
SPECULAR LOUVER

Paralux III  
Recessed Grid or  
Air Supply Traffer



## ENERGY DATA

Input Watts:  
EB Ballast & STD Lamps  
340 (136)  
332 (137)

ES Ballast & STD Lamps  
340 (136)  
332 (136)

Luminaire Efficacy Rating  
LER = 110-60  
Catalog Number: 2EP3GAX-332

Yearly Cost of 1000 lumens,  
3000 hrs at .08 KWH = \$4.32

\*Compatibility applies to housing only. Accessories with existing metal assemblies must be utilized.

\*\*Reference the lamp/fixture data in the technical section for specific lamp/fixture requirements.





## DESCRIPTION

GC8 is a premium grade specification lensed troffer series. This innovative, high quality luminaire is dedicated to the latest T8 lamp and micro electronic ballast technology for optimal performance and energy efficiency. The GC8 is compatible with all of today's popular ceiling systems and is available with a number of options and accessories for application versatility.

## APPLICATION

The GC8 Series features efficiency, quality and performance. The series is an excellent choice for commercial office spaces, schools, hospitals or retail merchandising areas.

## SPECIFICATION FEATURES

### A - Construction

Rigid housing is die formed of code gauge prime cold rolled steel and features full length die-formed stiffeners for added strength. Side flanges are hemmed. Innovative design provides superior lens brightness uniformity and visual comfort. Micro ballast cover\*\*\* reduces ballast shadow for superior lens brightness uniformity and is easily removed without tools. Die formed captive lampholder brackets fully enclose lampholder wiring permitting easy lampholder replacement. Heavy endplates are securely attached with interlocking tabs and screws. Four auxiliary fixture end suspension points provided. KDs for continuous row wiring. Endplates have integral Grid-lock feature for safety and convenience.

### B - Electrical

Ballasts are CBM/ETL Class "P" and are positively secured by mounting bolts. Pressure lock lampholders, UL/CUL listed. Suitable for damp locations.\*\*

### C - Finish

Multistage, iron phosphate pretreatment ensures maximum bonding and rust inhibition. Housing and ballast cover finished with new 90% reflective white enamel for superior performance. "PAF" Painted After Fabrication option also available.

### D - Hinging/Latching

Positive cam action spring loaded steel latches with baked white enamel finish. Safety-lock T-hinges allow hinging and latching either side.

### E - Frame/Shielding

Die formed, heavy gauge, flat steel door with reinforced mitered corners and baked white enamel finish. Flat and regressed aluminum doors also available. Positive light seals. Light stabilized 100% virgin acrylic prismatic lens. Standard #12 pattern. Numerous additional shielding options available.


Catalog #	2GC-332A125-UNV-L8735-ER81-	TYPE	
	GTD		
Project	KILGORE SCHOOL		R4-GTD
Comments:			
Prepared by		Date	



**2GC8332**

2' X 4' TROFFER  
3 LAMP

Specification 18 Troffer



Maximum overall nominal depth

## ENERGY DATA

Input Watts:  
EB Ballast & STD Lamps  
332 (181)

ES Ballast & GTD Lamps  
332 (186)

Luminaire Efficacy Rating

1 ER = FL-69

Catalog Number: 2GC8-332A


Yearly Cost of 1000 lumens,  
3000 hrs at .08 KW/H = \$3.40

\*Please see the technical data in the Technical Section for specific lamp/shield requirements.

\*\*Consult Pre Sales Technical Support.

\*\*\*Fluorescent ballast cover for dual lamps and emergency option.


## MOUNTING DATA



## DOOR FRAMES



## LAMP CONFIGURATIONS



## CEILING COMPATIBILITY

G	B	G	F	C	Ceiling Type	Trim Type
Grid/Key-in Standard	Concrete T	Slot Grid	Flange Trim With Supporting Swag Gates	Module Trim With Supporting Swag Gates	Exposed/Out G Gypsum I Slot Grid Flange Metal Pie	G G G E C

COOPER LIGHTING

ADF031937  
(Supersedes ADF021376)



PHOTOMETRICS



**2GC8-332A-PAF**  
Electronic Ballast  
(3) F032/35K Lamps  
2800 lumens  
Spacing criteria:  
(H) 1.2 x mounting  
height, (L) 1.3 x  
mounting height  
Efficiency 83.0%  
Test Report:  
2GC8332A-PAF-00PPLES  
LER = FL-33  
Yearly Cost of 1000  
lumens, 3000 hrs at  
CR kWh = \$3.29

Candela			
Angle	Along H	45°	Across L
0	2828	2323	2048
5	2623	2179	1856
10	2441	2025	1678
15	2285	1872	1515
20	2151	1730	1367
25	2036	1597	1234
30	1937	1474	1115
35	1852	1361	1009
40	1781	1257	916
45	1722	1162	835
50	1673	1076	764
55	1633	998	703
60	1599	928	651
65	1571	864	607
70	1548	806	571
75	1529	754	541
80	1513	707	516
85	1500	665	492
90	1490	627	469

Coefficients of Utilization

CR	Effective Room cavity reflectance 20%												
	30%	40%	50%	60%	70%	80%	90%	10%	20%	30%	40%	50%	
1	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8
2	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
3	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6
4	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
5	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
6	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3
7	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
8	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Zonal Lumen Summary

Zone	Lumens	Lamp	Fixture
0-0	2124	35.4	38.5
0-40	2484	21.5	42.0
0-50	5071	68.2	84.0
0-90	6975	53.1	100.5
0-100	5975	53.0	100.7

Typical VCP Percentages

Beam Size (ft.)	Height Along	Height Across
1.5' x 2.5'	6.5'	10.0'
2' x 2'	6.5'	10.0'
3' x 3'	14.1'	10.0'
3' x 4'	14.1'	14.1'
3' x 5'	14.1'	17.7'
4' x 6'	14.1'	24.4'



**2GC8-332A**  
Electronic Ballast  
(3) F032/35K Lamps  
2800 lumens  
Spacing criteria:  
(H) 1.2 x mounting  
height, (L) 1.3 x  
mounting height  
Efficiency 81.6%  
Test Report:  
2GC8332A-IES  
LER = FL-68  
Yearly Cost of 1000  
lumens, 3000 hrs at  
CR kWh = \$3.45

Candela			
Angle	Along H	45°	Across L
0	2624	2124	1824
5	2424	1974	1634
10	2242	1824	1452
15	2082	1674	1282
20	1942	1524	1122
25	1814	1374	972
30	1704	1224	832
35	1604	1074	702
40	1514	924	582
45	1434	774	472
50	1362	624	372
55	1298	474	282
60	1242	324	192
65	1192	174	102
70	1148	24	12
75	1110	0	0
80	1078	0	0

Coefficients of Utilization

CR	Effective Room cavity reflectance 20%												
	30%	40%	50%	60%	70%	80%	90%	10%	20%	30%	40%	50%	
1	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8
2	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7	0.7
3	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6
4	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5	0.5
5	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4	0.4
6	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3
7	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
8	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1
9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Zonal Lumen Summary


Zone	Lumens	Lamp	Fixture
0-0	2081	24.5	30.5
0-40	2429	21.5	50.0
0-50	5785	83.7	84.1
0-90	6895	51.6	100.0
0-100	6185	47.8	100.0

Typical VCP Percentages

Beam Size (ft.)	Height Along	Height Across
1.5' x 2.5'	6.4'	10.0'
2' x 2'	6.4'	10.0'
3' x 3'	14.0'	10.0'
3' x 4'	14.0'	14.0'
3' x 5'	14.0'	17.6'
4' x 6'	14.0'	24.2'

ORDERING INFORMATION

SAMPLE NUMBER 2GC8-332A-120V-EBB1-U



Notes: 1) Actual beam diameter is approximately 10% larger than nominal. 2) Standard electronic ballast compartment of 3-lamp fixture. 3) 4-lamp also available in non-US voltage and frequencies for international markets. 4) Not available when ordering emergency ballast. Voltage must be specified.

Specifications and product data are subject to change without notice. Contact your Cooper Lighting representative for availability and ordering information.

## DESCRIPTION

GC8 is a premium grade specification lensed troffer series. This innovative, high quality luminaire is dedicated to the latest T8 lamp and micro electronic ballast technology for optimal performance and energy efficiency. The GC8 is compatible with all of today's popular ceiling systems and is available with a number of options and accessories for application versatility.

## APPLICATION

The GC8 Series features efficiency, quality and performance. The series is an excellent choice for commercial office spaces, schools, hospitals or retail merchandising areas.

## SPECIFICATION FEATURES

### A - Construction

Rigid housing is die formed of code gauge prime cold rolled steel and features full length die-formed stiffeners for added strength. Side flanges are hemmed. Innovative design provides superior lens brightness uniformity and visual comfort. Micro ballast cover\*\* reduces ballast shadow for superior lens brightness uniformity and is easily removed without tools. Die formed captive lampholder brackets fully enclose lampholder wiring permitting easy lampholder replacement. Heavy endplates are securely attached with interlocking tabs and screws. Four auxiliary fixture end suspension points provided. KO's for continuous row wiring. Endplates have integral Grid-lock feature for safety and convenience.

### B - Electrical

Ballasts are CBM/ETL Class "P" and are positively secured by mounting bolts. Pressure lock lampholders, U/CUL listed. Suitable for damp locations.\*\*

### C - Finish

Multistage, iron phosphate pretreatment ensures maximum bonding and rust inhibition. Housing and ballast cover finished with new 90% reflective white enamel for superior performance. "PAF" Painted After Fabrication option also available.


### D - Hinging/Latching

Positive cam action spring loaded steel latches with baked white enamel finish. Safety-lock T-hinges allow hinging and latching either side.

### E - Frame/Shielding

Die formed, heavy gauge, flat steel door with reinforced internal corners and baked white enamel finish. Flat and regressed aluminum doors also available. Positive light seal. Light stabilized 100% virgin acrylic prismatic lens. Standard #12 pattern. Numerous additional shielding options available.


Catalog #	2GC-332A125-UNV-L8735-ER81	Type	
Project	KILGORE SCHOOL		R4
Comments			
Prepared by		Date	



**2GC8332**


2' X 4' TROFFER  
3 LAMP

Specification T8 Troffer



\*Maximum overall non-rail depth

## MOUNTING DATA



## DOOR FRAMES

007 Flat White Steel  
0082 Flat Silver White Enamel  
0083 Flat Regressed Extruded Veneer Aluminum



## LAMP CONFIGURATIONS



## CEILING COMPATIBILITY

G Gridkey® Standard	H Concealed	N Slot Grid	F Flange Trim With Supporting Grids	C Modular Trim With Supporting Swing Codes	Coiling Type	Trim Type
					Exposed Grid	A
					Concealed	B
					Slot Grid	G
					Flange	F
					Metal Pan	D
Verify ceiling compatibility with your installer.						

## ENERGY DATA

Input Watts:  
FB Ballast & STD Lamps  
332 (91)

EG Ballast & STD Lamps  
332 (106)

## Luminaire Efficacy Rating:

1FR - FL80

Catalog Number: 2GC8-332A

## Yearly Cost of 1000 lumens:

Approx. \$1.00 (US) (1000h) = \$5.40

Reference the application note in the Technical Section for specific installation requirements.

\*\*Consult the Sales Technical Support.

\*\*Not listed ballast code for bi-pin lamps and emergency options.




**PHOTOMETRICS**



**ZGC8-332A-PAF**  
Electronic Ballast  
(3) FO32/35K lumens  
2800 lumens  
Spacing criterion:  
10) 1.2 x mounting  
height (1.1 x 1.3 x  
mounting height  
Efficiency 83.0%  
Test Report:  
ZGC8332A-PAF-IES  
LER = FL-73  
Yearly Cost of 1000  
lumens, 3000 hrs at  
.08 KWH = \$3.29

**Candela**

Angle	Along	45	Across
0	2955	2886	2666
5	2913	2803	2666
10	2861	2693	2670
15	2800	2582	2662
20	2667	2546	2662
25	2582	2487	2652
30	2446	2457	2643
35	2300	2435	2636
40	2161	2420	2631
45	1992	2411	2629
50	1832	2404	2628
55	1684	2400	2627
60	1547	2397	2626
65	1420	2394	2625
70	1302	2391	2624
75	1192	2388	2623
80	1090	2385	2622
85	995	2382	2621
90	907	2379	2620
95	825	2375	2619
100	748	2371	2618
105	675	2367	2617
110	606	2362	2616
115	541	2357	2615
120	479	2352	2614
125	420	2347	2613
130	364	2342	2612
135	311	2337	2611
140	260	2332	2610
145	211	2327	2609
150	164	2322	2608
155	119	2317	2607
160	76	2312	2606
165	35	2307	2605
170	0	2302	2604
175	0	2297	2603
180	0	2292	2602



**ZGC8-332A**  
Electronic Ballast  
(3) FO32/35K lumens  
2800 lumens  
Spacing criterion:  
10) 1.2 x mounting  
height (1.1 x 1.3 x  
mounting height  
Efficiency 81.8%  
Test Report:  
ZGC8332A-IES  
LER = FL-69  
Yearly Cost of 1000  
lumens, 3000 hrs at  
.08 KWH = \$3.46

**Candela**

Angle	Along	45	Across
0	2924	2833	2624
5	2882	2750	2624
10	2830	2660	2624
15	2769	2569	2624
20	2699	2481	2624
25	2614	2400	2624
30	2514	2327	2624
35	2400	2261	2624
40	2274	2200	2624
45	2136	2144	2624
50	1987	2092	2624
55	1828	2043	2624
60	1660	1997	2624
65	1484	1954	2624
70	1302	1913	2624
75	1116	1873	2624
80	927	1834	2624
85	735	1795	2624
90	541	1757	2624
95	346	1720	2624
100	152	1683	2624
105	0	1646	2624
110	0	1610	2624
115	0	1574	2624
120	0	1538	2624
125	0	1503	2624
130	0	1467	2624
135	0	1432	2624
140	0	1397	2624
145	0	1362	2624
150	0	1327	2624
155	0	1292	2624
160	0	1257	2624
165	0	1222	2624
170	0	1187	2624
175	0	1152	2624
180	0	1117	2624

**Coefficients of Utilization**

Effective floor cavity reflectance = 20%

LR	60%	70%	80%	90%	10%	20%	30%	40%	50%	60%	70%	80%	90%	10%
1	0.90	0.80	0.70	0.60	0.50	0.40	0.30	0.20	0.10	0.00	0.00	0.00	0.00	0.00
2	0.87	0.77	0.67	0.57	0.47	0.37	0.27	0.17	0.07	0.00	0.00	0.00	0.00	0.00
3	0.84	0.74	0.64	0.54	0.44	0.34	0.24	0.14	0.04	0.00	0.00	0.00	0.00	0.00
4	0.81	0.71	0.61	0.51	0.41	0.31	0.21	0.11	0.01	0.00	0.00	0.00	0.00	0.00
5	0.78	0.68	0.58	0.48	0.38	0.28	0.18	0.08	0.00	0.00	0.00	0.00	0.00	0.00
6	0.75	0.65	0.55	0.45	0.35	0.25	0.15	0.05	0.00	0.00	0.00	0.00	0.00	0.00
7	0.72	0.62	0.52	0.42	0.32	0.22	0.12	0.02	0.00	0.00	0.00	0.00	0.00	0.00
8	0.69	0.59	0.49	0.39	0.29	0.19	0.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00
9	0.66	0.56	0.46	0.36	0.26	0.16	0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00
10	0.63	0.53	0.43	0.33	0.23	0.13	0.03	0.00	0.00	0.00	0.00	0.00	0.00	0.00

**Coefficients of Utilization**

Effective floor cavity reflectance = 20%

LR	60%	70%	80%	90%	10%	20%	30%	40%	50%	60%	70%	80%	90%	10%
1	0.97	0.87	0.77	0.67	0.57	0.47	0.37	0.27	0.17	0.07	0.00	0.00	0.00	0.00
2	0.94	0.84	0.74	0.64	0.54	0.44	0.34	0.24	0.14	0.04	0.00	0.00	0.00	0.00
3	0.91	0.81	0.71	0.61	0.51	0.41	0.31	0.21	0.11	0.01	0.00	0.00	0.00	0.00
4	0.88	0.78	0.68	0.58	0.48	0.38	0.28	0.18	0.08	0.00	0.00	0.00	0.00	0.00
5	0.85	0.75	0.65	0.55	0.45	0.35	0.25	0.15	0.05	0.00	0.00	0.00	0.00	0.00
6	0.82	0.72	0.62	0.52	0.42	0.32	0.22	0.12	0.02	0.00	0.00	0.00	0.00	0.00
7	0.79	0.69	0.59	0.49	0.39	0.29	0.19	0.09	0.00	0.00	0.00	0.00	0.00	0.00
8	0.76	0.66	0.56	0.46	0.36	0.26	0.16	0.06	0.00	0.00	0.00	0.00	0.00	0.00
9	0.73	0.63	0.53	0.43	0.33	0.23	0.13	0.03	0.00	0.00	0.00	0.00	0.00	0.00
10	0.70	0.60	0.50	0.40	0.30	0.20	0.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00

**Zonal Lumen Summary**


Zone	Lumens	%Lumen	%Fixture	Beam Size (ft.)	Height Along	Height Across
1	272	25.3	30.5	20.0 x 20.0	8.5'	15.8'
2	3482	47.1	45.6	20.0 x 20.0	5.1'	6.1'
3	5881	69.8	44.2	20.0 x 20.0	4.1'	4.4'
4	8912	92.6	19.0	20.0 x 20.0	6.0'	6.3'
5	9375	93.0	19.0	20.0 x 20.0	5.1'	5.3'


**Zonal Lumen Summary**

Zone	Lumens	%Lumen	%Fixture	Beam Size (ft.)	Height Along	Height Across
1	2033	21.9	20.5	20.0 x 20.0	8.5'	15.8'
2	4129	45.8	45.0	20.0 x 20.0	5.1'	6.1'
3	5760	63.1	44.1	20.0 x 20.0	4.1'	4.4'
4	8555	93.6	19.0	20.0 x 20.0	6.0'	6.3'
5	8555	93.6	19.0	20.0 x 20.0	5.1'	5.3'

**ORDERING INFORMATION**

SAMPLE NUMBER: ZGC8-332A-120V-EB81-U





Suspended

3 T8

Direct/Indirect

9506T03 or 9507T03 C/R

High performance optical system designed to accommodate up to four T8 or T5/HO lamps.

Available in a wide range of factory colors.

Three lighting distributions to choose from: Direct/Indirect, Semi-indirect, or Indirect.

Factory pre-wired with quick-wire connectors for fast, easy installation.

Affordable pricing & fast delivery - standard orders can ship in 9 working days.




Order Number Guide

→ <10% PROGRAMMED RAPID START BALLAST


<b>950</b> Series Centris	<b>T03</b> Lamps 3 T8	<b>Lower Optics</b> C - Solid baffle w/ solid housing D - Round perf baffle w/ solid housing	<b>Upper Optics</b> N - None (30% Down) F - Dust cover D - V0 Kit (Variable Optics) Y - Lamp separator <small>*Not available with H or F Optics</small>	<b>Length</b> 04 - 4ft 08 - 8ft 12 - 12ft 16 - 16 FT	<b>Wiring Options</b> 1 - 1cct 2 - 2cct 3 - 1cct w/ Emergency ckt 4 - 2cct w/ Emergency ckt 5 - 1cct w/ Battery Pack 6 - 2cct w/ Battery Pack 7 - 1cct w/ Dimming 8 - 1cct w/ Thru Wire 9 - 2cct w/ Thru Wire  <small>Consult factory for complete list of standard wiring options</small>	<b>Voltage</b> 1 - 120V 2 - 277V 3 - 347V* X - Custom  <small>*Consult factory for availability</small>	<b>E</b> Ballast (Electronic)	<b>Finish</b> W - Standard White C - Factory Color* X - Custom Color  <small>*See factory color chart</small>
------------------------------	--------------------------	--	--	--	---	---	----------------------------------	--

Cross Section




Weight 3.0 lb/ft

Ends / Joints



Modules


Linear runs are made by combining 4ft, 8ft and 12ft modules



Indicates location of ballast  
Optional emergency control ballast controls all lamps OR  
Optional battery pack (standard controls one lamp only)

Indicates Module length / Mounting distance  
\*MODULE length does not include endcap

Baffle Detail





Suspended

3 T8


Direct/Indirect

9506T03 or 9507T03 C/R

## Photometry

© 2006 Ledaite Architectural Products. All rights reserved. Ledaite.com

### Standard - CN/RN



Report # 2101530  
 Efficiency 34.1%  
 Peak Candela Value 1,740 @ 180°  
 Peak Zenith Ratio 1.0:1

Vert. angle	AVERAGE LUMINANCE (cd/m <sup>2</sup> )		
	0	45	90
05	1429	1206	912
05	846	796	615
75	319	783	831
85	105	171	962

### CANDELA DISTRIBUTION


Vert. Angle	Horizontal Angle					Zonal Lumens
	0	22.5	45	67.5	90	
0	727	727	727	727	727	727
5	727	112	707	681	685	67
15	685	520	592	556	562	157
25	598	507	479	418	412	215
35	452	531	357	316	322	224
45	320	282	250	214	219	213
55	201	181	154	136	136	173
65	98	111	125	152	165	133
75	52	52	88	96	122	80
85	28	35	53	58	82	52
90	7	29	45	59	51	
95	5	47	215	183	212	268
105	153	525	695	647	676	612
115	647	771	1002	1058	1066	913
125	827	896	1205	1339	1377	1048
135	1179	1235	1357	1438	1511	1038
145	1389	1429	1470	1551	1582	928
155	1554	1555	1597	1518	1691	735
165	1688	1535	1581	1592	1596	475
175	1730	1730	1733	1722	1730	186
180	1733	1740	1743	1743	1740	

### COEFFICIENTS OF UTILIZATION (%)

Coeff. Util. CCR	COEFFICIENTS OF UTILIZATION (%)										
	0	10	20	30	40	50	60	70	80	90	0
0	81	81	81	81	73	73	73	55	35	25	12
1	75	77	78	80	67	64	61	45	25	16	12
2	65	63	58	54	61	56	52	42	30	17	11
3	62	55	50	45	58	50	43	37	24	14	9
4	57	49	43	38	52	45	38	31	20	12	7
5	51	43	37	32	48	38	32	25	15	10	6
6	47	39	32	27	43	33	28	22	13	8	5
7	43	35	28	23	37	31	26	20	12	7	4
8	41	31	25	21	35	28	23	17	10	6	3
9	38	29	23	19	34	25	20	15	9	5	2
10	35	26	21	17	31	23	18	12	7	4	1

Based on a floor reflectance of 0.2

### High Performance - CN/RN



Report # 2101602  
 Efficiency 33.8%  
 Peak Candela Value 1,672 @ 140°  
 Peak Zenith Ratio 1.8:1

Vert. angle	AVERAGE LUMINANCE (cd/m <sup>2</sup> )		
	0	45	90
05	1422	975	686
05	912	727	579
75	740	647	521
85	725	570	403

### CANDELA DISTRIBUTION

Vert. Angle	Horizontal Angle					Zonal Lumens
	0	22.5	45	67.5	90	
0	744	744	744	744	744	744
5	738	725	711	688	695	64
15	587	632	657	684	588	166
25	584	511	479	421	421	219
35	405	391	335	305	312	222
45	336	282	247	217	202	235
55	205	185	170	174	188	164
65	95	109	117	132	142	119
75	47	51	59	74	76	73
85	17	28	43	47	51	43
90	6	28	41	47	60	
95	76	158	285	71	235	158
105	239	372	644	614	684	608
115	496	483	1126	1076	1121	958
125	709	1043	1445	1542	1604	1153
135	912	1145	1537	1771	1345	1124
145	1038	1223	1523	1793	1529	953
155	1105	1270	1466	1523	1565	671
165	1282	1310	1377	1469	1477	393
175	1322	1332	1341	1369	1351	136
180	1335	1332	1333	1333	1333	

### COEFFICIENTS OF UTILIZATION (%)

Coeff. Util. CCR	COEFFICIENTS OF UTILIZATION (%)										
	0	10	20	30	40	50	60	70	80	90	0
0	83	87	81	83	72	73	73	54	34	24	14
1	78	79	80	80	66	66	61	47	25	14	12
2	68	67	61	54	59	56	52	42	31	17	10
3	63	55	49	43	55	46	44	37	24	14	8
4	55	49	43	38	50	41	35	31	19	10	7
5	51	44	37	32	46	38	31	24	15	9	6
6	46	38	31	28	42	34	28	20	12	7	5
7	43	33	27	24	39	30	24	18	10	6	4
8	41	32	25	21	36	28	23	17	10	6	3
9	38	29	23	19	34	25	20	14	8	5	2
10	35	26	21	17	31	23	18	12	7	4	1

Based on a floor reflectance of 0.2

## Specifications

### Housing

Die-finished 20 gauge cold-rolled steel

### Optical System

Constructed of 36% reflective white steel, and a perforated optical filter with acrylic overlay to produce a Direct/Indirect distribution. High Performance (HP) option utilizes additional highly specular aluminum reflectors. Louvers are white blades spaced 2.45" apart and are 0.77" deep (18 coils per 4ft section). Perforation of louver blades and housing are optional. Variable Optics™ option provides the ability to add additional downlight where needed.

### Endcaps

Die-cast endcap or optional die-cast sculptured endcap

### Joints & Intersections

Self-aligning joining system with hand-free push/pull wire access

### Mounting

Aircraft cable gripper is tamper-resistant and provides infinite vertical adjustment capability. Aircraft cable, grip and cable gripper independently tested to meet stringent safety requirements.

### Electrical

All luminaires shall be factory pre-wired to section ends with quick-wire connectors.

### Ballast

Electronic

### Approvals

Compliant to UL & CSA standards.

### Finish

High quality powder coat, factory applied to meet AAMA 2603-98. Available in Ledaite Standard White textured matte finish, a selection of optional factory colors (see factory color chart), or custom colors. Consult factory for details.



Available with Response Integrated Controls. See www.ledalite.com for details.

Due to continuing product improvements, Ledaite reserves the right to change specifications without notice.



## DESCRIPTION

The BA Series features a brushed aluminum finish that is a quiet complement to any interior environment. The injection molded end plates have been designed to match the brushed housing finish. The wall bracket offers effective down and up lighting functions that have been incorporated into this series with contemporary styling and architectural appeal. The BA Series also features the latest in energy efficient technology for outstanding performance.

## APPLICATION

The BA Series architectural wall bracket styling contributes aesthetic appeal to contemporary decor, providing ideal lighting conditions for all areas in which comfortable, concentrated illumination is specified. Healthcare facility patient rooms, powder rooms, dressing rooms and work areas.

## SPECIFICATION FEATURES

### A - Lens Housing Construction

Lens housing is constructed of premium grade extruded anodized aluminum with a brushed finish. It's easily removed for installation and maintenance. High impact, injection molded end plates have matching brushed aluminum finish.

### B - Internal Channel Construction

Internal steel channel is die formed of code gauge prime cold rolled steel. Channel cover is secured by quarter-turn fasteners for easy wireway access. Internal channel back has numerous KO's for easy installation.

### C - Electrical

Ballast are CBM/FTL Class "P" and positively secured by mounting bolts. Pressure lock lampholders, UL/CUL listed. Suitable for damp locations.

### D - Lens Housing Finish

Extruded brushed aluminum lens housing has a clear anodic coating. Sturdy, high impact injection molded end plates have matching brushed aluminum-type finish. Decorative recessed walnut trim-stripe, front and ends.

### E - Internal Channel Finish

Internal channel and all steel reflective surfaces are finished with electrostatically applied baked white polyester powder enamel. Multi-stage cleaning cycle, iron phosphate coating with rust inhibitor. Conveyorized application and baking time are accurately controlled at an elevated temperature.

### F - Internal Light Baffle


Optional internal light baffle is available for up, down or combination lighting. (BAUB)

### G - Latching



Lens housing secured to internal channel by spring-loaded latches.

### H - Shielding



Downlight diffuser is 100% virgin prismatic acrylic, #12 pattern. Low brightness even illumination is provided. Uplight diffuser is smooth matte opal acrylic.



## MOUNTING DATA



## LAMP CONFIGURATIONS



COOPER LIGHTING

Catalog #	BAU-217-UNV-ER81	Type	
Project	KILGORE SCHOOL	W5	
Comments			
Prepared by		Date	



**BA,BAU220**  
217  
230  
225  
240  
232

## SPECIFICATION WALL BRACKET

2' Wall Bracket  
2 Lamp L'S or HTS  
3' or 4' Wall Bracket  
2 Lamp

## ENERGY DATA

(Half Watts)

### EB Ballast & STD Lamps

217 (36)  
230 (60)  
225 (47)  
240 (72)  
232 (61)

### ES Ballast & STD Lamps

220 (58)  
217 (45)  
230 (74)  
225 (63)  
240 (86)  
232 (71)

Luminaire Efficacy Rating

LER = FL-44

Catalog Number: BA-232A


Yearly Cost of 1000 lumens,  
3000 hrs at 08 KWH = \$5.45

ADF020653  
150supercedes ADF0001931






SIDE VIEW




TOP VIEW



**FIXTURE SPECIFICATIONS**

FIXTURE	#LAMP	WATTS	BALLAST TYPE
SP7HF	2 Quad	13	EX - Electronic 120/277 (standard)
		18	DA1 - Advance MK10 Dimming 120
		26	DA2- Advance MK10 Dimming 277
	1 Lamp PLT	13	DL1- Lutron Compact SE Dimming 120
		18	DL2 -Lutron Compact SE Dimming 277
		26	DM7X- Advance MK7 Dimming 120/277
		32	
		42	

**TRIM SPECIFICATIONS**



TRIM NO:	SPLAY/FLANGE:	LENS
<b>7420-</b> 2 lamps 13W - 26W (Quad only)	<b>WS</b> -White Splay/Flange (standard) <b>SG</b> -Soft Glow Alzak Splay/White Flange	<b>GL</b> - Clear Temp Glass Lens <b>CA</b> - ClearAcrylic Lens <b>FG</b> - Frosted Glass Lens
<b>7425-</b> 1 lamp 13W- 42W PLT	<b>RW</b> -Regressed Baffled Splay White <b>RB</b> -Regressed Baffled Splay Black W/White Flange	<b>FA</b> - Flat Alba Lens <b>FL</b> - Fresnel Glass Lens <b>DO</b> - Drop Opal Glass Lens <b>PG</b> - Prismatic Glass Lens

**TYPICAL ORDER**

Line item 1 (FRAME): **SP7HF126EX**  
Line Item 2 (TRIM): **7425 WS PG**

**PRODUCT INFORMATION**

- Specular clear shallow plenum alzak reflector w/regressed/ baffled lens splay.
- Specular clear Alzak reflector, white flange.
- 20 gauge galvanized frame.
- 12" bar hangers expandable to 24" standard
- Junction box pre-wired, grounded.
- Electronic ballast 120/277v standard.
- Ballast serviceable from the ceiling aperture.
- Suitable for use in damp location.
- UL listed.
- Wet location (WL) available.

**FRAME OPTIONS**

- RM** - Remodeler (Cut Away).
- FS** - Fusing
- EM** - Emergency (Specify voltage)
- EMIT** - Emergency W/integral test switch(Specify voltage)
- BH27** - 27" Mounting Bars (2 Per Set).
- PR** - Plaster Ring (see available depths).

**TRIM OPTIONS**

- GS** - Gasket (For Reflector).
- WL** - Wet location

**SUBMITTAL WORKSHEET**

FIXTURE NO.

FRAME-IN-KIT NO.

FIXTURE TYPE



[ABOUT LIGHTTECH](#)

[PRODUCTS](#)

[ORDER TRACKING](#)

[TECHNICAL INFORMATION](#)

[CONTACT US](#)

## Steplights & Nightlights • SL-8130 Series- Recessed Horizontal Step Light

### SL-8130 Series- Recessed Horizontal Step Light

Compact fluorescent, LED or incandescent  
Specification-grade design and construction  
IBEW union made in the USA

#### Specifications

##### Construction:

Heavy-duty cast aluminum face plate.

18 ga. electro galvanized steel housing, suitable for embedding in concrete.

##### Face finishes:

Matte black powder coat is standard.

Optional white, dark bronze or silver powder coat.

##### Illumination:



Incandescent: For use of one 25-watt A-19 medium base lamp (by others).

Compact fluorescent: For use of one 7 or 9 watt twin tube, 13 watt or 18 watt quad tube lamp (by others), supplied with voltage-specific (120V or 277V) electronic ballast.

LEDs: 6, 12 or 18 bright white (louver face) or 20 bright white (open face, indirect illumination) LEDs.

#### HOW TO ORDER

Example: SL-8130-PLD18-W-SPC (An SL-8130 for use of an 18 watt compact fluorescent lamp, silver powder coat face, for wet location and/or concrete pour.)



#### Catalog No.

#### Catalog No.

#### Lamp

Louver Face

Glass Face

SL-8130

SL-8130-G-W

One 25-Watt A-19 Medium Base Incandescent Lamp  
SL-8130-G with incandescent lamp suitable for outdoor, wet location, or poured concrete only.

SL-8130-PL7

SL-8130-PL7-G

One 7-Watt Twin Tube Fluorescent Lamp

SL-8130-PL9

SL-8130-PL9-G

One 9-Watt Twin Tube Compact Fluorescent Lamp

SL-8130-PLD13	SL-8130-PLD13-G	One 13-Watt Quad Tube Compact Fluorescent Lamp
SL-8130-PLD18	SL-8130-PLD18-G	One 18-watt Quad Tube Compact Fluorescent Lamp
SL-8130-LED		6 White LEDs is standard. Also offered with 12 or 18 LEDs (please specify).
	SL-8130-G-LED	20 White LEDs

### Options:

WET LOCATION: Neoprene gaskets  
 LONGLIFE WIRING: Incandescent lamps only  
 EXTERNAL WIRING: "J" box for feed through  
 277 VOLT FLUORESCENT: 277V ballast  
 TAMPER RESISTANT SCREWS  
 ALTERNATE FACE FINISHES:  
 Silver Powder coat  
 White Powder coat  
 Dark bronze powder coat

*Add suffix to catalog number.*

### Catalog Suffix:

W  
 LL  
 J  
 277V  
 TP  
 SPC  
 WPC  
 DBPC


Please note: Ligttech reserves the right to make changes without notice.

---

[More info](#) | [Steplights & Nightlights](#) | [Custom Signage](#) | [Institutional Lighting](#)  
[Architectural & Exterior products](#) | [Green & LED Products](#) | [Un-Catalog](#) | [Contact Ligttech](#)

Type C

Lamp=3 200 lm  
Max=256.6 cd/klm  
Power=48 W  
Multiplier=3.2  
Degrees=0




-0.46875x-0.46875x0 feet

Manufacturer: COOPER LIGHTING - PORTFOLIO  
Luminaire catalog: C6142E-6180LI1  
Luminaire: PORTFOLIO 6 IN RECESSED FLUORESCENT DOWNLIGHT  
Lamp catalog: CFL42W/U/4P 42 WATTS  
Lamp: 4 PIN TTT COMPACT FLUORESCENT LAMP

Type C

Lamp=2 950 lm  
Max=583.2 cd/klm  
P 3x30=90 W  
Multiplier=2.95  
Degrees=0




Box 0.66x4x0.24 feet

Manufacturer: Ledalite Architectural Products 604-888-6811  
Luminaire catalog: 9506T03CN-RN  
Luminaire: Centris  
Lamp: F32T8

Type C

Lamp=2 400 lm  
Max=342.1 cd/klm  
Power=37 W  
Multiplier=2.4  
Degrees=0




Box 1.0149x1.0149x0.905646 feet

Manufacturer: Spectrum Lighting  
Luminaire catalog: SP6VF132EX/6410SG- lower position  
Lamp catalog: CF32DT/E/841  
Lamp: Fluor. 32W DULUX triple tube

Type C

Lamp=2 950 lm  
Max=583.2 cd/klm  
P 3x30=90 W  
Multiplier=2.95  
Degrees=0




Box 0.66x4x0.24 feet

Manufacturer: Ledalite Architectural Products 604-888-6811  
Luminaire catalog: 9506T03CN-RN  
Luminaire: Centris  
Lamp: F32T8

Type C


Lamp=2 850 lm  
Max=7 531 cd/klm  
P 2x28=57 W  
Multiplier=0.1  
Degrees=0



Box 0.3542x3.9375x0.19 feet  
Manufacturer: COOPER LIGHTING - METALUX  
Luminaire catalog: BC-232A  
Luminaire: Wall Bracket with white translucent lens.  
Lamp: Two-F32T8/35K - 2850 Lumens ea. - 32 Watts ea.

Type C

Lamp=2 850 lm  
Max=426 cd/klm  
P 2x28=57 W  
Multiplier=2.85  
Degrees=0



Box 0.75x3.958x0.115 feet

Manufacturer: COOPER LIGHTING - FAIL-SAFE  
Luminaire catalog: FWS 232-120-EB81  
Luminaire: 2/32W T8 4'SURFACE MNT LUMINAIRE w/WHITE BODY REFL  
Lamp catalog: F32T8/735/RS

Catalog Number	
Notes	Type

## FEATURES & SPECIFICATIONS

### INTENDED USE

For applications that require medium to high light levels such as manufacturing, warehousing, storage, retail or task lighting. Ideal for mounting heights up to 25'.

### ATTRIBUTES

Heavy-duty design for demanding industrial environments. Pressure-lock lampholders enclosed in snap-in turret housing. Available in 4' or 8' lengths. 6" lamp spacing of 2-lamp models, 3" lamp spacing on 3-lamp models. Solid top, 10% or 20% uplight reflectors available, painted after fabrication.

### CONSTRUCTION

Die-embossed reflector constructed of heavy gauge cold-rolled steel. White enamel reflector finish standard, porcelain finish optional.

### FINISH

Five-stage iron-phosphate pretreatment ensures superior paint adhesion and rust resistance. Finish is high-gloss baked white enamel.

### ELECTRICAL SYSTEM

Thermally protected, resetting, Class P, HPF, UL listed, CSA Certified ballast is standard. Energy saving and electronic ballasts are sound rated A.

Fixture is suitable for damp locations. AWM, TFN or THHN wire used throughout, rated for required temperatures.

### INSTALLATION

For surface or suspended mounting, unit or row installation.

### LISTING


120V, 277V and MVOLT are UL Listed and CSA Certified (standard). 347V is CSA Certified (see Options). NOM Certified (see Options).

### WARRANTY

Guaranteed for one year against mechanical defects in manufacture.

## Heavy-Duty Turret Industrial


# AF



Rapid Start  
4' or 8' lengths  
1, 2, 3 or 4 lamps

### Specifications

Length: 49-13/16 (1265) or 99-5/8 (2530)  
Width: 13-3/8 (340)  
Height: 6-5/8 (168)



All dimensions are inches (millimeters).  
Specifications subject to change without notice.

## ORDERING INFORMATION

For shortest lead times, configure product using **standard options (shown in bold)**.

Example: AF 3 32 277 1/3 GEB10IS

Series	Lamps	Lamp type	Voltage	Options
AFST Solid reflector	1	<b>32 32W T8 (48")</b>	<b>120</b>	<b>Shipped installed in fixture</b>
AF10 10% uplight apertured reflector	2		<b>277</b>	1/3 One 3-lamp ballast (32 watt electronic ballast only)
<b>AF 20% uplight apertured reflector</b>	3		<b>347</b>	1/4 One 4-lamp ballast (32 watt electronic ballast only)
	4		<b>MVOLT<sup>2</sup></b>	GEB T8 electronic ballast, ≤20% THD
	Not included.			<b>GEB10IS T8 electronic ballast, ≤10% THD, instant start<sup>1</sup></b>
				<b>GEB10RS T8 electronic ballasts, 10% THD, rapid start</b>
				EL Emergency battery pack (nominal 300 lumens), see Life Safety Section
				GLR Internal fast-blow fusing (add X for external)
				GMF Internal slow-blow fusing (add X for external)
				PLF_ Plug-in wiring. Specify 1, 2 or 3 branch circuits & hot wires (A = black, B = red, C = blue, AB or AC)
				TILW Tandem in-line wiring
				PO White porcelain reflector finish
				CSA CSA Certified (347V only)
				NOM NOM Certified
				BDP Ballast disconnect <sup>3</sup>

For tandem double-length unit, add prefix T.  
Example: TAF10

### Accessories

Order as separate catalog number.

ACEP	Full-depth endplates (1 pair)
HRUN	Hooker® T-bar hanger for 5" channel (flush to ceiling)
HRUN1	Hooker® T-bar hanger for 5" channel (1-1/2" from ceiling)
SQ_	Swivel stem hanger (specify length in 2" increments)
1B	Ceiling spacer (1-1/2" to 2-1/2" from ceiling)
HC36	Chain hangers (1 pair, 36" long)
THUN	Tong hanger for 5" channel
WGAFPV	Wireguard, 4' white (order 2 for 8' fixtures) <sup>4</sup>
DLAF ME	4' 30° x 30° metal eggcrate louver <sup>4</sup>
DLAF A12	4' framed acrylic prismatic lens <sup>4</sup>

### NOTES:

- Available only with 32 lamp type.
- Electronic ballast 120 through 277 volt only. Available with 32 watt T8 only. MVOLT must specify GEB10IS.
- Meets codes that require in fixture disconnect.
- Order 2 for 8' fixtures.


# AF Rapid Start

## MOUNTING DATA

For unit or row installation. Surface or stem mounting.<sup>1</sup>

UNIT INSTALLATION — Minimum of two hangers required.

ROW INSTALLATION — One hanger per fixture plus one per row required.



## DIMENSIONS

A = 1/4 x 1/2 (64 x 13) Oval Hole

C = 7/8 (22) Dia. K.O.





D = 11/16 (17) Dia. K.O.

E = 2 (51) Dia. K.O.

F = 7/16 (111) Dia. K.O.

All dimensions are inches (millimeters).

Specifications subject to change without notice.



Energy (Calculated in accordance with NEMA standard LE-5)					
LER.FW	ANNUAL ENERGY COST*	LAMP DESCRIPTION	LAMP LUMENS	BALLAST FACTOR	WATTS
74	\$3.24	(2) F32T8	2800	.88	60

\*Calculated in accordance with NEMA Standards LE-5.

## PHOTOMETRICS

Calculated using the zonal cavity method in accordance with IESNA LM41 procedure. Floor reflectances are 20%. Lamp configurations shown are typical. All data based on 25°C. Full photometric data on these and other configurations available upon request.

AF 2 32

Report ITL 5711

S/MH 1.4

Coefficient of Utilization

Ceiling	80%			70%			50%		
	70%	50%	30%	70%	50%	30%	50%	30%	10%
1	94	90	86	90	86	83	79	76	74
2	86	79	73	82	75	70	69	65	61
3	78	69	62	74	66	60	61	56	52
4	72	61	54	68	59	52	54	48	44
5	65	54	46	62	52	44	48	41	37
10	43	31	24	41	30	23	28	22	18


Zonal Lumens Summary

Zone	Lumens	%Lamp	%Fixture
0-30	998	17.2	19.0
0-40	1677	28.9	31.9
0-60	3126	53.9	59.6
0-90	4074	70.2	77.6
90-180	1175	20.3	22.4
0-180	5249	90.5	100.0



Type C

Lamp=2 900 lm  
Max=427.9 cd/klm  
P 2x29=58 W  
Multiplier=2.9  
Degrees=0



Rect 1.13x4 feet

Manufacturer: Lithonia Lighting  
Luminaire catalog: AF 2 32 MVOLT GEB10IS  
Luminaire: HEAVY DUTY TURRET INDUSTRIAL 20% UPLIGHT 50" X 4' 2 L  
Lamp: TWO 32-WATT T8 LINEAR FLUORESCENT.

## DESCRIPTION

Round wall mount lens downlight with 6 inch aperture for vertical ED17 medium base quartz or ceramic metal halide lamp. Medium beam distribution with 45° cutoff to lamp produces even illumination with good efficiency. Available in white, black or bronze finish and can be used to blend with or accent varying architectural styles.

Catalog #		Type
Project		
Comments		Date
Prepared by		

## SPECIFICATION FEATURES

### Housing

Fabricated 0.062 thick aluminum housing and integral 0.125 thick extruded aluminum arm is available in various painted finishes.

### Mounting Plate

Die formed 0.060 thick pre-galvanized steel mounting plate attached directly to wall mounted junction box. Housing attached to mounting plate and drawn tight to mounting surface with two Philips drive screws.

### Reflector

Spun 0.050" thick aluminum reflector provides medium beam distribution. Available in all Portfolio Alzak® finishes. Also available with seamless grooved black baffle.

### Shielding

Tempered glass lens provides lamp containment.

### Trim Retention

Keyholes align reflector to preinstalled machine screws that pull flange tight to the housing.

### Socket

Pulse rated E26 medium base porcelain socket with nickel plated brass screw shell.

### Ballast

Magnetic core and coil 120/277V or 347V ballast. Quick connector plugs into housing for tool-less ballast installation / replacement.

### Code Compliance

UL listed, CSA certified for standard wet locations. Exempt from EISA ballast efficiency standards.



**M8605727**  
**M8605737**  
**M8605747**

**44600**


50/70/100W

ED17

Metal Halide

6 Inch

Round Wall Mount Cylinder



## Energy Data

### 50W

120V Input Power: 72	277V Input Power: 72	347V Input Power: 67
120V Input Current: 1.0	277V Input Current: 5	347V Input Current: 48

### 70W

120V Input Power: 90	277V Input Power: 90	347V Input Power: 90
120V Input Current: 1.9	277V Input Current: 8	347V Input Current: 7

### 100W

120V Input Power: 129	277V Input Power: 129	347V Input Power: 129
120V Input Current: 2.3	277V Input Current: 1	347V Input Current: 1

Minimum Starting Temp: -20°F, -30°C


**ORDERING INFORMATION**

Sample Number: M8605737P = 6" wall mount round cylinder, white with 120/277V ballast for a 70W ED17 MH lamp (Order housing and trim separately.)

<b>Housing</b> <b>M8605</b> = 6" Round MH Wall Mount Cylinder	<b>Housing Finish</b> <b>P</b> = White <b>BZ</b> = Bronze <b>MB</b> = Black	<b>Trim</b> <b>44600</b> = 6" Medium beam reflector	<b>Finish</b> (Alzak ® Finishes) <b>LI</b> = Specular Clear, low iridescent <b>H</b> = Semi-specular clear <b>WMH</b> = Warm Haze <b>G</b> = Gold <b>WH</b> = Wheat <b>GP</b> = Graphite <b>GPH</b> = Graphite Haze <b>K</b> = Cognac <b>KH</b> = Cognac Haze <b>B</b> = Black  (Omit finish code for black baffle option)	<b>Options</b> <b>BA</b> = Black Baffle  <b>Accessories</b> (None)
<b>Ballast</b> <b>727</b> = 50W M148/M110 120/277V 60Hz magnetic <b>7267</b> = 50W M148/M110 347V 50/60Hz magnetic <b>737</b> = 70W M143/M98 120/277V 60Hz magnetic <b>7376</b> = 70W M143/M98 347V 50/60Hz magnetic <b>747</b> = 100W M140/M90 120/277V 60Hz magnetic <b>7476</b> = 100W M140/M90 347V 50/60Hz magnetic	<b>Options</b> <b>F</b> = Time delay fuse			

**PHOTOMETRICS**

**Candlepower Distribution**



Test No. E428-428  
**M8605P-737-44600LI**  
 Lamp=M100C  
 Lumens=8000  
 Spacing Criteria=1.1  
 Efficiency=38.5%

**Candlepower**

Deg.	CD
0	1988
5	2003
15	2217
25	1974
35	1117
45	542
55	191
65	60
75	8
85	0
90	0

**Average Luminance**

Deg.	CD/SQ M
45	46706
55	20291
65	8651
75	1883
85	0

**Cone of Light**

Distance to Illuminated Plane	Initial Nadir Footcandles	Beam Diameter
5'6"	66	6'6"
6'6"	47	7'6"
8'0"	31	9'0"
10'0"	20	11'6"
12'0"	14	13'6"
14'0"	10	16'0"

Beam diameter is to 50% of maximum footcandles, rounded to the nearest half-foot.

Footcandle values are initial, apply appropriate light loss factors where necessary.

**Cone Color Multiplier**  
 Gold x 0.90

**Lamp Wattage Multiplier**  
 70W x 0.625

**Zonal Lumen Summary**

Zone	Lumens	%Lamp	%Luminaire
0-30	1713	21.4	55.7
0-40	2413	30.2	78.4
0-60	3012	37.6	97.9
0-90	3076	38.5	100.0
90-180	0	0.0	0.0
0-180	3076	38.5	100.0

**Coefficient of Utilization**


rc	80%				70%				50%				30%				10%				0%
	70	50	30	10	50	30	10	50	10	50	10	50	10	50	10	50	10	0			
<b>RCR</b>																					
<b>0</b>	46	46	46	46	45	45	45	43	43	41	41	39	39	39	39	38	38	38	38		
<b>1</b>	44	43	42	41	42	41	40	40	39	39	38	37	37	37	37	36	36	36	36		
<b>2</b>	41	40	38	37	39	38	36	38	36	37	35	35	34	34	33	33	33	33	33		
<b>3</b>	39	37	35	33	36	35	33	35	33	34	32	34	32	34	32	31	31	31	31		
<b>4</b>	37	34	32	31	34	32	30	33	30	32	30	32	29	32	29	29	29	29	29		
<b>5</b>	35	32	30	28	32	30	28	31	28	30	27	30	27	30	27	27	27	27	27		
<b>6</b>	33	30	28	26	30	27	26	29	26	28	25	28	25	28	25	25	25	25	25		
<b>7</b>	31	28	25	24	27	25	24	27	23	27	23	27	23	26	23	23	23	23	23		
<b>8</b>	30	26	23	22	26	23	22	25	22	25	22	24	21	24	21	21	21	21	21		
<b>9</b>	28	24	22	20	24	22	20	23	20	23	20	23	20	23	20	20	20	20	20		
<b>10</b>	26	22	20	18	22	20	18	22	18	22	18	21	18	21	18	18	18	18	18		

rc=Ceiling reflectance, rw=Wall reflectance, RCR=Room cavity ratio

CU Data Based on 20% Effective Floor Cavity Reflectance.

**PHOTOMETRICS**

**Candlepower Distribution**



Test No. E428-429  
**M8605P-737-44600BA**  
Lamp=M100C  
Lumens=8000  
Spacing Criteria=1.0  
Efficiency=35.0%

**Candlepower**

Deg.	CD
0	1918
5	1980
15	2154
25	1902
35	1017
45	438
55	143
65	29
75	2
85	0
90	0

**Average Luminance**

Deg.	CD/SQ M
45	36960
55	14876
65	4094
75	461
85	0

**Cone of Light**

Distance to Illuminated Plane	Initial Nadir Footcandles	Beam Diameter
5'6"	64	6'0"
6'6"	46	7'6"
8'0"	30	9'0"
10'0"	19	11'0"
12'0"	13	13'6"
14'0"	10	16'0"

Beam diameter is to 50% of maximum footcandles, rounded to the nearest half-foot.

Footcandle values are initial, apply appropriate light loss factors where necessary.

**Lamp Wattage Multiplier**  
70W x 0.625

**Zonal Lumen Summary**

Zone	Lumens	%Lamp	%Luminaire
0-30	1656	20.7	59.1
0-40	2296	28.7	81.9
0-60	2769	34.6	98.8
0-90	2804	35.0	100.0
90-180	0	0.0	0.0
0-180	2804	35.0	100.0

**Coefficient of Utilization**

rc	80%				70%				50%				30%				10%				0%			
	70	50	30	10	50	30	10	50	10	50	10	50	10	50	10	50	10	50	10	50	10			
<b>RCR</b>																								
<b>0</b>	42	42	42	42	41	41	41	39	39	37	37	36	36	35	35	33	33	31	31	29	29	27		
<b>1</b>	40	39	38	37	38	37	37	37	36	35	34	34	33	33	31	31	29	29	27	27	25	25		
<b>2</b>	38	36	35	34	36	35	33	35	33	34	32	33	31	31	29	29	27	27	25	25	23	23		
<b>3</b>	36	34	32	31	34	32	31	33	30	32	30	31	29	29	27	27	25	25	23	23	21	21		
<b>4</b>	34	32	30	29	31	30	28	31	28	30	28	29	27	27	25	25	23	23	21	21	19	19		
<b>5</b>	33	30	28	26	29	28	26	29	26	28	26	28	26	28	26	28	26	28	26	28	26	28		
<b>6</b>	31	28	26	24	28	26	24	27	24	27	24	26	24	26	24	26	24	26	24	26	24	26		
<b>7</b>	29	26	24	22	26	24	22	25	22	25	22	24	22	25	22	24	22	25	22	24	22	25		
<b>8</b>	28	24	22	21	24	22	21	24	21	23	21	23	20	23	20	23	20	23	20	23	20	23		
<b>9</b>	26	23	21	19	22	20	19	22	19	22	19	22	19	22	19	22	19	22	19	22	19	22		
<b>10</b>	25	21	19	18	21	19	18	21	18	21	18	20	18	21	18	20	18	21	18	20	18	21		

rc=Ceiling reflectance, rw=Wall reflectance, RCR=Room cavity ratio

CU Data Based on 20% Effective Floor Cavity Reflectance.









# SP 2'x4' Static T8 Troffer

## MOUNTING DATA

Continuous row mounting of flanged units requires CRE and CRM trim options (see Options).

## DIMENSIONS

All dimensions are inches (millimeters). Specifications subject to change without notice.



### NOTES:

- 1 Recommended rough-in dimensions for F trim fixtures 24" x 48" (Tolerance is +1/4", -0"). Swing-gate range 1-5/8" to 3-3/4". Swing-gate span 23-3/8" to 26-11/16".

## PHOTOMETRICS

Calculated using the zonal cavity method in accordance with IESNA LM41 procedure. Floor reflectances are 20%. Lamp configurations shown are typical. Full photometric data on these and other configurations available upon request.

### 2SP 3 32 A12125

Report: LTL13408

LUMENS PER LAMP:2850

Luminaire Efficiency:81.5%

### 2SP 3 32 A12

Report: LTL13410

LUMENS PER LAMP:2850

Luminaire Efficiency:81.9%

### 2SP 3 32 A19

Report: LTL13472

LUMENS PER LAMP:2850

Luminaire Efficiency:76.9%

		Coefficients of Utilization								
		80%			20%			30%		
pc	80%	50%	30%	50%	30%	10%	50%	30%	10%	
pw	70%	50%	30%	50%	30%	10%	50%	30%	10%	
0	97	97	97	91	91	91	87	87	87	
1	89	86	83	80	78	76	77	75	74	
2	82	76	71	71	67	64	69	65	63	
3	75	67	61	64	59	55	61	57	54	
4	69	60	53	57	52	47	55	50	47	
5	64	54	47	51	46	41	50	45	41	
6	59	49	42	47	41	37	45	40	36	
7	55	45	38	43	37	33	42	36	32	
8	51	41	34	39	33	29	38	33	29	
9	48	37	31	36	30	26	35	30	26	
10	45	35	28	33	28	24	33	28	24	

		Coefficients of Utilization								
		80%			20%			30%		
pc	80%	50%	30%	50%	30%	10%	50%	30%	10%	
pw	70%	50%	30%	50%	30%	10%	50%	30%	10%	
0	98	98	98	91	91	91	87	87	87	
1	90	86	83	81	78	76	78	76	74	
2	82	76	71	72	68	64	69	66	63	
3	76	67	61	64	59	55	62	57	54	
4	70	60	53	57	52	47	55	51	47	
5	64	54	47	52	46	41	50	45	41	
6	59	49	42	47	41	37	45	40	36	
7	55	45	38	43	37	33	42	36	32	
8	52	41	34	39	33	29	38	33	29	
9	48	38	31	36	30	26	35	30	26	
10	45	35	28	33	28	24	33	28	24	

		Coefficients of Utilization								
		80%			20%			30%		
pc	80%	50%	30%	50%	30%	10%	50%	30%	10%	
pw	70%	50%	30%	50%	30%	10%	50%	30%	10%	
0	92	92	92	85	85	85	82	82	82	
1	85	82	79	77	75	73	74	73	71	
2	79	73	69	69	66	63	67	64	62	
3	73	66	61	63	58	55	60	57	54	
4	67	59	54	57	52	48	55	51	47	
5	63	54	48	51	46	43	50	46	42	
6	58	49	43	47	42	38	46	41	38	
7	54	45	39	43	38	34	42	37	34	
8	51	41	35	40	34	31	39	34	31	
9	47	38	32	37	32	28	36	31	28	
10	45	35	29	34	29	26	33	29	25	

Zonal Lumen Summary			
Zone	Lumens	% Lamp	% Fixture
0° - 30°	2217	25.9	31.8
0° - 40°	3626	42.4	52.0
0° - 60°	5947	69.6	85.4
0° - 90°	6968	81.5	100.0
90° - 180°	0	0.0	0.0
0° - 180°	6968	81.5	100.0

Zonal Lumen Summary			
Zone	Lumens	% Lamp	% Fixture
0° - 30°	2219	25.9	31.7
0° - 40°	3621	42.3	51.7
0° - 60°	5944	69.5	84.9
0° - 90°	7005	81.9	100.0
90° - 180°	0	0.0	0.0
0° - 180°	7005	81.9	100.0


Zonal Lumen Summary			
Zone	Lumens	% Lamp	% Fixture
0° - 30°	2413	28.2	36.7
0° - 40°	3949	46.2	60.0
0° - 60°	5947	69.6	90.4
0° - 90°	6578	76.9	100.0
90° - 180°	0	0.0	0.0
0° - 180°	6578	76.9	100.0



Lithonia Lighting  
Fluorescent  
One Lithonia Way, Conyers, GA 30012  
Phone: 800-858-7763  
www.lithonia.com

Type C

Lamp=2 725 lm  
Max=805.9 cd/klm  
P 3x25=75 W  
Multiplier=2.725  
Degrees=0



Rect 1.69x1.75 feet

Manufacturer: Lithonia Lighting  
Luminaire catalog: 2SP G B 3U31 A12 1/3 GEB  
Luminaire: Specification Premium Troffer Air Handling, 2'x4', 3 Lamp, T8 U, F  
Lamp catalog: FBO31/835  
Lamp: THREE (3) U-BENT T8 32 W NON-LINEAR LAMPS

Catalog Number	
Notes	Type

## FEATURES & SPECIFICATIONS

**INTENDED USE** — The Avante 2x4 is a general lighting luminaire for large spaces including open offices, circulation areas, classrooms, libraries, cafeterias, airport ticketing and wait areas, and numerous other commercial applications. Static or air functions available. **Certain airborne contaminants can diminish integrity of acrylic.** [Click here for Acrylic Environmental Compatibility table for suitable uses.](#)

**CONSTRUCTION** — Housing is gloss white enamel on cold rolled steel. All edges hemmed or rounded.

All shieldings pivot on light traps and swing down for easy lamp access.

Molded light traps prevent light leaks between shielding and endplates.

All air and screw slot units supplied with screw-on tee bar clips. Ballast access is from below.

**OPTICS** — Twin matte white polyester powder paint finished reflectors provide uniform light distribution. Optional low brightness diffuse aluminum stepped reflectors available.

All diffusers control direct light distribution and glare by shielding lamps from direct view.

Metal diffuser staggered round holes (MDR) 52% open perforated metal with .075" diameter holes backed with white acrylic diffuser.

Straight blade louver (SBL) sides of perforated metal with staggered round holes and solid blade louvered center. Sides and louver backed with white acrylic diffuser. Metal diffuser aligned mini slots (MDM) 46% open perforated metal backed with white acrylic diffuser.

Acrylic diffuser prismatic lens (ADP) extruded acrylic lens backed with white acrylic diffuser.

Metal diffuser with center slots (MDC). 52% open metal, .075" diameter holes with 1" wide solid center. Slotted with 1/2"x2" open slots. Diffuser is backed with white acrylic overlay.

**ELECTRICAL** — All ballasts supplied are class P, thermally protected, resetting, HPF, non-PCB, UL Listed, CSA Certified. Ballasts are sound rated A. Standard combinations conform to UL 935.

**INSTALLATION** — Trims available for standard 1" and 9/16" tee bar or screw slot grids. Fixtures can be row mounted end-to-end.

Drywall ceiling adapters available.

**LISTINGS** — UL Listed to US and Canadian safety standards. Chicago Plenum approved and NYC approved (see Options).



Avante is covered by one or more of the following patents: 5,988,829; 399,586; 411,641; 413,402; 2,212,513; 87,513.

NOTE: Specifications are subject to change without notice.

*Avante*<sup>®</sup>  
Direct/Indirect Lighting

# 2AV 2'x4'

Linear Fluorescent  
T8  
1, 2 or 3 lamps



### Specifications

Length: 48" (1219)  
Width: 24" (602)  
Diffuser Width: 8" (203)  
Depth: 5-1/2" (140)

All dimensions are inches (millimeters).

## ORDERING INFORMATION


For shortest lead times, configure product using **standard options (shown in bold)**.

Example: 2AV G 2 32 MDR MVOLT GEB10IS


<b>2AV</b>	<b>32</b>	<b>32</b>			
Series	Number of lamps	Lamp type	Voltage	Options	
<b>2AV 2' wide</b>	1 2 3 Not included.	<b>32 32W T8 (48")</b>	<b>MVOLT<sup>2</sup></b> 347 Others available.	<b>GEB10IS</b> Electronic ballast, ≤ 10% THD, instant start	
Trim type	Air function	Diffuser		GEB10RS Electronic ballast, ≤ 10% THD, rapid start	
<b>G Grid trim</b> ST Screw slot	(blank) <b>Static (no air function)</b> A Air return/supply	<b>MDR Metal diffuser, round holes</b> SBL Straight blade louver, round holes MDM Metal diffuser, mini slots ADP Acrylic diffuser, linear prismatic lens MDC Metal diffuser, round holes with large center slots <sup>1</sup> Others available.		S5100 1.0 ballast factor, SIMPLY5™ system <sup>4</sup> ALG Acrylic litter guard <sup>1</sup>	
<i>Accessories</i>					
Order as separate catalog number.					
DGA24	Drywall ceiling adapter, unit installation. Use G trim plus DGA accessory for fixture trim flange and fixture support in plaster or plasterboard ceilings.				
<p>NOTES:</p> <p>1 Refer to options and accessories section for more detailed information.</p> <p>2 MVOLT (120 - 277 volt).</p> <p>3 Must specify voltage, 120 or 277.</p> <p>4 SIMPLY5 system includes 13' S5SSC RELOC wiring system. Specify voltage unless HW (hardware) or PWS1836 is ordered.</p>					
				<b>EL14</b> Emergency battery pack (nominal 1400 lumens, see Life Safety section)	
				GLR Internal fast-blow fuse <sup>3</sup>	
				HW Hardwire for SIMPLY5™ system; replaces RELOC® wiring	
				<b>PWS1836</b> 6' prewire, 3/8" dia., 18-gauge, 3 wires	
				NY3 New York City approved	
				CP Chicago Plenum approved	
				APB Air pattern control blades <sup>1</sup>	
				<u>Reflector option</u>	
				ASR Aluminum stepped reflector	

# 2AV 2x4 Direct/Indirect Lighting


2AV G 2 32 MDR, (2) 32W T8 lamps, 2850 lumens per lamp, s/m 1.2 (along) 1.3 (across), test no. LTL 10121



2AV G 3 32 MDR, (3) 32W T8 lamps, 2850 lumens per lamp, s/m 1.3 (along) 1.3 (across), test no. LTL 10155




2AV G 3 32 MDR ASR, (3) 32W T8 lamps, 2850 lumens per lamp, s/m 1.2 (along) 1.3 (across), test no. LTL 10120



For additional photometric information, visit our website at 'lithonia.com'.

## MOUNTING DATA


Ceiling Type	Appropriate Trim Type
Exposed grid tee (1' and 9/16")	G
Concealed grid tee	G
Screw slot	ST
Plaster or plasterboard	G*



\*DGA accessory available to provide ceiling trim flange and fixture support for plaster or plasterboard ceiling. Recommended rough-in dimensions for DGA installation is 24-3/4" x 48-3/4" (Tolerance is +1/8", -0").

Type C

Lamp=2 850 lm  
Max=566 cd/klm  
P 3x29=88 W  
Multiplier=2.85  
Degrees=0



Rect 1.92x3.93 feet

Manufacturer: Lithonia Lighting  
Luminaire catalog: 2AV G 3 32 SBL 1/3 ASR  
Luminaire: 2X4 AVante, recessed, 3 lamp T8 32 watt, Straight Blade Louver  
Lamp catalog: F32T8  
Lamp: THREE 32-WATT T8 LINEAR FLUORESCENT.

**FEATURES & SPECIFICATIONS**

**INTENDED USE** — Use in high mounting heights that require high efficiencies, horizontal illumination, premium contrast control, total enclosure of lamp, and higher thermal performance. Ideal for manufacturing, warehousing, gymnasiums (with wireguard) and retail areas.

**ATTRIBUTES** — Completely enclosed borosilicate glass reflector inhibits entrance of dust and air-borne particulate while providing maximum durability and cleanability. Designed for optimum efficiencies and a balance of uplight and downward distributions. Electrical components are horizontally opposed in ballast housing to create a cooler running fixture.

**CONSTRUCTION** — Housing — Vertically seamed, heavy-duty, die-cast aluminum. Ballast and electrical components are heat-sunked and horizontally opposed. Integral splice box mounting flange ensures structural integrity.

**FINISH** — Electrostatically applied white polyester powder paint.

**OPTICAL SYSTEM** — 21" diameter heat-resistant borosilicate glass reflector/refractor. Three plated steel support retain the glass reflector/refractor between a cast aluminum upper enclosure and a corrosion-resistant steel flange. Clear tempered glass lens is fully gasketed to inhibit the entrance of ambient contaminants. Lens assembly is hinged and latched to allow easy maintenance. Meets UL lamp rupture containment specifications.

**ELECTRICAL SYSTEM** — Ballast: All ballasts are 100% factory tested. HPS: Constant wattage autotransformer; MH: Super CWA Pulse Start ballasts, 88% efficient and EISA legislation compliant, are required for 250-450W (must order SCWA option) for US shipments only. CSA, NOM or INTL required for probe start shipments outside the US. 1000W is Constant Wattage Autotransformer.

Socket — Porcelain, vertically oriented, mogul-base socket with copper alloy, nickel-plated screw shell and center contact. UL listed 1500W, 600V and 5KV pulse rated.

**INSTALLATION** — Ballast Housing — Removable cast aluminum pendant splice box slides on integral die-cast aluminum housing mounting flange and mounts to 3/4" pendant conduit prior to ballast housing installation. Matching wire access cover accepts RELOC® modular wiring. Complete assembly meets or exceeds UL 50-pound pull test. Optical Mounting — Six 8-32 zinc-plated, tri-lobular, thread-rolling screws are arranged concentrically around the lamp socket. Cast upper enclosure is gasketed and provided with matching keyhole slot pattern for vibration-resistant mounting.


**LISTING** — UL Listed -30°C to 55°C ambient operations and damp locations. 750W, 875W and 1000W pulse start -30°C to 40°C. UL Listed to US and Canadian safety standards (see Options). NOM Certified (see Options).

Catalog Number	
Notes	Type




Enclosed Glass High Bay Industrial Lighting

**TPGE PG21GLE**



**Metal Halide**  
350W - 1000W  
**High Pressure Sodium**  
400W - 1000W



*Specifications*

Height: 28-1/2 (72.4)\*

Reflector Height: 19-1/2 (49.5)

Width: 22 (55.9)

Weight: 55 lbs (25 kg)

All dimensions are inches (centimeters) unless otherwise specified.

**ORDERING INFORMATION**

Choose the boldface catalog nomenclature that best suits your needs and write it on the appropriate line. Order accessories as separate catalog numbers (shipped separately).

Example: **TPGE 1000M PG21GLE C21 120**

TPGE	PG21GLE						
Series	Reflector	Distribution	Voltage	Ballast <sup>6</sup>	Options		
TPGE	PG21GLE	C21 Concentrating (400S, 1000S and 1000M)	120 208 <sup>1,2</sup> 240 <sup>1,2,3</sup> 277 347 480 <sup>1,2</sup> TB <sup>4</sup>	<b>Pulse Start</b> 	<u>Shipped installed in fixture</u>		
<b>Wattage/lamp</b>		N21 Narrow (350M to 875M only)		NOTE: For shipments to U.S. Territories, SCWA must be specified to comply with EISA.	SF Single fuse (120, 277, 347V) <sup>7</sup>	TR Remote ballast	
High pressure sodium				SCWA Super constant wattage autotransformer	DF Double fuse (208, 240, 480V) <sup>7</sup>	RC3NP TR with prewired 3' cord <sup>7</sup>	
400S 1000S				RLB Regulated lag ballast	EC Emergency circuit <sup>6,9</sup>	ENC Encapsulated CWA ballast (120, 277, 347V)	
Metal halide				SCWI Isolated SCWA <sup>5</sup>	QRS Quartz restrike system <sup>6,8</sup>	KW1 KiloWatch 120V control relay <sup>6</sup>	
350M 450M 875M				(blank) Standard magnetic ballast <sup>5</sup>	QRST QRS time delay <sup>6,9</sup>	KW4 KiloWatch 277V control relay <sup>6</sup>	
400M 750M 1000M				CWI Constant wattage isolated <sup>5</sup>	HA 65°C ambient operation <sup>14</sup>	KW150 KiloWatch 120V control relay-50% light output <sup>6</sup>	
Metal halide - Title 20 <sup>13</sup>				MRB Magnetic regulator ballast	CR Corrosion-resistant finish	KW450 KiloWatch 277V control relay-50% light output <sup>6</sup>	
750M 875M 1000M					TOB Through-wire outlet box	KW1S KiloWatch II with integral sensor	
					LCPP Loop, cord, plug requires TPH, PPH <sup>7</sup>	CSA Listed and labeled to comply with Canadian Standards	
					LC3P Loop, 3' cord, 15A NEMA twistlock plug <sup>7,10</sup>	NOM NOM Certified (Consult factory)	
					HC3P Hook, 3' cord, 15A NEMA twistlock plug <sup>7,10</sup>		
					LOCS Loop, 5' white cord, RELOC OCS <sup>7,11</sup>		
					HOCS Hook, 5' white cord, RELOC OCS <sup>7,11</sup>		
					LOCU Loop, 5' white cord, RELOC OCU <sup>6,7,10,11,12</sup>		
					HOCU Hook, 5' white cord, RELOC OCU <sup>6,7,10,11,12</sup>		

**Accessories**

- Order as separate catalog numbers.
- HKF Fixture hook female
  - LPF Fixture loop female
  - SCK 60" safety chain kit
  - TMB Twin mounting bar (consult factory)
  - HKM Fixture hook male
  - HKMG Grommeted fixture hook male
  - LPM Fixture loop male
  - LPMG Grommeted fixture loop male
  - TPH Throughwire power hook
  - TPHKR Through-wire power hook for KiloWatch System
  - PPH Pendant power hook


**NOTES:**

- Requires CWI or RLB option in Canada for MH. Available for 175-450W.
- Requires CWI or MRB option in Canada for HPS. Available for 70-400W.
- 220V and 240V 50Hz and 60Hz ballasts available for use with U.S. metal halide lamps.
- Optional multi-tap ballast (120, 208, 240, 277V). For voltage specific options specify tap position (TB1=120V, TB2=208V, TB3=240V, TB4=277V).
- Available for shipments outside of U.S. only.
- For specific ordering information, see Product Selection Guide.


- Must specify voltage or tap position.
- Lamp not included.
- See Product Selection Guide (QRS Lamp Wattage Table) for maximum lamp wattage.
- 20A standard 480V.
- May be ordered with 10', 15', and 20' cords. For black cord, specify BK (i.e. HOC3BK).
- When using RELOC with KiloWatch, LOCU or HOCU option must be used with TAP1KW, TAP3KW or TAP13KW. Consult factory for 208, 240, 480V.
- These wattages comply with California Title 20.
- Not available with 750M, 875M or 1000M pulse start.

# TPGE Metal Halide, High Pressure Sodium, Enclosed Glass High Bay

**TPGE 1000M PG21GLE C21 (concentrating), 1000W clear Metal Halide lamp, 1.3 s/mh, 110000 rated lumens, test no. 98120504**



**TPGE 1000M PG21GLE C21 (concentrating), 1000W coated Metal Halide lamp, 1.1 s/mh, 107000 rated lumens, test no. 98120505**



## Electrical Characteristics

1000 CWA-HPF wattage/ballast, 1000 input watts 90+ power factor, ±10% = ±10% regulation line V=lamp wattage.

Wattage/ballast	Primary voltage	Line current (amps) start/operating	Primary dropout voltage	Input watts	Power factor (%)	Regulation Line V = Lamp watts
	120	5.70/9.20	80			
	208	3.40/5.30	140			
1000 CWA	240	2.90/4.60	160	1080	90+	±10% = ±10%
Peak-lead	277	2.50/4.00	160			
	480	1.50/2.30	320			

Tested to current IES and NEMA standards under stabilized laboratory conditions. Various operating factors can cause differences between laboratory data and actual field measurements. Dimensions and specifications on this sheet are based on the most current available data and are subject to change without notice.

## Mounting Height Correction Factor

(Multiply the fc level by the correction factor)

25 ft. = 1.44

35 ft. = .73

40 ft. = .56

$$\left( \frac{\text{Existing Mounting Height}}{\text{New Mounting Height}} \right)^2 = \text{Correction Factor}$$

## Energy (Calculated in accordance with NEMA Standard LE-5)


LERHID	ANNUAL* ENERGY COST	LAMP DESCRIPTION	LAMP LUMENS	BALLAST FACTOR	WATTS
87	\$2.76	M1000/U	110,000	1	1080

\* comparative yearly lighting energy cost per 1000 lumens.



Type C

Lamp=36 000 lm  
Max=502.8 cd/klm  
Power=458 W  
Multiplier=36  
Degrees=0



Vertical cilinder D=1.72 H=1.02 feet

Manufacturer: Lithonia Lighting  
Luminaire catalog: TPGE 400M PG21GLE N (COATED) ( SC=0.9)  
Luminaire: ENCLOSED GLASS OPTICAL, 400 MH W/ NARROW DISTRIBUTION  
Lamp catalog: MH400/C/U  
Lamp: ONE 400-WATT COATED BT-37 METAL HALIDE, VERTICAL BASE-

# COOPER LIGHTING - LUMARK®

## DESCRIPTION

The IMPACT Quarter Sphere cutoff wall mount luminaire makes an ideal complement to site designed U.L. Listed and CSA Certified for wet locations in down mount applications and damp locations in up mounted applications.

Rugged construction and full cutoff efficiency provides facade and security lighting for high restricted zones surrounding schools, office complexes, apartments, and recreational facilities.

Catalog #		Type
Project		
Comments		Date
Prepared by		

## SPECIFICATION FEATURES

### A ... Housing

The housing is a two piece design of die cast aluminum for precise control of tolerances and repeatability.

### B ... Mounting

Gasketed and zinc plated rigid steel mounting attachment fits directly to 4 J-Box or wall with Hook-N-Lock mechanism for quick installation. Secured with two (2) captive corrosion resistant black oxide coated allen head set screws concealed but accessible from bottom.

### C ... Optical Modules

Optical modules utilize high performance 95% reflective sheet Strong Type optical modules standard.

### D ... Ballast

High density resin supported with high power factor ballast with Class H insulation. Minimum starting temperatures are 40°C (104°F) for HPS and 30°C (86°F) for MH Compact Fluorescent luminaire feature electronic universal 120-277V high efficiency 50/60Hz ballast with 18°C (64°F) minimum starting.

### E ... Door

Die cast door features, 1/8" heat and impact resistant clear tempered glass lens mounted with interior plated steel caps and sealed with EPDM gasketing. Hinged door secured in place via two (2) captive fasteners.

### F ... Finish

Durable polyester powder coat finish. Standard colors bronze. Optional white and black colors available. Other finishes consult your Cooper Lighting Representative concerning specifications and requirements.




## IP IMPACT QUARTER SPHERE

50 - 175W  
High Pressure Sodium  
Metal Halide  
26 - 52W

Compact Fluorescent

FULL CUTOFF  
WALL MOUNT LUMINAIRE

**IMPACT™**  
Cutoff Wall Luminaires




**DARK SKY  
COMPLIANT** FCO  
Full Cutoff

In daylight applications only.

## HOOK-N-LOCK MOUNTING

(Mounting attachment included. J-Box not included.)



## TECHNICAL DATA

25°C Maximum Ambient Temperature  
External Supply Wiring 90°C Minimum  
Down Mounted—Wet Location  
Up Mounted—Damp Location

## ENERGY DATA

### High Reactance Ballast Input Watts

50W HPS HPF (66 Watts)  
50W MH HPF (72 Watts)  
70W HPS HPF (91 Watts)  
70W MH HPF (90 Watts)  
100W HPS HPF (130 Watts)  
100W MH HPF (129 Watts)  
150W HPS HPF (190 Watts)  
150W MH HPF (185 Watts)

### CWA Ballast Input Watts

175W MH HPF (210 Watts)


### Electronic Ballast Input Watts

26W PL HPF (29 Watts)  
32W PL HPF (36 Watts)  
42W PL HPF (46 Watts)  
52W PL HPF (65 Watts)

## SHIPPING DATA


Approximate Net Weight:  
18 lbs. (8 kgs.)





**MHIP-S-175-MT-LL**

175-Watt MH  
17,500-Lumen Clear Lamp



**HPIP-S-150-MT-LL**

150-Watt HPS  
16,000-Lumen Clear Lamp

**Footcandle Table**

Select mounting height and read across for footcandle values of each isofootcandle line. Distance in units of mounting height.

Mounting Height	Footcandle Values for Isofootcandle Lines				
	A	B	C	D	E
10'	4.50	2.25	1.13	0.45	0.23
15'	2.00	1.00	0.50	0.20	0.10
20'	1.12	0.56	0.28	0.11	0.06

**ORDERING INFORMATION**

Sample Number: **MHIP-S-150-MT-LL**



**Lamp Type**  
**HP:** High Pressure Sodium  
**MH:** Metal Halide  
**PL:** Compact Fluorescent

**Series**  
**IP:** IMPACT

**Fixture Shape**  
**S:** Quarter Sphere

**Lamp Wattage**  
**HID** <sup>1</sup>  
**50:** 50W<sup>2</sup>  
**70:** 70W<sup>3</sup>  
**100:** 100W  
**150:** 150W  
**175:** 175W<sup>4</sup>  
**Compact Fluorescent** <sup>5</sup>  
**26/32/42:** 26, 32, or 42W  
**52:** (2) 26W  
**64:** (2) 32W  
**84:** (2) 42W

**Voltage** <sup>6</sup>  
**120V:** 120V  
**208V:** 208V  
**240V:** 240V  
**277V:** 277V  
**347V:** 347V  
**480V:** 480V  
**DT:** Dual-Tap<sup>7</sup>  
**MT:** Multi-Tap, <sup>8</sup>  
 wired 277V  
**TT:** Triple-Tap,<sup>9</sup>  
 wired 347V  
**E:** Electronic <sup>10</sup>  
 (200-277V)


**Options** <sup>11</sup>  
**Q:** Quartz Restrike T4 Lamp<sup>12, 13, 14, 15</sup>  
**EM:** Emergency Quartz Restrike T4 Lamp w/<sup>12, 13, 14, 15</sup>  
 Time Delay Relay  
**EMI40-XXX:** CFL Cold Weather Emergency Battery<sup>16, 17</sup>  
 Pack (Must Specify 120V or 277V)  
**CF/EM-XXX:** Emergency Battery Pack (Must Specify<sup>16, 18</sup>  
 120V or 277V)  
**QMR:** Quartz Restrike MR16 Lamp<sup>14, 15, 19</sup>  
**EMMR:** Emergency Quartz Restrike MR16 Lamp w/<sup>14, 15, 19</sup>  
 Time Delay Relay  
**EM/SC:** Emergency Separate Circuit T4 Lamp<sup>13, 15, 20</sup>  
**EM/SC/MR:** Emergency Separate Circuit MR16<sup>21, 19, 20</sup>  
 Lamp  
**EM/SC/12V:** Emergency Separate Circuit (12V)<sup>21, 22</sup>  
**F1:** Single Fuse (120, 277 or 347V only)  
**F2:** Double Fuse (208, 240 or 480V only)  
**LL:** Lamp Included (Must Specify Wattage on PL)<sup>23</sup>  
**TR:** Tamper Resistant Screw (Door and Mounting Plate)  
**PE:** Internal Photocontrol (Specify Voltage)

**Standard Color**  
 —: Bronze (Standard)  
**WH:** White  
**BK:** Black

- Notes:**
- All HID lamps are medium base.
  - Available in 120V, 277V and Dual Tap.
  - Not available in 480V.
  - Metal Halide only.
  - 52W is (2) 26W quad tube lamps. 32, 42, 64, 84W use compact triple tube CF lamps.
  - Products also available in non US voltages and 50HZ for international markets.
  - Dual Tap ballast is 120/277V wired 277V.
  - Multi Tap ballast 120/208/240/277V wired 277V.
  - Triple Tap ballast 120/277/347V wired 347V.
  - Supplied with 120V through 277V 50/60Hz for Compact Fluorescent.
  - Add as suffix in the order shown.
  - The power might need to cycle and allow HID lamp to cool in warm climates. Available up to 175W HID.
  - For use with T4 double contact bayonet base, 100W maximum, 120V halogen lamp by others.
  - Lamps wired to quartz restrike relay.
  - Not available with CFL.
  - Battery pack will operate up to 42W CFL lamp for 90 minutes.
  - CF lamps only, rated for minimum temperature of 0°F ( 18°C), (1) 42W CFL maximum, heater rated for 300W with thermostat control.
  - CF lamps only, rated for minimum temperature of 32°F (0°C), (1) 42W CFL maximum.
  - For use with MR16, GU10 base, 50W maximum, 120V halogen lamp by others.
  - Leads run out back for connection to auxiliary 120V circuit.
  - Not Available with 52, 64, 84 CFL.
  - Supplied with 12V Bi pin socket for connection to emergency battery pack (supplied by others). For use with MR16, GU5.3 base, 35W maximum, 12V halogen lamp by others.
  - Lamp is shipped separate from luminaire. Lamp is Cooper designated product based on luminaire requirements. Specified lamps must be ordered as a separate line item.

**STOCK SAMPLE NUMBER (Lamp Included)**

SAMPLE NUMBER: MHIS17



NOTES: Options not available with stock products. Order Accessories as separate items for field installation. Refer to standard ordering information to add options and accessories.  
 \* Painted bronze. Supplied with lamp and Multi-Tap HPF ballast wired 277V.