

**Duke Energy Ohio
Case No. 20-1411-GA-BTX
Staff Second Set Data Requests
Date Received: February 16, 2021**

STAFF-DR-02-004

REQUEST:

Referring to page 112 of the Application, what is the maximum anticipated height of the heater exhaust stack?

RESPONSE: It is anticipated that the maximum height of the heater exhaust stack will be 20' above final grade, although the height of the exhaust stack could vary based on manufacturer.

PERSON RESPONSIBLE: Christopher Siok