

**DANGER**  
RISK OF ELECTRIC SHOCK  
DO NOT OPEN  
SAFETY INFORMATION  
SEE USER MANUAL

RESET

CL 10  
40-140 V  
4W Y Δ

60 Hz  
TA 2.5  
K<sub>h</sub> 1.8

CTR: 200/5  
VTR: 600/1

WATT HOUR  
FLASH  
VAR HOUR

AUX PWR  
40-140V

ENERGY MANAGEMENT REVENUE METER

DELIVERED  
0136770.064 kWh

FORM 9S  
TYPE M5S71

PASSWORD REQUIRED TO EDIT  
MULT. BY:

NO. 82235C20-0478

2 495 960

SELMAN WINDPOWER  
115KV REVENUE METER

DWP 30 LEVEL 2  
DWP ADDRESS: 1  
BALD RATE: 9000

S3

ME P  
\*KZ L92495960 12443 \*

Landis+Gyr

-572