

**Duke Energy Ohio  
Case No. 21-0018-EL-BLN  
STAFF Third Set of Data Requests  
Date Received: February 3, 2021  
STAFF-DR-03-001**

**REQUEST:**

Will there be a new 345-kV circuit breaker installed at the Miami Fort Substation?

**RESPONSE:** No.

**PERSON RESPONSIBLE:** David Forcum