



Case No.: 12-2760-EL-EEC

Mercantile Customer: **The Christ Hospital**

Electric Utility: **Duke Energy**

**Program Title or
Description:** **Cooling Tower Fan #1 VFD**

Rule 4901:1-39-05(F), Ohio Administrative Code (O.A.C.), permits a mercantile customer to file, either individually or jointly with an electric utility, an application to commit the customer's existing demand reduction, demand response, and energy efficiency programs for integration with the electric utility's programs. The following application form is to be used by mercantile customers, either individually or jointly with their electric utility, to apply for commitment of such programs in accordance with the Commission's pilot program established in Case No. [10-834-EL-POR](#)

Completed applications requesting the cash rebate reasonable arrangement option (Option 1) in lieu of an exemption from the electric utility's energy efficiency and demand reduction (EEDR) rider will be automatically approved on the sixty-first calendar day after filing, unless the Commission, or an attorney examiner, suspends or denies the application prior to that time. Completed applications requesting the exemption from the EEDR rider (Option 2) will also qualify for the 60-day automatic approval so long as the exemption period does not exceed 24 months. Rider exemptions for periods of more than 24 months will be reviewed by the Commission Staff and are only approved up the issuance of a Commission order.

Complete a separate application for each customer program. Projects undertaken by a customer as a single program at a single location or at various locations within the same service territory should be submitted together as a single program filing, when possible. Check all boxes that are applicable to your program. For each box checked, be sure to complete all subparts of the question, and provide all requested additional information. Submittal of incomplete applications may result in a suspension of the automatic approval process or denial of the application.

Any confidential or trade secret information may be submitted to Staff on disc or via email at ee-pdr@puc.state.oh.us.

Section 1: Mercantile Customer Information

Name: **The Christ Hospital**

Principal address: **2139 Auburn Avenue Cincinnati, Ohio 45219**

Address of facility for which this energy efficiency program applies:

2139 Auburn Avenue Cincinnati, Ohio 45219

Name and telephone number for responses to questions:

Grady Reid, Jr. 513-287-1038

Electricity use by the customer (check the box(es) that apply):

- The customer uses more than seven hundred thousand kilowatt hours per year at the above facility. (Refer to Appendix A for documentation)**
- The customer is part of a national account involving multiple facilities in one or more states. (Please attach documentation.)

Section 2: Application Information

A) The customer is filing this application (choose which applies):

- Individually, without electric utility participation.
- Jointly with the electric utility.**

B) The electric utility is: **Duke Energy**

C) The customer is offering to commit (check any that apply):

- Energy savings from the customer's energy efficiency program. (Complete Sections 3, 5, 6, and 7.)
- Capacity savings from the customer's demand response/demand reduction program. (Complete Sections 4, 5, 6, and 7.)
- Both the energy savings and the capacity savings from the customer's energy efficiency program. (Complete all sections of the Application.)**

Section 3: Energy Efficiency Programs

A) The customer's energy efficiency program involves (check those that apply):

- ✓ Early replacement of fully functioning equipment with new equipment. (Provide the date on which the customer replaced fully functioning equipment, and the date on which the customer would have replaced such equipment if it had not been replaced early. Please include a brief explanation for how the customer determined this future replacement date (or, if not known, please explain why this is not known)).

The following new equipment was installed starting February 2012 and was finished June 2012.

1 VFD on 125 HP Cooling Tower #1

- Installation of new equipment to replace equipment that needed to be replaced The customer installed new equipment on the following date(s): _____.
- Installation of new equipment for new construction or facility expansion. The customer installed new equipment on the following date(s): _____.
- Behavioral or operational improvement.

B) Energy savings achieved/to be achieved by the energy efficiency program:

- 1) If you checked the box indicating that the project involves the early replacement of fully functioning equipment replaced with new equipment, then calculate the annual savings [(kWh used by the original equipment) - (kWh used by new equipment) = (kWh per year saved)]. Please attach your calculations and record the results below:

Annual savings: 284,961 kWh

Refer to Appendix B for calculations and supporting documents

- 2) If you checked the box indicating that the customer installed new equipment to replace equipment that needed to be replaced, then calculate the annual savings [(kWh used by less efficient new equipment) - (kWh used by the higher efficiency new equipment) = (kWh per year saved)]. Please attach your calculations and record the results below:

Annual savings: _____kWh

Please describe any less efficient new equipment that was rejected in favor of the more efficient new equipment.

- 3) If you checked the box indicating that the project involves equipment for new construction or facility expansion, then calculate the annual savings [(kWh used by less efficient new equipment) - (kWh used by higher efficiency new equipment) = (kWh per year saved)]. Please attach your calculations and record the results below:

Annual savings: _____kWh

Please describe the less efficient new equipment that was rejected in favor of the more efficient new equipment.

- 4) If you checked the box indicating that the project involves behavioral or operational improvements, provide a description of how the annual savings were determined.
-

Section 4: Demand Reduction/Demand Response Programs

- A) The customer's program involves (check the one that applies):
- Coincident peak-demand savings from the customer's energy efficiency program.**
 - Actual peak-demand reduction. (Attach a description and documentation of the peak-demand reduction.)
 - Potential peak-demand reduction (check the one that applies):
 - The customer's peak-demand reduction program meets the requirements to be counted as a capacity resource under a tariff of a regional transmission organization (RTO) approved by the Federal Energy Regulatory Commission.
 - The customer's peak-demand reduction program meets the requirements to be counted as a capacity resource under a program that is equivalent to an RTO program, which has been approved by the Public Utilities Commission of Ohio.

- B) On what date did the customer initiate its demand reduction program?

June 2012

- C) What is the peak demand reduction achieved or capable of being achieved (show calculations through which this was determined):

23.9 kW

Refer to Appendix B for calculations and supporting documentation.

Section 5: Request for Cash Rebate Reasonable Arrangement (Option 1) or Exemption from Rider (Option 2)

Under this section, check the box that applies and fill in all blanks relating to that choice.

Note: If Option 2 is selected, the application will not qualify for the 60-day automatic approval. All applications, however, will be considered on a timely basis by the Commission.

A) The customer is applying for:

Option 1: A cash rebate reasonable arrangement.

OR

Option 2: An exemption from the energy efficiency cost recovery mechanism implemented by the electric utility.

OR

Commitment payment

B) The value of the option that the customer is seeking is:

Option 1: A cash rebate reasonable arrangement, which is the lesser of (show both amounts):

A cash rebate of **\$11,500.00**. Refer to Appendix C for documentation.

Option 2: An exemption from payment of the electric utility's energy efficiency/peak demand reduction rider.

An exemption from payment of the electric utility's energy efficiency/peak demand reduction rider for ____ months (not to exceed 24 months). (Attach calculations showing how this time period was determined.)

OR

A commitment payment valued at no more than \$_____. (Attach documentation and

calculations showing how this payment amount was determined.)

OR

- Ongoing exemption from payment of the electric utility's energy efficiency/peak demand reduction rider for an initial period of 24 months because this program is part of the customer's ongoing efficiency program. (Attach documentation that establishes the ongoing nature of the program.) In order to continue the exemption beyond the initial 24 month period, the customer will need to provide a future application establishing additional energy savings and the continuance of the organization's energy efficiency program.)

Section 6: Cost Effectiveness

The program is cost effective because it has a benefit/cost ratio greater than 1 using the (choose which applies):

- Total Resource Cost (TRC) Test. The calculated TRC value is: _____
(Continue to Subsection 1, then skip Subsection 2)
- ✓ **Utility Cost Test (UCT) . The calculated UCT value is: 9.37 Refer to Appendix D for calculations and supporting documents.**

Subsection 1: TRC Test Used (please fill in all blanks).

The TRC value of the program is calculated by dividing the value of our avoided supply costs (generation capacity, energy, and any transmission or distribution) by the sum of our program overhead and installation costs and any incremental measure costs paid by either the customer or the electric utility.

The electric utility's avoided supply costs were _____.

Our program costs were _____.

The incremental measure costs were _____.

Subsection 2: UCT Used (please fill in all blanks).

We calculated the UCT value of our program by dividing the value of our avoided supply costs (capacity and energy) by the costs to our electric utility (including administrative costs and incentives paid or rider exemption costs) to obtain our commitment.

Our avoided supply costs were **\$173,120**.

The utility's program costs were **\$6,979**

The utility's incentive costs/rebate costs were **\$11,500**.

Refer to Appendix D for calculations and supporting documents.

Section 7: Additional Information

Please attach the following supporting documentation to this application:

Narrative description of the program including, but not limited to, make, model, and year of any installed and replaced equipment.

A copy of the formal declaration or agreement that commits the program or measure to the electric utility, including:

- 1) any confidentiality requirements associated with the agreement;
- 2) a description of any consequences of noncompliance with the terms of the commitment;
- 3) a description of coordination requirements between the customer and the electric utility with regard to peak demand reduction;
- 4) permission by the customer to the electric utility and Commission staff and consultants to measure and verify energy savings and/or peak-demand reductions resulting from your program; and,
- 5) a commitment by the customer to provide an annual report on your energy savings and electric utility peak-demand reductions achieved.

Refer to Rebate Offer Letter following this application

A description of all methodologies, protocols, and practices used or proposed to be used in measuring and verifying program results. Additionally, identify and explain all deviations from any program measurement and verification guidelines that may be published by the Commission.



DUKE ENERGY
Mercantile Self Direct Program
139 East Fourth Street
Cincinnati, OH 45202
513 629 5572 fax

September 25, 2012

Mr. Robert Barnett
The Christ Hospital
2129 Auburn Avenue
Cincinnati Ohio 45219

Subject: Your Application for a Duke Energy Mercantile Self-Direct Rebate

Dear Mr. Barnett:

Thank you for your Duke Energy Mercantile Self Direct rebate application. As noted in the Energy Conservation Measure (ECM) chart on page two, a total rebate of \$11,500.00 has been proposed for your variable frequency drive project completed in the 2012 calendar year. **All Self Direct Rebates are contingent upon approval by the Public Utilities Commission of Ohio (PUCO).**

At your earliest convenience, please indicate if you accept this rebate by

- providing your signature on page two
- completing the PUCO-required affidavit on page three.

Please return the documents to my attention via fax at 513-629-5572 or e-mail to SelfDirect@Duke-Energy.com. Upon receipt, Duke Energy will submit the necessary documentation to PUCO. Following PUCO's approval, Duke Energy will remit payment.

At Duke Energy, we value your business and look forward to working with you on this and future energy efficiency projects. We hope you will consider our Smart \$aver® incentives, when applicable. Please contact me if you have any questions.

Sincerely,

Grady Reid, Jr.
Product Manager
Mercantile Self Direct Rebates

cc: Mike Heath, Duke Energy
Rob Jung, WECC
Ronald Smolinski, Fosdick and Hilmer, Inc

Please indicate your response to this rebate offer within 30 days of receipt.

Rebate is accepted.

Rebate is declined.

By accepting this rebate, The Christ Hospital affirms its intention to commit and integrate the energy efficiency projects listed on the following pages into Duke Energy's peak demand reduction, demand response and/or energy efficiency programs.

Additionally, The Christ Hospital also agrees to serve as joint applicant in any future filings necessary to secure approval of this arrangement as required by PUCO and to comply with any information and reporting requirements imposed by rule or as part of that approval.


Finally, The Christ Hospital affirms that all application information submitted to Duke Energy pursuant to this rebate offer is true and accurate. Information in question would include, but not be limited to, project scope, equipment specifications, equipment operational details, project costs, project completion dates, and the quantity of energy conservation measures installed.

If rebate is accepted, will you use the monies to fund future energy efficiency and/or demand reduction projects?

YES

NO

If rebate is declined, please indicate reason (optional):



Robert Brawett

9/23/12

Customer Signature

Printed Name

Date

Proposed Rebate Amounts

| Measure ID | Energy Conservation Measure (ECM) | Proposed Rebate Amount |
|------------|--|------------------------|
| ECM-1 | Cooling Tower #1 - CT Fan VFD (125 HP) | \$11500.00 |
| Total | | \$11500.00 |



**Public Utilities
Commission**

Application to Commit
Energy Efficiency/Peak
Demand Reduction
Programs
(Mercantile Customers
Only)

Case No.: _____ - _____ -EL-EEC

State of Ohio :

Robert Barrett, Affiant, being duly sworn according to law, deposes and says that:

- I am the duly authorized representative of:
The Christ Hospital
[insert customer or EDU company name and any applicable name(s) doing business as]
- I have personally examined all the information contained in the foregoing application, including any exhibits and attachments. Based upon my examination and inquiry of those persons immediately responsible for obtaining the information contained in the application, I believe that the information is true, accurate and complete.
- I am aware of fines and penalties which may be imposed under Ohio Revised Code Sections 2921.11, 2921.31, 4903.02, 4903.03, and 4903.99 for submitting false information.

Robert Barrett
Signature of Affiant & Title

Sworn and subscribed before me this 16th day of October,
2012 Month/Year

[Signature]
Signature of official administering oath

Angela M Szabo, Notary
Print Name and Title

My commission expires on Dec. 9, 2013



ANGELA M. SZABO
Notary Public, State of Ohio
My Commission Expires
December 9, 2013

| | | |
|----------------------|------|-------------------|
| 03800672 01 | | |
| CHRIST HOSPITAL | | |
| 2139 AUBURN | | |
| CINCINNATI, OH 45219 | | |
| Read Date | Days | KWH Usage |
| 8/31/2010 | 29 | 4,565,352 |
| 9/30/2010 | 30 | 4,519,611 |
| 10/29/2010 | 29 | 3,904,961 |
| 12/1/2010 | 33 | 4,045,391 |
| 1/4/2011 | 34 | 3,995,010 |
| 2/2/2011 | 29 | 3,441,637 |
| 3/3/2011 | 29 | 3,436,881 |
| 4/1/2011 | 29 | 3,508,032 |
| 5/3/2011 | 32 | 4,289,033 |
| 6/2/2011 | 30 | 4,307,382 |
| 7/1/2011 | 29 | 4,577,225 |
| 8/31/2011 | 29 | 4,743,140 |
| Total | | 49,333,655 |

Appendix B - Christ Hospital - Energy Savings Achieved

| | Baseline Used ¹ | | | Post Project Actual | | | Hours of Operation | Savings | |
|--------|---|------------|----------------------|-------------------------|------------|----------------------|--------------------|------------|-----------------------------------|
| | Description | Annual kWh | Summer Coincident kW | Description | Annual kWh | Summer Coincident kW | | Annual kWh | Summer Coincident kW ² |
| ECM- 1 | 125 HP Motor on Cooling Tower #1 (No VFD) | 654,646 | 94 | Cooling Tower VFD Added | 389,398 | 88.0 | 6,936 | 265,248 | 6.0 |

Application of 7.43% line losses yields **284,961 kWh savings** and **23.9 summer coincident kW**. These values may also reflect minor DSMore modeling software rounding error.

Notes: 1. Energy consumption baseline, demand baseline and post-project energy consumption basis are outlined in the following pages (see following Calculation tabs).

2 This value is the difference between the maximum kW demand before implementation and the maximum kW demand after implementation, both of which occur in May and June. The maximum kW demand savings in any month is 45 kW, which occurs in both December and January

CALCULATION INPUT DATA

JAN 2012 V2.0

| | |
|-----------------------------|-----------------------------|
| Salesforce Opportunity Name | Christ Hospital - VFD Tower |
| Project Name | Christ Hospital - VFD Tower |
| ECM | 1 |

Application # 12-495

Rev. 0
State OH

Note: all data from the "Part2-Self-Direct-Custom-VFD-App.xlsx" file, except as otherwise noted

| | | | | |
|------------------------------------|-------------|------------------|-------------|-----|
| Driven Equipment | Name | Cooling Tower #1 | Type | Fan |
| Quantity | | 1 | | |
| Brake HP (BHP) at Full Load | | 120.7 | | |
| Nameplate HP | | 125.0 | | |

Current Equipment Operation without VFD - Input values for ONE driven equipment and its motor.

| % of Full Load BHP of Driven Equipment | BHP of Driven Equipment @ Actual Load (BHP) | Motor output HP as % of Nameplate HP | Motor Efficiency @ Motor Output HP (%) | | Motor Electrical Power Draw (kw) | Monthly hours that each motor runs | | | | | | | | | | | | Yearly Total (hr) | |
|--|---|--------------------------------------|--|---|----------------------------------|------------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|-------------------|--------------|
| | | | | | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | | |
| | | | | | | 100 | % | 120.7 | 97% | 95.4 | % | 94.38 | 480 | 228 | 408 | 684 | 744 | | 720 |
| Not Running | 0.0 | 0% | NA | % | 0.00 | 264 | 444 | 336 | 36 | 0 | 0 | 0 | 0 | 0 | 0 | 276 | 468 | 1,824 | |
| Totals | | | | | | 744 | 672 | 744 | 720 | 744 | 720 | 744 | 744 | 720 | 744 | 720 | 744 | 744 | 8,760 |

Proposed Equipment Operation with VFD - Input values for ONE driven equipment and its motor.

| | | |
|-------------------|----|---|
| Efficiency of VFD | 96 | % |
|-------------------|----|---|

| % of Full Load BHP of Driven Equipment | BHP of Driven Equipment @ Actual Load (BHP) | Motor output HP as % of Motor Nameplate | Motor Efficiency @ Motor Output HP (%) | | Motor Electrical Power Draw (kw) | Monthly hours that each motor runs | | | | | | | | | | | | Yearly Total (hr) | | |
|--|---|---|--|------|----------------------------------|------------------------------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|-------------------|--------------|----|
| | | | | | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | | | |
| | | | | | | 100 | % | 120.7 | 97% | 95.4 | % | 94.38 | 0 | 0 | 0 | 0 | 0 | | 0 | 0 |
| 90 | % | 108.6 | 87% | 95.4 | % | 84.95 | 0 | 0 | 0 | 0 | 36 | 36 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 72 |
| 80 | % | 96.6 | 77% | 95.4 | % | 75.51 | 0 | 0 | 0 | 0 | 168 | 324 | 612 | 504 | 228 | 0 | 0 | 0 | 1,836 | |
| 70 | % | 84.5 | 68% | 95.4 | % | 66.07 | 0 | 0 | 24 | 108 | 132 | 300 | 96 | 204 | 168 | 84 | 0 | 0 | 1,116 | |
| 60 | % | 72.4 | 58% | 95.4 | % | 56.63 | 0 | 60 | 60 | 156 | 60 | 60 | 24 | 36 | 192 | 96 | 48 | 0 | 792 | |
| 50 | % | 60.4 | 48% | 94.4 | % | 47.69 | 12 | 12 | 12 | 132 | 60 | 0 | 12 | 0 | 120 | 252 | 36 | 12 | 660 | |
| 40 | % | 48.3 | 39% | 92.4 | % | 38.98 | 0 | 0 | 48 | 96 | 144 | 0 | 0 | 0 | 12 | 216 | 96 | 0 | 612 | |
| 30 | % | 36.2 | 29% | 90.5 | % | 29.85 | 468 | 156 | 264 | 192 | 144 | 0 | 0 | 0 | 0 | 96 | 264 | 264 | 1,848 | |
| 20 | % | 24.1 | 19% | 85.6 | % | 21.04 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 10 | % | 12.1 | 10% | 74.5 | % | 12.09 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| Not Running | 0.0 | 0% | NA | % | 0.00 | 264 | 444 | 336 | 36 | 0 | 0 | 0 | 0 | 0 | 0 | 276 | 468 | 1,824 | | |
| Totals | | | | | | 744 | 672 | 744 | 720 | 744 | 720 | 744 | 744 | 720 | 744 | 720 | 744 | 744 | 8,760 | |

DETAILED CALCULATIONS

JAN 2012 V2.0

| | |
|-----------------------------|-----------------------------|
| Salesforce Opportunity Name | Christ Hospital - VFD Tower |
| Project Name | Christ Hospital - VFD Tower |
| ECM | 1 |

Application # 12-495 MSD

| | |
|-------|----|
| Rev. | 0 |
| State | OH |

1. BASE CONDITION OPERATION without VFD

| | Energy Demand (kw) | | | | | | | | | | | | Maximum |
|---------|--------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|---------|
| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | |
| 100% | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 |
| Maximum | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 | 94 |

| | Energy Usage (kw-hr) | | | | | | | | | | | | |
|-------|----------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|---------|
| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Total |
| 100% | 45,304 | 21,520 | 38,509 | 64,559 | 70,222 | 67,956 | 70,222 | 70,222 | 67,956 | 70,222 | 41,906 | 26,050 | 654,646 |
| Total | 45,304 | 21,520 | 38,509 | 64,559 | 70,222 | 67,956 | 70,222 | 70,222 | 67,956 | 70,222 | 41,906 | 26,050 | 654,646 |

2. PROPOSED OPERATION with VFD

| % of Full Load Capacity of Driven Equipment | Energy Demand (kw) | | | | | | | | | | | | Maximum |
|---|--------------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|---------|
| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | |
| 100% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 90% | 0 | 0 | 0 | 0 | 88 | 88 | 0 | 0 | 0 | 0 | 0 | 0 | 88 |
| 80% | 0 | 0 | 0 | 0 | 79 | 79 | 79 | 79 | 79 | 0 | 0 | 0 | 0 |
| 70% | 0 | 0 | 69 | 69 | 69 | 69 | 69 | 69 | 69 | 69 | 0 | 0 | 69 |
| 60% | 0 | 59 | 59 | 59 | 59 | 59 | 59 | 59 | 59 | 59 | 59 | 0 | 59 |
| 50% | 50 | 50 | 50 | 50 | 50 | 0 | 50 | 0 | 50 | 50 | 50 | 50 | 50 |
| 40% | 0 | 0 | 41 | 41 | 41 | 0 | 0 | 0 | 41 | 41 | 41 | 0 | 41 |
| 30% | 31 | 31 | 31 | 31 | 31 | 0 | 0 | 0 | 0 | 31 | 31 | 31 | 31 |
| 20% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 10% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Maximum | 50 | 59 | 69 | 69 | 88 | 88 | 79 | 79 | 79 | 69 | 59 | 50 | 88 |

DETAILED CALCULATIONS

JAN 2012 V2.0

| | |
|-----------------------------|-----------------------------|
| Salesforce Opportunity Name | Christ Hospital - VFD Tower |
| Project Name | Christ Hospital - VFD Tower |
| ECM | 1 |

Application # 12-495 MSD

| | |
|-------|----|
| Rev. | 0 |
| State | OH |

| % of Full Load Capacity of Driven Equipment | Energy Usage (kw-hr) | | | | | | | | | | | | |
|---|----------------------|--------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|---------------|--------------|----------------|
| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Total |
| 100% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 90% | 0 | 0 | 0 | 0 | 3,185 | 3,185 | 0 | 0 | 0 | 0 | 0 | 0 | 6,371 |
| 80% | 0 | 0 | 0 | 0 | 13,214 | 25,484 | 48,136 | 39,641 | 17,933 | 0 | 0 | 0 | 144,407 |
| 70% | 0 | 0 | 1,652 | 7,433 | 9,084 | 20,646 | 6,607 | 14,040 | 11,562 | 5,781 | 0 | 0 | 76,805 |
| 60% | 0 | 3,539 | 3,539 | 9,202 | 3,539 | 3,539 | 1,416 | 2,124 | 11,326 | 5,663 | 2,832 | 0 | 46,720 |
| 50% | 596 | 596 | 596 | 6,558 | 2,981 | 0 | 596 | 0 | 5,961 | 12,519 | 1,788 | 596 | 32,788 |
| 40% | 0 | 0 | 1,949 | 3,898 | 5,847 | 0 | 0 | 0 | 487 | 8,770 | 3,898 | 0 | 24,849 |
| 30% | 14,551 | 4,850 | 8,208 | 5,970 | 4,477 | 0 | 0 | 0 | 0 | 2,985 | 8,208 | 8,208 | 57,458 |
| 20% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 10% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Total | 15,147 | 8,986 | 15,944 | 33,060 | 42,328 | 52,855 | 56,755 | 55,804 | 47,270 | 35,718 | 16,726 | 8,804 | 389,398 |

SECTION 4 - SAVINGS

| | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Yearly |
|--------------------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|--------|---------|
| Energy Demand (kw) | 45 | 35 | 26 | 26 | 6 | 6 | 16 | 16 | 16 | 26 | 35 | 45 | 45 |
| Energy Use (kw-hr) | 30,157 | 12,534 | 22,564 | 31,498 | 27,894 | 15,101 | 13,467 | 14,417 | 20,687 | 34,503 | 25,180 | 17,246 | 265,248 |

Appendix C - Christ Hospital Cash Rebate Calculation

VFD

| Measure | Quantity | Cash Rebate Rate | Cash Rebate |
|-------------------------|-----------------|---|--------------------|
| Cooling Tower VFD Added | 1 | 50% of incentive that would be offered by the Smart \$aver Custom program | \$11,500 |

Appendix D -Christ Hospital - UCT Value

VFD

| Measure | Total Avoided Cost | Program Cost | Incentive | Quantity | Measure UCT |
|-------------------------|---------------------------|---------------------|------------------|-----------------|--------------------|
| Cooling Tower VFD Added | \$173,120 | \$6,979 | \$11,500 | 1 | 9.37 |
| Totals | \$173,120 | \$6,979 | \$11,500 | 1 | |

| | | | |
|----------------------------|-----------|----------------------------------|-------------|
| Total Avoided Supply Costs | \$173,120 | <i>Aggregate Application UCT</i> | 9.37 |
| Total Program Costs | \$6,979 | | |
| Total Incentive | \$11,500 | | |

Ohio Mercantile Self Direct Program

Application Guide & Cover Sheet

Questions? Call 1-866-380-9580 or visit www.duke-energy.com.

Email this form along with completed Mercantile Self Direct Prescriptive or Custom applications, proof of payment, energy savings calculations and spec sheets to SelfDirect@Duke-Energy.com. You may also fax to 1-513-629-5572.

Mercantile customers, defined as using at least 700,000 kWh annually are eligible for the Mercantile Self Direct program. Please indicate mercantile qualification:

- a single Duke Energy Ohio account
- multiple accounts in Ohio (energy usage with other utilities may be counted toward the total)

Please list Duke Energy account numbers below (attach listing of multiple accounts and/or billing history for other utilities as required):

| Account Number | Annual Usage | Account Number | Annual Usage |
|----------------|--------------|----------------|--------------|
| | | | |
| | | | |
| | | | |
| | | | |

Self Direct rebates are available for completed Custom projects that have not previously received a Duke Energy Smart \$aver® Custom Incentive. Self Direct incentives are applicable to Prescriptive measures that were installed more than 90 days prior to submission to Duke Energy and have not previously received a Duke Energy Prescriptive rebate.

Self Direct Program requirements dictate that certain projects that may be Prescriptive in nature under the Smart \$aver program must be evaluated using the Custom process. Use the table on page two as a guide to determine which Self Direct program fits your project(s). Apply for Self Direct projects using the appropriate application forms in conjunction with this cover sheet. Where Mercantile Self Direct Prescriptive applications are listed, please refer to the measure list on that application. If your measure is not listed, you may be eligible for a Self Direct Custom rebate. Self Direct Custom applications, like Smart \$aver Custom applications, should include detailed analysis of pre-project and post-project energy usage and project costs. Please indicate which type of rebate applications are included in the table provided on page two.

Please check each box to indicate completion of the following program requirements:

| | | | |
|--|--|--|---|
| <input checked="" type="checkbox"/> All sections of appropriate application(s) are completed | <input checked="" type="checkbox"/> Proof of payment.* | <input checked="" type="checkbox"/> Manufacturer's Spec sheets | <input checked="" type="checkbox"/> Energy model/calculations and detailed inputs for Custom applications |
|--|--|--|---|

* If a single payment record is intended to demonstrate the costs of both Prescriptive & Custom projects, please include an additional document with an estimated breakout of costs for each Prescriptive and Custom energy conservation measure.

| Application Type | Replaced equipment at end of lifetime or because equipment failed** | Replaced fully operational equipment to improve efficiency*** | New Construction |
|--|---|--|---|
| Lighting | MSD Custom Part 1 <input type="checkbox"/> Custom Lighting Worksheet <input type="checkbox"/> | MSD Prescriptive Lighting <input type="checkbox"/> | MSD Prescriptive Lighting <input type="checkbox"/> |
| | | MSD Custom Part 1 <input type="checkbox"/> Custom Lighting Worksheet <input type="checkbox"/> | MSD Custom Part 1 <input type="checkbox"/> Custom Lighting Worksheet <input type="checkbox"/> |
| Heating & Cooling | MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/> | MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/> | MSD Prescriptive Heating & Cooling <input type="checkbox"/> |
| | | | MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/> |
| Window Films, Programmable Thermostats, & Guest Room Energy Management Systems | MSD Custom Part 1 <input type="checkbox"/> MSD Custom General and/or EMS Worksheet(s) <input type="checkbox"/> | MSD Prescriptive Heating & Cooling <input type="checkbox"/> | MSD Custom Part 1 <input type="checkbox"/> MSD Custom General and/or EMS Worksheet(s) <input type="checkbox"/> |
| Chillers & Thermal Storage | MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/> | MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/> | MSD Prescriptive Chillers & Thermal Storage <input type="checkbox"/> |
| | | | MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/> |
| Motors & Pumps | MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/> | MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/> | MSD Prescriptive Motors, Pumps & Drives <input type="checkbox"/> |
| | | | MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/> |
| VFDs | Not Applicable | MSD Prescriptive Motors, Pumps & Drives <input type="checkbox"/> | MSD Custom Part 1 <input checked="" type="checkbox"/> MSD Custom VFD Worksheet <input checked="" type="checkbox"/> |
| | | MSD Custom Part 1 <input type="checkbox"/> MSD Custom VFD Worksheet <input type="checkbox"/> | |
| Food Service | MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/> | MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/> | MSD Prescriptive Food Service <input type="checkbox"/> |
| | | | MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/> |
| Air Compressors | MSD Custom Part 1 <input type="checkbox"/> MSD Custom Compressed Air Worksheet <input type="checkbox"/> | MSD Custom Part 1 <input type="checkbox"/> MSD Custom Compressed Air Worksheet <input type="checkbox"/> | MSD Prescriptive Process <input type="checkbox"/> |
| | | | MSD Custom Part 1 <input type="checkbox"/> MSD Custom Compressed Air Worksheet <input type="checkbox"/> |
| Process | MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/> | MSD Prescriptive Process <input type="checkbox"/> | MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/> |
| | | MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/> | |
| Energy Management Systems | MSD Custom Part 1 <input type="checkbox"/> MSD Custom EMS Worksheet <input type="checkbox"/> | MSD Custom Part 1 <input type="checkbox"/> MSD Custom EMS Worksheet <input type="checkbox"/> | MSD Custom Part 1 <input type="checkbox"/> MSD Custom EMS Worksheet <input type="checkbox"/> |
| Chiller Tune-ups | MSD Prescriptive Chiller Tune-ups <input type="checkbox"/> | | |
| Behavioral*** & No/Low Cost | MSD Custom Part 1 <input type="checkbox"/> MSD Custom General Worksheet <input type="checkbox"/> | | |

** Under the Self Direct program, failed equipment and equipment at the end of its useful life are evaluated differently than early replacement of fully functioning equipment. **All equipment replacements due to failure or old age will be evaluated via the Custom program.**

*** Please ensure that you include the age of the replaced equipment for measures classified as "Early Replacement" in your application as well as the estimated date that you would have otherwise replaced the existing equipment if you had not chosen a more energy efficient option.

**** Behavioral energy efficiency and demand reduction projects must be both measurable and verifiable. Provide justification with your application.

Mercantile Self Direct Nonresidential Custom Rebate Application PART 1



Proposed energy efficiency measures may be eligible for Self-Direct Custom rebates if they clearly reduce electrical consumption and/or demand as compared to the appropriate baseline.

Before you complete this application, please note the following important criteria:

- Submitting this application does not guarantee a rebate will be approved.
- Rebates are based on electricity conservation only.
- Electric demand and/or energy reductions must be well documented with auditable calculations.
- Incomplete applications cannot be reviewed; all fields are required.

Refer to the complete list of Instructions and Disclaimers, beginning on page 6.

Notes on the Application Process

If you have any questions concerning how to complete any portion of the application or what supplementary information is required, please contact your Duke Energy Ohio, Inc account manager or the Duke Energy Smart \$aver® team at 1-866-380-9580.

Every application must include calculations of the baseline electrical usage and the electrical usage of the proposed high-efficiency equipment/system. Monthly calculations are best. You, the Duke Energy Ohio customer, or your equipment vendor / engineer should perform these calculations and submit them to Duke Energy for review. *We strongly encourage the use of modeling software (such as eQuest or comparable) for complex projects.*

Upon receipt of your application, an acknowledgement email will be sent to you with an estimated response time based on an initial assessment of your application. The application review may include some communication to resolve any questions about the project or to request additional information. Applications that are received complete without missing information have a faster review time.

There are two ways to submit your completed application.

Email your scanned form to: SelfDirect@duke-energy.com

Or, fax your form to 513-629-5572

**Mercantile Self Direct
Nonresidential Custom Rebate Application
PART 1**



1. Contact Information (Required)

| Duke Energy Customer Contact Information | | | | | |
|--|--|--------------|---------------|----------|---------------|
| Company Name | The Christ Hospital | | | | |
| Address | 2139 Auburn Ave. | | | | |
| Project Contact | Robert Barnett | | | | |
| City | Cincinnati | State | Ohio | Zip Code | 45219 |
| Title | Manager Plant Operations & Maintenance | | | | |
| Office Phone | (513)585-2964 | Mobile Phone | (513)310-3392 | Fax | (513)585-3913 |
| E-mail Address | Robert.Barnett@thechristhospital.com | | | | |

| Equipment Vendor / Contractor / Architect / Engineer Contact Information | | | | | |
|--|---|--------------|---------------|----------|---------------|
| Company Name | Fosdick & Hilmer, Inc. | | | | |
| Address | 309 Vine St. | | | | |
| City | Cincinnati | State | Ohio | Zip Code | 45202 |
| Project Contact | Ronald Smolinski | | | | |
| Title | Engineer | | | | |
| Office Phone | (513)419-4216 | Mobile Phone | (513)319-9620 | Fax | (513)241-3659 |
| E-mail Address | rsmolinski@fheng.com | | | | |
| Describe Role | Engineer for chiller plant energy calculations, component selection, and design | | | | |

| Payment Information | | | | | |
|--|--|-------|--|----------|--|
| Payee Legal Company Name (as shown on Federal income tax return): | | | | | |
| Mailing Address | | | | | |
| City | | State | | Zip Code | |
| Type of organization (check one) <input type="checkbox"/> Individual/Sole Proprietor <input type="checkbox"/> Corporation <input type="checkbox"/> Partnership <input type="checkbox"/> Unit of Government <input type="checkbox"/> Non-Profit (non-corporation) | | | | | |
| Payee Federal Tax ID # of Legal Company Name Above: | | | | | |
| Who should receive incentive payment? (select one) <input type="checkbox"/> Customer <input type="checkbox"/> Vendor (Customer must sign below) | | | | | |
| If the vendor is to receive payment, please sign below: I hereby authorize payment of incentive directly to vendor: | | | | | |
| Customer Signature _____ Date ____/____/____ (mm/dd/yyyy) | | | | | |

**Mercantile Self Direct
Nonresidential Custom Rebate Application
PART 1**



2. Project Information (Required)

- A. Please indicate project type:
- New Construction
 - Expansion at an existing facility
 - Replacing equipment due to equipment failure
 - Replacing equipment that is estimated to have remaining useful life of 2 years or less
 - Replacing equipment that is estimated to have remaining useful life of more than 2 years
 - Behavioral, operational and/or procedural programs/projects
- B. Please describe your project, or attach a detailed project description that describes the project.
Add a cooling tower and variable speed drive.
- C. When did you start and complete implementation?
Start date 02/2012 (mm/yyyy) End date 06/2012 (mm/yyyy)
- D. Are you also applying for Self-Direct Prescriptive incentives and, if so, which one(s)¹?
- E. Please indicate which worksheet(s) you are submitting for this application (check all that apply):
- Lighting
 - Variable Frequency Drive (VFD)
 - Compressed Air
 - Energy Management System (EMS)
 - General (for projects not easily submitted using one of the above worksheets)
- F. Please tell us if there is anything about your electrical energy projections (either for the baseline or the proposed project) that you are either unsure about or for which you have made significant assumptions. Attach additional sheets as needed.

Required: Attach a supplier or contractor invoice or other equivalent information documenting the Implementation Cost for each project listed in your application. (Note: self-install costs cannot be included in the Implementation Cost)

¹ If your project involves some equipment that is eligible for prescriptive incentives and some equipment that is likely eligible for custom incentives, and if it is feasible to separate the equipment for the energy analysis, then the equipment will be evaluated separately. If it is not feasible to separate the equipment for analysis, then the equipment will be evaluated together in the custom application.

**Mercantile Self Direct
Nonresidential Custom Rebate Application
PART 1**



3. Signature (Required – must be signed by Duke Energy customer)

Customer Consent to Release of Personal Information

I, (insert name) Bob Barnett, do hereby consent to Duke Energy disclosing my Duke Energy Ohio, Inc Account Number and Federal Tax ID Number to its subcontractors solely for the purpose of administering Duke Energy Ohio's Mercantile Self-Direct Program. I understand that such subcontractors are contractually bound to otherwise maintain my Duke Energy Ohio, Inc Account Number and Federal Tax ID Number in the strictest of confidence.

I realize that under the rules and regulations of the public utilities commission, I may refuse to allow Duke Energy Ohio, Inc to release the information set forth above. By my signature, I freely give Duke Energy Ohio, Inc permission to release the information designated above.

Application Signature

I certify that I meet the eligibility requirements of the Duke Energy Ohio, Inc Mercantile Self Direct Custom Incentives Program and that all information provided within this application is correct to the best of my knowledge. I agree to the terms and conditions set forth for this program. I certify that the numbers, energy savings, and responses shown on this form are correct. Further, I certify that the taxpayer identification number is current and correct. I am not subject to backup withholding because: (a) I am exempt from backup withholding; or (b) I have not been notified by the IRS that I am subject to backup withholding as a result of a failure to report all interest or dividends; or (c) the IRS has notified me that I am no longer subject to backup withholding. I am a U.S. citizen (includes a U.S. resident alien).

Duke Energy Ohio, Inc Customer Signature

Print Name

Robert O Barnett

Date

9/1/12

**Mercantile Self Direct
Nonresidential Custom Rebate Application
PART 1**



Checklist for completing the Application

INCOMPLETE APPLICATIONS WILL RESULT IN DELAYS IN DUKE ENERGY PROCESSING YOUR APPLICATION AND NOTIFYING YOU CONCERNING ANY REBATES. Before submitting the application and the required supplementary information, use the following checklist to ensure that your application is complete and the information in the application is accurate. (Note: this checklist is for your use only – do not submit this checklist with your application)

| Section No. & Title | Have You: |
|--------------------------------------|--|
| 1. Contact Information | <input checked="" type="checkbox"/> Completed the contact information for the Duke Energy customer? <input checked="" type="checkbox"/> Completed the contact information for the equipment vendor / project engineer that can answer questions about the technical aspects of the project, if that is a different person than above? |
| 2. Project Information | <input checked="" type="checkbox"/> Answered the questions A-E, including providing a description of your project. <input checked="" type="checkbox"/> Completed and attached the lighting, compressed air, VFD, EMS and/or General worksheet(s)? |
| 3. Signature | <input type="checkbox"/> Signed your name? <input type="checkbox"/> Printed your name? <input type="checkbox"/> Entered the date? |
| Supplementary information (Required) | <input type="checkbox"/> Attached a supplier or contractor's invoice or other equivalent information documenting the Implementation Cost for projects listed in your application? (Note: self-install costs cannot be included in the Implementation Cost) <input type="checkbox"/> (If submitting the General Worksheet) attached calculations documenting the energy usage and energy savings for each project listed in your application? |

If you have any questions concerning how to complete any portion of the application or what supplementary information is required, please contact:

- your Duke Energy account manager
- or,
- the Duke Energy Smart \$aver® team at 1-866-380-9580.

Mercantile Self Direct Nonresidential Custom Rebate Application PART 1



Instructions/Terms/Conditions

Note: Please keep for your records- do not submit with the application

1. Energy service companies or contractors may assist in preparing the application, but an authorized representative of the customer must sign this application to be eligible to participate in the Mercantile Self Direct Program. Completion of this application does not guarantee the approval of a Self Direct Custom Rebate.
2. Once all documentation requested in this application is received by *Duke Energy Ohio, Inc*, and any follow-up information requested by *Duke Energy* is received, the rebate amount for each Energy Conservation Measure (ECM) will be communicated to the customer. The rebate amount will be based on ECM energy savings and ECM incremental installation cost.
3. All rebates require approval by the Public Utilities Commission of Ohio. *Duke Energy Ohio, Inc* will submit an application for rebate on the customer's behalf upon customer attestation to program terms, conditions and requirements as outlined in the rebate offer letter and upon customer completion of attestation documents required by the Public Utilities Commission of Ohio.
4. *Duke Energy Ohio, Inc* will issue a Self Direct Custom Rebate check, based on the approved rebate amount for each ECM, upon receiving approval from the Public Utilities Commission of Ohio. *Duke Energy Ohio, Inc* does not guarantee PUCO approval.
5. With the application, the customer must provide a list of all sites where the ECMs were installed. *Duke Energy Ohio, Inc* requests that sites of similar size, hours of operation and energy consuming characteristics be grouped together in one application for the determination of the rebate amount. The application should identify the site where each unique ECM was installed.
6. Based on the information submitted with the application and the information gathered both before and after the initial installation of the ECM, *Duke Energy Ohio, Inc* will calculate the rebate amount for each ECM.
7. *Duke Energy Ohio, Inc* may conduct random site inspections of a sample of the locations where the ECMs are installed to verify installation and operability of the ECMs and to obtain information needed to calculate the Approved Incentive Amount.
8. Customers are encouraged to retain copies of all forms, invoices and supporting documentation for their records.
9. Approved rebates are valid for 6 months from the date communicated to the customer by *Duke Energy Ohio, Inc*, subject to the expiration of measure eligibility based on project completion dates and application submission deadlines as defined by PUCO. Customers are encouraged to execute their rebate offer contracts and PUCO-required affidavits promptly to ensure eligibility is not forfeited.

**Mercantile Self Direct
Nonresidential Custom Rebate Application
PART 1**



10. *Duke Energy Ohio, Inc* reserves the right to recover all unrecoverable costs associated with the project approval if the customer decides not to execute the rebate contract, after the project is approved by *Duke Energy Ohio, Inc*.
11. Projects financially supported by other funding sources will be evaluated on a case-by-case basis for potential partial funding from *Duke Energy Ohio, Inc*.
12. Participants must be *Duke Energy Ohio, Inc* nonresidential, mercantile customers with the project sites in the *Duke Energy Ohio, Inc* service territory.
13. Customers or trade allies may not use any *Duke Energy* logo without prior written permission.
14. Only trade allies registered with *Duke Energy* are eligible to participate.
15. All equipment must be new. Used or rebuilt equipment is not eligible for incentives. All old existing equipment must be removed on retrofit projects.
16. Disclaimers: *Duke Energy Ohio, Inc*
 - a. does not endorse any particular manufacturer, product or system design within the program;
 - b. will not be responsible for any tax liability imposed on the customer as a result of the payment of incentives;
 - c. does not expressly or implicitly warrant the performance of installed equipment. (Contact your contractor for details regarding equipment warranties.);
 - d. is not responsible for the proper disposal/recycling of any waste generated or obsolete or old equipment as a result of this project;
 - e. is not liable for any damage caused by the installation of the equipment nor for any damage caused by the malfunction of the installed equipment; and
 - f. reserves the right to change or discontinue this program at any time. The acceptance of program applications is determined solely by *Duke Energy Ohio, Inc*.



The VFD Worksheet is part 2 of the application. Do not submit this file without submitting a completed Part1 Custom Application document file, which can be found at www.duke-energy.com.

Before you complete this application, please note the following important criteria:

- Submitting this application does not guarantee an incentive will be approved.
- Rebates are based on electricity conservation only.
- Electric demand and/or energy reductions must be well documented with auditable calculations.
- Incomplete applications will not be reviewed; all fields are required.

Refer to the complete list of Instructions and Disclaimers, found in the Mercantile Self Custom Application Part 1 document.

Please enter your information and data into the cells that are shaded.
Cells in white are locked and cannot be written over.

Duke Energy Customer Contact Information (Match the information in Application Part 1):

| | |
|---------|---------------------|
| Name | Robert Barnett |
| Company | The Christ Hospital |

Equipment Vendor / Project Engineer Contact Information

| | |
|---------|------------------------|
| Name | Ronald Smolinski |
| Company | Fosdick & Hilmer, Inc. |

Location of Proposed VFD Project

| | |
|----------------------------|------------------|
| Site Name | Chiller Plant |
| Electric Account Number(s) | 0380-0672-01-4 |
| Site Address | 2139 Auburn Ave. |

Before proceeding with the custom application, please verify that your project is not on the Self-Direct Prescriptive application.

The prescriptive incentive applications can be found at:

<http://www.duke-energy.com/ohio-large-business/smart-saver/mercantile-self-direct.asp>

Prescriptive rebate amounts are pre-approved.



Use one worksheet for each type of motor or fan that is being evaluated for a VFD

| | | | | |
|---|-------------|------------------|-------------|-----|
| Driven Equipment | Name | Cooling Tower #1 | Type | Fan |
| Quantity | | 1 | | |
| Brake HP (BHP) at Full Load (see note 1) | | 120.7 | | |
| Nameplate HP | | 125.0 | | |

| | |
|----------------|--|
| App No. | |
| Rev. | |

Current Equipment Operation without VFD - Input values for ONE driven equipment and its motor.

| % of Full Load BHP of Driven Equipment | BHP of Driven Equipment @ Actual Load (BHP) | Motor output HP as % of Nameplate HP | Motor Efficiency @ Motor Output HP (%) | Motor Electrical Power Draw (kw) | Annual hours that motor runs (see note 2) | Monthly hours that each motor runs (see note 3) | | | | | | | | | | | | Yearly Total (hr) | | |
|--|---|--------------------------------------|--|----------------------------------|---|---|--------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|-------------------|------------|--------------|
| | | | | | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | | | |
| | | | | | | 100 | % | 120.7 | 97% | 95.4 | % | 94.38 | 480 | 228 | 408 | 684 | 744 | | 720 | 744 |
| | % | 0.0 | 0% | | % | #DIV/0! | | | | | | | | | | | | | | 0 |
| | % | 0.0 | 0% | | % | #DIV/0! | | | | | | | | | | | | | | 0 |
| | % | 0.0 | 0% | | % | #DIV/0! | | | | | | | | | | | | | | 0 |
| Not Running | | 0.0 | 0% | NA | % | 0.00 | 8,760 | 264 | 444 | 336 | 36 | 0 | 0 | 0 | 0 | 0 | 0 | 276 | 468 | 1,824 |
| Totals | | | | | | | 8,760 | 744 | 672 | 744 | 720 | 744 | 720 | 744 | 744 | 720 | 744 | 720 | 744 | 8,760 |

Proposed Equipment Operation with VFD - Input values for ONE driven equipment and its motor.

| | | |
|--------------------------|----|---|
| Efficiency of VFD | 96 | % |
|--------------------------|----|---|

| % of Full Load BHP of Driven Equipment | BHP of Driven Equipment @ Actual Load (BHP) | Motor output HP as % of Motor Nameplate | Motor Efficiency @ Motor Output HP (%) | Motor Electrical Power Draw (kw) | Annual hours that motor runs (see note 2) | Monthly hours that each motor runs (see note 3) | | | | | | | | | | | | Yearly Total (hr) | | | |
|--|---|---|--|----------------------------------|---|---|--------------|------------|------------|------------|-----------|----------|----------|----------|----------|----------|----------|-------------------|------------|------------|--------------|
| | | | | | | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | | | | |
| | | | | | | 100 | % | 120.7 | 97% | 95.4 | % | 94.38 | 0 | 0 | 0 | 0 | 0 | | 0 | 0 | 0 |
| 90 | % | 108.6 | 87% | 95.4 | % | 84.95 | 0 | 0 | 0 | 0 | 36 | 36 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 72 | |
| 80 | % | 96.6 | 77% | 95.4 | % | 75.51 | 0 | 0 | 0 | 0 | 168 | 324 | 612 | 504 | 228 | 0 | 0 | 0 | 0 | 1836 | |
| 70 | % | 84.5 | 68% | 95.4 | % | 66.07 | 0 | 0 | 24 | 108 | 132 | 300 | 96 | 204 | 168 | 84 | 0 | 0 | 0 | 1116 | |
| 60 | % | 72.4 | 58% | 95.4 | % | 56.63 | 0 | 60 | 60 | 156 | 60 | 60 | 24 | 36 | 192 | 96 | 48 | 0 | 0 | 792 | |
| 50 | % | 60.4 | 48% | 94.4 | % | 47.69 | 12 | 12 | 12 | 132 | 60 | 0 | 12 | 0 | 120 | 252 | 36 | 12 | 0 | 660 | |
| 40 | % | 48.3 | 39% | 92.4 | % | 38.98 | 0 | 0 | 48 | 96 | 144 | 0 | 0 | 0 | 12 | 216 | 96 | 0 | 0 | 612 | |
| 30 | % | 36.2 | 29% | 90.5 | % | 29.85 | 468 | 156 | 264 | 192 | 144 | 0 | 0 | 0 | 0 | 96 | 264 | 264 | 0 | 1848 | |
| 20 | % | 24.1 | 19% | 85.6 | % | 21.04 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 10 | % | 12.1 | 10% | 74.5 | % | 12.09 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| Not Running | | 0.0 | 0% | NA | % | 0.00 | 8,760 | 264 | 444 | 336 | 36 | 0 | 0 | 0 | 0 | 0 | 0 | 276 | 468 | 1,824 | |
| Totals | | | | | | | 8,760 | 264 | 444 | 336 | 36 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 276 | 468 | 1,824 |

Detailed Project Description Attached? (Required)

1 Brake HP (BHP) at Full Load

The "full load" operating condition is the condition at which the driven equipment operates for the base condition (i.e., without the VFD)

2 Annual hours that motor runs

If the % operating loads do not vary between months, then enter the total annual hours that the motor will run at full load, partial load and hours not operating.

3 Monthly hours that each motor runs

If the % operating loads vary between months (due to weather conditions or seasonal load), fill in the expected hours that the motor will run each month at full load, partial load and hours not operating.



| | |
|---------|---|
| App No. | 0 |
| Rev. | 0 |

Operating Hours (see note 4)

| 24 x 7 | Weekday | | Saturday | | Sunday | | Weeks of Use in Year (see note 5) | Total Annual Hours of Use |
|--------|------------|----------|------------|----------|------------|----------|-----------------------------------|---------------------------|
| | Start Hour | End Hour | Start Hour | End Hour | Start Hour | End Hour | | |
| | | | | | | | | |

Energy Savings

| | Existing (no VFD) | Proposed (VFD) | Savings | Describe how energy numbers were calculated |
|-----------------------------|-------------------|----------------|-------------|---|
| Annual Electric Energy | 654,620 kWh | 373,832 kWh | 280,788 kWh | |
| Electric Demand (kilowatts) | 0 kW | 0 kW | 0 kW | |
| Calculations attached | Yes | Yes | | |

Simple Payback

| | |
|--|--------------------|
| Average electric rate (\$/kWh) on the applicable accounts (see note 6) | \$0.07 |
| Estimated annual electric savings | \$18,251 |
| Other annual savings in addition to electric savings, such as operations, maintenance, other fuels | \$0.00 |
| Incremental cost to implement the project (equipment & installation) (see note 7) | \$57,486.00 |
| Copy of vendor proposal is attached (see note 8) | Yes |
| Simple Electric Payback in years (see note 9) | 3.149708599 |
| Total Payback in years | 3.149708599 |

4 Operating Hours

Describe when the equipment is typically used. If the project is proposed for more than one site, provide any variations in operating hours between the sites on a separate sheet.

5 Weeks of Use in Year

If the equipment is not in use 52 weeks during the year (for example, during holiday or summer break), provide an explanation of when usage is not expected and why:

| |
|--|
| |
|--|

6 Average electric rate (\$/kWh)

If you do not know your average electric rate, use \$0.10/kWh.

7 Incremental cost to implement the project

Costs exclude self installation costs.

Retrofit projects, incremental cost is the total cost of the proposed project. New construction or where the existing equipment must be replaced anyway, then incremental cost is the premium of the proposed high efficiency project over baseline.

8 Copy of vendor invoice is attached

Vendor invoices detailing costs of the project are always required.

New construction projects or where the existing equipment must be replaced anyway, vendor proposal of baseline must also be attached.

9 Simple Electric Payback

If the simple payback on the project is less than 1 year, the rebate structure is affected.

Please check that the electric rate is accurate based on history.

DUKE REBATE PROPOSAL

August 15, 2012

August 30, 2012 (Rev1)

This proposal to Duke Energy consists of:

1. This document explains the difference in control strategy from constant speed to variable speed fan design and the calculations that support the energy savings calculations.
2. The Part 1 and Part 2 Application forms for the Mercantile Self Direct program.

The bottom line is that the net annual electrical energy savings are estimated at \$18,251.21. We believe that the actual savings will be greater, but the engineering cost to wring out every last dollar would not result in any savings for the Hospital.

The analysis presented herein describes two modes of operation: 1. constant speed fan, plus base loading the new tower; 2. Variable speed operation, sharing the same speed signal with the other tower fans. There has been a belief by certain staff members (but not all) at the Hospital that staging on fans, as needed, would result in the lowest power consumption due to a smaller quantity of fan motors in operation. Part of the purpose for this analysis is to resolve this argument by providing the rationale for this specific chiller plant.

1. Constant speed operation for the new tower – The new tower will operate alongside the other four towers, but one plan for operating the new tower was to stage it on first, then add a tower for each additional chiller. The variable speed towers designated #2 through #5, have variable speed fans and all currently receive the same signal.
2. Variable speed operation for all 5 towers – All five towers have variable speed fans and all receive the same signal, per the alternate operating plan. Fans are turned off when the fan reaches minimum allowable speed of 25% (manufacturer's requirement). This is how the controls are currently configured; however, the Hospital wants a definitive calculation that will demonstrate that this method of operation will result in saves energy and saved money.
3. One assumption is that this mode of operation does not become effective until one chiller of a 100 ton size, or larger, is energized. During free cooling operation, and until at least 100 tons of cooling load is present, the cooling hours are excluded for both modes of analysis.

There is an Excel spreadsheet that accompanies this proposal, entitled: "CT-1 Loads July2010 to June2011_Duke Rebate Calcs.xlsx". This spreadsheet tallies 730 data points (2 per day) that were collected from the Hospital's Building Automation System. The data file identifies which chillers were energized during a recent 12 month period. The reason we used this data, rather than rely on historical weather data, is due to the unique way in which many hospitals operate. In TCH's case, extra chillers are kept on line at very low capacity so that extra cooling will immediately be available should a chiller inadvertently shut down. Furthermore, and in keeping with operating sequences that date back decades, almost all of the equipment is constant speed. This results in "shallow" delta temperatures at part load, due to excess water flow and air flow.

FOSDICK & HILMER, Inc.

309 Vine St., Suite 50, Cincinnati, OH 45202, Tel: (513) 241-5640

<http://www.fheng.com>

We felt that this type of part-load operation cannot be simulated in any “off-the-shelf” software package. In addition, the big savings for TCH will be to add as many VFDs as possible to compensate for having so many pieces of equipment operating at very low loads (40-50%) for 1,000s of hours. This same philosophy applies to the pumps and chillers which are the focus of additional Duke Energy Incentive applications we intend to process.

There was also a point made by the evaluator that 2011 was an abnormally hot year and that the data should be normalized. We certainly recognize that June 2011 had 31 (14%) more cooling degree days than normal, but our data spans portions of two summers, both of which were warmer than usual due possibly to global warming.

Regardless, our calculations compare that the cost of operating at constant speed versus operating at variable speed, for actual circumstances. The calculations use the same data on the plus side, as on the minus side. So we feel that other factors such as normalizing data are small relative to the savings that could have been had during those 12 months.

In summary....

The cost of electricity to operate the tower per sequence #1 above, less the cost of electricity to operate the tower per sequence #2, is the net savings described above. This translates into a rebate request of \$9,125.00.00, based on 50% of first year electrical savings.

The total installed cost for the electrician (Mayers Electric) is \$52,260, plus 10% engineering fee, for a total of \$57,486.00.

MAYERS ELECTRIC COMPANY

INCORPORATED

ELECTRICAL CONTRACTORS * COMMERCIAL and INDUSTRIAL WIRING

4004 Erie Court, Cincinnati, OH 45227 Phone (513) 272-2900 FAX (513) 272-2904

August 29, 2012

Fosdick & Hilmer
309 Vine St. Suite 50
Cincinnati, OH 45202

Attn. Gerry Donahue

RE: The Christ Hospital Cooling Tower

Dear Gerry,

Per your request, we are pleased to submit a proposal for the electrical work associated with providing a Square D VFD for the new cooling tower at The Christ Hospital.

Total price for this work is **\$ 50,260.00**

Qualifications:

- Work to be completed during normal working hours.
- Work to be completed per Christ Hospital's Infectious Disease Policies.

Thank you for allowing us the opportunity to submit a proposal for this work.
If you have any questions, please advise.

Sincerely,
Mayers Electric Company, Inc.

Bill Puthoff
Project Manager



CHRIST 280900
EDD!

REVIEWED FOR SUBMITTAL

Messer
WeAreBuilding.

Submittal Number: 16000-01

Messer Job #: 12-2420-07

Date: 4.26.12

Reviewed By: SMM

Quotat

Q2C Number: 31421375

Quote Number: 2

Revision Number: 0

Project Name: CHRIST HOSPITAL-COOLING TOWER

Project Sub-Name:

Project Location: CINCINNATI, OH

Quote Name: COPY OF QUOTE1

Through Addenda Number: 0

Bid Date: 04/16/2012

Consultant / Specifier:

Contractor / Installer:

Sales Representative: PHIL POSTOLSKI

Terms & Conditions

This Quotation is subject to Schneider Electric USA, Inc.'s published Terms and Conditions

Payment Terms: STANDARD

Billing Type(s):

Currency: US DOLLARS

RECEIVED 04.26.12

NO EXCEPTIONS NOTED

EXCEPTIONS NOTED
REVISE AND SUBMIT FILE COPY

RETURN FOR CORRECTION
REVISE AND RESUBMIT

BY [Signature] DATE 4/30/12

REVIEW DOES NOT RELIEVE THE CONTRACTOR FROM RESPONSIBILITY FOR ERRORS OR DEVIATIONS FROM CONTRACT REQUIREMENTS

Quote Markings

FOSDICK & HILMER, INC.

309 VINE STREET, SUITE 50
CINCINNATI, OHIO 45202

Q2C Number: 31421375

Quote Number: 2

Revision Number: 0

Project Name: CHRIST HOSPITAL-COOLING TOWER

Quote Name: COPY OF QUOTE1

| Item No. | Qty. | Catalog Number / Details |
|----------|------|---|
| 003-00 | 1 | <p>Designation: mcccc1 Model 6 LVMCC Model 6 MCC - Standard Package</p> <p>-----</p> <p>System Voltage: 480V 3PH 3W 60Hz Max Available Fault Current (RMS) - 65kA Control Power - 120Vac 1/4" x 1" Horizontal Ground Bus, Tin Plated Copper Class 1 Type B Wiring 1200A Tin Plated Copper Horizontal Bus 20" Deep Construction General Purpose Type 1 Enclosure 65kA Bus Withstand Rating Master Nameplate Engraved with Black Surface/White Letters Standard Exterior Paint ANSI 49 Equipment Mounting Height 72" Manual Vertical Bus Shutters Rodent Barriers Engineered To Order (ETO) 2 - Section(s) with no Vertical Bus</p> <p>DIMENSIONS AND WEIGHT</p> <p>-----</p> <p>Dimensions: 50.00"W X 20"D X 94.5"H Approximate Weight: 1440.00 lbs / 653.18 kgs</p> <p>INCOMING</p> <p>-----</p> <p>Transition to Existing Model 6 Connection on Left of New MCC Existing Factory Order #: 12345678</p> <p>ADJUSTABLE SPEED DRIVES</p> <p>-----</p> <p>1 - Altivar 61 AC Drive 125 HP w/Circuit Breaker Rated for Variable Torque Applications 300VA Control Power Transformer #16 AWG MTW Control Wire 30mm Type K Pilot Devices Hand & Auto Push-to-Test LED Pilot Lights (Yellow) 2 Additional Pilot Device Contact Blocks ASD/Off/Bypass Selector Switch Extended I/O Option Card Barriered NEMA Bypass Contactors ASD On Push-to-Test LED Pilot Light (Red) Bypass On Push-to-Test LED Pilot Light (Yellow) Fault Push-to-Test LED Pilot Light (Yellow) Motor Off Push-to-Test LED Pilot Light (Green) Ethernet (ModbusTCP) Comm Card Auto Start Relay With 1.5-30 sec. Delay Hand-Off-Auto SW with Manual Speed Potentiometer Motor On Push-to-Test LED Pilot Light (Red) Line Reactor (3%) (1) FORWARD-OFF-REVERSE-SELECTOR S (TAG#: P48)</p> |

Q2C Number: 31421375

Quote Number: 2



Revision Number: 0

Project Name: CHRIST HOSPITAL-COOLING TOWER

Quote Name: COPY OF QUOTE1


| Item No. | Qty. | Catalog Number / Details |
|----------|------|--|
| | | MISCELLANEOUS DEVICES ----- 1 - NEMA Barrired Bypass for Adjustable Speed Drive |
| 004-00 | 1 | HU364DSEI SW UNFUSED HD 200A STAINLESS/INTERLOCK |

| REV | DESCRIPTION | BY | DATE | | | | | | |
|-----|-------------|----|------|---|---|---|---|---|---|
| - | - | - | - | - | - | - | - | - | - |




ANCHOR DETAIL


ENGLISH DIMENSIONS: INCHES

| | |
|---|---|
| JOB NAME: CHRIST HOSPITAL-COOLING TOWER | EQUIPMENT DESIGNATION: mccc01 |
| JOB LOCATION: CINCINNATI OH | EQUIPMENT TYPE: MODEL 6 MOTOR CONTROL CENTER |
| DRAWN BY: (Q2C) | DRAWING TYPE: ELEVATION |
| ENGR: |  |
| DATE: April 25 2012 | by Schneider Electric |
| DRAWING STATUS: QUOTE | DWG# F31421375-01 PG 1 OF 3 REV - |

| REV | DESCRIPTION | BY | DATE | | | | | | |
|-----|-------------|-----|------|-----|-----|-----|-----|-----|-----|
| --- | --- | --- | --- | --- | --- | --- | --- | --- | --- |



TOP VIEW



FLOOR VIEW

CROSSED AREA REPRESENTS CONDUIT ENTRY AREA. NUMBERS IN BOXES INDICATE VERTICAL CLEARANCE TO NEAREST OBSTRUCTION.

ENGLISH DIMENSIONS: INCHES

| | | | |
|-----------------|-------------------------------|------------------------|------------------------------|
| JOB NAME: | CHRIST HOSPITAL-COOLING TOWER | EQUIPMENT DESIGNATION: | mcgccp1 |
| JOB LOCATION: | CINCINNATI OH | EQUIPMENT TYPE: | MODEL 6 MOTOR CONTROL CENTER |
| DRAWN BY: | (Q2C) | DRAWING TYPE: | ELEVATION |
| ENGR: | | | |
| DATE: | April 25 2012 | | |
| DRAWING STATUS: | QUOTE | | |
| | | DWG# F31421375-01 | PG 2 OF 3 REV - |

| REV | DESCRIPTION | BY | DATE | | | | | | |
|-----|-------------|-----|------|-----|-----|-----|-----|-----|-----|
| --- | --- | --- | --- | --- | --- | --- | --- | --- | --- |

GENERAL NOTES

Class 1 Type B Wiring

PRODUCT DESCRIPTION AND RATINGS

POWER SYSTEM DATA:

480V 3PH 3W 60Hz
 SHORT CIRCUIT RATING: 65kA
 POWER CONNECTS TO EXISTING
 CONTROL POWER: 120Vac

BUS SYSTEM DATA:

MAIN HORIZONTAL BUS: 1200 Amp Copper/Tin Plated / 1.5"
 BUS BRACING: 65kA
 HORIZONTAL GROUND BUS: .25" X 1.0" (6.35mm X 25.4mm) Tin Plated Copper
 Units Securely Grounded To Structure

ENCLOSURE DATA:

ENCLOSURE TYPE: 20" DEEP Type 1
 EXTERIOR COLOR: Electrodeposition Finish ANSI 49 Medium Light Grey
 INTERIOR COLOR: Electrodeposition Finish ANSI 49 Medium Light Grey

STRUCTURE MODIFICATIONS:

Ground Bus Lug
 Rodent Barriers 1,2
 Manual Bus Shutters
 Master Nameplate 1
 Splice to M6 L

EQUIPMENT WEIGHT:


SHIPPING SPLIT # 1: 1440.00 Lbs. (653.18 Kg.)
 TOTAL LINEUP WEIGHT (APPROX): 1440.00 Lbs. (653.18 Kg.)

PRODUCT ACCESSORIES:

See Unit Features


| | | | |
|-----------------|-------------------------------|------------------------|------------------------------|
| JOB NAME: | CHRIST HOSPITAL-COOLING TOWER | EQUIPMENT DESIGNATION: | mcccc1 |
| JOB LOCATION: | CINCINNATI OH | EQUIPMENT TYPE: | MODEL 6 MOTOR CONTROL CENTER |
| DRAWN BY: | (Q2C) | DRAWING TYPE: | ELEVATION |
| ENGR: | | | |
| DATE: | April 25 2012 | | |
| DRAWING STATUS: | QUOTE | | |
| | | DWG# F31421375-01 | PG 3 OF 3 REV - |

| REV | DESCRIPTION | BY | DATE | | | | | | |
|-----|-------------|----|------|---|---|---|---|---|---|
| - | - | - | - | - | - | - | - | - | - |



| | | | |
|-----------------|---------------------------------|------------------------|------------------------------|
| JOB NAME: | CHRIST HOSPITAL - COOLING TOWER | EQUIPMENT DESIGNATION: | mcccp1 |
| JOB LOCATION: | CINCINNATI, OH | EQUIPMENT TYPE: | MODEL 6 MOTOR CONTROL CENTER |
| DRAWN BY: | (QZC) | DRAWING TYPE: | ONE LINE DIAGRAM |
| ENGR: | | | |
| DATE: | April 25 2012 | | |
| DRAWING STATUS: | QUOTE | DWG# 031421375-01 | PG. 1 OF 1 REV - |

| REV | DESCRIPTION | BY | DATE |
|-----|-------------|----|------|
| 1 | | | |



DRAWING IS NOT COMPLETE AND IS FOR QUOTATION PURPOSES ONLY.

| | | | |
|-----------------|-------------------------------|------------------------|------------------------------|
| JOB NAME: | CHRIST HOSPITAL-COOLING TOWER | EQUIPMENT DESIGNATION: | mcccc1 |
| JOB LOCATION: | CINCINNATI OH | EQUIPMENT TYPE: | MODEL 6 MOTOR CONTROL CENTER |
| DRAWN BY: | (G2C) | DRAWING TYPE: | ELEMENTARY |
| ENGR: | | | |
| DATE: | April 25 2012 | | |
| DRAWING STATUS: | QUOTE | DWG# | E31421375-01 |

| MENU No. | SUB-MENU | DESCRIPTION | CODE | ADJ. |
|----------|----------|----------------------|------|---------------------|
| LAC 2 | | ACCESS LEVEL | LAC | EPV 1 |
| SPC 1.4 | | POWER IDENTIFICATION | PID | SPD 1, 2 |
| SM 1.1 | | 2/3 WIRE CONTROL | CC | PC 2 |
| SM 1.1 | | MACRO CONFIGURATION | CFC | PC 2 |
| SM 1.1 | | STANDARD MGT. FREQ. | MF | BO 2 |
| I-O 1.5 | | 2 WIRE TRIP | TR | LF 1 |
| I-O 1.5 | | AG CONFIGURATION | AG | VAL 1 |
| I-O 1.5 | | R2 CONFIGURATION | R2 | ASSIGNMENT 1, 2 |
| Fun 1.7 | | OUTPUT CONTACTOR CMD | OUT | CONTACTOR ASS. 1, 2 |
| PLT 1.8 | | OUTPUT PHASE LOSS | UL | PHASE LOSS 1, 2 |
| COM 1.9 | | FORCED LOCAL | FLD | FLD 1, 2 |
| COM 1.9 | | FORCED LOCAL | FLD | FLD 1, 2 |

UNIT SPEED
 4-30 RPM
 OR
 0-10V

SHUTDOWN
 (REMOVE JUMPER
 IF USED)

SHUTDOWN
 (REMOVE JUMPER
 IF USED)

USER SUPPLIED
 2A SHUTDOWN
 2A FTB
 1
 REMOVE JUMPER
 IF USED

USER SUPPLIED
 2A SHUTDOWN
 2A FTB
 1
 REMOVE JUMPER
 IF USED

DRIVE CATALOG NUMBER ATV61HD75N4

DRIVE UNIT USER CONNECTIONS

| | | | | | | | | | | | | | | |
|---|---|---|---|---|---|----|----|---|---|---|---|---|---|---|
| 1 | 2 | 3 | 4 | 5 | 6 | 19 | 20 | A | B | C | D | E | F | H |
|---|---|---|---|---|---|----|----|---|---|---|---|---|---|---|



DRIVE UNIT USER CONNECTIONS

| | | | | | | | | | | | | | | |
|---|---|---|---|---|---|----|----|---|---|---|---|---|---|---|
| 1 | 2 | 3 | 4 | 5 | 6 | 19 | 20 | A | B | C | D | E | F | H |
|---|---|---|---|---|---|----|----|---|---|---|---|---|---|---|

DRIVE UNIT USER CONNECTIONS

| | | | | | | | | | | | | | | |
|---|---|---|---|---|---|----|----|---|---|---|---|---|---|---|
| 1 | 2 | 3 | 4 | 5 | 6 | 19 | 20 | A | B | C | D | E | F | H |
|---|---|---|---|---|---|----|----|---|---|---|---|---|---|---|

DRIVE UNIT USER CONNECTIONS



TERMINAL LUG DATA ‡

| AMPERES | MAX WIRE | MIN WIRE | TYPE |
|---------|-----------|----------|-------|
| 200 | 250 KCMIL | #6 AWG | CU/AL |

DUAL DIMENSIONS: INCHES
MILLIMETERS

| CATALOG NUMBER | VOLTAGE RATINGS | WIRING DIAG | HORSEPOWER RATINGS | | | | | | | | | | | | | |
|----------------|-----------------|-------------|--------------------|-----|-----|-----|--------|-----|-----|------|--------|-----|---------|---------|-----|-----|
| | | | 240VAC | | | | 480VAC | | | | 600VAC | | 250 VDC | 600 VDC | | |
| | | | STD | | MAX | | STD | | MAX | | STD | MAX | STD | STD | | |
| | | | 1Ø | 3Ø | 1Ø | 3Ø | 1Ø | 3Ø | 1Ø | 3Ø | 1Ø | 3Ø | 1Ø | 3Ø | | |
| H224DS | 240VAC;250VDC | A | 15 | 25& | - | 60& | - | - | - | - | - | - | - | 40~ | - | |
| H324DS | 240VAC;250VDC | B | 15~ | 25& | - | 60& | - | - | - | - | - | - | - | 40~ | - | |
| H364DS | 600VAC;600VDC | B | 15~ | 25& | - | 60& | 25~ | 50& | 50~ | 125& | 30~ | 60 | 50~ | 150 | 40~ | 50~ |
| H364NDS | 600VAC;600VDC | C | 15~ | 25# | - | 60# | 25~ | 50# | 50~ | 125# | 30~ | 60 | 50~ | 150 | 40~ | 50~ |
| HU3B4DS | 600VAC;600VDC | D | - | - | 15~ | 80& | - | - | 60~ | 125& | - | - | 50~ | 150 | 40~ | 50~ |

NOTES:
 FINISH - TYPE 304 STAINLESS STEEL
 UL LISTED - E2875
 NEUTRALS - INSULATED ROUNDABLE
 SUITABLE FOR USE AS SERVICE EQUIPMENT
 SHORT CIRCUIT CURRENT RATINGS:
 10,000 AMPERES WHEN USED WITH OR PROTECTED BY CLASS H OR K FUSES.
 200,000 AMPERES WHEN USED WITH OR PROTECTED BY CLASS R OR J FUSES.
 ON 600V SWITCHES, 100,000 AMPERES MAX ON CORNER GROUNDED DELTA WHEN PROTECTED BY
 BY CLASS J OR R FUSES, 200 AMPERE MAX.
 ‡ LUGS SUITABLE FOR 76°C CONDUCTORS.
 # IF CORNER GROUNDED DELTA, USE OUTER SWITCHING POLES FOR UNGROUNDED CONDUCTORS.
 & IF CORNER GROUNDED DELTA, INSTALL NEUTRAL AND USE OUTER SWITCHING POLES FOR UNGROUNDED CONDUCTORS.
 ~ USE ANY TWO SWITCHING POLES.
 < MAX RATING

HEAVY DUTY SAFETY SWITCHES
 VISIBLE BLADE TYPE
 200 AMPERE - SERIES F6
 ENCLOSURE - NEMA 4, 4X AND 5 STAINLESS STEEL

SQUARE D COMPANY

DWG# 3232
ND.

Calculations for Duke Custom Incentive

Basis: TCH data July 1, 2010 to June 30, 2011

| DateTime | Total Chiller Load, 2011 | Total Chiller Load, 2012 | Total Chiller Load, 2013 | Indicates when a chiller is running | VFD speed (% of total connected tons) | Variable Speed Fan %Capacity | Motor HP at GPM | Monthly hours at % GPM | % of Maximum GPM | % of Full Load BHP of Fan Motor | % Load Range for Part 2 of Custom Incentive | |
|--------------------------|--------------------------|--------------------------|--------------------------|-------------------------------------|---------------------------------------|------------------------------|-----------------|------------------------|------------------|---------------------------------|---|------|
| | Monthly hours at % Load | Monthly hours at % Load | | | | | | | | | | |
| Minimum Condenser | | | | | | | | | | | | |
| 01 Jul 2010 07:29:43:000 | 2116 | | 3,229 | 1 | 56.4% | 0 | 56.43% | | | | 1 | |
| 01 Jul 2010 19:29:43:000 | 2506 | 2,656 | 3,919 | 1 | 66.8% | 0 | 66.83% | | | | 1 | |
| 02 Jul 2010 07:29:43:000 | 2051 | | 3,139 | 1 | 54.7% | 0 | 54.69% | | | | 1 | |
| 02 Jul 2010 19:29:43:000 | 2588 | 2,738 | 4,032 | 1 | 69.0% | 0 | 69.01% | | | | 1 | |
| 03 Jul 2010 07:29:43:000 | 2139 | | 3,261 | 1 | 57.0% | 0 | 57.04% | | | | 1 | |
| 03 Jul 2010 19:29:43:000 | 2931 | | | 1 | 78.2% | 0 | 78.16% | | | | 1 | |
| 04 Jul 2010 07:29:43:000 | 2824 | | | 1 | 75.3% | 0 | 75.31% | | | | 1 | |
| 04 Jul 2010 19:29:43:000 | 2949 | | | 1 | 78.6% | 0 | 78.64% | | | | 1 | |
| 05 Jul 2010 07:29:43:000 | 2843 | | | 1 | 75.8% | 0 | 75.81% | | | | 1 | |
| 05 Jul 2010 19:29:43:000 | 3060 | | | 1 | 81.6% | 0 | 81.60% | | | | 1 | |
| 06 Jul 2010 07:29:43:000 | 3054 | | | 1 | 81.4% | 0 | 81.44% | | | | 1 | |
| 06 Jul 2010 19:29:43:000 | 3027 | | | 1 | 80.7% | 0 | 80.72% | | | | 1 | |
| 07 Jul 2010 07:29:43:000 | 2976 | | | 1 | 79.4% | 0 | 79.36% | | | | 1 | |
| 07 Jul 2010 19:29:43:000 | 2865 | | | 1 | 76.4% | 0 | 76.40% | | | | 1 | |
| 08 Jul 2010 07:29:43:000 | 2818 | | | 1 | 75.1% | 0 | 75.15% | | | | 1 | |
| 08 Jul 2010 19:29:43:000 | 2974 | | | 1 | 79.3% | 0 | 79.31% | | | | 1 | |
| 09 Jul 2010 07:29:43:000 | 3021 | | | 1 | 80.6% | 0 | 80.56% | | | | 1 | |
| 09 Jul 2010 19:29:43:000 | 2899 | | | 1 | 77.3% | 0 | 77.31% | | | | 1 | |
| 10 Jul 2010 07:29:43:000 | 2973 | | | 1 | 79.3% | 0 | 79.28% | | | | 1 | |
| 10 Jul 2010 19:29:43:000 | 2918 | | | 1 | 77.8% | 0 | 77.81% | | | | 1 | |
| 11 Jul 2010 07:29:43:000 | 2714 | | | 1 | 72.4% | 0 | 72.37% | | | | 1 | |
| 11 Jul 2010 19:29:43:000 | 2897 | | | 1 | 77.3% | 0 | 77.25% | | | | 1 | |
| 12 Jul 2010 07:29:43:000 | 2902 | | | 1 | 77.4% | 0 | 77.39% | | | | 1 | |
| 12 Jul 2010 19:29:43:000 | 2966 | | | 1 | 79.1% | 0 | 79.09% | | | | 1 | |
| 13 Jul 2010 07:29:43:000 | 3101 | | | 1 | 82.7% | 0 | 82.69% | | | | 1 | |
| 13 Jul 2010 19:29:43:000 | 2953 | | | 1 | 78.7% | 0 | 78.75% | | | | 1 | |
| 14 Jul 2010 07:29:43:000 | 2818 | | | 1 | 75.1% | 0 | 75.15% | | | | 1 | |
| 14 Jul 2010 19:29:43:000 | 2909 | | | 1 | 77.6% | 0 | 77.57% | | | | 1 | |
| 15 Jul 2010 07:29:43:000 | 2990 | | | 1 | 79.7% | 0 | 79.73% | | | | 1 | |
| 15 Jul 2010 19:29:43:000 | 2915 | | | 1 | 77.7% | 0 | 77.73% | | | | 1 | |
| 16 Jul 2010 07:29:43:000 | 2976 | | | 1 | 79.4% | 0 | 79.36% | | | | 1 | |
| 16 Jul 2010 19:29:43:000 | 2914 | | | 1 | 77.7% | 0 | 77.71% | | | | 1 | |
| 17 Jul 2010 07:29:43:000 | 2941 | | | 1 | 78.4% | 0 | 78.43% | | | | 1 | |
| 17 Jul 2010 19:29:43:000 | 2959 | | | 1 | 78.9% | 0 | 78.91% | | | | 1 | |
| 18 Jul 2010 07:29:43:000 | 2853 | | | 1 | 76.1% | 0 | 76.08% | | | | 1 | |
| 18 Jul 2010 19:29:43:000 | 3010 | | | 1 | 80.3% | 0 | 80.27% | | | | 1 | |
| 19 Jul 2010 07:29:43:000 | 2898 | | | 1 | 77.3% | 0 | 77.28% | | | | 1 | |
| 19 Jul 2010 19:29:43:000 | 3004 | | | 1 | 80.1% | 0 | 80.11% | | | | 1 | |
| 20 Jul 2010 07:29:43:000 | 2880 | | | 1 | 76.8% | 0 | 76.80% | | | | 1 | |
| 20 Jul 2010 19:29:43:000 | 3044 | | | 1 | 81.2% | 0 | 81.17% | | | | 1 | |
| 21 Jul 2010 07:29:43:000 | 2932 | | | 1 | 78.2% | 0 | 78.19% | | | | 1 | |
| 21 Jul 2010 19:29:43:000 | 2929 | | | 1 | 78.1% | 0 | 78.11% | | | | 1 | |
| 22 Jul 2010 07:29:43:000 | 3079 | | | 1 | 82.1% | 0 | 82.11% | | | | 1 | |
| 22 Jul 2010 19:29:43:000 | 2977 | | | 1 | 79.4% | 0 | 79.39% | | | | 1 | |
| 23 Jul 2010 07:29:43:000 | 2832 | | | 1 | 75.5% | 0 | 75.52% | | | | 1 | |
| 23 Jul 2010 19:29:43:000 | 2867 | | | 1 | 76.5% | 0 | 76.45% | | | | 1 | |
| 24 Jul 2010 07:29:43:000 | 2998 | | | 1 | 79.9% | 0 | 79.95% | | | | 1 | |
| 24 Jul 2010 19:29:43:000 | 2932 | | | 1 | 78.2% | 0 | 78.19% | | | | 1 | |
| 25 Jul 2010 07:29:43:000 | 2905 | | | 1 | 77.5% | 0 | 77.47% | | | | 1 | |
| 25 Jul 2010 19:29:43:000 | 2947 | | | 1 | 78.6% | 0 | 78.59% | | | | 1 | |
| 26 Jul 2010 07:29:43:000 | 2829 | | | 1 | 75.4% | 0 | 75.44% | | | | 1 | |
| 26 Jul 2010 19:29:43:000 | 2987 | | | 1 | 79.7% | 0 | 79.65% | 0 | 100% | 1 | 744 | 100% |
| 27 Jul 2010 07:29:43:000 | 2803 | | | 1 | 74.7% | 0 | 74.75% | 0 | 90% | 1 | 0 | 90% |
| 27 Jul 2010 19:29:43:000 | 2946 | | | 1 | 78.6% | 0 | 78.56% | 612 | 80% | 1 | 0 | 80% |
| 28 Jul 2010 07:29:43:000 | 3003 | | | 1 | 80.1% | 0 | 80.08% | 96 | 70% | 1 | 0 | 70% |
| 28 Jul 2010 19:29:43:000 | 2850 | | | 1 | 76.0% | 0 | 76.00% | 24 | 60% | 1 | 0 | 60% |
| 29 Jul 2010 07:29:43:000 | 2772 | | | 1 | 73.9% | 0 | 73.92% | 12 | 50% | 1 | 0 | 50% |
| 29 Jul 2010 19:29:43:000 | 3029 | | | 1 | 80.8% | 0 | 80.77% | 0 | 40% | 1 | 0 | 40% |
| 30 Jul 2010 07:29:43:000 | 2466 | | | 1 | 65.8% | 0 | 65.76% | 0 | 30% | 1 | 0 | 30% |
| 30 Jul 2010 19:29:43:000 | 2746 | | | 1 | 73.2% | 0 | 73.23% | | 20% | 1 | 0 | 20% |
| 31 Jul 2010 07:29:43:000 | 2653 | | | 1 | 70.7% | 0 | 70.75% | | 10% | 1 | 0 | 10% |
| 31 Jul 2010 19:29:43:000 | 2849 | | | 1 | 76.0% | 0 | 75.97% | 744 | | 1 | 744 | |

Calculations for Duke Custom Incentive

Basis: TCH data July 1, 2010 to June 30, 2011

| | | | | | | | | | |
|--------------------------|------|---|-------|---|--------|-----|------|-----|------|
| 01 Aug 2010 07:29:43:000 | 2608 | 1 | 69.5% | 0 | 69.55% | | | | 1 |
| 01 Aug 2010 19:29:43:000 | 2814 | 1 | 75.0% | 0 | 75.04% | | | | 1 |
| 02 Aug 2010 07:29:43:000 | 2758 | 1 | 73.5% | 0 | 73.55% | | | | 1 |
| 02 Aug 2010 19:29:43:000 | 2826 | 1 | 75.4% | 0 | 75.36% | | | | 1 |
| 03 Aug 2010 07:29:43:000 | 2916 | 1 | 77.8% | 0 | 77.76% | | | | 1 |
| 03 Aug 2010 19:29:43:000 | 2824 | 1 | 75.3% | 0 | 75.31% | | | | 1 |
| 04 Aug 2010 07:29:43:000 | 2966 | 1 | 79.1% | 0 | 79.09% | | | | 1 |
| 04 Aug 2010 19:29:43:000 | 2992 | 1 | 79.8% | 0 | 79.79% | | | | 1 |
| 05 Aug 2010 07:29:43:000 | 2937 | 1 | 78.3% | 0 | 78.32% | | | | 1 |
| 05 Aug 2010 19:29:43:000 | 2930 | 1 | 78.1% | 0 | 78.13% | | | | 1 |
| 06 Aug 2010 07:29:43:000 | 2865 | 1 | 76.4% | 0 | 76.40% | | | | 1 |
| 06 Aug 2010 19:29:43:000 | 2851 | 1 | 76.0% | 0 | 76.03% | | | | 1 |
| 07 Aug 2010 07:29:43:000 | 2736 | 1 | 73.0% | 0 | 72.96% | | | | 1 |
| 07 Aug 2010 19:29:43:000 | 2828 | 1 | 75.4% | 0 | 75.41% | | | | 1 |
| 08 Aug 2010 07:29:43:000 | 2720 | 1 | 72.5% | 0 | 72.53% | | | | 1 |
| 08 Aug 2010 19:29:43:000 | 2855 | 1 | 76.1% | 0 | 76.13% | | | | 1 |
| 09 Aug 2010 07:29:43:000 | 2791 | 1 | 74.4% | 0 | 74.43% | | | | 1 |
| 09 Aug 2010 19:29:43:000 | 2977 | 1 | 79.4% | 0 | 79.39% | | | | 1 |
| 10 Aug 2010 07:29:43:000 | 2891 | 1 | 77.1% | 0 | 77.09% | | | | 1 |
| 10 Aug 2010 19:29:43:000 | 2816 | 1 | 75.1% | 0 | 75.09% | | | | 1 |
| 11 Aug 2010 07:29:43:000 | 2988 | 1 | 79.7% | 0 | 79.68% | | | | 1 |
| 11 Aug 2010 19:29:43:000 | 2995 | 1 | 79.9% | 0 | 79.87% | | | | 1 |
| 12 Aug 2010 07:29:43:000 | 2857 | 1 | 76.2% | 0 | 76.19% | | | | 1 |
| 12 Aug 2010 19:29:43:000 | 2878 | 1 | 76.7% | 0 | 76.75% | | | | 1 |
| 13 Aug 2010 07:29:43:000 | 3027 | 1 | 80.7% | 0 | 80.72% | | | | 1 |
| 13 Aug 2010 19:29:43:000 | 2963 | 1 | 79.0% | 0 | 79.01% | | | | 1 |
| 14 Aug 2010 07:29:43:000 | 2990 | 1 | 79.7% | 0 | 79.73% | | | | 1 |
| 14 Aug 2010 19:29:43:000 | 3031 | 1 | 80.8% | 0 | 80.83% | | | | 1 |
| 15 Aug 2010 07:29:43:000 | 2902 | 1 | 77.4% | 0 | 77.39% | | | | 1 |
| 15 Aug 2010 19:29:43:000 | 2982 | 1 | 79.5% | 0 | 79.52% | | | | 1 |
| 16 Aug 2010 07:29:43:000 | 2674 | 1 | 71.3% | 0 | 71.31% | | | | 1 |
| 16 Aug 2010 19:29:43:000 | 2876 | 1 | 76.7% | 0 | 76.69% | | | | 1 |
| 17 Aug 2010 07:29:43:000 | 2700 | 1 | 72.0% | 0 | 72.00% | | | | 1 |
| 17 Aug 2010 19:29:43:000 | 3007 | 1 | 80.2% | 0 | 80.19% | | | | 1 |
| 18 Aug 2010 07:29:43:000 | 2724 | 1 | 72.6% | 0 | 72.64% | | | | 1 |
| 18 Aug 2010 19:29:43:000 | 2920 | 1 | 77.9% | 0 | 77.87% | | | | 1 |
| 19 Aug 2010 07:29:43:000 | 2929 | 1 | 78.1% | 0 | 78.11% | | | | 1 |
| 19 Aug 2010 19:29:43:000 | 2905 | 1 | 77.5% | 0 | 77.47% | | | | 1 |
| 20 Aug 2010 07:29:43:000 | 2781 | 1 | 74.2% | 0 | 74.16% | | | | 1 |
| 20 Aug 2010 19:29:43:000 | 2920 | 1 | 77.9% | 0 | 77.87% | | | | 1 |
| 21 Aug 2010 07:29:43:000 | 2849 | 1 | 76.0% | 0 | 75.97% | | | | 1 |
| 21 Aug 2010 19:29:43:000 | 2982 | 1 | 79.5% | 0 | 79.52% | | | | 1 |
| 22 Aug 2010 07:29:43:000 | 2800 | 1 | 74.7% | 0 | 74.67% | | | | 1 |
| 22 Aug 2010 19:29:43:000 | 2991 | 1 | 79.8% | 0 | 79.76% | | | | 1 |
| 23 Aug 2010 07:29:43:000 | 2664 | 1 | 71.0% | 0 | 71.04% | | | | 1 |
| 23 Aug 2010 19:29:43:000 | 2848 | 1 | 75.9% | 0 | 75.95% | | | | 1 |
| 24 Aug 2010 07:29:43:000 | 2714 | 1 | 72.4% | 0 | 72.37% | | | | 1 |
| 24 Aug 2010 19:29:43:000 | 2828 | 1 | 75.4% | 0 | 75.41% | | | | 1 |
| 25 Aug 2010 07:29:43:000 | 2751 | 1 | 73.4% | 0 | 73.36% | | | | 1 |
| 25 Aug 2010 19:29:43:000 | 2890 | 1 | 77.1% | 0 | 77.07% | | | | 1 |
| 26 Aug 2010 07:29:43:000 | 2344 | 1 | 62.5% | 0 | 62.51% | | | | 1 |
| 26 Aug 2010 19:29:43:000 | 2721 | 1 | 72.6% | 0 | 72.56% | 0 | 100% | 744 | 100% |
| 27 Aug 2010 07:29:43:000 | 2141 | 1 | 57.1% | 0 | 57.09% | 0 | 90% | 0 | 90% |
| 27 Aug 2010 19:29:43:000 | 2567 | 1 | 68.5% | 0 | 68.45% | 504 | 80% | 0 | 80% |
| 28 Aug 2010 07:29:43:000 | 2337 | 1 | 62.3% | 0 | 62.32% | 204 | 70% | 0 | 70% |
| 28 Aug 2010 19:29:43:000 | 2859 | 1 | 76.2% | 0 | 76.24% | 36 | 60% | 0 | 60% |
| 29 Aug 2010 07:29:43:000 | 2795 | 1 | 74.5% | 0 | 74.53% | 0 | 50% | 0 | 50% |
| 29 Aug 2010 19:29:43:000 | 2800 | 1 | 74.7% | 0 | 74.67% | 0 | 40% | 0 | 40% |
| 30 Aug 2010 07:29:43:000 | 2893 | 1 | 77.1% | 0 | 77.15% | 0 | 30% | 0 | 30% |
| 30 Aug 2010 19:29:43:000 | 2898 | 1 | 77.3% | 0 | 77.28% | | 20% | 0 | 20% |
| 31 Aug 2010 07:29:43:000 | 2939 | 1 | 78.4% | 0 | 78.37% | | 10% | 0 | 10% |
| 31 Aug 2010 19:29:43:000 | 3030 | 1 | 80.8% | 0 | 80.80% | 744 | | 744 | |
| 01 Sep 2010 07:29:43:000 | 2945 | 1 | 78.5% | 0 | 78.53% | | | | 1 |
| 01 Sep 2010 19:29:43:000 | 1888 | 1 | 50.3% | 0 | 50.35% | | | | 1 |
| 02 Sep 2010 07:29:43:000 | 2840 | 1 | 75.7% | 0 | 75.73% | | | | 1 |
| 02 Sep 2010 19:29:43:000 | 3028 | 1 | 80.7% | 0 | 80.75% | | | | 1 |
| 03 Sep 2010 07:29:43:000 | 2942 | 1 | 78.5% | 0 | 78.45% | | | | 1 |
| 03 Sep 2010 19:29:43:000 | 2600 | 1 | 69.3% | 0 | 69.33% | | | | 1 |

Calculations for Duke Custom Incentive

Basis: TCH data July 1, 2010 to June 30, 2011

| | | | | | | | | | |
|--------------------------|------|---|-------|---|--------|-----|------|-----|------|
| 04 Sep 2010 07:29:43:000 | 2027 | 1 | 54.1% | 0 | 54.05% | | | | 1 |
| 04 Sep 2010 19:29:43:000 | 2396 | 1 | 63.9% | 0 | 63.89% | | | | 1 |
| 05 Sep 2010 07:29:43:000 | 1820 | 1 | 48.5% | 0 | 48.53% | | | | 1 |
| 05 Sep 2010 19:29:43:000 | 2409 | 1 | 64.2% | 0 | 64.24% | | | | 1 |
| 06 Sep 2010 07:29:43:000 | 2102 | 1 | 56.1% | 0 | 56.05% | | | | 1 |
| 06 Sep 2010 19:29:43:000 | 2734 | 1 | 72.9% | 0 | 72.91% | | | | 1 |
| 07 Sep 2010 07:29:43:000 | 2446 | 1 | 65.2% | 0 | 65.23% | | | | 1 |
| 07 Sep 2010 19:29:43:000 | 3030 | 1 | 80.8% | 0 | 80.80% | | | | 1 |
| 08 Sep 2010 07:29:43:000 | 2371 | 1 | 63.2% | 0 | 63.23% | | | | 1 |
| 08 Sep 2010 19:29:43:000 | 2600 | 1 | 69.3% | 0 | 69.33% | | | | 1 |
| 09 Sep 2010 07:29:43:000 | 2010 | 1 | 53.6% | 0 | 53.60% | | | | 1 |
| 09 Sep 2010 19:29:43:000 | 2565 | 1 | 68.4% | 0 | 68.40% | | | | 1 |
| 10 Sep 2010 07:29:43:000 | 2097 | 1 | 55.9% | 0 | 55.92% | | | | 1 |
| 10 Sep 2010 19:29:43:000 | 2620 | 1 | 69.9% | 0 | 69.87% | | | | 1 |
| 11 Sep 2010 07:29:43:000 | 2353 | 1 | 62.7% | 0 | 62.75% | | | | 1 |
| 11 Sep 2010 19:29:43:000 | 2880 | 1 | 76.8% | 0 | 76.80% | | | | 1 |
| 12 Sep 2010 07:29:43:000 | 2580 | 1 | 68.8% | 0 | 68.80% | | | | 1 |
| 12 Sep 2010 19:29:43:000 | 2577 | 1 | 68.7% | 0 | 68.72% | | | | 1 |
| 13 Sep 2010 07:29:43:000 | 2375 | 1 | 63.3% | 0 | 63.33% | | | | 1 |
| 13 Sep 2010 19:29:43:000 | 2818 | 1 | 75.1% | 0 | 75.15% | | | | 1 |
| 14 Sep 2010 07:29:43:000 | 2405 | 1 | 64.1% | 0 | 64.13% | | | | 1 |
| 14 Sep 2010 19:29:43:000 | 2600 | 1 | 69.3% | 0 | 69.33% | | | | 1 |
| 15 Sep 2010 07:29:43:000 | 2253 | 1 | 60.1% | 0 | 60.08% | | | | 1 |
| 15 Sep 2010 19:29:43:000 | 2979 | 1 | 79.4% | 0 | 79.44% | | | | 1 |
| 16 Sep 2010 07:29:43:000 | 3023 | 1 | 80.6% | 0 | 80.61% | | | | 1 |
| 16 Sep 2010 19:29:43:000 | 2896 | 1 | 77.2% | 0 | 77.23% | | | | 1 |
| 17 Sep 2010 07:29:43:000 | 2428 | 1 | 64.7% | 0 | 64.75% | | | | 1 |
| 17 Sep 2010 19:29:43:000 | 2576 | 1 | 68.7% | 0 | 68.69% | | | | 1 |
| 18 Sep 2010 07:29:43:000 | 2304 | 1 | 61.4% | 0 | 61.44% | | | | 1 |
| 18 Sep 2010 19:29:43:000 | 2846 | 1 | 75.9% | 0 | 75.89% | | | | 1 |
| 19 Sep 2010 07:29:43:000 | 2596 | 1 | 69.2% | 0 | 69.23% | | | | 1 |
| 19 Sep 2010 19:29:43:000 | 2863 | 1 | 76.3% | 0 | 76.35% | | | | 1 |
| 20 Sep 2010 07:29:43:000 | 2705 | 1 | 72.1% | 0 | 72.13% | | | | 1 |
| 20 Sep 2010 19:29:43:000 | 2971 | 1 | 79.2% | 0 | 79.23% | | | | 1 |
| 21 Sep 2010 07:29:43:000 | 2658 | 1 | 70.9% | 0 | 70.88% | | | | 1 |
| 21 Sep 2010 19:29:43:000 | 3077 | 1 | 82.1% | 0 | 82.05% | | | | 1 |
| 22 Sep 2010 07:29:43:000 | 3049 | 1 | 81.3% | 0 | 81.31% | | | | 1 |
| 22 Sep 2010 19:29:43:000 | 2847 | 1 | 75.9% | 0 | 75.92% | | | | 1 |
| 23 Sep 2010 07:29:43:000 | 2952 | 1 | 78.7% | 0 | 78.72% | | | | 1 |
| 23 Sep 2010 19:29:43:000 | 2985 | 1 | 79.6% | 0 | 79.60% | | | | 1 |
| 24 Sep 2010 07:29:43:000 | 2339 | 1 | 62.4% | 0 | 62.37% | | | | 1 |
| 24 Sep 2010 19:29:43:000 | 2985 | 1 | 79.6% | 0 | 79.60% | | | | 1 |
| 25 Sep 2010 07:29:43:000 | 2340 | 1 | 62.4% | 0 | 62.40% | | | | 1 |
| 25 Sep 2010 19:29:43:000 | 2472 | 1 | 65.9% | 0 | 65.92% | 0 | 100% | 720 | 100% |
| 26 Sep 2010 07:29:43:000 | 1865 | 1 | 49.7% | 0 | 49.73% | 0 | 90% | 0 | 90% |
| 26 Sep 2010 19:29:43:000 | 2385 | 1 | 63.6% | 0 | 63.60% | 228 | 80% | 0 | 80% |
| 27 Sep 2010 07:29:43:000 | 1789 | 1 | 47.7% | 0 | 47.71% | 168 | 70% | 0 | 70% |
| 27 Sep 2010 19:29:43:000 | 1826 | 1 | 48.7% | 0 | 48.69% | 192 | 60% | 0 | 60% |
| 28 Sep 2010 07:29:43:000 | 1875 | 1 | 50.0% | 0 | 50.00% | 120 | 50% | 0 | 50% |
| 28 Sep 2010 19:29:43:000 | 1909 | 1 | 50.9% | 0 | 50.91% | 12 | 40% | 0 | 40% |
| 29 Sep 2010 07:29:43:000 | 1342 | 1 | 35.8% | 0 | 35.79% | 0 | 30% | 0 | 30% |
| 29 Sep 2010 19:29:43:000 | 2147 | 1 | 57.3% | 0 | 57.25% | | 20% | 0 | 20% |
| 30 Sep 2010 07:29:43:000 | 1781 | 1 | 47.5% | 0 | 47.49% | | 10% | 0 | 10% |
| 30 Sep 2010 19:29:43:000 | 2144 | 1 | 57.2% | 0 | 57.17% | 720 | | 720 | |
| 01 Oct 2010 07:29:43:000 | 1708 | 1 | 45.5% | 0 | 45.55% | | | | 1 |
| 01 Oct 2010 19:29:43:000 | 2006 | 1 | 53.5% | 0 | 53.49% | | | | 1 |
| 02 Oct 2010 07:29:43:000 | 1742 | 1 | 46.5% | 0 | 46.45% | | | | 1 |
| 02 Oct 2010 19:29:43:000 | 1635 | 1 | 43.6% | 0 | 43.60% | | | | 1 |
| 03 Oct 2010 07:29:43:000 | 1410 | 1 | 37.6% | 0 | 37.60% | | | | 1 |
| 03 Oct 2010 19:29:43:000 | 1625 | 1 | 43.3% | 0 | 43.33% | | | | 1 |
| 04 Oct 2010 07:29:43:000 | 1423 | 1 | 37.9% | 0 | 37.95% | | | | 1 |
| 04 Oct 2010 19:29:43:000 | 1723 | 1 | 45.9% | 0 | 45.95% | | | | 1 |
| 05 Oct 2010 07:29:43:000 | 1440 | 1 | 38.4% | 0 | 38.40% | | | | 1 |
| 05 Oct 2010 19:29:43:000 | 1992 | 1 | 53.1% | 0 | 53.12% | | | | 1 |
| 06 Oct 2010 07:29:43:000 | 1403 | 1 | 37.4% | 0 | 37.41% | | | | 1 |
| 06 Oct 2010 19:29:43:000 | 1929 | 1 | 51.4% | 0 | 51.44% | | | | 1 |
| 07 Oct 2010 07:29:43:000 | 1785 | 1 | 47.6% | 0 | 47.60% | | | | 1 |
| 07 Oct 2010 19:29:43:000 | 2280 | 1 | 60.8% | 0 | 60.80% | | | | 1 |

Calculations for Duke Custom Incentive

Basis: TCH data July 1, 2010 to June 30, 2011

| | | | | | | | | | | |
|--------------------------|------|---|-------|---|--------|-----|------|---|-----|------|
| 08 Oct 2010 07:29:43:000 | 1720 | 1 | 45.9% | 0 | 45.87% | | | | 1 | |
| 08 Oct 2010 19:29:43:000 | 2419 | 1 | 64.5% | 0 | 64.51% | | | | 1 | |
| 09 Oct 2010 07:29:43:000 | 1864 | 1 | 49.7% | 0 | 49.71% | | | | 1 | |
| 09 Oct 2010 19:29:43:000 | 2477 | 1 | 66.1% | 0 | 66.05% | | | | 1 | |
| 10 Oct 2010 07:29:43:000 | 2065 | 1 | 55.1% | 0 | 55.07% | | | | 1 | |
| 10 Oct 2010 19:29:43:000 | 2710 | 1 | 72.3% | 0 | 72.27% | | | | 1 | |
| 11 Oct 2010 07:29:43:000 | 2138 | 1 | 57.0% | 0 | 57.01% | | | | 1 | |
| 11 Oct 2010 19:29:43:000 | 2632 | 1 | 70.2% | 0 | 70.19% | | | | 1 | |
| 12 Oct 2010 07:29:43:000 | 2238 | 1 | 59.7% | 0 | 59.68% | | | | 1 | |
| 12 Oct 2010 19:29:43:000 | 2504 | 1 | 66.8% | 0 | 66.77% | | | | 1 | |
| 13 Oct 2010 07:29:43:000 | 1903 | 1 | 50.7% | 0 | 50.75% | | | | 1 | |
| 13 Oct 2010 19:29:43:000 | 2356 | 1 | 62.8% | 0 | 62.83% | | | | 1 | |
| 14 Oct 2010 07:29:43:000 | 1500 | 1 | 40.0% | 0 | 40.00% | | | | 1 | |
| 14 Oct 2010 19:29:43:000 | 1807 | 1 | 48.2% | 0 | 48.19% | | | | 1 | |
| 15 Oct 2010 07:29:43:000 | 1634 | 1 | 43.6% | 0 | 43.57% | | | | 1 | |
| 15 Oct 2010 19:29:43:000 | 1862 | 1 | 49.7% | 0 | 49.65% | | | | 1 | |
| 16 Oct 2010 07:29:43:000 | 1329 | 1 | 35.4% | 0 | 35.44% | | | | 1 | |
| 16 Oct 2010 19:29:43:000 | 1767 | 1 | 47.1% | 0 | 47.12% | | | | 1 | |
| 17 Oct 2010 07:29:43:000 | 1756 | 1 | 46.8% | 0 | 46.83% | | | | 1 | |
| 17 Oct 2010 19:29:43:000 | 1726 | 1 | 46.0% | 0 | 46.03% | | | | 1 | |
| 18 Oct 2010 07:29:43:000 | 1568 | 1 | 41.8% | 0 | 41.81% | | | | 1 | |
| 18 Oct 2010 19:29:43:000 | 1700 | 1 | 45.3% | 0 | 45.33% | | | | 1 | |
| 19 Oct 2010 07:29:43:000 | 1488 | 1 | 39.7% | 0 | 39.68% | | | | 1 | |
| 19 Oct 2010 19:29:43:000 | 1723 | 1 | 45.9% | 0 | 45.95% | | | | 1 | |
| 20 Oct 2010 07:29:43:000 | 1468 | 1 | 39.1% | 0 | 39.15% | | | | 1 | |
| 20 Oct 2010 19:29:43:000 | 1845 | 1 | 49.2% | 0 | 49.20% | | | | 1 | |
| 21 Oct 2010 07:29:43:000 | 1634 | 1 | 43.6% | 0 | 43.57% | | | | 1 | |
| 21 Oct 2010 19:29:43:000 | 1638 | 1 | 43.7% | 0 | 43.68% | | | | 1 | |
| 22 Oct 2010 07:29:43:000 | 1258 | 1 | 33.5% | 0 | 33.55% | | | | 1 | |
| 22 Oct 2010 19:29:43:000 | 1748 | 1 | 46.6% | 0 | 46.61% | | | | 1 | |
| 23 Oct 2010 07:29:43:000 | 1539 | 1 | 41.0% | 0 | 41.04% | | | | 1 | |
| 23 Oct 2010 19:29:43:000 | 1739 | 1 | 46.4% | 0 | 46.37% | | | | 1 | |
| 24 Oct 2010 07:29:43:000 | 1727 | 1 | 46.1% | 0 | 46.05% | | | | 1 | |
| 24 Oct 2010 19:29:43:000 | 2712 | 1 | 72.3% | 0 | 72.32% | | | | 1 | |
| 25 Oct 2010 07:29:43:000 | 2427 | 1 | 64.7% | 0 | 64.72% | | | | 1 | |
| 25 Oct 2010 19:29:43:000 | 2528 | 1 | 67.4% | 0 | 67.41% | | | | 1 | |
| 26 Oct 2010 07:29:43:000 | 2725 | 1 | 72.7% | 0 | 72.67% | | | | 1 | |
| 26 Oct 2010 19:29:43:000 | 1663 | 1 | 44.3% | 0 | 44.35% | 0 | 100% | 1 | 744 | 100% |
| 27 Oct 2010 07:29:43:000 | 1510 | 1 | 40.3% | 0 | 40.27% | 0 | 90% | 1 | 0 | 90% |
| 27 Oct 2010 19:29:43:000 | 2244 | 1 | 59.8% | 0 | 59.84% | 0 | 80% | 1 | 0 | 80% |
| 28 Oct 2010 07:29:43:000 | 1616 | 1 | 43.1% | 0 | 43.09% | 84 | 70% | 1 | 0 | 70% |
| 28 Oct 2010 19:29:43:000 | 1158 | 1 | 30.9% | 0 | 30.88% | 96 | 60% | 1 | 0 | 60% |
| 29 Oct 2010 07:29:43:000 | 1155 | 1 | 30.8% | 0 | 30.80% | 252 | 50% | 1 | 0 | 50% |
| 29 Oct 2010 19:29:43:000 | 1102 | 1 | 29.4% | 0 | 29.39% | 216 | 40% | 1 | 0 | 40% |
| 30 Oct 2010 07:29:43:000 | 1144 | 1 | 30.5% | 0 | 30.51% | 96 | 30% | 1 | 0 | 30% |
| 30 Oct 2010 19:29:43:000 | 1173 | 1 | 31.3% | 0 | 31.28% | | 20% | 1 | 0 | 20% |
| 31 Oct 2010 07:29:43:000 | 1124 | 1 | 30.0% | 0 | 29.97% | | 10% | 1 | 0 | 10% |
| 31 Oct 2010 19:29:43:000 | 1161 | 1 | 31.0% | 0 | 30.96% | 744 | | 1 | 744 | |
| 01 Nov 2010 07:29:43:000 | 1155 | 1 | 30.8% | 0 | 30.80% | | | 1 | | |
| 01 Nov 2010 19:29:43:000 | 1167 | 1 | 31.1% | 0 | 31.12% | | | 1 | | |
| 02 Nov 2010 07:29:43:000 | 1186 | 1 | 31.6% | 0 | 31.63% | | | 1 | | |
| 02 Nov 2010 19:29:43:000 | 1113 | 1 | 29.7% | 0 | 29.68% | | | 1 | | |
| 03 Nov 2010 07:29:43:000 | 1120 | 1 | 29.9% | 0 | 29.87% | | | 1 | | |
| 03 Nov 2010 19:29:43:000 | 1179 | 1 | 31.4% | 0 | 31.44% | | | 1 | | |
| 04 Nov 2010 07:29:43:000 | 1170 | 1 | 31.2% | 0 | 31.20% | | | 1 | | |
| 04 Nov 2010 19:29:43:000 | 1134 | 1 | 30.2% | 0 | 30.24% | | | 1 | | |
| 05 Nov 2010 07:29:43:000 | 1168 | 1 | 31.1% | 0 | 31.15% | | | 1 | | |
| 05 Nov 2010 19:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 06 Nov 2010 07:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 06 Nov 2010 19:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 07 Nov 2010 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 07 Nov 2010 18:29:43:000 | 1112 | 1 | 29.7% | 0 | 29.65% | | | 1 | | |
| 08 Nov 2010 06:29:43:000 | 1108 | 1 | 29.5% | 0 | 29.55% | | | 1 | | |
| 08 Nov 2010 18:29:43:000 | 1526 | 1 | 40.7% | 0 | 40.69% | | | 1 | | |
| 09 Nov 2010 06:29:43:000 | 1550 | 1 | 41.3% | 0 | 41.33% | | | 1 | | |
| 09 Nov 2010 18:29:43:000 | 1596 | 1 | 42.6% | 0 | 42.56% | | | 1 | | |
| 10 Nov 2010 06:29:43:000 | 1154 | 1 | 30.8% | 0 | 30.77% | | | 1 | | |
| 10 Nov 2010 18:29:43:000 | 2134 | 1 | 56.9% | 0 | 56.91% | | | 1 | | |

Calculations for Duke Custom Incentive

Basis: TCH data July 1, 2010 to June 30, 2011

| | | | | | | | | | | | |
|--------------------------|------|---|-------|---|--------|-----|------|---|-----|------|--|
| 15 Dec 2010 06:29:43:000 | 1074 | 1 | 28.6% | 0 | 28.64% | | | | 1 | | |
| 15 Dec 2010 18:29:43:000 | 1192 | 1 | 31.8% | 0 | 31.79% | | | | 1 | | |
| 16 Dec 2010 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 16 Dec 2010 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 17 Dec 2010 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 17 Dec 2010 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 18 Dec 2010 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 18 Dec 2010 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 19 Dec 2010 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 19 Dec 2010 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 20 Dec 2010 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 20 Dec 2010 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 21 Dec 2010 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 21 Dec 2010 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 22 Dec 2010 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 22 Dec 2010 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 23 Dec 2010 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 23 Dec 2010 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 24 Dec 2010 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 24 Dec 2010 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 25 Dec 2010 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 25 Dec 2010 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | | |
| 26 Dec 2010 06:29:43:000 | 1147 | 1 | 30.6% | 0 | 30.59% | | | | 1 | | |
| 26 Dec 2010 18:29:43:000 | 1175 | 1 | 31.3% | 0 | 31.33% | 0 | 100% | 1 | 276 | 100% | |
| 27 Dec 2010 06:29:43:000 | 1103 | 1 | 29.4% | 0 | 29.41% | 0 | 90% | 1 | 0 | 90% | |
| 27 Dec 2010 18:29:43:000 | 1126 | 1 | 30.0% | 0 | 30.03% | 0 | 80% | 1 | 0 | 80% | |
| 28 Dec 2010 06:29:43:000 | 1134 | 1 | 30.2% | 0 | 30.24% | 0 | 70% | 1 | 0 | 70% | |
| 28 Dec 2010 18:29:43:000 | 1137 | 1 | 30.3% | 0 | 30.32% | 0 | 60% | 1 | 0 | 60% | |
| 29 Dec 2010 06:29:43:000 | 1182 | 1 | 31.5% | 0 | 31.52% | 12 | 50% | 1 | 0 | 50% | |
| 29 Dec 2010 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | 0 | 40% | - | 0 | 40% | |
| 30 Dec 2010 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | 264 | 30% | - | 0 | 30% | |
| 30 Dec 2010 18:29:43:000 | 1102 | 1 | 29.4% | 0 | 29.39% | | 20% | 1 | 0 | 20% | |
| 31 Dec 2010 06:29:43:000 | 826 | 1 | 22.0% | 0 | 22.03% | | 10% | 1 | 0 | 10% | |
| 31 Dec 2010 18:29:43:000 | 1877 | 1 | 50.1% | 0 | 50.05% | 276 | | 1 | 276 | | |
| 01 Jan 2011 06:29:43:000 | 1764 | 1 | 47.0% | 0 | 47.04% | | | 1 | | | |
| 01 Jan 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | | |
| 02 Jan 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | | |
| 02 Jan 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | | |
| 03 Jan 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | | |
| 03 Jan 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | | |
| 04 Jan 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | | |
| 04 Jan 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | | |
| 05 Jan 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | | |
| 05 Jan 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | | |
| 06 Jan 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | | |
| 06 Jan 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | | |
| 07 Jan 2011 06:29:43:000 | 1158 | 1 | 30.9% | 0 | 30.88% | | | 1 | | | |
| 07 Jan 2011 18:29:43:000 | 1147 | 1 | 30.6% | 0 | 30.59% | | | 1 | | | |
| 08 Jan 2011 06:29:43:000 | 1144 | 1 | 30.5% | 0 | 30.51% | | | 1 | | | |
| 08 Jan 2011 18:29:43:000 | 1162 | 1 | 31.0% | 0 | 30.99% | | | 1 | | | |
| 09 Jan 2011 06:29:43:000 | 1046 | 1 | 27.9% | 0 | 27.89% | | | 1 | | | |
| 09 Jan 2011 18:29:43:000 | 1110 | 1 | 29.6% | 0 | 29.60% | | | 1 | | | |
| 10 Jan 2011 06:29:43:000 | 1169 | 1 | 31.2% | 0 | 31.17% | | | 1 | | | |
| 10 Jan 2011 18:29:43:000 | 1190 | 1 | 31.7% | 0 | 31.73% | | | 1 | | | |
| 11 Jan 2011 06:29:43:000 | 1160 | 1 | 30.9% | 0 | 30.93% | | | 1 | | | |
| 11 Jan 2011 18:29:43:000 | 1118 | 1 | 29.8% | 0 | 29.81% | | | 1 | | | |
| 12 Jan 2011 06:29:43:000 | 1190 | 1 | 31.7% | 0 | 31.73% | | | 1 | | | |
| 12 Jan 2011 18:29:43:000 | 1160 | 1 | 30.9% | 0 | 30.93% | | | 1 | | | |
| 13 Jan 2011 06:29:43:000 | 1083 | 1 | 28.9% | 0 | 28.88% | | | 1 | | | |
| 13 Jan 2011 18:29:43:000 | 1155 | 1 | 30.8% | 0 | 30.80% | | | 1 | | | |
| 14 Jan 2011 06:29:43:000 | 1168 | 1 | 31.1% | 0 | 31.15% | | | 1 | | | |
| 14 Jan 2011 18:29:43:000 | 1196 | 1 | 31.9% | 0 | 31.89% | | | 1 | | | |
| 15 Jan 2011 06:29:43:000 | 1155 | 1 | 30.8% | 0 | 30.80% | | | 1 | | | |
| 15 Jan 2011 18:29:43:000 | 1160 | 1 | 30.9% | 0 | 30.93% | | | 1 | | | |
| 16 Jan 2011 06:29:43:000 | 1116 | 1 | 29.8% | 0 | 29.76% | | | 1 | | | |
| 16 Jan 2011 18:29:43:000 | 1158 | 1 | 30.9% | 0 | 30.88% | | | 1 | | | |
| 17 Jan 2011 06:29:43:000 | 1166 | 1 | 31.1% | 0 | 31.09% | | | 1 | | | |
| 17 Jan 2011 18:29:43:000 | 1171 | 1 | 31.2% | 0 | 31.23% | | | 1 | | | |

Calculations for Duke Custom Incentive

Basis: TCH data July 1, 2010 to June 30, 2011

| | | | | | | | | | | |
|--------------------------|------|---|-------|---|--------|-----|------|-----|---|----------|
| 18 Jan 2011 06:29:43:000 | 1150 | 1 | 30.7% | 0 | 30.67% | | | | 1 | |
| 18 Jan 2011 18:29:43:000 | 1186 | 1 | 31.6% | 0 | 31.63% | | | | 1 | |
| 19 Jan 2011 06:29:43:000 | 1134 | 1 | 30.2% | 0 | 30.24% | | | | 1 | |
| 19 Jan 2011 18:29:43:000 | 1144 | 1 | 30.5% | 0 | 30.51% | | | | 1 | |
| 20 Jan 2011 06:29:43:000 | 1114 | 1 | 29.7% | 0 | 29.71% | | | | 1 | |
| 20 Jan 2011 18:29:43:000 | 1129 | 1 | 30.1% | 0 | 30.11% | | | | 1 | |
| 21 Jan 2011 06:29:43:000 | 1158 | 1 | 30.9% | 0 | 30.88% | | | | 1 | |
| 21 Jan 2011 18:29:43:000 | 1182 | 1 | 31.5% | 0 | 31.52% | | | | 1 | |
| 22 Jan 2011 06:29:43:000 | 1162 | 1 | 31.0% | 0 | 30.99% | | | | 1 | |
| 22 Jan 2011 18:29:43:000 | 1110 | 1 | 29.6% | 0 | 29.60% | | | | 1 | |
| 23 Jan 2011 06:29:43:000 | 1142 | 1 | 30.5% | 0 | 30.45% | | | | 1 | |
| 23 Jan 2011 18:29:43:000 | 1180 | 1 | 31.5% | 0 | 31.47% | | | | 1 | |
| 24 Jan 2011 06:29:43:000 | 1197 | 1 | 31.9% | 0 | 31.92% | | | | 1 | |
| 24 Jan 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 25 Jan 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 25 Jan 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | 480 | - | |
| 26 Jan 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 26 Jan 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | 0 | 100% | | - | 480 100% |
| 27 Jan 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | 0 | 90% | | - | 0 90% |
| 27 Jan 2011 18:29:43:000 | 400 | 1 | 10.7% | 0 | 10.67% | 0 | 80% | | 1 | 0 80% |
| 28 Jan 2011 06:29:43:000 | 400 | 1 | 10.7% | 0 | 10.67% | 0 | 70% | | 1 | 0 70% |
| 28 Jan 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | 0 | 60% | | - | 0 60% |
| 29 Jan 2011 06:29:43:000 | 1064 | 1 | 28.4% | 0 | 28.37% | 12 | 50% | | 1 | 0 50% |
| 29 Jan 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | 0 | 40% | | - | 0 40% |
| 30 Jan 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | 468 | 30% | | - | 0 30% |
| 30 Jan 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | 20% | | - | 0 20% |
| 31 Jan 2011 06:29:43:000 | 1079 | 1 | 28.8% | 0 | 28.77% | | 10% | | 1 | 0 10% |
| 31 Jan 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | 480 | | | - | 480 |
| 01 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 01 Feb 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 02 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 02 Feb 2011 18:29:43:000 | 1106 | 1 | 29.5% | 0 | 29.49% | | | | 1 | |
| 03 Feb 2011 06:29:43:000 | 1135 | 1 | 30.3% | 0 | 30.27% | | | | 1 | |
| 03 Feb 2011 18:29:43:000 | 1178 | 1 | 31.4% | 0 | 31.41% | | | | 1 | |
| 04 Feb 2011 06:29:43:000 | 1147 | 1 | 30.6% | 0 | 30.59% | | | | 1 | |
| 04 Feb 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 05 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 05 Feb 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 06 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 06 Feb 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 07 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 07 Feb 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 08 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 08 Feb 2011 18:29:43:000 | 400 | 1 | 10.7% | 0 | 10.67% | | | | 1 | |
| 09 Feb 2011 06:29:43:000 | 400 | 1 | 10.7% | 0 | 10.67% | | | | 1 | |
| 09 Feb 2011 18:29:43:000 | 1152 | 1 | 30.7% | 0 | 30.72% | | | | 1 | |
| 10 Feb 2011 06:29:43:000 | 1199 | 1 | 32.0% | 0 | 31.97% | | | | 1 | |
| 10 Feb 2011 18:29:43:000 | 1109 | 1 | 29.6% | 0 | 29.57% | | | | 1 | |
| 11 Feb 2011 06:29:43:000 | 1113 | 1 | 29.7% | 0 | 29.68% | | | | 1 | |
| 11 Feb 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 12 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 12 Feb 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 13 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 13 Feb 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 14 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 14 Feb 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 15 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 15 Feb 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 16 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 16 Feb 2011 18:29:43:000 | 2349 | 1 | 62.6% | 0 | 62.64% | | | | 1 | |
| 17 Feb 2011 06:29:43:000 | 1112 | 1 | 29.7% | 0 | 29.65% | | | | 1 | |
| 17 Feb 2011 18:29:43:000 | 2353 | 1 | 62.7% | 0 | 62.75% | | | | 1 | |
| 18 Feb 2011 06:29:43:000 | 2382 | 1 | 63.5% | 0 | 63.52% | | | | 1 | |
| 18 Feb 2011 18:29:43:000 | 2223 | 1 | 59.3% | 0 | 59.28% | | | | 1 | |
| 19 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 19 Feb 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 20 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |
| 20 Feb 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | | - | |

Calculations for Duke Custom Incentive

Basis: TCH data July 1, 2010 to June 30, 2011

| | | | | | | | | | | |
|--------------------------|------|---|-------|---|--------|-----|------|---|-----|------|
| 21 Feb 2011 06:29:43:000 | 1762 | 1 | 47.0% | 0 | 46.99% | | | 1 | | |
| 21 Feb 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 22 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 22 Feb 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 23 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 23 Feb 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | 0 | 100% | - | 228 | 100% |
| 24 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | 0 | 90% | - | 0 | 90% |
| 24 Feb 2011 18:29:43:000 | 358 | 1 | 9.5% | 0 | 9.55% | 0 | 80% | 1 | 0 | 80% |
| 25 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | 0 | 70% | - | 0 | 70% |
| 25 Feb 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | 60 | 60% | - | 0 | 60% |
| 26 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | 12 | 50% | - | 0 | 50% |
| 26 Feb 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | 0 | 40% | - | 0 | 40% |
| 27 Feb 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | 156 | 30% | - | 0 | 30% |
| 27 Feb 2011 18:29:43:000 | 1169 | 1 | 31.2% | 0 | 31.17% | | 20% | 1 | 0 | 20% |
| 28 Feb 2011 06:29:43:000 | 2096 | 1 | 55.9% | 0 | 55.89% | | 10% | 1 | 0 | 10% |
| 28 Feb 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | 228 | | - | 228 | |
| 01 Mar 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 01 Mar 2011 18:29:43:000 | 332 | 1 | 8.9% | 0 | 8.85% | | | - | 1 | |
| 02 Mar 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 02 Mar 2011 18:29:43:000 | 338 | 1 | 9.0% | 0 | 9.01% | | | - | 1 | |
| 03 Mar 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 03 Mar 2011 18:29:43:000 | 1118 | 1 | 29.8% | 0 | 29.81% | | | - | 1 | |
| 04 Mar 2011 06:29:43:000 | 1121 | 1 | 29.9% | 0 | 29.89% | | | - | 1 | |
| 04 Mar 2011 18:29:43:000 | 880 | 1 | 23.5% | 0 | 23.47% | | | - | 1 | |
| 05 Mar 2011 06:29:43:000 | 959 | 1 | 25.6% | 0 | 25.57% | | | - | 1 | |
| 05 Mar 2011 18:29:43:000 | 646 | 1 | 17.2% | 0 | 17.23% | | | - | 1 | |
| 06 Mar 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 06 Mar 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 07 Mar 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 07 Mar 2011 18:29:43:000 | 280 | 1 | 7.5% | 0 | 7.47% | | | - | 1 | |
| 08 Mar 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 08 Mar 2011 18:29:43:000 | 1237 | 1 | 33.0% | 0 | 32.99% | | | - | 1 | |
| 09 Mar 2011 06:29:43:000 | 703 | 1 | 18.7% | 0 | 18.75% | | | - | 1 | |
| 09 Mar 2011 18:29:43:000 | 1225 | 1 | 32.7% | 0 | 32.67% | | | - | 1 | |
| 10 Mar 2011 06:29:43:000 | 695 | 1 | 18.5% | 0 | 18.53% | | | - | 1 | |
| 10 Mar 2011 18:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 11 Mar 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 11 Mar 2011 18:29:43:000 | 328 | 1 | 8.7% | 0 | 8.75% | | | - | 1 | |
| 12 Mar 2011 06:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 12 Mar 2011 18:29:43:000 | 1382 | 1 | 36.9% | 0 | 36.85% | | | - | 1 | |
| 13 Mar 2011 07:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 13 Mar 2011 19:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 14 Mar 2011 07:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 14 Mar 2011 19:29:43:000 | 316 | 1 | 8.4% | 0 | 8.43% | | | - | 1 | |
| 15 Mar 2011 07:29:43:000 | 290 | 1 | 7.7% | 0 | 7.73% | | | - | 1 | |
| 15 Mar 2011 19:29:43:000 | 810 | 1 | 21.6% | 0 | 21.60% | | | - | 1 | |
| 16 Mar 2011 07:29:43:000 | 356 | 1 | 9.5% | 0 | 9.49% | | | - | 1 | |
| 16 Mar 2011 19:29:43:000 | 1573 | 1 | 41.9% | 0 | 41.95% | | | - | 1 | |
| 17 Mar 2011 07:29:43:000 | 718 | 1 | 19.1% | 0 | 19.15% | | | - | 1 | |
| 17 Mar 2011 19:29:43:000 | 2335 | 1 | 62.3% | 0 | 62.27% | | | - | 1 | |
| 18 Mar 2011 07:29:43:000 | 2259 | 1 | 60.2% | 0 | 60.24% | | | - | 1 | |
| 18 Mar 2011 19:29:43:000 | 1561 | 1 | 41.6% | 0 | 41.63% | | | - | 1 | |
| 19 Mar 2011 07:29:43:000 | 696 | 1 | 18.6% | 0 | 18.56% | | | - | 1 | |
| 19 Mar 2011 19:29:43:000 | 946 | 1 | 25.2% | 0 | 25.23% | | | - | 1 | |
| 20 Mar 2011 07:29:43:000 | 644 | 1 | 17.2% | 0 | 17.17% | | | - | 1 | |
| 20 Mar 2011 19:29:43:000 | 2262 | 1 | 60.3% | 0 | 60.32% | | | - | 1 | |
| 21 Mar 2011 07:29:43:000 | 2222 | 1 | 59.3% | 0 | 59.25% | | | - | 1 | |
| 21 Mar 2011 19:29:43:000 | 2608 | 1 | 69.5% | 0 | 69.55% | | | - | 1 | |
| 22 Mar 2011 07:29:43:000 | 1773 | 1 | 47.3% | 0 | 47.28% | | | - | 1 | |
| 22 Mar 2011 19:29:43:000 | 2468 | 1 | 65.8% | 0 | 65.81% | | | - | 1 | |
| 23 Mar 2011 07:29:43:000 | 2287 | 1 | 61.0% | 0 | 60.99% | | | - | 1 | |
| 23 Mar 2011 19:29:43:000 | 1475 | 1 | 39.3% | 0 | 39.33% | | | - | 1 | |
| 24 Mar 2011 07:29:43:000 | 815 | 1 | 21.7% | 0 | 21.73% | | | - | 1 | |
| 24 Mar 2011 19:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 25 Mar 2011 07:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 25 Mar 2011 19:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 26 Mar 2011 07:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 26 Mar 2011 19:29:43:000 | 0 | 0 | 0.0% | 0 | 0.00% | 0 | 100% | - | 408 | 100% |

Calculations for Duke Custom Incentive

Basis: TCH data July 1, 2010 to June 30, 2011

| | | | | | | | | | | |
|--------------------------|------|---|-------|---|--------|-----|------|---|-----|------|
| 27 Mar 2011 07:29:43:00C | 0 | 0 | 0.0% | 0 | 0.00% | 0 | 90% | - | 0 | 90% |
| 27 Mar 2011 19:29:43:00C | 0 | 0 | 0.0% | 0 | 0.00% | 0 | 80% | - | 0 | 80% |
| 28 Mar 2011 07:29:43:00C | 0 | 0 | 0.0% | 0 | 0.00% | 24 | 70% | - | 0 | 70% |
| 28 Mar 2011 19:29:43:00C | 0 | 0 | 0.0% | 0 | 0.00% | 60 | 60% | - | 0 | 60% |
| 29 Mar 2011 07:29:43:00C | 0 | 0 | 0.0% | 0 | 0.00% | 12 | 50% | - | 0 | 50% |
| 29 Mar 2011 19:29:43:00C | 0 | 0 | 0.0% | 0 | 0.00% | 48 | 40% | - | 0 | 40% |
| 30 Mar 2011 07:29:43:00C | 0 | 0 | 0.0% | 0 | 0.00% | 264 | 30% | - | 0 | 30% |
| 30 Mar 2011 19:29:43:00C | 0 | 0 | 0.0% | 0 | 0.00% | | 20% | - | 0 | 20% |
| 31 Mar 2011 07:29:43:00C | 0 | 0 | 0.0% | 0 | 0.00% | | 10% | - | 0 | 10% |
| 31 Mar 2011 19:29:43:00C | 0 | 0 | 0.0% | 0 | 0.00% | 408 | | - | 408 | |
| 01 Apr 2011 07:29:43:00C | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 01 Apr 2011 19:29:43:00C | 313 | 1 | 8.3% | 0 | 8.35% | | | 1 | | |
| 02 Apr 2011 07:29:43:00C | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 02 Apr 2011 19:29:43:00C | 400 | 1 | 10.7% | 0 | 10.67% | | | 1 | | |
| 03 Apr 2011 07:29:43:00C | 0 | 0 | 0.0% | 0 | 0.00% | | | - | | |
| 03 Apr 2011 19:29:43:00C | 2265 | 1 | 60.4% | 0 | 60.40% | | | 1 | | |
| 04 Apr 2011 07:29:43:00C | 2240 | 1 | 59.7% | 0 | 59.73% | | | 1 | | |
| 04 Apr 2011 19:29:43:00C | 910 | 1 | 24.3% | 0 | 24.27% | | | 1 | | |
| 05 Apr 2011 07:29:43:00C | 640 | 1 | 17.1% | 0 | 17.07% | | | 1 | | |
| 05 Apr 2011 19:29:43:00C | 755 | 1 | 20.1% | 0 | 20.13% | | | 1 | | |
| 06 Apr 2011 07:29:43:00C | 698 | 1 | 18.6% | 0 | 18.61% | | | 1 | | |
| 06 Apr 2011 19:29:43:00C | 2257 | 1 | 60.2% | 0 | 60.19% | | | 1 | | |
| 07 Apr 2011 07:29:43:00C | 1865 | 1 | 49.7% | 0 | 49.73% | | | 1 | | |
| 07 Apr 2011 19:29:43:00C | 2234 | 1 | 59.6% | 0 | 59.57% | | | 1 | | |
| 08 Apr 2011 07:29:43:00C | 1856 | 1 | 49.5% | 0 | 49.49% | | | 1 | | |
| 08 Apr 2011 19:29:43:00C | 2587 | 1 | 69.0% | 0 | 68.99% | | | 1 | | |
| 09 Apr 2011 07:29:43:00C | 1934 | 1 | 51.6% | 0 | 51.57% | | | 1 | | |
| 09 Apr 2011 19:29:43:00C | 2216 | 1 | 59.1% | 0 | 59.09% | | | 1 | | |
| 10 Apr 2011 07:29:43:00C | 2155 | 1 | 57.5% | 0 | 57.47% | | | 1 | | |
| 10 Apr 2011 19:29:43:00C | 2752 | 1 | 73.4% | 0 | 73.39% | | | 1 | | |
| 11 Apr 2011 07:29:43:00C | 2608 | 1 | 69.5% | 0 | 69.55% | | | 1 | | |
| 11 Apr 2011 19:29:43:00C | 2534 | 1 | 67.6% | 0 | 67.57% | | | 1 | | |
| 12 Apr 2011 07:29:43:00C | 1527 | 1 | 40.7% | 0 | 40.72% | | | 1 | | |
| 12 Apr 2011 19:29:43:00C | 1125 | 1 | 30.0% | 0 | 30.00% | | | 1 | | |
| 13 Apr 2011 07:29:43:00C | 797 | 1 | 21.3% | 0 | 21.25% | | | 1 | | |
| 13 Apr 2011 19:29:43:00C | 2214 | 1 | 59.0% | 0 | 59.04% | | | 1 | | |
| 14 Apr 2011 07:29:43:00C | 1511 | 1 | 40.3% | 0 | 40.29% | | | 1 | | |
| 14 Apr 2011 19:29:43:00C | 2215 | 1 | 59.1% | 0 | 59.07% | | | 1 | | |
| 15 Apr 2011 07:29:43:00C | 1615 | 1 | 43.1% | 0 | 43.07% | | | 1 | | |
| 15 Apr 2011 19:29:43:00C | 1411 | 1 | 37.6% | 0 | 37.63% | | | 1 | | |
| 16 Apr 2011 07:29:43:00C | 1947 | 1 | 51.9% | 0 | 51.92% | | | 1 | | |
| 16 Apr 2011 19:29:43:00C | 817 | 1 | 21.8% | 0 | 21.79% | | | 1 | | |
| 17 Apr 2011 07:29:43:00C | 881 | 1 | 23.5% | 0 | 23.49% | | | 1 | | |
| 17 Apr 2011 19:29:43:00C | 2177 | 1 | 58.1% | 0 | 58.05% | | | 1 | | |
| 18 Apr 2011 07:29:43:00C | 2166 | 1 | 57.8% | 0 | 57.76% | | | 1 | | |
| 18 Apr 2011 19:29:43:00C | 2223 | 1 | 59.3% | 0 | 59.28% | | | 1 | | |
| 19 Apr 2011 07:29:43:00C | 1845 | 1 | 49.2% | 0 | 49.20% | | | 1 | | |
| 19 Apr 2011 19:29:43:00C | 2188 | 1 | 58.3% | 0 | 58.35% | | | 1 | | |
| 20 Apr 2011 07:29:43:00C | 2221 | 1 | 59.2% | 0 | 59.23% | | | 1 | | |
| 20 Apr 2011 19:29:43:00C | 1580 | 1 | 42.1% | 0 | 42.13% | | | 1 | | |
| 21 Apr 2011 07:29:43:00C | 778 | 1 | 20.7% | 0 | 20.75% | | | 1 | | |
| 21 Apr 2011 19:29:43:00C | 1378 | 1 | 36.7% | 0 | 36.75% | | | 1 | | |
| 22 Apr 2011 07:29:43:00C | 1119 | 1 | 29.8% | 0 | 29.84% | | | 1 | | |
| 22 Apr 2011 19:29:43:00C | 1659 | 1 | 44.2% | 0 | 44.24% | | | 1 | | |
| 23 Apr 2011 07:29:43:00C | 1956 | 1 | 52.2% | 0 | 52.16% | | | 1 | | |
| 23 Apr 2011 19:29:43:00C | 1915 | 1 | 51.1% | 0 | 51.07% | | | 1 | | |
| 24 Apr 2011 07:29:43:00C | 1869 | 1 | 49.8% | 0 | 49.84% | | | 1 | | |
| 24 Apr 2011 19:29:43:00C | 2023 | 1 | 53.9% | 0 | 53.95% | | | 1 | | |
| 25 Apr 2011 07:29:43:00C | 1989 | 1 | 53.0% | 0 | 53.04% | | | 1 | | |
| 25 Apr 2011 19:29:43:00C | 2686 | 1 | 71.6% | 0 | 71.63% | 0 | 100% | 1 | 684 | 100% |
| 26 Apr 2011 07:29:43:00C | 2506 | 1 | 66.8% | 0 | 66.83% | 0 | 90% | 1 | 0 | 90% |
| 26 Apr 2011 19:29:43:00C | 2728 | 1 | 72.7% | 0 | 72.75% | 0 | 80% | 1 | 0 | 80% |
| 27 Apr 2011 07:29:43:00C | 2695 | 1 | 71.9% | 0 | 71.87% | 108 | 70% | 1 | 0 | 70% |
| 27 Apr 2011 19:29:43:00C | 2476 | 1 | 66.0% | 0 | 66.03% | 156 | 60% | 1 | 0 | 60% |
| 28 Apr 2011 07:29:43:00C | 915 | 1 | 24.4% | 0 | 24.40% | 132 | 50% | 1 | 0 | 50% |
| 28 Apr 2011 19:29:43:00C | 1274 | 1 | 34.0% | 0 | 33.97% | 96 | 40% | 1 | 0 | 40% |
| 29 Apr 2011 07:29:43:00C | 1101 | 1 | 29.4% | 0 | 29.36% | 192 | 30% | 1 | 0 | 30% |
| 29 Apr 2011 19:29:43:00C | 1496 | 1 | 39.9% | 0 | 39.89% | | 20% | 1 | 0 | 20% |

Calculations for Duke Custom Incentive

Basis: TCH data July 1, 2010 to June 30, 2011

| | | | | | | | | | | |
|--------------------------|------|---|-------|---|--------|-----|------|---|-----|------|
| 30 Apr 2011 07:29:43:000 | 1100 | 1 | 29.3% | 0 | 29.33% | | 10% | 1 | 0 | 10% |
| 30 Apr 2011 19:29:43:000 | 1737 | 1 | 46.3% | 0 | 46.32% | 684 | | 1 | 684 | |
| 01 May 2011 07:29:43:000 | 1700 | 1 | 45.3% | 0 | 45.33% | | | 1 | | |
| 01 May 2011 19:29:43:000 | 1769 | 1 | 47.2% | 0 | 47.17% | | | 1 | | |
| 02 May 2011 07:29:43:000 | 1369 | 1 | 36.5% | 0 | 36.51% | | | 1 | | |
| 02 May 2011 19:29:43:000 | 1208 | 1 | 32.2% | 0 | 32.21% | | | 1 | | |
| 03 May 2011 07:29:43:000 | 959 | 1 | 25.6% | 0 | 25.57% | | | 1 | | |
| 03 May 2011 19:29:43:000 | 1078 | 1 | 28.7% | 0 | 28.75% | | | 1 | | |
| 04 May 2011 07:29:43:000 | 862 | 1 | 23.0% | 0 | 22.99% | | | 1 | | |
| 04 May 2011 19:29:43:000 | 1113 | 1 | 29.7% | 0 | 29.68% | | | 1 | | |
| 05 May 2011 07:29:43:000 | 935 | 1 | 24.9% | 0 | 24.93% | | | 1 | | |
| 05 May 2011 19:29:43:000 | 1452 | 1 | 38.7% | 0 | 38.72% | | | 1 | | |
| 06 May 2011 07:29:43:000 | 1133 | 1 | 30.2% | 0 | 30.21% | | | 1 | | |
| 06 May 2011 19:29:43:000 | 1636 | 1 | 43.6% | 0 | 43.63% | | | 1 | | |
| 07 May 2011 07:29:43:000 | 1404 | 1 | 37.4% | 0 | 37.44% | | | 1 | | |
| 07 May 2011 19:29:43:000 | 1626 | 1 | 43.4% | 0 | 43.36% | | | 1 | | |
| 08 May 2011 07:29:43:000 | 1564 | 1 | 41.7% | 0 | 41.71% | | | 1 | | |
| 08 May 2011 19:29:43:000 | 1710 | 1 | 45.6% | 0 | 45.60% | | | 1 | | |
| 09 May 2011 07:29:43:000 | 1416 | 1 | 37.8% | 0 | 37.76% | | | 1 | | |
| 09 May 2011 19:29:43:000 | 2572 | 1 | 68.6% | 0 | 68.59% | | | 1 | | |
| 10 May 2011 07:29:43:000 | 2329 | 1 | 62.1% | 0 | 62.11% | | | 1 | | |
| 10 May 2011 19:29:43:000 | 2853 | 1 | 76.1% | 0 | 76.08% | | | 1 | | |
| 11 May 2011 07:29:43:000 | 2809 | 1 | 74.9% | 0 | 74.91% | | | 1 | | |
| 11 May 2011 19:29:43:000 | 3221 | 1 | 85.9% | 0 | 85.89% | | | 1 | | |
| 12 May 2011 07:29:43:000 | 3107 | 1 | 82.9% | 0 | 82.85% | | | 1 | | |
| 12 May 2011 19:29:43:000 | 3176 | 1 | 84.7% | 0 | 84.69% | | | 1 | | |
| 13 May 2011 07:29:43:000 | 2910 | 1 | 77.6% | 0 | 77.60% | | | 1 | | |
| 13 May 2011 19:29:43:000 | 2973 | 1 | 79.3% | 0 | 79.28% | | | 1 | | |
| 14 May 2011 07:29:43:000 | 2643 | 1 | 70.5% | 0 | 70.48% | | | 1 | | |
| 14 May 2011 19:29:43:000 | 2538 | 1 | 67.7% | 0 | 67.68% | | | 1 | | |
| 15 May 2011 07:29:43:000 | 1388 | 1 | 37.0% | 0 | 37.01% | | | 1 | | |
| 15 May 2011 19:29:43:000 | 1470 | 1 | 39.2% | 0 | 39.20% | | | 1 | | |
| 16 May 2011 07:29:43:000 | 1178 | 1 | 31.4% | 0 | 31.41% | | | 1 | | |
| 16 May 2011 19:29:43:000 | 1255 | 1 | 33.5% | 0 | 33.47% | | | 1 | | |
| 17 May 2011 07:29:43:000 | 1151 | 1 | 30.7% | 0 | 30.69% | | | 1 | | |
| 17 May 2011 19:29:43:000 | 1193 | 1 | 31.8% | 0 | 31.81% | | | 1 | | |
| 18 May 2011 07:29:43:000 | 1211 | 1 | 32.3% | 0 | 32.29% | | | 1 | | |
| 18 May 2011 19:29:43:000 | 1442 | 1 | 38.5% | 0 | 38.45% | | | 1 | | |
| 19 May 2011 07:29:43:000 | 1636 | 1 | 43.6% | 0 | 43.63% | | | 1 | | |
| 19 May 2011 19:29:43:000 | 1757 | 1 | 46.9% | 0 | 46.85% | | | 1 | | |
| 20 May 2011 07:29:43:000 | 1638 | 1 | 43.7% | 0 | 43.68% | | | 1 | | |
| 20 May 2011 19:29:43:000 | 2642 | 1 | 70.5% | 0 | 70.45% | | | 1 | | |
| 21 May 2011 07:29:43:000 | 2339 | 1 | 62.4% | 0 | 62.37% | | | 1 | | |
| 21 May 2011 19:29:43:000 | 2911 | 1 | 77.6% | 0 | 77.63% | | | 1 | | |
| 22 May 2011 07:29:43:000 | 2706 | 1 | 72.2% | 0 | 72.16% | | | 1 | | |
| 22 May 2011 19:29:43:000 | 2766 | 1 | 73.8% | 0 | 73.76% | | | 1 | | |
| 23 May 2011 07:29:43:000 | 2184 | 1 | 58.2% | 0 | 58.24% | | | 1 | | |
| 23 May 2011 19:29:43:000 | 3056 | 1 | 81.5% | 0 | 81.49% | | | 1 | | |
| 24 May 2011 07:29:43:000 | 2770 | 1 | 73.9% | 0 | 73.87% | | | 1 | | |
| 24 May 2011 19:29:43:000 | 3062 | 1 | 81.7% | 0 | 81.65% | | | 1 | | |
| 25 May 2011 07:29:43:000 | 2834 | 1 | 75.6% | 0 | 75.57% | | | 1 | | |
| 25 May 2011 19:29:43:000 | 3221 | 1 | 85.9% | 0 | 85.89% | | | 1 | | |
| 26 May 2011 07:29:43:000 | 2917 | 1 | 77.8% | 0 | 77.79% | | | 1 | | |
| 26 May 2011 19:29:43:000 | 2696 | 1 | 71.9% | 0 | 71.89% | 0 | 100% | 1 | 744 | 100% |
| 27 May 2011 07:29:43:000 | 2024 | 1 | 54.0% | 0 | 53.97% | 36 | 90% | 1 | 0 | 90% |
| 27 May 2011 19:29:43:000 | 2097 | 1 | 55.9% | 0 | 55.92% | 168 | 80% | 1 | 0 | 80% |
| 28 May 2011 07:29:43:000 | 2148 | 1 | 57.3% | 0 | 57.28% | 132 | 70% | 1 | 0 | 70% |
| 28 May 2011 19:29:43:000 | 2740 | 1 | 73.1% | 0 | 73.07% | 60 | 60% | 1 | 0 | 60% |
| 29 May 2011 07:29:43:000 | 2747 | 1 | 73.3% | 0 | 73.25% | 60 | 50% | 1 | 0 | 50% |
| 29 May 2011 19:29:43:000 | 2999 | 1 | 80.0% | 0 | 79.97% | 144 | 40% | 1 | 0 | 40% |
| 30 May 2011 07:29:43:000 | 2852 | 1 | 76.1% | 0 | 76.05% | 144 | 30% | 1 | 0 | 30% |
| 30 May 2011 19:29:43:000 | 3232 | 1 | 86.2% | 0 | 86.19% | | 20% | 1 | 0 | 20% |
| 31 May 2011 07:29:43:000 | 3125 | 1 | 83.3% | 0 | 83.33% | | 10% | 1 | 0 | 10% |
| 31 May 2011 19:29:43:000 | 3098 | 1 | 82.6% | 0 | 82.61% | 744 | | 1 | 744 | |
| 01 Jun 2011 07:29:43:000 | 3243 | 1 | 86.5% | 0 | 86.48% | | | 1 | | |
| 01 Jun 2011 19:29:43:000 | 2882 | 1 | 76.9% | 0 | 76.85% | | | 1 | | |
| 02 Jun 2011 07:29:43:000 | 2728 | 1 | 72.7% | 0 | 72.75% | | | 1 | | |
| 02 Jun 2011 19:29:43:000 | 2873 | 1 | 76.6% | 0 | 76.61% | | | 1 | | |

HOURS AT PERCENT CAPACITY, GPM

| % GPM | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC | | % BHP |
|--------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|------|--------------|
| 100% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 100% |
| 90% | 0 | 0 | 0 | 0 | 0 | 36 | 36 | 0 | 0 | 0 | 0 | 0 | 72 | 90% |
| 80% | 0 | 0 | 0 | 0 | 168 | 324 | 612 | 504 | 228 | 0 | 0 | 0 | 1836 | 80% |
| 70% | 0 | 0 | 24 | 108 | 132 | 300 | 96 | 204 | 168 | 84 | 0 | 0 | 1116 | 70% |
| 60% | 0 | 60 | 60 | 156 | 60 | 60 | 24 | 36 | 192 | 96 | 48 | 0 | 792 | 60% |
| 50% | 12 | 12 | 12 | 132 | 60 | 0 | 12 | 0 | 120 | 252 | 36 | 12 | 660 | 50% |
| 40% | 0 | 0 | 48 | 96 | 144 | 0 | 0 | 0 | 12 | 216 | 96 | 0 | 612 | 40% |
| 30% | 468 | 156 | 264 | 192 | 144 | 0 | 0 | 0 | 0 | 96 | 264 | 264 | 1848 | 30% |
| 20% | | | | | | | | | | | | | 0 | 20% |
| 10% | | | | | | | | | | | | | 0 | 10% |
| | 480 | 228 | 408 | 684 | 744 | 720 | 744 | 744 | 720 | 744 | 444 | 276 | 6936 | |

HOURS AT PERCENT MOTOR CAPACITY, HP

| % HP | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC | | % BHP | |
|-------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--------------|------|
| 100% | 480 | 228 | 408 | 684 | 744 | 720 | 744 | 744 | 744 | 720 | 744 | 444 | 276 | 6936 | 100% |
| 90% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 90% |
| 80% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 80% |
| 70% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 70% |
| 60% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 60% |
| 50% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 50% |
| 40% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 40% |
| 30% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 30% |
| 20% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 20% |
| 10% | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 10% |
| | 480 | 228 | 408 | 684 | 744 | 720 | 744 | 744 | 744 | 720 | 744 | 444 | 276 | 6936 | |
| | 744 | 672 | 744 | 744 | 744 | 720 | 744 | 744 | 744 | 720 | 744 | 720 | 744 | | |
| | 264 | 444 | 336 | 60 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 276 | 468 | | |

FOSDICK & HILMER, Inc.

309 Vine St., Suite 50, Cincinnati, OH 45202, Tel: (513) 241-5640

<http://www.fheng.com>

| | <u>kW-Hr</u> |
|--------|--------------|
| 100.38 | - |
| 90.34 | 6,504 |
| 80.31 | 147,449 |
| 70.27 | 78,421 |
| 60.23 | 47,702 |
| 50.7 | 33,462 |
| 41.45 | 25,367 |
| 31.74 | 58,656 |
| 22.37 | - |
| 12.84 | - |
| | 397,562 |

| | <u>kW-Hr</u> |
|-------|--------------|
| 95.79 | 664,399 |
| | - |
| | - |
| | - |
| | - |
| | - |
| | - |
| | - |
| | - |
| | - |

Data for input to Duke Part 2 Custom Incentive Application

| CT-1 operating at full power | | |
|------------------------------|------|-----------|
| 95.79 | 6936 | 664399.44 |
| 0.00 | 0 | 0.00 |
| 0.00 | 0 | 0.00 |
| 0.00 | 0 | 0.00 |
| 0.00 | 0 | 0.00 |
| 0.00 | 0 | 0.00 |
| 0.00 | 0 | 0.00 |
| 0.00 | 0 | 0.00 |
| 0.00 | 0 | 0.00 |
| 0.00 | 0 | 0.00 |
| 0.00 | 0 | 0.00 |

| | | | |
|-------|------------|---------|----------------------------------|
| 6,936 | 664,399.44 | \$0.065 | \$43,185.964 |
| HR | kW-HR | | Cost to run constant speed fan ^ |

| Variable speed fan power consumption | | |
|--------------------------------------|--------|-------|
| 100% | 100.38 | 0 |
| 90% | 90.34 | 72 |
| 80% | 80.31 | 1,836 |
| 70% | 70.27 | 1,116 |
| 60% | 60.23 | 792 |
| 50% | 50.70 | 660 |
| 40% | 41.45 | 612 |
| 30% | 31.74 | 1,848 |
| 20% | 22.37 | 0 |
| 10% | 12.84 | 0 |

100%
90%
80%
70%
60%
50%
40%
30%
20%
10%

| | | | |
|-------|------------|---------|----------------------------------|
| 6,936 | 397,562.04 | \$0.065 | \$25,841.533 |
| HR | kW-HR | | Cost to run variable speed fan ^ |

SAVINGS >>> \$17,344.43