



Office of the Ohio Consumers' Counsel

Your Residential Utility Advocate

Janine L. Migden-Ostrander
Consumers' Counsel

RECEIVED-DOCKETING DIV

2007 APR 10 PM 4:11

PUCO

FILE

April 10, 2007

Ms. Renee Jenkins, Secretary
Public Utilities Commission of Ohio
Docketing Division
180 E. Broad St., 13th Floor
Columbus, Ohio 43215-3793

Re: Supplemented Testimony of Peter J. Lanzalotta in Case No. 06-222-EL-SLF

Dear Ms. Jenkins:

The Ohio Consumers' Counsel ("OCC") files the attached, revised testimony of Peter J. Lanzalotta, in accordance with the March 7, 2007, Entry in the above-captioned case. The revised testimony supplements Mr. Lanzalotta's testimony originally filed on January 19, 2007. The testimony has been updated with information gleaned from American Electric Power's ("AEP") Annual Reliability Reports filed in compliance with Ohio Adm. Code 4901:1-10-10(B)(3), 4901:1-10-10(C)(1), and 4901:1-10-10(C)(2), on March 23, 2007.

The revisions to Mr. Lanzalotta's testimony consist solely of additions and/or revisions to Table 1 on page 14 of the testimony, Table 2 on page 17 of the testimony, and Table 3 on page 28 of the testimony, as well as textual references to those tables. All the revisions are related directly to the Ohio Adm. Code filings noted above. The exhibits to Mr. Lanzalotta's testimony remain unchanged.

Yours very truly,

Richard C. Reese
Assistant Consumers' Counsel

Cc: Parties of Record

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business
Technician DOB Date Processed 4-11-07

FILE

RECEIVED-DOCKETING DIV

OCC EXHIBIT _____

2007 APR 10 PM 4:09

PUCO
BEFORE
THE PUBLIC UTILITIES COMMISSION OF OHIO

In the Matter of the Self-Complaint of)
Columbus Southern Power Company and)
Ohio Power Company Regarding the) Case No. 06-222-EL-SLF
Implementation of Programs to Enhance)
Distribution Service Reliability.)

SUPPLEMENTAL TESTIMONY
OF
PETER J. LANZALOTTA

ON BEHALF OF
THE OFFICE OF THE OHIO CONSUMERS' COUNSEL
*10 West Broad Street, Suite 1800
Columbus, Ohio 43215-3485
(614) 466-8574*

Dated: April 10, 2007

This is to certify that the images appearing are an
accurate and complete reproduction of a case file
document delivered in the regular course of business
Technician DB Date Processed 4-11-07

TABLE OF CONTENTS

I.	INTRODUCTION	1
II.	HISTORY OF AEP OHIO'S DISTRIBUTION SERVICE RELIABILITY	7
III.	DISTRIBUTION RELIABILITY STANDARDS AND MEASUREMENTS	12
	A. <i>Commonly Used Measurements</i>	12
	B. <i>AEP Ohio's Historical Performance</i>	14
IV.	ELECTRIC SERVICE AND SAFETY STANDARDS AND RULES	19
	A. <i>Data Retention Period</i>	20
	B. <i>Distribution System Reliability</i>	23
	C. <i>Customer Interruption Data</i>	25
V.	TARGETS FOR RELIABILITY INDICES	28
VI.	THE PLAN: BASE RELIABILITY PROGRAMS	31
	A. <i>Pole Inspection Program</i>	31
	B. <i>Overhead Circuit Inspection Program</i>	32
	C. <i>Vegetation Management Program</i>	33
	D. <i>Distribution Reliability Programs</i>	37

TABLE OF CONTENTS

VII.	THE PLAN: INCREMENTAL RELIABILITY PROGRAMS.....	38
A.	<i>Vegetation Management</i>	38
1.	<i>Trees Outside The Right-Of-Way</i>	41
B.	<i>Overhead Line Inspections</i>	42
C.	<i>Overhead Mitigation Programs</i>	43
D.	<i>Underground Mitigation Programs</i>	45
E.	<i>Substation Programs</i>	46
F.	<i>Automation and SCADA Program</i>	47
G.	<i>Summary</i>	48
VIII.	SUMMARY	50

EXHIBITS

Exhibit – PJL-1
Exhibit – PJL-2
Exhibit – PJL-3
Exhibit – PJL-4
Exhibit – PJL-5
Exhibit – PJL-6
Exhibit – PJL-7
Exhibit – PJL-8
Exhibit – PJL-9
Exhibit – PJL-10
Exhibit – PJL-11
Exhibit – PJL-12
Exhibit – PJL-13
Exhibit – PJL-14
Exhibit – PJL-15

1 **I. INTRODUCTION**

2
3
4 **Q1. Please state your name, affiliation and business address.**

5 A1. Peter J. Lanzaotta, Lanzaotta & Associates LLC, 67 Royal Pointe Drive, Hilton
6 Head Island, South Carolina 29926.

7
8 **Q2. Please describe your educational background.**

9 A2. I am a graduate of Rensselaer Polytechnic Institute, where I received a Bachelor
10 of Science degree in Electric Power Engineering. In addition, I hold a Masters
11 degree in Business Administration with a concentration in Finance from Loyola
12 College in Baltimore.

13
14 **Q3. Please describe your professional experience.**

15 A3. I am a Principal of Lanzaotta & Associates LLC, which was formed in January
16 2001. Prior to that, I was a partner of Whitfield Russell Associates, with which I
17 had been associated since March 1982. My areas of expertise include electric
18 utility system planning and operation, electric service reliability, cost of service,
19 and utility rate design. I am a registered professional engineer in the states of
20 Maryland and Connecticut. My prior professional experience is described in
21 Exhibit PJJ-1, which is attached hereto.

22
23 I have been involved with the planning operation, and analysis of electric utility
24 systems and with utility regulatory matters, including reliability-related matters,
25 certification of new facilities, cost of service, cost allocation, and rate design, as

1 an employee of and as a consultant to a number of privately- and publicly-owned
2 electric utilities, regulatory agencies, developers, and electricity users over a
3 period exceeding thirty years.

4
5 I have been involved in a number of projects focused on electric utility
6 transmission and distribution system reliability. I have worked for many years on
7 behalf of a number of both public and privately-owned clients on electric
8 reliability-related matters. I am currently or have recently been engaged by
9 various government offices and agencies in the states of Delaware, Maryland,
10 New Jersey, and Pennsylvania to help address electric service reliability concerns.

11
12 **Q4. Have you given expert testimony in any judicial or quasi-judicial**
13 **proceedings?**

14 **A4.** Yes. I have presented expert testimony before the Federal Energy Regulatory
15 Commission ("FERC") and before regulatory commissions and other judicial and
16 legislative bodies in 20 states, the District of Columbia, and the Provinces of
17 Alberta and Ontario. My clients have included utilities, regulatory agencies,
18 ratepayer advocates, independent producers, industrial consumers, the federal
19 government, and various city and state government agencies. The proceedings in
20 which I have testified are listed in Exhibit PJL-2.

1 **Q5. What is the purpose of your testimony?**

2 A5. My testimony, on behalf of the Ohio Consumers' Counsel ("OCC") presents the
3 results of my evaluation of the reliability-related policies and practices that are
4 applied to the distribution systems of the AEP Ohio electric distribution
5 companies, Columbus Southern Power Company ("CSP") and Ohio Power
6 Company ("OPC") (collectively, "AEP Ohio" or "the Company"). My testimony
7 also addresses the electric service reliability performance of these distribution
8 systems, as reflected in the electric service outage experience of the Company's
9 distribution customers. This performance has become less reliable in recent
10 years, as reflected in the electric service reliability index data collected by the
11 Company. This declining performance calls into question the Company's policies
12 and practices as they affect the reliability of the Company's electric distribution
13 system. My evaluation compares the Company's policies, practices, and
14 performance against typical industry practice, Ohio requirements, and against
15 other standards of care. I also review the Company's proposed reliability
16 programs regarding need, reasonableness, and whether these programs really
17 represent something beyond what utilities would normally be undertaking.

18

19 **Q6. On what information is your testimony based?**

20 A6. In preparing my testimony I have reviewed the reports and other documents
21 discussed or mentioned in this testimony (for example, AEP Ohio's Enhanced
22 Distribution Service Reliability Plan ("the Plan"), the responses to multiple
23 rounds of discovery, various FERC filings, and other documents related to electric

1 service reliability). Also, I have reviewed documents not specifically mentioned
2 in this testimony including the May 2003 Staff Report and Stipulation filed in
3 Case No. 03-2570-EL-UNC, AEP Ohio's Final Report, and AEP Ohio's Self
4 Complaint filed in the instant case before the Public Utilities Commission of Ohio
5 ("PUCO" or "Commission").
6

7 **Q7. Please summarize your findings.**

8 A7. Based on my review, my findings are as follows:

- 9 1. System reliability performance (with major storms excluded), as reflected
10 in AEP Ohio's reliability indices, has become less reliable, particularly in
11 the area of outage frequency (SAIFI) and average outage minutes per year
12 (SAIDI), prior to 2006.
- 13 2. System reliability index performance, with major storm data included, has
14 become increasingly less reliability and more divergent from reliability
15 indices with storm data excluded, especially in 2003 and 2004.
- 16 3. AEP Ohio's reliability index targets, especially those for outage frequency
17 (SAIFI), keep getting less demanding, justified by the Company based on
18 the fact that its reliability index performance in recent years has reflected
19 lower reliability.
- 20 4. AEP Ohio installed an automated distribution system outage reporting
21 system in the early 2000s to replace its system of manual data entry and
22 handling of outage data. However, it apparently did so without
23 benchmarking the effects of this system on its reliability indices by

1 performing parallel runs for the old and new systems using the same data
2 for the same time period. The Company claims that this new technology
3 has resulted in increases in its reliability indices (i.e. decreasing
4 reliability), but, without parallel run verification, these increases in the
5 reliability indices could just well be increasing, in whole or in part,
6 because system reliability is getting worse.

7 5. Prior to 2006, AEP Ohio's reliability index targets have been moving in
8 the direction of lower reliability, especially regarding outage frequency
9 (SAIFI). The Company attributes this to the installation of its automated
10 outage recording system, but without the parallel run benchmarking
11 discussed in Item #4 above, these changes should be attributed in part or in
12 their entirety to actual changes in system reliability.

13 6. Several of AEP Ohio's current reliability-related programs, including
14 overhead circuit inspections and vegetation management, have been
15 marked by large swings in the level of effort over the past four to five
16 years, raising potential questions as to the consistency of the quality of
17 these programs.

18 7. AEP Ohio's base vegetation management program is described in the Plan
19 as performance-based, and I believe this has contributed to the
20 deterioration in the Company's reliability index performance in 2003 and
21 2004, especially during major storms, as well as the need to spend in
22 excess of \$90 million over 2004 and 2005 for catch-up vegetation
23 management.

- 1 8. AEP Ohio's incremental vegetation management program promises to
2 inspect or trim all of its distribution circuits once during the next four
3 years. However, the need to double the number of crews over five years,
4 before reducing the number of these crews, raises questions to whether a
5 more consistent level of vegetation management effort would be more
6 sustainable and effective.
- 7 9. A program to deal with trees outside the right-of-way needs to be specified
8 and made part of the vegetation management effort.
- 9 10. The incremental overhead line inspection program does not appear to be
10 significantly different from the Company's existing program.
- 11 11. Parts of the Company's overhead mitigation program appear to represent
12 incremental efforts that address significant reliability concerns regarding
13 fuse cutouts and lightning arrestors that have been demonstrating
14 increasing failure rates. The 34.5 kV program, however, while laudable,
15 does not reflect an incremental effort.
- 16 12. The parts of the incremental reliability programs that deal with the
17 replacement of aging equipment should not be considered as incremental
18 to normal utility practice.
- 19 13. The installation of Supervisory Control and Data Acquisition ("SCADA")
20 capability in those substations which do not currently have it should take
21 precedence over more sophisticated distribution automation efforts.

1 14. The Plan appears deficient in several areas addressing implementation
2 details, expected reliability benefits, formalized reporting, and regulatory
3 review.
4

5 **II. HISTORY OF AEP OHIO'S DISTRIBUTION SERVICE RELIABILITY**
6
7

8 **Q8. Please describe the events that have lead up to this evaluation of AEP Ohio's**
9 **electric distribution reliability in Ohio.**

10 A8. In early 2003, concerns about the reliability of the distribution service being
11 provided in rural Ohio service territories by CSP and OPC caused the
12 Commission staff to look more closely at the Company's policies, practices, and
13 recordkeeping as they relate to inspecting, maintaining, and operating its
14 distribution systems. The result was a May 1, 2003 report titled "Staff Concerns
15 and Recommendations About Columbus Southern Power Company and Ohio
16 Power Company's Provision of Electric Service" ("2003 Staff Report").
17

18 The 2003 Staff Report addressed concerns resulting from (1) rural distribution
19 circuits that were among the Company's worst performing circuits from one year
20 to the next, (2) reductions in distribution-related capital and maintenance
21 expenditures, and (3) increases in service-related complaints from the Company's
22 customers. The 2003 Staff Report also discussed a number of topics related to
23 outage mitigation, including tree-trimming, wind-related outages, animal-related
24 outages, system deterioration, equipment inspections and maintenance, and other
25 topics related to the Company's electric service distribution system reliability.

1 The 2003 Staff Report expressed the opinion that the Company appeared to not be
2 complying with certain Ohio Electric Service and Safety Standards ("ESSS
3 Rules") and made a number of recommendations, which if implemented, could
4 improve the Company's reliability performance.

5
6 Negotiations between the Commission staff and the Company during 2003
7 resulted in the December 31, 2003 Stipulation and Settlement Agreement
8 ("Stipulation"), in which the Company agreed, among other things, to improve by
9 40% the 2002 reliability performance of the worst performing 25% (the 1st
10 quartile) of its distribution circuits in Ohio over the two years following the
11 Stipulation, without letting reliability performance of the rest of the distribution
12 circuits decline.¹

13
14 **Q9. Please describe AEP Ohio's Final Report and Self Complaint filed on**
15 **January 31, 2006.**

16 **A9.** On January 31, 2006 AEP Ohio filed in Case No. 06-222-EL-SLF a "Year Two"
17 final report which described the Companies' progress toward the improved
18 reliability required in the Stipulation. The system average interruption duration
19 index ("SAIDI") target for the first quartile of 279.2 minutes of annual outages
20 per customer was met and exceeded at the end of 2005 with a SAIDI of 258.7
21 minutes. However, AEP Ohio reported that the 2002 baseline SAIDI was not

¹ In the Matter of a Settlement Agreement between the Staff of the Public Utilities Commission of Ohio and Columbus Southern Power Company and Ohio Power Company, Case No. 03-2570-EL-UNC ("03-2570"), Stipulation and Settlement Agreement dated December 31, 2003 at Item #1, p 2, and Item #4, p 3.

1 maintained for the remaining three quartiles of distribution circuits. AEP Ohio
2 described unforeseen and uncontrollable events that the Companies believed
3 contributed to their inability to meet the baseline SAIDI. According to AEP Ohio
4 these issues included an increase in the failure rate of distribution line equipment,
5 an increase in the number of distribution station outages, and uncontrollable
6 events such as vehicle accidents and the mutual assistance needs of other electric
7 utilities.

8
9 AEP Ohio also filed a Self Complaint on January 31, 2006 that was intended to
10 focus the Commission on the future direction of service reliability. AEP Ohio
11 pointed out that some of the factors impacting SAIDI were controllable by the
12 Companies at some incremental cost. AEP Ohio requested that the Commission
13 implement a proceeding in which an enhanced reliability program, proposed by
14 AEP Ohio, would be reviewed and authorized by the Commission.

15
16 **Q10. Please describe the Staff Investigative Report of April 17, 2006.**

17 A10. On April 17, 2006, Commission staff filed a report setting forth its findings and
18 recommendations for improving AEP Ohio's distribution service reliability
19 ("2006 Staff Report"). In its report, Commission staff analyzed the drivers of the
20 Company's reliability performance. Commission staff felt that the Company's
21 distribution system is in need of a resource intensive plan for replacement of
22 aging underground and overhead infrastructure. Commission staff found that
23 over the past five years, AEP Ohio's system-wide reliability performance has

1 been getting worse on all measures, even after their efforts during the stipulation
2 period. Commission staff recommended that the Commission separate the
3 consideration of the issues into two separate dockets. The 03-2570-EL-UNC
4 docket should focus solely on the consequences of the Companies' failure to
5 comply with the Commission Order approving the Stipulation. The 06-222-EL-
6 SLF docket could address the reliability concerns of the future. Commission staff
7 recommended that the comprehensive plans to address future reliability should
8 address the replacement of aging system infrastructure, vegetation management,
9 mitigation of lightning-caused faults, improved fault cause identification,
10 reduction of errors, and improved outage restoration times.

11
12 **Q11. Please describe AEP Ohio's Enhanced Distribution Service Reliability Plan.**

13 A11. The Company filed its Enhanced Distribution Service Reliability Plan on October
14 6, 2006 in response to the Commission's July 26th order for the Company to
15 submit a proposed reliability plan. The Plan reviews selected parts of what the
16 Company calls base distribution reliability programs, and includes the distribution
17 pole inspection program, overhead circuit inspection programs, pad-mounted
18 transformer programs, line recloser programs, line capacitor programs, the
19 network system maintenance program, the distribution vegetation management
20 program, and the distribution substation reliability programs. These programs are
21 already in effect.

1 The Plan also describes what it calls its incremental distribution reliability plan.
2 This incremental plan is touted as the means by which the Company can reach the
3 next level of reliability, by focusing on initiatives to address the Company's aging
4 infrastructure and customers' demand for increased quality of service. The
5 incremental distribution reliability plan expands on the Company's base
6 distribution reliability programs, adds incremental reliability programs, and
7 provides for increased funding by ratepayers for the Company's reliability-related
8 programs. The incremental distribution reliability programs proposed by the
9 Company address vegetation management, overhead line inspections, overhead
10 mitigation programs (including an accelerated equipment and hardware
11 replacement program, an incremental recloser protection program, an incremental
12 34.5 kV protection program, and an incremental fault indicator program),
13 underground mitigation programs, distribution substation programs, and programs
14 implementing developing technology.

15
16 I will discuss the Plan proposal, the reasons the Company gives for proceeding
17 with this proposal, and the base and incremental programs that make up the Plan
18 later in my testimony.

1 **III. DISTRIBUTION RELIABILITY STANDARDS AND MEASUREMENTS**

2
3
4 *A. Commonly Used Measurements*

5
6
7 **Q12. How is electric distribution service reliability typically measured?**

8 **A12.** Although there are a number of different ways to measure electric distribution
9 service reliability performance, the reliability indices SAIFI, CAIDI, and SAIDI
10 are among the most widely used.

11
12 SAIFI refers to the System Average Interruption Frequency Index, and is
13 calculated by dividing the total number of sustained customer service
14 interruptions by the total number of customers served. For a calendar year period,
15 SAIFI represents the average number of sustained electric service outages per
16 customer served during that period. SAIFI may be calculated for time periods
17 other than a calendar year as well.

18
19 CAIDI refers to the Customer Average Interruption Duration Index, and is
20 calculated by dividing the sum of the individual customers' minutes of sustained
21 electric service interruption by the total number of individual customer
22 interruptions. For a calendar year period, CAIDI represents the average number
23 of minutes of electric service interruption for each customer service interruption,
24 or, put another way, the average outage duration. CAIDI may be calculated for
25 time periods other than a calendar year as well, and is sometimes calculated in
26 hours, rather than in minutes.

SAIDI refers to the System Average Interruption Duration Index, and is calculated by dividing the sum of the individual customers' minutes of sustained electric service interruption by the total number of customers served. SAIDI can also be calculated by multiplying SAIFI times CAIDI. For a calendar year period, SAIDI represents the average number of minutes of electric service interruption for each customer served. SAIDI may be calculated for time periods other than a calendar year as well, and is sometimes calculated in hours, rather than in minutes.

For all of these reliability performance indices, a lower value reflects more reliable performance, while a higher value reflects less reliable performance. For example, for CAIDI, which measures the average duration of outages, a value of 100 would mean 100 minutes of outage time, while a value of 140 would mean 140 minutes of outage time – a longer period of time without electricity.

Q13. Are there any other reliability index data reported by the Company?

A13. Yes. The Company also reports Average Service Availability Index ("ASAI"). The ASAI is calculated by dividing (1) the customer-hours of service supplied despite the outages that occurred by (2) the total customer hours of service that would have been supplied if there were no outages. I feel that use of the ASAI tends to obscure meaningful evaluations of electric service reliability performance, and is also duplicative of data found in the other reliability indices.

For these reasons, my evaluation of AEP Ohio's reliability performance primarily uses other reliability indices in preference to ASAI.

B. AEP Ohio's Historical Performance

Q14. What has the Company's reliability performance been like in recent years?

A14. Table 1 below depicts reliability index data by year for the CSP and OPC distribution systems as reported in response to ESSS Rule 10.

Table 1

AEP Ohio Reliability Indices (major storms excluded)							
	CSP				Ohio Power		
	SAIFI	CAIDI	SAIDI		SAIFI	CAIDI	SAIDI
1998	1.200	120.0	138.0		1.000	198.0	198.0
1999	1.399	121.8	170.4		0.914	142.2	130.0
2000	1.572	141.6	222.6		0.918	160.2	147.1
2001	1.474	120.4	177.5		1.240	140.1	173.7
2002	1.620	122.8	198.9		1.345	167.4	225.1
2003	1.905	123.6	235.5		1.415	151.5	214.3
2004	1.861	116.8	217.4		1.451	144.4	209.5
2005	1.894	130.7	247.6		1.511	146.7	221.7
2006 ²	1.47	113.83	166.79		1.410	137.63	194.7
2006 ³	1.340	116.9	156.0		1.190	143.9	172.0
Avg. 1998- 2001	1.411	126.0	177.1		1.018	160.1	162.2
Avg. 2002- 2006 ⁴	1.750	121.5	213.24		1.426	149.53	213.1
Percent Change	24.00	-3.50	20.39		40.12	-6.62	31.38

Source: Data for 1998-2006 from the Company's response to OCC Interrogatory 10 and ESSS Rule 10 reports.

² Rule #10, 2006 Distribution System Reliability Report.

³ Projected reliability for 2006 based on the Company's original Application, updated by the responses to OCC Interrogatory 10 and Staff data Requests 1.3, and 4.1. CSP and OPC customers experienced more outage minutes than projected by AEP for 2006.

⁴ Based upon actual 2006 experience.

1 The SAIFI data in Table 1 reflects the number of electric service outages per year
2 experienced by the average customer. The CAIDI data reflects the length of the
3 average customer outage, in minutes. The SAIDI data reflects the total number of
4 minutes of electric service outages experienced by the average customer per year.
5 As can be seen above, reliability performance, prior to 2006, had declined in
6 several important respects starting around 2001 (as noted earlier, higher index
7 values mean lower electric service reliability). This decline in performance is
8 reflected by an increase in SAIFI index values (more customer outages per year)
9 and in SAIDI index values (more minutes of outages per customer per year) for
10 both CSP and OPC. As can also be seen from Table 1 in 2006 the Company's
11 electric service reliability performance, with major storms excluded, improved, in
12 some cases considerably, compared to the four previous years.

13
14 The average CSP customer saw an average of 1.75 service interruptions per year
15 from 2002 to 2006, compared to an average of 1.411 service interruptions per
16 year for the four years before that (an increase of 24.0%). The average OPC
17 customer saw an increase in average annual service interruptions to 1.426
18 interruptions per year from 1.018 interruptions per year over the same period (an
19 increase of 40.12%).

20
21 The average CSP customer saw an average of about 213.24 minutes of service
22 interruptions per year from 2002 to 2006, compared to an average of about 177.1
23 minutes of service interruptions per year for the four years before that (an increase

1 of 20.39%). The average OP customer saw an increase in the average annual
2 minutes of service interruptions to about 213.1 minutes per year from 162.2
3 minutes per year over the same period (an increase of 31.38%). The average
4 duration of each Company's electric service interruption (CAIDI) decreased
5 slightly over the same time periods.

6
7 Of course, the reliability index data in Table 1 does not really reflect the electric
8 service reliability being experienced by AEP Ohio's customers, since it excludes
9 all electric service outages that occur during major storms. Because storm
10 activity is typically not constant from one year to the next, removing storm
11 impacts from reliability data de-emphasizes the more variable reliability effects of
12 storms. However, this approach loses touch with what electric service customers
13 are actually experiencing, and, at best, can actually encourage maintenance and
14 operating practices that tend to ignore the reliability impacts suffered during
15 storms, and, at worst, can actually increase the reliability impacts suffered during
16 storms.

17 Table 2 below reflects the same reliability indices as in Table 1, only these
18 indices include electric service interruptions experienced by customers during
19 major storms.

Table 2

AEP Ohio Reliability Indices (major storms included)							
	CSP				Ohio Power		
	SAIFI	CAIDI	SAIDI		SAIFI	CAIDI	SAIDI
1998	1.264	121.2	153.2		1.066	228.0	243.1
1999	1.439	118.5	170.6		0.973	134.1	130.5
2000	1.678	132.9	223.1		1.051	141.1	148.3
2001	1.485	119.5	177.5		1.380	126.5	174.6
2002	1.779	148.7	264.5		1.643	231.3	380.1
2003	2.506	347.9	871.8		2.068	431.2	891.6
2004	2.759	652.7	1,801.0		2.126	466.0	990.7
2005	2.130	141.1	300.4		1.880	369.2	694.4
2006	1.69	141.71	239.01		1.85	310.36	574.64
Avg. 1998 – 2001	1.467	123.1	181.1		1.118	157.4	174.1
Avg. 2002 – 2006	2.17	286.41	695.34		1.91	361.62	706.29
Increase	48.16%	132.76%	283.98%		71.22%	129.70%	305.63%

Source: ESSS Rule 10 Reports.

As shown in the last three lines of Table 2, looking at the average electric service outage frequency (SAIFI) with storm outages included the average CSP customer saw an average of 2.17 service interruptions per year from 2002 to 2006, compared to an average of 1.467 service interruptions per year for the four years before that (an increase of 48%). The average OPC customer saw an increase in average annual service interruptions to 1.91 interruptions per year from 1.118 interruptions per year over the same period (an increase of 71%).

Similarly, looking at the average annual minutes of service interruptions per customer (SAIDI) with storm outages included the average CSP customer saw an

1 average of about 695 minutes of service interruptions per year from 2002 to 2006,
2 compared to an average of about 181 minutes of service interruptions per year for
3 the four years before that (an increase of 284%). The average OPC customer saw
4 an increase in the average annual minutes of service interruptions to about 706
5 minutes per year from 174 minutes per year over the same period (an increase of
6 306%). The average duration of each Company's electric service interruption
7 (CAIDI) also increased substantially over the same time periods when outages
8 occurring during major storms are included, although by less than for SAIDI.

9
10 It is also useful to note, comparing data from Table 2 to Table 1, that there is
11 relatively little difference between the average reliability indices for the period
12 1998 to 2001 regardless of whether storm-related outages are included or not. By
13 way of contrast, there are large percent increases in the number of interruptions
14 experienced and their duration during 2002-2006 when storm related outages are
15 included in the reliability indices. While the level of storm activity may have
16 varied before and after January 1, 2002, based on the increases in outage duration
17 reflected in Table 2, the ability of the Company to deal effectively with storms
18 seems to have weakened significantly over the same period.

1 **Q15. What have been the leading causes of outages on the Company's system?**

2 A15. The Company's top five outage causes in recent years are equipment failure,
3 distribution substation causes, trees in the right-of-way, trees outside the right-of-
4 way, and weather or lightning.⁵

5
6 **IV. ELECTRIC SERVICE AND SAFETY STANDARDS AND RULES**
7
8

9 **Q16. What are Ohio's requirements regarding providing reliable electric**
10 **distribution service?**

11 A16. The requirements regarding providing reliable service are found in Ohio
12 Administrative Code Chapter 4901:1-10, titled Electric Service and Safety
13 Standards ("ESSS"). These rules, as a whole, "...are intended to promote safe
14 and reliable service to consumers and the public, and to provide minimum
15 standards for uniform and reasonable practices."⁶ Thus, the ESSS Rules address
16 electric service issues that involve reliability and/or safety.

17
18 Some of the sub-parts of the ESSS Rules specifically impact electric service
19 reliability. For example, 4901:1-10-02 Purpose and scope ("ESSS Rule 02"),
20 states that the Rules apply to investor-owned electric distribution utilities
21 ("EDUs") and transmission owners with the intent described above. This Rule
22 goes on to give the Commission the power to waive or to go beyond the
23 requirements of the Rules, and states that the Rules do not relieve the EDUs or the

⁵ The Plan at 20-21.

⁶ 4901:1-10-02(A)(2) Purpose and scope.

1 transmission owners from the responsibility to provide adequate service and
2 facilities, as prescribed by the Commission. Thus, the Commission can
3 specifically address the level of service reliability that is being provided to rural
4 portions of the system, if such level of reliability can be shown to be inadequate.

5
6 **Q17. Are there any other standards by which to judge electric service reliability?**

7 A17. Yes. I believe that electric utilities have a responsibility to avoid declining
8 electric service reliability performance even in the absence of regulatory
9 requirements, rules or statutes. Even if all requirements deriving from the ESSS
10 Rules are met, ongoing declines in electric service reliability that are within the
11 Company's control should be considered a breach of this general standard, unless
12 such changes are approved by the Commission.

13
14 *A. Data Retention Period*

15
16
17 **Q18. Please discuss the data retention period that is provided for in the ESSS**
18 **Rules.**

19 A18. 4901:1-10-03 Retention of records ("ESSS Rule 03") requires that, unless
20 otherwise specified, records sufficient to demonstrate compliance with the Rules
21 shall be maintained for three years. However, in areas regarding distribution
22 system planning, maintenance and operation, retention of data for only three years
23 is really too short a period to be sufficient for reliability purposes. There are a
24 number of reasons for this. One reason that three years is too short is because
25 changes in the facilities installed on a distribution circuit, and/or changes in

1 maintenance being applied to a distribution circuit typically take some time to
2 implement and more time before they are reflected in the reliability performance
3 of the circuit to which they apply. For example, in order to determine if a
4 distribution circuit is having reliability performance problems, typically at least
5 one year of reliability performance data is needed. (Presumably, the reliability of
6 a distribution circuit could be so poor as to be identifiable from less than one year
7 of operation, but, for system-wide application, at least a year of performance data
8 is preferable.)

9
10 Next, once a distribution circuit is determined to be a candidate for reliability
11 improvement, the repair and/or replacement of poles, crossarms, and/or
12 conductors, the application of directed tree trimming, and the implementation of
13 other improvements will take some time to be completed. These types of actions
14 could take part of a year, or longer, to be implemented. Finally, once
15 implemented, it will take some time for the reliability performance of the circuit
16 in question to reflect these improvements, typically at least one year of operation
17 after the completion of improvements.

18
19 Without more than three years of information, we begin to lose our ability to
20 correlate the level of maintenance and design that lead to poor reliability
21 performance, and, therefore, to contrast it with what was done to improve
22 reliability performance.

1 Another reason that three years is too short a data retention period is that design
2 or policy changes take time to actually be applied to enough of the system to have
3 an impact on system performance. Let's say, for example, that AEP Ohio decided
4 to change its distribution circuit tree-trimming policy from once every 4 to 6 years
5 to once every 3 to 5 years. When such a policy change is decided upon, it will
6 typically take time for this policy change to actually be reflected in the trimming
7 of all distribution circuits. If a distribution circuit that would have been trimmed
8 every six years under the old policy is trimmed the year the policy change goes
9 into effect, then it could take three to five years for the new policy to actually be
10 reflected. Then, another year would be needed after that, at a minimum, to get
11 one full year of reliability performance data reflecting full implementation of the
12 policy change.

13
14 A third reason that more than three years of data is needed is that some kinds of
15 distribution system maintenance and/or inspections can be reduced or
16 discontinued with little or no immediate impact on system reliability, but, that,
17 over time, such reductions or discontinuances can have significant reliability
18 impacts. For example, if distribution tree-trimming were to be sharply curtailed,
19 it could be more than a year before such curtailments were reflected in significant
20 numbers of distribution circuits and the vegetation of these circuits had grown
21 enough to affect reliability. Then, another year would be needed after that, at a
22 minimum, to get one full year of reliability performance data reflecting full
23 implementation of the reduction/discontinuance.

1 **Q19. What minimum data retention period do you recommend?**

2 A19. A minimum data retention period of five years is needed in order to have a
3 reasonable chance of correlating the level of distribution system electric service
4 reliability that results from specific planning, maintenance, or operating policies.

5
6 *B. Distribution System Reliability*
7
8

9 **Q20. What other ESSS rules address electric system reliability?**

10 A20. 4901:1-10-10 Distribution System Reliability (“ESSS Rule 10”) addresses what
11 electric service reliability index data should be used in measuring electric service
12 reliability performance of EDU distribution systems. The reliability indices
13 discussed previously reflect Rule 10. Rule 10 also addresses what electric service
14 reliability performance data should be excluded from the calculation of reliability
15 indices, and how targets for reliability index performance are set.

16
17 **Q21. Are there any other aspects of ESSS Rule 10 that you wish to address**
18 **regarding electric service reliability performance?**

19 A21. Yes. Rule 10(B)(3) provides that outage data for service interruptions that occur
20 during major storms⁷, and outage data for service interruptions caused by outages
21 of transmission facilities should not be included in the calculation of reliability
22 performance indices or used in the determination of index performance targets.

⁷ Major Storms are storms in which the restoration of electric service takes more than 24 hours and in which assistance from another district is required. See AEP Ohio response to OCC Interrogatory 21. (Exhibit PJL-3).

1 While there are justifications for using outage data that has been stripped of
2 customer outages that occur during especially bad weather⁸ (or for using outages
3 data stripped of customer outages resulting from transmission system events⁹),
4 there is a good reason for also calculating a set of reliability indices with customer
5 outages that include major storms.

6
7 Including major storm service interruptions in the calculation of one set of
8 reliability indices reflects what the customer is actually seeing in the way of
9 distribution service reliability. If a purpose of looking at reliability index
10 calculations is to promote the provision of reliable electric service to customers,
11 then reliability index calculations that include major storm-related outages that
12 customers are experiencing should be available. The removal of major storm-
13 related customer outages from all reliability indices can obscure changes in the
14 distribution system's ability to provide reliable service during bad weather. If
15 major storm-related customer outages carry lesser weight in evaluating
16 distribution system reliability performance than outages that are not storm-related,
17 then EDUs will have less incentive to design and/or maintain their distribution
18 systems so as to maintain or to increase their ability to withstand storm-related
19 events. As system components age, they become more susceptible to failure

⁸ Because the effects of bad weather on distribution system reliability typically vary from year to year, removing the customer outages resulting from bad weather from the calculation of the reliability indices attempts to make year-to-year reliability indices more reflective of the reliability inherent in the system and less reflective of variations in weather.

⁹ Removal of customer outages resulting from transmission system interruptions from the calculation of reliability indices results in reliability indices that focus on distribution system performance. Since most customer outages typically result from distribution system events, this focus is useful.

1 during high stress events, such as during storms. Recent AEP Ohio policies to
2 withhold tree-trimming from distribution circuits until they show negative
3 reliability impacts due to tree contact can be expected to increase storm-related
4 customer outages due to lack of tree-trimming, as the effects of wind and ice on
5 reliability are increased by the lack of tree-trimming.

6
7 For these reasons, it is reasonable and appropriate for the Commission to require
8 AEP Ohio to calculate a set of reliability index data (SAIFI, CAIDI, SAIDI) for
9 each of its companies reflecting all distribution-related outages without
10 exclusions.

11
12 *C. Customer Interruption Data*
13
14

15 **Q22. Has AEP Ohio made changes in its handling of customer interruption data**
16 **that resulted in impacts on the reliability indexes it calculates?**

17 A22. Yes. AEP Ohio claims that improvements it has made to its handling of customer
18 interruption data have increased the accuracy of this data, and, as a result, the
19 reliability indexes it calculates from this interruption data have been increased
20 compared to what they would have been. However, as my testimony shows,
21 increases in AEP Ohio's reliability index data indicate less reliable service.

22
23 In 1995, the Company started installing an automated distribution service outage
24 reporting system in which electric service outages, the number of customers

1 affected, the length of the outage, and other data are recorded electronically.¹⁰

2 The initial installation process lasted until 2001, with upgrades continuing until
3 August, 2003.¹¹

4
5 Utilities which install automated distribution service outage reporting systems
6 frequently claim to experience increases in the numbers of outages recorded,
7 increases in the number of customers experiencing, and/or increases in the
8 customer-minutes of service interruption.¹² However, these claims are based on
9 comparing outage data recorded by the old system for the period of time prior to
10 the implementation of the automated system with the outage data recorded by the
11 automated system after it is implemented. The problem with this type of
12 comparison is that any change in the reported system reliability performance
13 between these two separate time periods is typically attributed to the
14 implementation of the automated system, and not to the significant possibility that
15 the actual reliability performance may have changed from one time period to the
16 next.

17
18 Without conducting parallel run studies which look at the data produced by the
19 automated system over a certain period of time and compare it with data produced
20 by the manual data collection system operating over the same period of time, it is

¹⁰ Prior to this, outage data was manually recorded or manually entered into a recording system.

¹¹ See AEP Ohio response to OCC Interrogatory 253 (Exhibit PJL-4).

¹² See AEP Ohio response to OCC Request for Production 85 (Exhibit PJL-5).

1 not possible to say for certain just what impact the implementation of an
2 automated outage reporting system has had for a particular utility.

3
4 AEP Ohio implemented its automated system without any apparent attempt to
5 measure the impact of the change from a manual system to an automated system
6 on a common set of outage data by conducting parallel runs of both the new
7 automated system and the manual system that preceded it.¹³ Therefore, it is
8 impossible to know from the information available whether the implementation of
9 AEP Ohio's automated distribution service outage recording system has resulted
10 in increased reliability indices, or whether distribution system reliability has
11 actually gotten worse. All we know for sure is that, from 2002 through 2005,
12 AEP Ohio's outage frequency, as reflected in its SAIFI index, increased
13 significantly (See Table 1 above).

14
15 Considering that one primary use of reliability indices is to allow comparison of
16 current reliability performance with historical reliability performance, AEP
17 Ohio's actions undermine one of the basic purposes of the ESSS Rules.

¹³ Ibid.

V. TARGETS FOR RELIABILITY INDICES

Q23. How are the reliability indices calculated by AEP Ohio used to evaluate electric service reliability on its system?

A23. They are used in several ways. One of these, as addressed in ESSS Rule 10, is to compare the EDU's system reliability indices for a period of time, typically one year, against performance targets. Rule 10 specifies that these performance targets should reflect historical performance, along with other factors. Table 3 below depicts reliability target data for the Company.

Table 3

	CSP Targets			Ohio Power Targets		
	SAIFI	CAIDI	SAIDI	SAIFI	CAIDI	SAIDI
1998	1.000	144.0	138.0	1.000	168.0	150.0
1999	1.000	144.0	138.0	1.000	168.0	150.0
2000	1.291	161.2	163.5	1.019	215.6	218.6
2001	1.291	161.2	163.5	1.019	215.6	218.6
2002	1.291	161.2	163.5	1.019	215.6	218.6
2003	1.291	161.2	163.5	1.019	215.6	218.6
2004	1.291	161.2	163.5	1.019	215.6	218.6
2005	1.291	161.2	163.5	1.019	215.6	218.6
2006	1.29	161.2	163.5	1.02	215.6	218.6
Proposed ¹⁴	1.859	143.0	265.8	1.397	169.0	236.0

SOURCE: ESSS Rule 10 Reports

¹⁴ Proposed by the Company in 2002, per its ESSS Rule 10 Report (Exhibit PJL-6).

1 AEP Ohio set performance targets in 1998, to be effective in 1999 that reflected
2 average interruption data for the five year period 1993 to 1997. Storm outage
3 data was included in these targets.¹⁵

4
5 AEP set new performance targets in 1999. These targets exclude storm outage
6 data.¹⁶ Normally, excluding storm outage data from the calculation of these
7 reliability indices would result in a reduction of the indices reflecting the
8 frequency of interruptions (SAIFI) as well as the indices depicting the average
9 annual minutes of interruption per customer. However, in this instance,
10 eliminating storm outage data was accompanied by an increase in CSP's target
11 outage frequency (SAIFI), from 1.0 outages per year to 1.291 outages per year, an
12 increase in CSP's target average outage duration (CAIDI) from 144 minutes per
13 outage to 161 minutes, and an increase in CSP's target average annual minutes of
14 interruption per customer (SAIDI) from 138 minutes per year to about 163
15 minutes per year. Similarly, eliminating storm data was accompanied by
16 increases in OPC's target outage frequency from 1.000 outages per year to 1.019
17 outages per year, an increase in OPC's target average outage duration from 168
18 minutes per outage to 216 minutes, and an increase in OPC's target average
19 annual minutes of interruption per customer from 150 minutes per year to 219
20 minutes per year.

¹⁵ Distribution System Performance Data reflecting 1997 performance, ESSS Rule 10 Report (Exhibit PJI-7).

¹⁶ Distribution System Performance Data for 1999, ESSS Rule 10 Report (Exhibit PJI-8).

1 These new targets reflected an apparent substantial decrease in target electric
2 service reliability. As stated above, the Company has taken the position that its
3 automated system for the collection of outage data is resulting in increased
4 reliability indices due to the improved accuracy of this system. However, there is
5 no data from any parallel runs studies between the automated system and the
6 manual system that preceded it to support this contention.

7
8 AEP Ohio requested another change in their system performance targets on
9 December 30, 2002, but subsequently agreed, as part of the Stipulation in 03-
10 2570, to withdraw this request, apparently with the understanding that new targets
11 could be submitted to the Commission staff when reliability mitigation impacts
12 have been determined. These requested changes, depicted on the last line of
13 Table 3, reflect substantial increases in outage frequency, reflected in the SAIFI
14 index, and varying increases in average annual minutes of outage per customer,
15 reflected in the SAIDI index, while reducing the target for average outage
16 duration (CAIDI). Because of the Company's lack of parallel analyses between
17 its automated data collection system and the manual system that preceded it, there
18 is no way to know if the proposed increases in allowable SAIFI and SAIDI reflect
19 the effects of the automated outage reporting system or if they reflect declining
20 system reliability. Based on 2006 reliability performance, the Company appears
21 to have met most of the targets with the exception of the CSP SAIFI and SAIDI
22 and the OPC SAIFI.

1 **VI. THE PLAN: BASE RELIABILITY PROGRAMS**

2
3
4 **Q24. How do the Plan proposals regarding distribution system maintenance fit in**
5 **with the ESSS rules?**

6 A24. The Plan proposals provide primarily for changes in system maintenance practices
7 that are traditionally addressed by Rule 27.

8
9 **Q25. Please describe the current distribution-related practices that are addressed**
10 **in the Plan.**

11 A25. The Plan first reviews selected parts of what the Company calls its base
12 distribution reliability programs. These programs are currently in effect and
13 include the distribution pole inspection program, overhead circuit inspection
14 programs, pad-mounted transformer programs, line recloser programs, line
15 capacitor programs, the distribution vegetation management program, the
16 distribution substation reliability programs, and others.

17
18 *A. Pole Inspection Program*

19
20 **Q26. Please address the distribution pole inspection program.**

21 A26. AEP Ohio conducts pole ground-line inspections and treatment on a ten-year
22 cycle for poles older than 20 years old. In recent years, the Company has
23 increased the time to the initial inspection from 16 years to the present 20 years¹⁷,
24 despite the increasingly prominent role that equipment failures have played in

¹⁷ See AEP Ohio response to OCC Request for Production of Documents 74 (Exhibit PJJ-9). AEP Ohio response to OCC Request for Production of Documents 74-2002.pdf (Exhibit PJJ-10), AEP Ohio response to OCC Request for Production of Documents 74-2004.doc (Exhibit PJJ-11), and the Plan at 7.

1 interrupting electric service to customers. A ten-year cycle for electric
2 distribution wood pole inspections is common practice in the electric utility
3 industry, in my experience.

4
5 *B. Overhead Circuit Inspection Program*

6
7 **Q27. Please address the overhead circuit inspection program.**

8 A27. AEP Ohio conducts overhead distribution circuit inspections on a five-year cycle.
9 This cycle is mandated by ESSS Rule 27. A five year cycle for such inspections
10 is common, in my experience.

11
12 I note that for the past five years, the number of miles of circuit inspections has
13 varied from less than 6,000 miles in 2002 to more than 13,000 miles in 2004, and
14 back down to something less than 8,000 miles in 2006.¹⁸ Wide swings in
15 inspection workload from one year to the next typically raise concerns about the
16 consistency of the quality of these inspections. It is questionable whether the
17 existing workforce is adequate to perform more than double the amount of a
18 particular type of work, without using less qualified or less experienced
19 personnel, or without neglecting other tasks. If additional personnel are required,
20 they must have the necessary qualifications and experience. When work levels
21 yo-yo up and down, retention of these qualified and experienced people becomes
22 a concern. In addition, when the Company is inspecting more than 13,000 miles
23 of circuit in one year, it becomes comparatively more difficult to address the

¹⁸ Plan Chart 2 (at 9).

1 problems turned up by these inspections in a timely manner. These are all
2 concerns that do not arise when inspections and maintenance are performed in a
3 consistent manner.

4
5 In addition, a more levelized inspection program also helps avoid customer outage
6 minutes that can occur if circuits that should have been inspected and repaired at
7 five years are part of a catch-up in some subsequent year. Also, the amount of
8 catch up, if any, that occurred between 2002 and 2006 may have been more
9 obvious had the Company provided circuit inspection data for a longer historical
10 period.

11
12 The Company also includes overhead distribution circuit inspections as an
13 incremental reliability program. This is addressed in the section of my testimony
14 that discusses the Company's proposed incremental reliability programs.

15
16 *C. Vegetation Management Program*

17
18 **Q28. Please address the distribution vegetation management program.**

19 A28. Vegetation management is one of the more problematic areas of the Company's
20 distribution maintenance programs. In the early 2000s, the Company's filed
21 distribution system vegetation management policy reflected total circuit trimming
22 on a four-to-six year cycle, with additional off-cycle clearing to deal with problem
23 areas prior to the next total trim. The 2003 Staff Report found¹⁹ that the Company

¹⁹ 2003 Staff Report at 8.

1 was using hot-spot trimming (isolated trimming in response to tree-caused
2 outages) and postponing tree trimming on a circuit until reliability performance
3 on that circuit deteriorates to the worst 15% of circuits due to tree-related service
4 interruptions, and that these policies were being substituted for the four-to-six
5 year cycle for the complete trimming of each circuit.²⁰ Staff believed that use of
6 these policies without having been reported under ESSS Rule 27 were
7 unauthorized and in violation of ESSS Rule 27 (E)(2)(c). Based on the
8 information available, I can only affirm this Staff conclusion.

9
10 In the Plan, the current vegetation management program is described as
11 “performance-based” which prioritizes work on distribution facilities based on a
12 number of variables, including the elapsed time since the last vegetation
13 management activities were performed on the facility, inspection results, tree-
14 related reliability performance, and other factors.²¹ Despite vigorous attempts via
15 discovery, I have little basis on which to evaluate how this prioritization process
16 works or what weight is given to these various factors.

17
18 I note that the annual miles of vegetation management activity over the past three
19 years, as reflected in Chart 8 of the Plan, varies from something over 7,000 miles
20 in 2004 to around 3,500 miles in 2006. Wide swings in vegetation management

²⁰ When OCC requested copies of the discovery material that had been provided to Staff and that was referenced by Staff in reaching these conclusions, the Company was unable to provide them, (Exhibit PJL-12).

²¹ Plan at 15.

workload from one year to the next typically raise concerns about the consistency of the quality of these activities for the same reasons raised in the previous discussion concerning overhead inspections.

There have also been wide swings in the Company's annual spending on vegetation management, shown in Table 4, below.²²

Table 4

AEP- Ohio	2002	2003	2004	2005
	\$20,226,371	\$24,999,544	\$40,278,595	\$51,289,697

The Company's spending on vegetation management more than doubled in 2004 and 2005, compared to the two previous years.

Q29. Please address the relationship between vegetation management and momentary outages.

A29. Vegetation management is usually a significant factor as a cause of momentary service interruptions, which last five minutes or less. These interruptions can cause loss of data in computers and can result in the need to reset many types of modern appliances and electronics. Commission staff mentions this in the 2003 Staff Report²³ and explains how circuit breakers and reclosers on overhead distribution circuits are designed to operate, i.e., open, when a fault is detected, and then to close after a few seconds, to see if the fault has cleared. If the fault is

²² Exhibit PJL-13.

²³ 2003 Staff Report at 10.

1 gone, the breaker or recloser stays closed, and customers downstream from that
2 device have experienced a momentary outage. If the fault is still there, the device
3 opens again and typically locks out in the open position until the circuit can be
4 checked for faults.²⁴ Falling tree branches and tree limbs swaying in the breeze
5 can cause faults that disappear after a second or two. When a customer, or a
6 distribution circuit, experiences high numbers of momentary outages, trees are
7 one of the most likely causes. Of course, since the Company does not report
8 numbers of momentary interruptions, a customer would most likely have to
9 complain before the Company became aware of the problem.

10
11 **Q30. Is the use of “performance-based” vegetation management typical among**
12 **electric utilities?**

13 A30. The use of “performance-based” direction of at least some vegetation
14 management activities is on the increase among electric utilities. It may take the
15 form of something as simple as annual listings of a utility’s worst performing
16 distribution circuits, with these circuits targeted for remedial action that
17 frequently includes tree trimming. However, many utilities still have an overall
18 trimming cycle based on a comprehensive trimming, or other application of
19 vegetation management techniques, every so many years. There is considerable
20 variability in the lengths of these cycles. My experience in other states indicates
21 that some utilities are currently switching to a three-year vegetation management

²⁴ Some circuit breakers or reclosers may be set to operate several times in this fashion before locking out.

1 cycle for distribution facilities, while others use a four-year, or longer, cycle.
2 Some use mid-cycle hot-spot trimming.
3 However, the use of a vegetation management policy that rations tree trimming
4 and other vegetation management activities only to those distribution circuits that
5 exhibit especially poor electric service reliability due to tree-related faults
6 probably comes at a cost to overall system reliability. Minimizing tree trimming
7 in this way leaves a lot of vegetation in close proximity to circuits, which also
8 tends to increase the tree-related problems that occur during storms. The
9 Company's recent reliability index performance during storms certainly suggests
10 that increased storm response and service restoration capabilities may be needed
11 as part of its performance-based program of vegetation management.
12 Vegetation management is also targeted in the incremental distribution reliability
13 plan, and is further discussed in that section of my testimony.

14
15 *D. Distribution Reliability Programs*

16
17 **Q31. Please address the distribution substation reliability programs.**

18 **A31.** The Company's current distribution substation reliability programs include
19 monthly inspections and for the maintenance of substation equipment, including
20 circuit breakers and transformers. The Company's filed practices in these areas
21 appear generally consistent with reliable operating practice, with one noteworthy
22 exception: replacement of old and obsolete equipment, both inside the substation
23 and out on the distribution circuits, is usually a part of normal utility practice and
24 is not an incremental activity. Electric system equipment is constantly aging and

1 utilities have always been faced with the need to replace such equipment as it
2 reaches the end of its useful life. This not a new activity or a new requirement of
3 maintaining an electric distribution system.

4
5 **VII. THE PLAN: INCREMENTAL RELIABILITY PROGRAMS**
6

7
8 **Q32. Please describe and address the incremental distribution reliability plan**
9 **described in the Plan.**

10 A32. The Plan describes what it calls its incremental distribution reliability plan, which
11 is touted as the means by which the Company can reach the next level of
12 reliability, by focusing on initiatives to address the Company's aging
13 infrastructure and customers' demand for increased quality of service. The
14 incremental distribution reliability plan expands on the Company's base
15 distribution reliability programs, adds incremental reliability programs, and
16 provides for increased funding by ratepayers for the Company's reliability-related
17 programs. The incremental distribution reliability programs proposed by the
18 Company are addressed below.

19
20 *A. Vegetation Management*

21
22 **Q33. Please address vegetation management as addressed in the incremental**
23 **distribution reliability plan.**

24 A33. Regarding vegetation management, AEP Ohio plans to balance its current
25 performance-based approach to reflect a greater consideration of cycle-based
26 factors. The Company commits to inspecting or maintaining all of its distribution

1 rights-of-way at least once during a four year period. During the initial four year
2 period of the incremental plan, the Company would totally clear out vegetation
3 and would employ the use of improved technology to collect, store, predict and
4 analyze specific vegetation data. During this period, the Company would
5 inventory tree species' growth rates to create detailed work plans for each circuit
6 to annually predict and schedule maintenance cycles as needed. Other factors that
7 would be considered are the location of vegetation in proximity to the conductors,
8 accessibility, density, and vegetation coverage. AEP Ohio proposes what it calls
9 significant increases in its vegetation management funding, which over a 12-
10 month period would double the current number of tree crews available to perform
11 end-to-end clearing on all of its distribution lines. Once the distribution system
12 has been totally cleared and inventoried, the Company expects the number of tree
13 crews to decrease.²⁵

14
15 The need to employ a four-year crash program in vegetation management is to
16 some degree an admission that the Company's Commission-unapproved
17 performance-based program of vegetation management has allowed the
18 vegetation situation on the distribution system to get out of control in recent years.
19 The deteriorating reliability index performance of the distribution system in
20 stormy weather supports this.

21
22 In addition, if the Company needs to double the current vegetation management
23 capability in order to fully inspect and/or trim each of its distribution feeders once

²⁵ Plan at 22-23.

1 over the next four years, this certainly suggests that current capabilities have been
2 allowed to atrophy to a level far short of what is needed to maintain system
3 reliability.

4
5 There are several apparent inconsistencies regarding the Company's vegetation
6 management proposal. The incremental vegetation management plan is described
7 as a significant increase in spending, yet it's annual costs (capital and O&M
8 combined) range from about \$23 million per year to about \$30 million per year
9 for five years.²⁶ However, in 2004 and 2005 the Company spent a combined \$90
10 million on vegetation management (see Table 4 above). The results were that the
11 contribution to SAIDI from trees has decreased by half since 2002 for trees in the
12 right-of-way and has decreased by about one-third since 2004 for trees outside the
13 right-of-way.²⁷ The need to double the number of crews so soon after the heavy
14 spending on vegetation management in 2004 and 2005 is an indication of the
15 extent to which the Company had allowed the situation to deteriorate.

16
17 I note also that the Company seems uncertain as to what kind of clearances above,
18 below and around electric distribution conductors it plans to achieve with its
19 vegetation management program. When asked this question (OCC-IR258), the

²⁶ Plan Chart 10 at 23.

²⁷ Plan Chart 9.

1 Company said only that its horizontal and vertical tree trimming clearances were
2 under review.²⁸

3
4 **1. Trees Outside The Right-Of-Way**

5 **Q34. Please discuss how the Company proposes to address the reliability problems**
6 **caused by trees located outside the distribution right-of-way.**

7 A34. The Company's vegetation management proposal does not appear to address the
8 interruption caused by trees located outside the distribution right-of-way. Such
9 trees represent a special problem, as a utility's right to trim trees located outside
10 the right-of-way is usually limited and frequently requires permission from
11 property owners.²⁹ Additionally, outages caused by such trees are listed by the
12 Company as one of the five leading causes of customer interruptions, as noted
13 earlier in my testimony.

14
15 Programs to try to deal with the most threatening trees located outside the right-
16 of-way are an increasingly common part of vegetation management plans. Such
17 programs typically take note of trees near the right-of-way whose limbs and trunk
18 could pose a danger to the distribution circuit if they were broken and fell to the
19 ground. If these pose an imminent threat to the line, such as if they are dead, or if
20 they overhang the line, they are typically removed for safety considerations.
21 Otherwise, permission to remove the tree from property owners is sometimes

²⁸ AEP Ohio response to OCC Interrogatory 258 (Exhibit PJL-14).

²⁹ The trimming of limbs that extend into the right-of-way are typically not restricted in this way.

1 required and is actively pursued. The Company's vegetation management plan
2 should include provisions to address these problem trees.

3
4 *B. Overhead Line Inspections*

5
6 **Q35. Please address overhead line inspections as included in the incremental
7 distribution reliability plan.**

8 A35. The Company proposes to maintain overhead line inspections on the current five-
9 year cycle, but to increase the comprehensiveness and attention to detail in the
10 inspections. The Company suggests that current overhead distribution line
11 inspections are more of a drive-by nature.³⁰ Under the incremental plan, circuits
12 would be walked, or perhaps inspected more closely by climbing structures or by
13 using a bucket truck to inspect hardware and equipment. Infrared scanning or
14 radio frequency detection devices would also be used.

15
16 It is not at all clear that there are significant differences between what the
17 Company proposes and what the Company is supposed to be doing currently,
18 regarding the five year overhead circuit inspections. It is not clear that personnel
19 currently performing these inspections perform them while driving down the road.
20 (In his deposition, AEP Ohio employee Karlen Cooper stated that these
21 inspections have always been performed by walking the circuit.³¹) If performed
22 from a parked vehicle, it is not clear that such inspections are inferior to

³⁰ Plan at 24.

³¹ Deposition of Karlen Cooper in Case No. 06-222-EL-SLF, January 9, 2007, p. 17, lines 15-22 (Exhibit PJL-15).

1 performing an inspection while standing up, as long as the circuit is in close
2 proximity. For circuits that do not follow roads, there is no way to perform such
3 inspections at present, short of walking the circuit, or, perhaps flying it. And
4 under current practice, if an inspection shows problems on an overhead circuit,
5 repairs are called for under the ESSS Rule 27 procedures AEP Ohio has filed.

6
7 The Company lists categories of repair and replacement work that might result
8 from these inspections. None of these categories or repair or replacement reflect
9 anything that utilities don't already do in response to inspections of overhead
10 distribution facilities. The Company plans to replace hardware and equipment
11 that are either prone to failure or that have the potential to fail within the next five
12 years. This suggests that, under the current program, hardware and equipment
13 that are known to be failure prone or that have the potential to fail within the next
14 five years are knowingly left in service, presumably until they fail.

15
16 *C. Overhead Mitigation Programs*

17
18 **Q36. Please address the overhead mitigation programs that are included as part of**
19 **the incremental reliability plan.**

20 **A36.** The Company is proposing overhead mitigation programs, including an
21 accelerated equipment and hardware replacement program, an incremental
22 recloser protection program, an incremental 34.5 kV protection program, and an
23 incremental fault indicator program.

1 The accelerated equipment and hardware replacement program addresses
2 reliability issues involving fused cutouts and lightning arrestor failures. The
3 Company reports experiencing premature failures on both these equipment types.
4 As the Plan indicates, premature failures of cutouts and arrestors is an industry-
5 wide problem.³² Addressing both of these equipment problems will help address
6 two of the more significant drivers of customer outages on the Company's
7 distribution system, i.e., line equipment failures and lightning.

8
9 The incremental recloser program deals with the replacement of 3-phase reclosers
10 with multiple single-phase reclosers. Three phase reclosers interrupt all three
11 phases of a distribution circuit, even if only one of the phases is experiencing an
12 electrical fault. Using single phase reclosers limits interruptions to the phase or
13 phases actually experiencing a fault, thereby reducing customer service
14 interruptions.

15
16 The incremental 34.5 kV protection program includes installing additional
17 sectionalizing devices on these circuits, installing lightning arrestors on these
18 circuits, and/or adding reactors to these circuits. Additional sectionalizing
19 devices, such as reclosers, will tend to limit the impact of faults so that only a
20 portion of a circuit will be impacted by faults in certain locations of the circuit.
21 Lightning arrestors work to limit the effects of lightning strikes on the circuit.
22 Reactors work to limit fault current on these circuits so as to lessen the stress on
23 devices (i.e., breakers, reclosers, fuses) that are responsible for interrupting such

³² Plan at 29.

1 fault currents when they occur, and to improve coordination among various
2 protection devices installed on each such circuit. These actions reflect normal
3 engineering practices for the management of distribution circuits. AEP Ohio has
4 not demonstrated how its incremental program goes beyond what it should be
5 doing on a normal basis.

6
7 The incremental fault indicator program provides a means for more quickly
8 locating where temporary or permanent faults are occurring. This capability is
9 especially useful on distribution circuits that include a mix of overhead and
10 underground facilities, as the locations of underground faults can be difficult to
11 locate. However, such devices can speed restoration, thus reducing restoration
12 costs and revenue loss, even on circuits that are predominantly overhead as well.
13 It is not clear why these devices are not being installed under current programs.

14
15 *D. Underground Mitigation Programs*

16
17 **Q37. Please address the proposed incremental underground mitigation programs.**

18 A37. These proposed programs deal with what the Company calls "proactive"
19 replacement (or, some cases, the rejuvenation) of power cables and of
20 underground residential distribution ("URD") cables. Power cables are used
21 inside substations and for the underground portion of distribution circuits used in
22 many substations to exit the immediate vicinity. URD is used primarily in
23 residential subdivisions. Both types have useful service lives that are typically a
24 bit shorter than those of overhead facilities. The proposed incremental program

1 will provide for replacement of power cables on the basis of cable condition and
2 operational history and for the rejuvenation or replacement of URD cable on the
3 same basis. Since the decision to replace or treat cables is made largely after
4 cables experience deterioration-related service interruptions, it is, perhaps,
5 questionable just how proactive this approach can be considered.

6
7 Programs such as these are becoming increasingly common with utilities, but
8 should be part of normal utility system maintenance. The replacement of
9 facilities due to deterioration from age or use is not a special condition but is a
10 part of maintaining and operating an electric utility system in prudent fashion.
11 The dollars spent on current facilities are recovered by a utility through the
12 depreciation component of rates and are available to contribute to the cost of
13 replacement facilities.

14
15 *E. Substation Programs*

16
17 **Q38. Please address the Company's proposed incremental distribution substation**
18 **programs.**

19 A38. The proposed incremental distribution substation program addresses installing
20 protection against animal contacts with energized equipment inside substations,
21 and replacing old, obsolete, and/or unserviceable circuit breakers and protective
22 relays. Both of these programs should help address outages caused by faults
23 inside substations, one of the Company's leading causes of service interruptions.
24 However, it is not clear just how incremental the breaker and relay program are.

1 The replacement of old facilities is not a newly occurring requirement of
2 operating a distribution system.

3
4 *F. Automation and SCADA Programs*

5
6 **Q39. Please address the Company's proposed automation and SCADA programs.**

7 A39. The Company's incremental plan includes the installation of distribution
8 automation ("DA") switched at selected locations, as well as the installation of
9 SCADA at some 160 substations that currently lack such capability. Distribution
10 automation³³ and basic substation SCADA both involve the use remote sensing
11 and remote control of various elements of the electric system.

12
13 Substation SCADA typically involves the ability to remotely control substation
14 switches that energize or de-energize substation transformers, switches that
15 control the flow of power within the substation, and breakers that control the flow
16 of power out on distribution circuits, as well as the ability to remotely sense the
17 status of major substation components. When there is a fault on a distribution
18 circuit that results in the tripping of the substation breaker for that circuit, system
19 operators would know almost immediately via SCADA that this trip had occurred,
20 if the substation is SCADA equipped. Otherwise, operators would have to wait
21 for customers served from that circuit to call the Company to report a loss of
22 electricity before they know that the outage is occurring. The presence of

³³ True distribution automation typically goes beyond the use of sectionalizers or reclosers on distribution circuits.

1 SCADA shortens outage restoration time for customers. Typically, virtually all
2 new substations are designed and built with SCADA capability.

3
4 The Company, however, currently has several hundred substations without
5 SCADA capability. Since all customers pay for the SCADA capability that is
6 installed, it is unequitable for so many substations to be without SCADA. These
7 customers should be provided the benefits of substation SCADA before being
8 asked to pay for others to receive the benefits from distribution automation.

9
10 Distribution automation provides remote sensing and remote control capabilities
11 such that outages of distribution circuits can remotely and/or automatically be
12 shortened by isolating faulted portions and the unfaulted portions of a distribution
13 circuit and connecting the unfaulted portions of the circuit back to the system,
14 thereby restoring service. DA normally will normally be installed only on circuits
15 that have substation SCADA capability and then, only on those circuits whose
16 configuration and load levels provide a significant enough benefit from DA to
17 justify the additional expense of providing DA. The successful implementation of
18 DA has the potential to provide a premium level of service reliability, but not
19 necessarily to all customers. It seems premature to start installing such capability
20 on a system where so many customers are still without SCADA capability. The
21 Company should focus first on the installation of SCADA capability.

1 *G. Summary*

2
3 **Q40. Please summarize AEP Ohio's proposed incremental reliability programs**
4 **and your associated recommendations.**

5 A40. The Self Complaint states that AEP Ohio would present a process that would
6 describe program details, including service reliability impacts and associated
7 costs. The Plan does not provide the information the Company proposed to
8 provide in the Self Complaint. It is especially weak regarding service reliability
9 impacts, and is short of program details in a number of areas, especially where the
10 vegetation management program is concerned.

11
12 According to page 48 of the Plan, AEP Ohio admits it is not really committing to
13 the Plan because a number of factors might affect the implementation of the Plan,
14 such as labor availability, material resource constraints, and reliability challenges
15 not yet identified. Even if I agreed with all aspects of the Plan as described, this
16 may not be what is actually implemented.

17
18 The Plan provides for little in the way of reporting what is being done, what it is
19 costing, and what reliability benefits are being realized, apart from the provision
20 that, as work is completed, the Company will meet with Staff to review the actual
21 work performed, the dollars spent, and the direct benefit. There needs to be
22 established a reporting protocol that provides for regular Plan reports, which need
23 to be available to parties other than just Staff, as well as an opportunity for others

to formally comment on Plan management, modifications, spending, progress, and benefits.

VIII. SUMMARY

Q41. Please summarize your testimony and recommendations.

A41. My conclusions and recommendations are as follows:

1. System reliability performance (with major storms excluded), as reflected in AEP Ohio's reliability indices, has become less reliable, particularly in the area of outage frequency (SAIFI) and average outage minutes per year (SAIDI), prior to 2006.
2. System reliability index performance, with major storm data included, has become increasingly less reliability and more divergent from reliability indices with storm data excluded, especially in 2003 and 2004.
3. AEP Ohio's reliability index targets, especially those for outage frequency (SAIFI), keep getting less demanding, justified by the Company based on the fact that its reliability index performance in recent years has reflected lower reliability.
4. AEP Ohio installed an automated distribution system outage reporting system in the early 2000s to replace its system of manual data entry and handling of outage data. However, it apparently did so without benchmarking the effects of this system on its reliability indices by performing parallel runs for the old and new systems using the same data for the same time period. The Company

1 claims that this new technology has resulted in increases in its
2 reliability indices (i.e. decreasing reliability), but, without parallel
3 run verification, these increases in the reliability indices could just
4 well be increasing, in whole or in part, because system reliability is
5 getting worse.

6 5. Prior to 2006, AEP Ohio's reliability index targets have been
7 moving in the direction of lower reliability, especially regarding
8 outage frequency (SAIFI). The Company attributes this to the
9 installation of its automated outage recording system, but without
10 the parallel run benchmarking discussed in Item #4 above, these
11 changes should be attributed in part or in their entirety to actual
12 changes in system reliability.

13 6. Several of AEP Ohio's current reliability-related programs,
14 including overhead circuit inspections and vegetation management,
15 have been marked by large swings in the level of effort over the
16 past four to five years, raising potential questions as to the
17 consistency of the quality of these programs.

18 7. AEP Ohio's base vegetation management program is described in
19 the Plan as performance-based, and I believe this has contributed
20 to the deterioration in the Company's reliability index performance
21 in 2003 and 2004, especially during major storms, as well as the
22 need to spend in excess of \$90 million over 2004 and 2005 for
23 catch-up vegetation management.

- 1 8. AEP Ohio's incremental vegetation management program
2 promises to inspect or trim all of its distribution circuits once
3 during the next four years. However, the need to double the
4 number of crews over five years, before reducing the number of
5 these crews, raises questions to whether a more consistent level of
6 vegetation management effort would be more sustainable and
7 effective.
- 8 9. A program to deal with trees outside the right-of-way needs to be
9 specified and made part of the vegetation management effort.
- 10 10. The incremental overhead line inspection program does not appear
11 to be significantly different from the Company's existing program.
- 12 11. Parts of the Company's overhead mitigation program appears to
13 represent incremental efforts that address significant reliability
14 concerns regarding fuse cutouts and lightning arrestors that have
15 been demonstrating increasing failure rates. The 34.5 kV program,
16 however, while laudable, does not reflect an incremental effort.
- 17 12. The parts of the incremental reliability programs that deal with the
18 replacement of aging equipment should not be considered as
19 incremental to normal utility practice.
- 20 13. The installation of SCADA capability in those substations which
21 do not currently have it should take precedence over more
22 sophisticated distribution automation efforts.


1 14. The Plan appears deficient in several areas addressing
2 implementation details, expected reliability benefits, formalized
3 reporting, and regulatory review.
4

5 **Q42. DOES THIS CONCLUDE YOUR DIRECT TESTIMONY?**

6 A42. Yes. However, I reserve the right to modify, amend, or add to this testimony
7 based on additional information that may become available.

CERTIFICATE OF SERVICE

I hereby certify that a copy of the Supplemental Testimony of Peter J. Lanzalotta by the Office of the Ohio Consumers' Counsel was served by first class United States Mail, postage prepaid, to the persons listed below, on this 10th day of April 2007.



Richard C. Reese
Assistant Consumers' Counsel

SERVICE LIST

Thomas McNamee
Attorney General's Office
Public Utilities Section
180 East Broad Street, 9th Floor
Columbus, Ohio 43215

Marvin I. Resnik
AEP Corporation
1 Riverside Plaza, 29th Floor
Columbus, Ohio 43215

Michael Smalz
Ohio State Legal Service Assoc.
555 Buttles Avenue
Columbus, Ohio 43215-1137

M. Howard Petricoff
Lifestyle Communities, Inc.
Vorys, Sater, Seymour & Pease, LLP
52 East Gay Street
Columbus, Ohio 43216

Dane Stinson
Direct Energy Services
Bailey Cavalier LLC
10 W. Broad St., Ste. 2100
Columbus, Ohio 43215

David C. Rinebolt
Ohio Partners for Affordable Energy
P.O. Box 1793
Findlay, Ohio 45839-1793

Steven T. Nourse
AEP Corporation
1 Riverside Plaza, 29th Floor
Columbus, Ohio 43215

Daniel Neilsen
Industrial Energy Users-Ohio
McNees, Wallace & Nurick LLC
Fifth Third Center, 17th Fl.
21 East State Street
Columbus, Ohio 43215

Sally Bloomfield
Bricker & Eckler
100 South Third Street
Columbus, Ohio 43215-4291