



Bricker & Eckler
ATTORNEYS AT LAW

COLUMBUS • CLEVELAND

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2388
sbloomfield@bricker.com

July 6, 2007

FILE

RECEIVED-DOCKETING DIV

2007 JUL -6 PM 3:57

VIA HAND DELIVERY

PUCO

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

**Re: Case No. 07-252-WS-UNC
Ohio American Water Company
Stipulation Page No. 16, ¶13D**

Dear Ms. Jenkins:

Pursuant to the Commission's March 7, 2007 Opinion and Order in Case No. 06-433-WS-AIR, Ohio American Water Company herewith submits for filing the June 2007 Hardness Report for the Lake Darby district.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician M Date Processed 7/6/07

Ohio American Water Co.
 Franklin County Operations
 Lake Darby Water Treatment Plant
 PWSID#2502612

Reporting Period June 2007

Date	Plant Process Control Concentration (mg/l)*	Central Laboratory Concentration (mg/l)*	Average Daily Plant Finished Water Hardness (mg/L)
1	134	131	133
2	130	128	129
3	142	142	142
4	132	132	132
5	134	143	139
6	128	134	131
7	127	128	128
8	133	134	134
9	126	142	134
10	130	128	129
11	128	129	129
12	130	128	129
13	132	130	131
14	130	128	129
15	127	130	129
16	135	128	132
17	130	128	129
18	129	130	130
19	131	142	137
20	130	136	133
21	127	128	128
22	127	126	127
23	135	132	134
24	130	112	121
25	142	142	142
26	139	142	141
27	138	144	141
28	138	136	137
29	133	136	135
30	130	130	130
		Min.	121
		Max	142
		Average	132
		% Above 150 mg/l	0
		% Below 120 mg/l	0.0

*All Hardness analyses were done using Standard Methods, 20th Ed., Method 2340c (Hardness as CaCO₃).

June 2007 - Lake Darby Daily Finished Water Hardness

