

OHIO AMERICAN WATER COMPANY
MARION - DISTRICT

2007

EFFLUENT HARDNESS / MG/L

June	RAW HARDNESS MG/L	EFFLUENT HARDNESS MG/L
1	430	142
2	450	146
3	450	141
4	412	137
5	389	143
6	445	148
7	456	146
8	430	131
9	444	149
10	444	143
11	406	143
12	410	142
13	418	144
14	435	146
15	442	141
16	453	141
17	465	140
18	460	144
19	438	140
20	437	139
21	438	137
22	432	129
23	442	142
24	450	142
25	448	139
26	458	142
27	480	141
28	485	140
29	475	140
30	400	136

AVERAGE	441	141
MAX	485	149
MIN	389	129

June 2007
EFFLUENT HARDNESS AVG - 141 MG/L
MARION DISTRICT

