

FILE

RECEIVED-DOCKETING DIV

July 18, 2007

2007 JUL 18 PM 4:52



Bricker & Eckler
ATTORNEYS AT LAW

COLUMBUS • CLEVELAND

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

VIA HAND DELIVERY

PUCO

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

Re: Case No. 07-252-WS-UNC
Ohio American Water Company
Stipulation Page No. 20, ¶18 L

Dear Ms. Jenkins:

Pursuant to the Commission's March 7, 2007 Opinion and Order in Case No. 06-433-WS-AIR, Ohio American Water Company ("Ohio American") submits for filing its compliance with the Stipulation and Recommendation, page 20 paragraph 18 L pertaining to the submission of leak logs for the second quarter of 2007.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician Am Date Processed 7/19/07

**Ohio American Water Company
Ashtabula District
2007 Water Leak Log
Second Quarter**

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other

Location	Service Area	Township	Leak Type	Size	Service Affecting (Y or N)	Report Date	Repair Date	Elapsed Days	Boil Order (Y or N)	Comment
1 NATHAN @52	CENTRAL		VLV	2"	N	12/19/2006	12/21/2006	2		
2 SILVIEUS	E SIDE		CWM	2"	N	12/28/2006	12/29/2006	1		
3 STATE	E SIDE		CWM	6"	N	1/3/2007	1/4/2007	1		
4 MAIN	CENTRAL		CSL	1"	N	12/27/2006	12/29/2006	2		
5 SRE	E SIDE		CWM	8"	N	1/2/2007	1/2/2007	0		
6 14TH & MICHIGAN	W HARBOR		CWM	2 1/2"	N	1/19/2007	1/20/2007	1		
7 COLUMBUS	CENTRAL		CWM	20"	N	1/12/2007	1/12/2007	0		
8 RT 84	E SIDE		CSL	10"	N	1/10/2007	1/10/2007	0		
9 Fargo	E SIDE		CWM	6"	N	1/25/2007	1/30/2007	5		
10 Roosevelt Ct	E SIDE		CWM	6"	N	1/28/2007	1/28/2007	0		
11 ANN AVE @33RD	CENTRAL		CWM	6"	N	2/1/2007	2/1/2007	0		
12 TANNERY HILL @ SCHENLEY	E SIDE		CWM	6"	N	2/2/2007	2/2/2007	0		
13 DICKENSON	E SIDE		CWM	6"	N	2/4/2007	2/4/2007	0		
14 UNION & W 9TH	W HARBOR		CWM	6"	N	2/6/2007	2/6/2007	0		
15 E 31ST & LINCOLN	E SIDE		CWM	6"	N	2/6/2007	2/6/2007	0		
16 McNUTT	W SIDE		CWM	2"	N	2/12/2007	2/12/2007	0		
17 HIRAM	CENTRAL		CWM	2"	N	2/10/2007	2/10/2007	0		
18 E 46TH	E SIDE		CWM	8"	N	2/20/2007	2/20/2007	0		
19 CARPENTER & MYRTLE	W HARBOR		CWM	8"	N	2/16/2007	2/16/2007	0		
20 LYNDON	W HARBOR		CWM	6"	N	2/18/2007	2/18/2007	0		
21 W 30TH	W SIDE		CWM	6"	N	2/19/2007	2/21/2007	2		
22 UNION	W HARBOR		CWM	6"	N	2/20/2007	2/20/2007	0		
23 FULLER	E SIDE		CWM	6"	N	2/20/2007	2/20/2007	0		
24 COOK	E SIDE		CWM	12"	N	2/21/2007	2/21/2007	0		
25 GLOVER	W HARBOR		CWM	8"	N	2/22/2007	2/22/2007	0		
26 COLLINS	CENTRAL		CWM	6"	N	2/23/2007	2/28/2007	0		
27 E 46TH	E SIDE		CWM	8"	N	2/20/2007	2/27/2007	7		
28 MAIN	CENTRAL		CWM	10"	N	2/27/2007	2/27/2007	0		
29 E 41	E SIDE		CWM	6"	N	3/1/2007	3/1/2007	0		
30 FOREST	CENTRAL		CWM	6"	N	3/1/2007	3/5/2007	4		
31 FOREST S OF KNOLLOWOOD	CENTRAL		CWM	6"	N	3/2/2007	3/2/2007	0		
32 E. 42	E SIDE		CWM	0	N	3/3/2007	3/3/2007	0		
33 NRE	E SIDE		CWM	6"	N	3/6/2007	3/9/2007	3		
34 ULLMAN	E SIDE		CWM	6"	N	3/24/2007	3/24/2007	0		
35 WOODMAN	W SIDE		HYD	6"	N	3/19/2007	3/25/2007	2		
36 WASHINGTON	W SIDE		CSL	6"	N	4/18/2007	4/19/2007	1		
37 SCHOOL	E SIDE		CWM	1 1/4"	N	4/24/2007	4/24/2007	0		
38 ROSS	CENTRAL		CSL	6"	N	4/23/2007	4/25/2007	2		
39 COLUMBUS	CENTRAL		CWM	20"	N	4/24/2007	4/30/2007	6		
40 WALNUT & MYRTLE	CENTRAL		REPACK	6"	N	5/4/2007	5/4/07	0		
41 E 49TH & DWIGHT	E SIDE		CLAMP	6"	N	4/25/2007	5/2/07	7		
42 DIANE	E SIDE		CUT IN PE	8"	N	5/9/2007	5/11/07	2		
43 N RIDGE E	E SIDE		CLAMP	12"	N	5/14/2007	5/15/07	1		
44 COOK	E SIDE		CLAMP	12"	N	5/16/2007	5/22/07	6		
45 N RIDGE E	E SIDE		CLAMP	12"	N	5/19/2007	5/19/07	0		
46 PERRYVILLE	W SIDE		CUT IN PE	8"	N	5/20/2007	5/21/07	1		
47 OLD PROSPECT	CENTRAL		CUT IN PE	8"	N	5/22/2007	5/23/07	1		
48 N RIDGE E	E SIDE		CUT IN PE	12"	N	5/23/2007	5/25/07	2		
49 DONNA	E SIDE		CUT IN PE	6"	N	5/29/2007	6/4/07	6		
50 W 8TH	W SIDE		COUPLING	1"	N	6/4/2007	6/4/07	0		
51 MARUBA & LAKE RD	E SIDE		CUT IN PE	2 1/2"	N	6/9/2007	6/13/07	4		
52 HIGHLAND	CENTRAL		CLAMP	2"	N	6/13/2007	6/14/07	1		
53 BLAKE	E SIDE		CLAMP	6"	N	6/15/2007	6/15/07	0		

54
55
56
57

**Ohio American Water Company
Franklin County District
2007 Water Leak Log
Second Quarter**

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other

[illegible]

**Ohio American Water Company
Lake White District
2007 Water Leak Log
Second Quarter**

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other

[illegible]

**Ohio American Water Company
Lawrence County District
2007 Water Leak Log
Second Quarter**

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other

Location	Service Area	Township	Leak Type	Size	Service	Report Date	Repair Date	Elapsed Days	Boil Order (Y or N)	Comment
					Affecting (Y or N)					
1 BURLINGTON TANK			CO		N	01/08/07	01/08/07	0		Altitude valve
2 NORTH HNTG. HEIGHTS			CWM	6	N	01/30/07	02/01/07	2		Clamp loose; tightened
3 200 ROCKWOOD AVE			CWM	8	Y	02/08/07	02/09/07	1		
4 WILLOW ST.			CWM	2	Y	02/10/07	02/10/07	0		
5 3726 ST. RT. 7			CWM	2	Y	02/10/07	02/11/07	1		
6 SYMMES CREEK RD.			CWM	8	N	02/08/07	02/08/07	0		
7 2ND, AVE & 5TH. ST.			CWM	2	N	02/19/07	02/19/07	0		
8 SCHOOL BUS GARAGE			CSL	3/4	Y	02/26/07	02/27/07	1		
9 11171 COUNTY RD. 1			CSL	3/4	N	03/11/07	03/12/07	1		
10 95 Private Drive 3			CSL	3/4	N	04/09/07	04/11/07	2		
11 Macedonia Road			CWM	2	N	04/11/07	04/12/07	1		
12 Macedonia Road			CWM	2	N	04/13/07	04/13/07	0		
13 Symmes Creek Road			CWM	8	N	04/20/07	04/20/07	0		
14 Big Branch Road			CWM	6	N	04/25/07	04/25/07	0		
15 312 Township Rd. 1024			CO	3/4	Y	04/27/07	04/27/07	0		
16 804 County Road 123			CWM	8	N	05/02/07	05/03/07	1		
17 Center Street			CSL	3/4	N	05/09/07	05/10/07	1		
18 311 Township Road 1156			CWM	3	Y	06/02/07	06/02/07	0		

19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50

**Ohio American Water Company
Mansfield District
2007 Water Leak Log
Second Quarter**

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other

[illegible]

**Ohio American Water Company
Marion District
2007 Leak Log
Second Quarter**

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other

Location	Service Area	Township	Leak Type	Size	Service Affecting (Y or N)	Report Date	Repair Date	Elapsed Days	Boil Order (Y or N)	Comment
1 Menards				F		1/3/2007	1/3/2007	0		
2 Main & Hazen				C		1/8/2007	1/8/2007	0		
3 Jamesway Hydrant				H		1/10/2007	1/10/2007	0		
4 Jamesway Hydrant				F		1/10/2007	1/10/2007	0		
5 423 Avondale				C		1/11/2007	1/11/2007	0		
6 Merkle & Barks				F		1/12/2007	1/12/2007	0		
7 503 Vernon Hts Blvd				P		1/15/2007	1/15/2007	0		
8 1500 Harding Hwy E				C		1/15/2007	1/18/2007	3		
9 Uhler S of Indiana				F		1/16/2007	1/16/2007	0		
10 Mary N of Silver				F		1/17/2007	1/17/2007	0		
11 697 Florence				P		1/17/2007	1/24/2007	7		
12 Mt Vernon W of Greenwood				F		1/18/2007	1/18/2007	0		
13 Capaldi & Harris				F		1/19/2007	1/19/2007	0		
14 Fairground & Likens Chapel				F		1/19/2007	1/19/2007	0		
15 295 Johnson				2		1/21/2007	1/21/2007	0		
16 Barks Crossing				F		1/22/2007	1/22/2007	0		
17 Linden Pl				4		1/24/2007	1/24/2007	0		
18 Barks Crossing				F		1/24/2007	1/24/2007	0		
19 1191 Bermuda				P		1/24/2007				
20 525 Susan Circle				P		1/24/2007				
21 Flush Quarry 7 B 9				F		1/25/2007	1/25/2007	0		
22 B & 6th				F		1/25/2007	1/25/2007	0		
23 Flush Quarry 7 B 9				F		1/26/2007	1/26/2007	0		
24 549 Lee St				P		1/27/2007	1/27/2007	0		
25 215 Ruth				P		1/28/2007	1/28/2007	0		
26 517 Bimini				P		1/29/2007	2/7/2007	9		Delayed by severe weather and shortage of labor
27 324 Pearl				P		1/30/2007	2/2/2007	3		
28 672 E Church				6		1/30/2007	1/30/2007	0		
29 331 E Church				4		1/31/2007	1/31/2007	0		
30 1191 Bermuda				P		1/24/2007	1/28/2007	4		
31 525 Susan Circle				P		1/24/2007	2/13/2007			Property leak; difficult for homeowner to get contractor
32 517 Bimini				P		1/29/2007	2/7/2007	8		
33 324 Pearl				P		1/30/2007	2/2/2007	3		
34 331 E Church				4		1/31/2007	2/1/2007	1		
35 Forest Lawn Blvd & Mt Vernon				8		2/1/2007	2/1/2007	0		
36 131 Garden Pl				P		2/1/2007	2/1/2007	0		
37 216 S Vine				P		2/1/2007	2/1/2007	0		
38 326 Blaine				P		2/1/2007	2/1/2007	0		
39 351 1/2 Leader				P		2/1/2007				
40 Flush Augusta				F		2/2/2007	2/2/2007	0		
41 504 Oak				P		2/2/2007				
42 565 Vernon Hts Blvd				P		2/3/2007	2/3/2007	0		
43 473 Fies				2		2/3/2007	2/3/2007	0		
44 351 Silver				P		2/3/2007	2/3/2007	0		
45 Klingel & Gooding				12		2/3/2007	2/4/2007	1		
46 514 N Greenwood				P		2/3/2007	2/3/2007	0		
47 380 Quarry				P		2/3/2007	2/3/2007	0		
48 Klingel & Gooding				F		2/3/2007	2/4/2007	0		
49 224 Jefferson				P		2/4/2007	2/4/2007	0		
50 266 Orchard				P		2/4/2007	2/4/2007	0		
51 309 Pearl St				P		2/4/2007	2/4/2007	0		
52 152.5 Oak				P		2/4/2007	2/4/2007	0		
53 589 Uncapher				P		2/4/2007	2/4/2007	0		
54 637-639 N Main				P		2/4/2007	2/4/2007	0		

**Ohio American Water Company
Marion District
2007 Leak Log
Second Quarter**

Location	Service Area	Township	Leak Type	Size	Service Affecting (Y or N)	Report Date	Repair Date	Elapsed Days	Boil Order (Y or N)	Comment
55 203 N Seffner				P		2/4/2007	2/4/2007	0		
56 David & Woodrow				4		2/5/2007	2/5/2007	0		
57 196 Glad				2		2/5/2007	2/5/2007	0		
58 Main & Walnut				12		2/5/2007	2/5/2007	0		
59 598 Herman				P		2/5/2007	2/5/2007	0		
60 104 Cemetary				P		2/5/2007	2/5/2007	0		
61 286 Clinton St				P		2/5/2007	2/5/2007	0		
62 725 N Main				P		2/5/2007	2/5/2007	0		
63 310 N Elm				P		2/5/2007	2/5/2007	0		
64 349 Waterloo				P		2/5/2007	2/5/2007	0		
65 450 Fies				P		2/6/2007	2/6/2007	0		
66 531 N State				P		2/6/2007	2/6/2007	0		
67 260 Owens				P		2/6/2007	2/6/2007	0		
68 223 N Seffner				P		2/6/2007	2/6/2007	0		
69 329 Blaine				P		2/6/2007	2/6/2007	0		
70 1207 Cheney				P		2/6/2007	2/6/2007	0		
71 180 Carhart				P		2/6/2007	2/6/2007	0		
72 387 Blaine				P		2/7/2007	2/7/2006	0		
73 579 Adams				P		2/7/2007	2/7/2006	0		
74 177 E Columbia				P		2/7/2007	2/7/2006	0		
75 Fies & Brown				2		2/7/2007	2/7/007	0		
76 266 Patterson				P		2/8/2007	2/8/2006	0		
77 1015 N Main				P		2/8/2007	2/8/2006	0		
78 553 N Main				P		2/8/2007	2/8/2006	0		
79 357 Milburn				P		2/8/2007	2/8/2006	0		
80 200 Forest				P		2/8/2007	2/8/2006	0		
81 212 Latourette				2		2/8/2007	2/12/2007	4		
82 444 Oak				P		2/9/2007	2/9/2006	0		
83 1922 Victory 222				P		2/9/2007	2/9/2006	0		
84 1045 Holland Rd				P		2/9/2007	2/9/2006	0		
85 219 Benton Pl				P		2/9/2007	2/9/2006	0		
86 Gooding & Beth				12		2/9/2007	2/9/2007	0		
87 Gooding & Beth				F		2/9/2007	2/9/2007	0		
88 St Rt 257 S of St Rt 47				12		2/9/2007	2/11/2007	2		
89 1106 E Church				P		2/10/2007	2/10/2006	0		
90 177 E Columbia				P		2/10/2007	2/10/2006	0		
91 209 N Grand				P		2/10/2007	2/10/2006	0		
92 376 Mary				P		2/10/2007	2/10/2006	0		
93 346 E Farming				P		2/10/2007	2/10/2006	0		
94 451 Sellar				P		2/10/2007	2/10/2006	0		
95 360 Oak				P		2/10/2007	2/11/2007	1		
96 407 Olney				P		2/11/2007	2/11/2006	0		
97 217 Glad St				P		2/11/2007	2/11/2006	0		
98 163 Homer St				P		2/11/2007	2/11/2006	0		
99 Oak St South of Chestnut				6		2/11/2007	2/11/2007	0		
100 674 Herman				P		2/12/2007	2/12/2006	0		
2022 Victory 81				P		2/12/2007	2/12/2006	0		
167 Latourette				P		2/12/2007	2/12/2006	0		
505 Thompson				P		2/12/2007	2/12/2006	0		
1030 Henry St				P		2/12/2007	2/12/2006	0		
154 N Main St				P		2/12/2007	2/12/2006	0		
132 Union				P		2/12/2007	2/12/2006	0		
389 Forest				P		2/12/2007	2/12/2006	0		
212 Waterloo				P		2/12/2007	2/12/2006	0		
833 Fairwood				P		2/12/2007	2/12/2006	0		
530 Mound St				P		2/12/2007	2/12/2006	0		
324 Girard				P		2/12/2007	2/12/2006	0		
217 Neil				P		2/12/2007	2/12/2006	0		
577 Herman				P		2/12/2007	2/12/2007	0		
200 Wallace				P		2/13/2007	2/13/2006	0		
467 Evans Rd				P		2/13/2007	2/13/2006	0		
487 N State				P		2/13/2007	2/13/2006	0		
139 W Walnut				P		2/13/2007	2/13/2006	0		

**Ohio American Water Company
Marion District
2007 Leak Log
Second Quarter**

Location	Service Area	Township	Leak Type	Size	Service Affecting (Y or N)	Report Date	Repair Date	Elapsed Days	Boil Order (Y or N)	Comment
640 Henry				P		2/13/2007	2/13/2006	0		
769 N State				P		2/13/2007	2/13/2006	0		
Henry & Woodrow				H		2/13/2007				
Uncapher & Broad				H		2/13/2007				
467 Pearl				P		2/13/2007	2/13/2007	0		
188 Nye St				P		2/14/2007	2/14/2006	0		
807 Forest Lawn				P		2/14/2007	2/15/2006	1		
Ballentine & Fairground				2		2/14/2007	2/14/2007	0		
488 ST Gallen				C		2/14/2007	2/20/2007	6		
294 Chestnut				6		2/15/2007	2/15/2007	0		
884 Adams St				2		2/15/2007	2/15/2007	0		
492 Lee				P		2/16/2007	2/16/2007	0		
631 Patterson				2		2/16/2007	2/16/2007	0		
462 Patterson				H		2/16/2007				
Mark & Park				H		2/16/2007				
Homer N of Indiana				6		2/16/2007	2/21/1900	5		
525 Toledo				P		2/17/2007	2/17/2006	0		
443 Girard				P		2/17/2007	2/17/2006	0		
965 Bikini				P		2/17/2007	2/17/2006	0		
519 Roberts				P		2/18/2007	2/18/2006	0		
383 Owens				P		2/18/2007	2/18/2006	0		
GSA				8		2/18/2007	2/18/2007	0		
Church & Vine				4		2/18/2007	2/19/2007	1		
210 E Fairground				P		2/19/2007	2/19/2006	0		
Johnson St				2		2/19/2007	2/19/2007	0		
287 Barnhart				P		2/20/2007	2/20/2006	0		
195 Chicago				P		2/20/2007	2/20/2006	0		
287 Barnhart				P		2/20/2007	2/20/2007	0		
209 Sharp				P		2/21/2007	2/21/2006	0		
356 Olney				P		2/21/2007	2/21/2006	0		
127 Lincoln				P		2/21/2007	2/21/2006	0		
845 Lorie Valley				P		2/21/2007				
560 Mound				2		2/21/2007	2/21/2007	0		
514 N State				P		2/22/2007	2/22/2006	0		
2066 Victory 15				P		2/22/2007	2/22/2006	0		
742 N State				P		2/22/2007				
505 Henry				P		2/22/2007	2/22/2006	0		
Main & Fairview				2		2/22/2007	2/22/2007	0		
Flush Augusta				F		2/22/2007	2/22/2007	0		
370 E Mark				P		2/22/2007	2/23/2006	1		
211 Glad				P		2/22/2007	2/23/2006	1		
263 Glad				P		2/22/2007	2/23/2006	1		
429 S Main				P		2/24/2007	2/24/2006	0		
138 Charles				P		2/24/2007	2/24/2006	0		
322 1/2 W Columbia				P		2/24/2007	2/24/2006	0		
322 W Columbia				P		2/24/2007	2/24/2006	0		
322 W Columbia Rear				P		2/24/2007	2/24/2006	0		
Merchant & Church				6		2/24/2007	2/25/2007	1		
607 Forest Lawn				P		2/25/2007	2/25/2006	0		
Midlam & Garfield				2		2/26/2007	2/26/2007	0		
Dana & Water				4		2/26/2007	2/27/2007	1		
495 Mound				P		2/26/2007	2/26/2007	0		
Gooding N of 47				12		2/27/2007	2/27/2007	0		
Cobblestone				F		2/27/2007	2/27/2007	0		
321 Waterloo				P		2/27/2007	2/27/2007	0		
Albany Estates				F		2/28/2007	2/28/2007	0		
219 Blaine				P		2/28/2007	2/28/2007	0		
351 1/2 Leader				P		2/11/2007	2/5/2007	4		
504 Oak				P		2/2/2007				
Henry & Woodrow				H		2/13/2007				
Uncapher & Broad				H		2/13/2007				
462 Patterson				H		2/16/2007				
Mark & Park				H		2/16/2007				

**Ohio American Water Company
Marion District
2007 Leak Log
Second Quarter**

Location	Service Area	Township	Leak Type	Size	Service Affecting (Y or N)	Report Date	Repair Date	Elapsed Days	Boil Order (Y or N)	Comment
845 Lorie Valley				P		2/21/2007	3/13/2007	18		Property leak; difficult for homeowner to get contractor
742 N State				P		2/22/2007	3/5/2007			Property leak; difficult for homeowner to get contractor
370 E Mark				P		2/23/2007	3/7/2007			Property leak; difficult for homeowner to get contractor
Gooding N of 47				12		2/27/2007	2/27/2007	0		
Flush Augusta				F		3/2/2007	3/2/2007	0		
467 Linda Mel				H		3/2/2007				
Blevins				F		3/2/2007	3/12/2007	10		Fire service
1078 Capri				2		3/4/2007	3/5/2007	1		
W Center				F		3/5/2007	3/5/2007	0		
531 N Greenwood				P		3/5/2007	4/3/2007	29		Property leak; difficult for homeowner to get contractor
Flush Jamesway				F		3/5/2007	3/5/2007	0		
375 Mary				P		3/5/2007	3/31/2007	26		Property leak; difficult for homeowner to get contractor
203 Hughes				P		3/5/2007				
148 Glad				2		3/6/2007	3/6/2007	0		
314 Reed				6		3/6/2007	3/13/2007	7		
364 Spencer				2		3/6/2007	3/8/2007	2		
999 Chateau				P		3/9/2007	3/31/2007	22		Property leak; difficult for homeowner to get contractor
956 Gebhardt				P		3/12/2007	3/19/2007	7		
335 E Church				4		3/12/2007	3/14/2007	2		
Market & East				H		3/12/2007				
Menards New Hydt				F		3/13/2007	3/13/2007	0		
Flush Augusta				F		3/16/2007	3/16/2007	0		
521 E Mark				P		3/19/2007	3/19/2007	0		
518 Grant				P		3/20/2007	3/20/2007	0		
Prospect & Church				H		3/21/2007	3/21/2007	0		
State South of Church				6		3/21/2007	3/27/2007	6		
Barks & Merkle				6		3/22/2007				
Marion General 8"				P		3/23/2007	3/23/2007	0		
Tyler & Vanburen				2		3/26/2007	3/27/2007	1		
726 Bennett				C		3/26/2007				
276 Ballentine				P		3/29/2007	4/2/2007	3		
Flush Augusta				F		3/30/2007	3/30/2007	0		
Hughes				C		3/26/2007	4/3/2007	8		
Silver & Chester				F		3/31/2007	4/4/2007	5		
Barks & Merkle				6		4/1/2007	4/9/2007	8		
Battle & East				H		4/2/2007	4/4/2007	2		
Linn Hipsher & New Road				F		4/3/2007	4/3/2007	0		
1205 Fairwood				P		4/4/2007	4/4/2007	0		
212 Short				P		4/4/2007	4/11/2007	7		
170 Lawrence Ave				P		4/5/2007	4/5/2007	0		
Center E of State				10		4/6/2007	4/7/2007	1		
333 W Columbia				C		4/6/2007	4/13/2007	7		
Flush Augusta				F		4/6/2007	4/6/2007	0		
Barks & Merkle				F		4/9/2007	4/9/2007	0		
401 Leader St				2		4/10/2007	4/10/2007	0		
400 Avondale				P		4/10/2007	4/10/2007	0		
536 Littleton				P		4/16/2007	4/23/2007	7		
1057 Jamaica				P		4/16/2007	4/23/2007	7		
553 Fountain				P		4/17/2007	4/24/2007	7		
1019 Bermuda				P		4/18/2007	4/25/2007	7		
Center & Scioto				2		4/19/2007	4/19/2007	0		
Flush Augusta				F		4/20/2007	4/20/2007	0		
376 Quarry				6		4/20/2007	4/23/2007	3		
6531 Gooding				12		4/22/2007	4/22/2007	0		
1362 Barks Rd E				C		4/27/2007	5/7/2007	10		Very small leak - other work took precedent
W Center & Waterloo				F		5/1/2007	5/1/2007	0		
Charles & Church				6		5/1/2007	5/2/2007	1		
598 Wood				P		5/2/2007	5/10/2007	8		Very small leak - Customer required another day to make repairs
872 N Main				C		5/3/2007	5/3/2007	0		
234 St James				P		5/3/2007	5/3/2007	0		
Augusta				F		5/4/2007	5/4/2007	0		
3060 Craven				C		5/7/2007	5/8/2007	1		

**Ohio American Water Company
Marion District
2007 Leak Log
Second Quarter**

Location	Service Area	Township	Leak Type	Size	Service Affecting (Y or N)	Report Date	Repair Date	Elapsed Days	Boil Order (Y or N)	Comment
Thompson & Roma				2		5/7/2007	5/9/2007	2		
915 Loire Valley				C		5/9/2007	5/9/2007	0		
1011 S Prospect				P		5/9/2007	5/15/2007	6		Hit by contractor
Hydt 292 Vine				F		5/10/2007	5/10/2007	0		Fire Service
W Center & Hoyte				F		5/11/2007	5/11/2007	0		
Park Blvd & Church				V		5/11/2007	5/16/2007	5		
124 Merchant				P		5/11/2007	5/11/2007	0		
1040 S Prospect St				F		5/12/2007	5/12/2007	0		
Mrs Williamsport				f		5/14/2007	5/14/2007	0		
292 S Vine				F		5/15/2007	5/15/2007	0		
Laura & Harvey				F		5/16/2007	5/16/2007	0		
814 Silver				C		5/16/2007	5/19/2007	3		
954 Bryant				P		5/17/2007	5/17/2007	0		
429 Jefferson				8		5/17/2007	5/24/2007	7		
400 N Main				6		5/18/2007	5/18/2007	0		
Augusta				F		5/18/2007	5/18/2007	0		
										Very small leak - other work took precedent - 2 people flushing hydrants & other crew making repairs to hydrants damaged during flushing program
Fies & Brown				2		5/21/2007	6/6/2007	12		
										Very small leak - other work took precedent - 2 people flushing hydrants & other crew making repairs to hydrants damaged during flushing program
Mark & Jefferson				H		5/21/2007	6/6/2007	12		
										Very small leak - other work took precedent - 2 people flushing hydrants & other crew making repairs to hydrants damaged during flushing program
274 Patten				C		5/21/2007	6/9/2007	15		
										Very small leak - Customer required more time to make repairs
629 Ballentine				P		5/21/2007	5/30/2007	9		
460 Elgin Ct				P		5/22/2007	5/22/2007	0		
										Very small leak - Customer required more time to make repairs
3000 Craven Dr				P		5/22/2007	5/31/2007	9		
614 E Farming				P		5/23/2007	5/30/2007	7		
1016 Oak Grove				P		5/24/2007	5/31/2007	7		
348 Bradford				P		5/24/2007	5/30/2007	6		
										Very small leak - other work took precedent - 2 people flushing hydrants & other crew making repairs to hydrants damaged during flushing program
216 Hughes				C		5/25/2007	6/2/2007	8		
918 Oak Grove				P		5/25/2007	5/25/2007	0		
Elgin Ct				2		5/26/2007	5/26/2007	0		
263 Latourette				P		5/29/2007	5/31/2007	2		
196 Kensington				P		5/29/2007	6/4/2007	5		
1775 Mar Waldo				C		5/30/2007	5/31/2007	1		
216 Hughes				P		6/1/2007	6/2/2007	1		
Osgood & Cheney				H		6/1/2007	6/20/2007	19		Very small leak. Had to co-ordinate water shut off w Nucor Steel
Fies & Brown				2		6/1/2007	6/6/2007	5		
Indiana & FLB				F		6/5/2007	6/5/2007	0		
290 Merchant				P		6/5/2007	6/13/2007	8		Small leak, Landlord having trouble finding plumber. Gave extra day
306 Nye St				P		6/5/2007	6/9/2007	4		
130 S Grand				P		6/5/2007	6/5/2007	0		
St Rt 309 & Nesbit				F		6/6/2007	6/6/2007	0		
Windsor & Thew				8		6/8/2007	6/12/2007	4		
Augusta				F		6/8/2007	6/8/2007	0		
680 Herman				P		6/8/2007	6/19/2007	11		Small leak, Landlord having trouble finding plumber. Gave extra day
1022 N State				P		6/8/2007	6/14/2007	8		
386 N Prospect St				P		6/9/2007	6/9/2007	0		
987 Amherst				P		6/12/2007	6/18/2007	6		
1170 Richland Rd				P		6/12/2007	6/12/2007	0		
387 silver St				P		6/12/2007	6/20/2007	8		Small leak, Landlord having trouble finding plumber. Gave extra day
1079 Barks Rd				P		6/13/2007	6/13/2007	0		
N Prospect St				F		6/14/2007	6/14/2007	0		
David & Cloumbia				V		6/15/2007	6/22/2007	7		
1425 Woodridge				P		6/18/2007	7/9/2007	21		Very Small leak, Landlord having trouble finding plumber. Gave extra time
Osgood & Cheney				F		6/20/2007	6/20/2007	0		
300 libbey lane				P		6/20/2007	6/27/2007	7		

**Ohio American Water Company
Marion District
2007 Leak Log
Second Quarter**

Location	Service Area	Township	Leak Type	Size	Service Affecting (Y or N)	Report Date	Repair Date	Elapsed Days	Boil Order (Y or N)	Comment
Augusta				F		6/21/2007	6/21/2007	0		
Flow Test W Center				F		6/21/2007	6/21/2007	0		
Flow Test Jamesway				F		6/21/2007	6/21/2007	0		
614 Westlawn				P		6/21/2007	6/28/2007	7		
High & Park Prospect				F		6/23/2007	6/27/2007	4		
860 Davids				P		6/25/2007	7/5/2007	10		Customer had issues w WLPP
224 Short				P		6/25/2007	7/3/2007	8		Small leak, Landlord having trouble finding plumber. Gave extra day
Central Soya Flush Fire				F		6/26/2007	6/26/2007	0		
718 Lilac				P		6/27/2007	7/5/2007	8		Customer given over holiday to make repairs
May & Toledo				F		6/28/2007	6/28/2007	0		
480 Elmwood				P		6/28/2007	7/10/2007	12		Customer not home
136 S Vine				P		6/29/2007	6/29/2007	0		

**Ohio American Water Company
Portage County District
2007 Water Leak Log
Second Quarter**

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other

[illegible]

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other

Location	Service Area	Township	Leak Type	Size	Affecting		Elapsed	Boil Order	Comment
					(Y or N)	Report Date			
1 Nile/W Perry Streets			CWM			12/28/2006	1/2/2007	5	main break
2 26 Grace St.			PSL			1/4/2007	1/19/2007	15	customer service leak
3 208 Circular St			PSL			1/4/2007	1/8/2007	4	customer service leak
4 14 W Market St			PSL			1/11/2007	1/27/2007	16	customer service leak
5 179 Minerva St			CWM			1/17/2007	1/17/2007	0	main break
6 26 Grace St			CSL			1/19/2007	1/23/2007	4	service leak
7 44 Rita Ln			CSL			1/12/2007	1/17/2007	5	service leak
8 123 Mohawk St			CWM			1/25/2007	1/25/2007	0	main break
9 Elte St west of River Rd			CWM			1/30/2007	1/30/2007	0	main break
10 133 Hunter St			CWM			1/31/2007	1/31/2007	0	main break
11 Heidelberg College			PSL			2/3/2007	2/3/2007	0	customer service leak
12 49 Main St			CWM			2/4/2007	2/5/2007	1	main break
13 15 Hudson St			CSL			2/5/2007	2/5/2007	0	service leak
14 87 Clinton Ave			HYD			2/8/2007	2/7/2007	1	hydrant leak
15 184 Main St			CSL			2/6/2007	2/7/2007	1	service leak
16 194 E Perry St			CWM			2/6/2007	2/8/2007	0	main break
17 2300 W St Rt 18			PO			2/9/2007	2/9/2007	0	fire service froze & broke-found by fire dept
18 928 W Market St			PSL			2/12/2007	still off	0	fire service froze & broke
19 98 Seneca St			CWM			2/13/2007	2/13/2007	0	main break
20 Kensington Ave			CWM			2/25/2007	2/25/2007	0	main break
21 670 N Shaffer Park Dr			PSL			2/25/2007	still off	0	shut off for customer leak
22 Highway 101			PO			3/1/2007		0	fire
23 135 N Washington St			CSL			3/3/2007			service leak
24 Sherwood Ct			CWM			3/4/2007	3/4/2007	0	main break
25 13 Miami St			PSL			3/5/2007			customer service leak
26 N Washington St @ Hudson			CWM			3/7/2007	3/7/2007	0	main break
27 Clinton Ave			CWM			3/8/2007	3/9/2007	1	main break
28 Seneca St			CO			2/27/2007	3/8/2007	9	valve repair
29 732 W Market-Taco Bell			PO			3/9/2007	still off	0	customer service leak
30 29 Grace St			CSL			3/17/2007	3/17/2007	0	service leak
31 354 Coe St			PSL			3/9/2007	3/27/2007	18	customer service leak
32 77-79 Webster St			PSL			3/6/2007	3/8/2007	2	customer service leak
33 W Perry/Franklin			PO			3/29/2007			fire
34 145 Cottage						4/5/2007	4/10/2007	5	replace hydrant
35 Grand/Northview						4/10/2007	4/10/2007	0	sewer crew hit main
36 70 Greenfield						4/23/2007	4/27/2007	4	valve repair
37 297 Wall						4/19/2007	4/21/2007	8	service leak
38 161 Schonhardt						3/26/2007	4/2/2007	7	service leak
39 8 Rebecca						4/23/2007		11	shut off 5/4/07-not able to get in contact with owner
40 various									hydrant leaks found during flushing program
41 721 N Water						4/23/2007			customer leak
42 511 W Williamsburg						5/2/2007	5/2/2007	0	main break-hit by contractor
43 Washington School-Elmer St						4/27/2007	5/3/2007	6	customer service leak
44 212 Hudson St						5/9/2007	5/9/2007	0	service leak
45 122 Park Ave						5/10/2007	5/10/2007	0	customer service leak-sewer crew hit
46 59 Boehler St						5/9/2007	5/11/2007	2	replace hydrant
47 Sherwood Ct						5/14/2007	5/15/2007	1	main break
48 115 Second Ave						5/16/2007	5/17/2007	1	service leak
49 441 Clinton Ave						5/15/2007	5/17/2007	2	replace valve
50 42 Madison St						5/18/2007	5/21/2007	3	customer service leak

DEFINITIONS

Location	Location of leak; may include street address of nearest residence or distance from intersecting street
Service Area	If Network service are is segmented, this information should be included
Township	Township in which leak occurred
Leak Type	List is found at top of sheet; each leak will be either Company or Private;
Size	This pertains to mains, valves and services
Service Affecting	Yor N answer; Service affecting leaks are determined to be those leaks that leave customers with little or no pressure
Report Date	The date the Company became aware of the leak
Repair Date	The date the leak was repaired
Elapsed Days	The number of days from the report date to repair date; under normal conditions, this should be between 0 to 1 days for service affecting leaks and 0 to 7 days for non-service affecting leaks
Boil Order	Was a boil order issued to customers
Comments	Any additional useful information; should include an explanation of any repair outside the regulated number of elaped days
CSL	Company Service Line
CWM	Company Water Main
HYD	Hydrant
VLV	Valve
CO	Company Other
PSL	Private Service Line
PWM	Private Water Main
PO	Private Other