

FILE

Staff Investigation Report and Recommendation

RECEIVED-DOCKETING DIV

2008 APR -9 PM 3:48

Case No.: 08-180-EL-BLN

Project: Allen Junction-Westgate 138 kV Transmission Line
Tap to the Flower Hospital Substation

PUCO

Applicants: American Transmission Systems, Inc.
Toledo Edison Company

Report Date: 9 April 2008

Automatic Approval Date: 13 April 2008 (Letter of Notification process)

Waiver Request: None

Inspection Date(s): 13 March 2008
Staff Assigned: J. O'Dell

Summary of Staff Recommendations (see report text for discussion):

Application: ☒ Approval ☐ Disapproval ☐ Approval with Conditions
Waiver: ☐ Approval ☐ Disapproval ☒ Not Applicable

Summary of Staff Recommended Conditions (see report text for discussion):

- None

Projected Docket Closure Date (if automatically approved): 1 October 2010

Investigation Report

Project Description: This project involves the construction of approximately 3,325 feet of single circuit 138 kV transmission line. The project is needed to provide a source of supply to a new hospital distribution substation.

Site Description: The project is located in city of Sylvania, Lucas County. Adequate access is available and no significant vegetative clearing is required. Land use in proximity to the project consists of commercial, institutional and utility corridor uses. Much of the route follows an existing distribution line r-o-w.

Discussion/Comments/Concerns: An intervention request by the City of Sylvania has been withdrawn. The construction of this project should pose only minimal negative social and ecological impacts.

This is to certify that the images appearing are an
accurate and complete reproduction of a case file
document delivered in the regular course of business.
Technician SM Date Processed 4/9/08