

FILE



Bricker & Eckler
ATTORNEYS AT LAW

COLUMBUS • CLEVELAND

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

August 5, 2008

VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

Re: Case No. 07-252-WS-UNC
Ohio American Water Company
Stipulation Page No. 16, ¶13D

Dear Ms. Jenkins:

Pursuant to the Commission's March 7, 2007 Opinion and Order in Case No. 06-433-WS-AIR, Ohio American Water Company submits for filing the July 2008 Hardness Report for the Lake Darby district.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

RECEIVED-DOCKETING DIV
2008 AUG-5 AM 11:52
PUCO

This is to certify that the images appearing are an
accurate and complete reproduction of a case file
document delivered in the regular course of business
Technician Amr Date Processed 8/5/08

Ohio American Water Co.
Franklin County Operations
Lake Darby Water Treatment Plant
PWSID#2502612

Reporting Period July 2008

Date	Plant Process Control Concentration (mg/l)*	Central Laboratory Concentration (mg/l)*	Average Daily Plant Finished Water Hardness (mg/L)
1	128	128	128
2	130	120	125
3	127	120	124
4	125	126	126
5	126	130	128
6	126	126	126
7	127	126	127
8	126	128	127
9	129	130	130
10	130	138	134
11	131	140	136
12	126	122	124
13	125	124	125
14	128	126	127
15	128	138	133
16	129	128	129
17	125	122	124
18	128	128	128
19	128	130	129
20	130	134	132
21	127	130	129
22	124	120	122
23	129	134	132
24	123	120	122
25	130	132	131
26	128	122	125
27	127	130	129
28	130	136	133
29	128	130	129
30	128	126	127
31	128	124	126
		Min.	122
		Max	136
		Average	128
		% Above 150 mg/l	0.0
		% Below 120 mg/l	0.0

*All Hardness analyses were done using Standard Methods, 20th Ed., Method 2340c (Hardness as CaCO₃).

July 2008 - Lake Darby Daily Finished Water Hardness

