

FILE

Staff Investigation Report and Recommendation

Case No.: 08-1028-EL-BNR

Project: Bayshore-Maclean-Lemoyne 138 kV
Transmission Line Reconductoring

Applicants: American Transmission Systems, Inc.

Report Date: 22 September 2008

Automatic Approval Date: 27 September 2008 (Construction Notice process)

Waiver Requests: None

Inspection Date(s): 8 September 2008

Staff Assigned: J. O'Dell

Summary of Staff Recommendations (see report text for discussion):

Application: ☒ Approval ☐ Disapproval ☐ Approval with Conditions
Waiver: ☐ Approval ☐ Disapproval ☒ Not Applicable

Summary of Staff Recommended Conditions (see report text for discussion):

- None

Projected Docket Closure Date (if automatically approved): 1 February 2011

Investigation Report

Project Description: This project involves reconductoring approximately 2.8 miles of double circuit 138 kV transmission line. The existing circuit would also be reconfigured into three separate circuits to improve reliability and mitigate contingency overloads. No new structures would be required.

Site Description: No new r-o-w is required and no appreciable clearing is necessary. Land use in proximity to the project consists of agricultural, interstate highway, railroad, and residential uses. This project is located in Troy Township, Wood County.

Discussion/Comments/Concerns: The construction of this project should pose only minimal negative social and ecological impacts.

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician Amr Date Processed 9/23/08

RECEIVED-DOCKETING DIV
2008 SEP 22 PM 5:18
PUCO