



Bricker & Eckler
ATTORNEYS AT LAW
COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

FILE

December 10, 2008

VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

Re: **Ohio American Water Company**
Case No. 08-1233-WS-UNC

Dear Ms. Jenkins:

Ohio American Water Company submits for filing the November 2008 Hardness Report for the Marion district. The Hardness Report for Lake Darby is not complete at this time as the format of report is being revised.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

RECEIVED-DOCKETING DIV
2008 DEC 10 PM 2:14
PUCO

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician TM Date Processed 12/10/2008

OHIO AMERICAN WATER COMPANY
MARION - DISTRICT

2008

EFFLUENT HARDNESS / MG/L

November	RAW HARDNESS MG/L	EFFLUENT HARDNESS MG/L
1	530	130
2	530	144
3	520	141
4	525	143
5	530	142
6	531	145
7	522	137
8	503	134
9	488	140
10	511	137
11	540	143
12	530	133
13	550	137
14	520	129
15	520	136
16	505	136
17	472	139
18	454	128
19	436	130
20	462	148
21	472	144
22	451	123
23	446	135
24	450	145
25	450	144
26	409	141
27	408	147
28	420	150
29	437	154
30	446	150

AVERAGE	486	140
MAX	550	154
MIN	408	123

November 2008
EFFLUENT HARDNESS AVG - 140 MG/L
MARION DISTRICT

