

FILE



Bricker & Eckler
ATTORNEYS AT LAW
COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

2

RECEIVED-DOCKETING DIV

January 14, 2009

2009 JAN 14 PM 2:42

PUCO

VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

**Re: Ohio American Water Company
Case No. 08-1233-WS-UNC**

Dear Ms. Jenkins:

Ohio American Water Company submits for filing the December 2008
Hardness Report for the Marion district.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

This is to certify that the images appearing are an
accurate and complete reproduction of a case file
document delivered in the regular course of business.
Technician SM Date Processed JAN 14 2009

OHIO AMERICAN WATER COMPANY
MARION - DISTRICT

2008

EFFLUENT HARDNESS / MG/L

December	RAW HARDNESS MG/L	EFFLUENT HARDNESS MG/L
1	446	128
2	446	124
3	450	137
4	455	129
5	488	137
6	502	132
7	499	139
8	520	132
9	540	133
10	520	133
11	510	141
12	480	137
13	430	121
14	410	131
15	406	137
16	433	135
17	444	141
18	452	139
19	451	134
20	434	131
21	425	130
22	439	144
23	452	146
24	422	143
25	455	135
26	508	147
27	493	145
28	533	142
29	515	143
30	475	147
31	449	144

AVERAGE	467	137
MAX	540	147
MIN	406	121

December 2008
EFFLUENT HARDNESS AVG - 137 MG/L
MARION DISTRICT

