



Bricker & Eckler
ATTORNEYS AT LAW
COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2388
sbloomfield@bricker.com

FILE

RECEIVED-DOCKETING DIV

January 23, 2009

2009 JAN 23 PM 4:09

PUCO

VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

Re: Case No. 08-1233-WS-UNC
Ohio American Water Company
Stipulation Page No. 11, ¶14D

Dear Ms. Jenkins:

Pursuant to the Commission's November 12, 2008 Opinion and Order in Case No. 07-1112-WS-AIR, Ohio American Water Company submits for filing the Lake Darby Hardness Monthly Reports for November and December 2008.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Attorney Examiner Dick Bulgrin (w/Enclosure)
Parties of Record (w/Enclosure)

Ohio-American Water Company
Franklin County District
Lake Darby Water Hardness Report
Interim Report

Reporting Month & Year November-08

Date	Day	On-Line Measurement (mg/L) Continuous	On-Line Unit (Y or N)	LDWTP Process Control Measurement (mg/L) Daily	QAWC WQ Lab Measurement (mg/L) Daily	LDWTP Outside Lab Measurement (mg/L) 1/Month	LDWTP Outside Lab Collection Time Sampler	Distribution Outside Lab Measurement (mg/L) 1/Month	Distribution Outside Lab Collection Time Sampler	Water Distribution Measurement (mg/L) 2/week
1	Sat	*	Y	138	183					
2	Sun	*	Y	139	186					
3	Mon	*	Y	122	120					138
4	Tue	*	Y	125	130					
5	Wed	*	Y	129	120					128
6	Thu	*	Y	124	120					
7	Fri	*	Y	127	130					
8	Sat	*	Y	128	130					
9	Sun	*	Y	124	126					140
10	Mon	*	Y	126	126					
11	Tue	*	Y	124	124					
12	Wed	*	Y	127	132					128
13	Thu	*	Y	128	132					
14	Fri	*	Y	125	124					
15	Sat	*	Y	128	128					
16	Sun	*	Y	121	120					116
17	Mon	*	Y	124	120					
18	Tue	*	Y	110	90					134
19	Wed	*	Y	112	114					
20	Thu	*	Y	116	92					
21	Fri	*	Y	112	102					
22	Sat	*	Y	110	108					
23	Sun	*	Y	112	110					
24	Mon	*	Y	110	102					
25	Tue	*	Y	110	110	87	J Ward	106	J Ward	116
26	Wed	*	Y	112	102					
27	Thu	*	Y	111	104					117
28	Fri	*	Y	110	110					
29	Sat	*	Y	126	126					
30	Sun	*	Y	122	120					
31										
Average		#DIV/0!		121	120					127
Max		0		139	183					140
Min		0		110	90					116
#>150		0		0	0					0

* = Waiting on data retrieval software.

- NOTES:
- 1) Operator shall make a notation in the Instrumentation Log Book on a DAILY basis on the status of the On-Line Hardness Analyzer.
 - 2) Week is Sunday to Saturday
 - 3) WQ Lab is responsible for delivering monthly sample to outside lab.
 - 4) For any test with a hardness <95 mg/L or >145 mg/L, notify the Network Operations Superintendent and the Operations Supervisor immediately.
 - 5) Rate Order & Stipulation effective 1/1/92/008

Ohio-American Water Company
Franklin County District
Lake Darby Water Hardness Report
Interim Report

Reporting Month & Year December-98

Date	Day	On-Line Measurement (mg/L)	On-Line Unit (Y or N)	LDWTP Process Control Measurement (mg/L) Daily	CAWC WQ Lab Measurement (mg/L) Daily	LDWTP Outside Lab Measurement (mg/L) 1/Month	LDWTP, Outside Lab, Collection Time, Sampler	Distribution Outside Lab Measurement (mg/L) 1/Month	Distribution, Outside Lab, Collection Time, Sampler	Water Distribution Measurement (mg/L) 2/week
1	Mon	112	Y	120	108	103	7:51 AM, J Ward	100	9:30 AM, J Ward	109
2	Tue	115	Y	112	120					112
3	Wed	112	Y	117	118					
4	Thu	112	Y	108	107					
5	Fri	*	Y	106	112					
6	Sat	*	Y	118	114					
7	Sun	*	Y	108	102					110
8	Mon	115	Y	114	110					
9	Tue	*	Y	107	104					106
10	Wed	*	Y	105	102					
11	Thu	120	Y	106	104					
12	Fri	129	Y	116	114					
13	Sat	139	Y	112	108					118
14	Sun	140	Y	112	114					
15	Mon	125	Y	112	112					122
16	Tue	130	Y	103	104					
17	Wed	130	Y	106	110					
18	Thu	122	Y	108	110					
19	Fri	133	Y	115	118					114
20	Sat	131	Y	116	110					120
21	Sun	130	Y	110	106					
22	Mon	130	Y	110	106					
23	Tue	133	Y	110	108					
24	Wed	133	Y	112	110					
25	Thu	108	Y	112	110					
26	Fri	108	Y	113	110					
27	Sat	133	Y	113	106					116
28	Sun	130	Y	110	108					
29	Mon	125	Y	110	106					
30	Tue	125	Y	112	109					114
31	Wed	140	Y	126	106					122
Average		103		0	0					106
Max										0
Min										
#>150										

* = Waiting on data retrieval software.

- NOTES:
- 1) Operator shall make a notation in the Instrumentation Log Book on a DAILY basis on the status of the On-Line Hardness Analyzer.
 - 2) Week is Sunday to Saturday
 - 3) WQ Lab is responsible for delivering monthly sample to outside lab.
 - 4) For any test with a hardness <95 mg/L or >145 mg/L, notify the Network Operations Superintendent and the Operations Supervisor immediately.