



Bricker & Eckler
ATTORNEYS AT LAW
COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sblloomfield@bricker.com

February 6, 2009

VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

**Re: Ohio American Water Company
Case No. 08-1233-WS-UNC**

Dear Ms. Jenkins:

Ohio American Water Company submits for filing the January 2009
Hardness Report for the Marion district.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

PUCO

2009 FEB -6 AM 10:22

RECEIVED-DOCKETING DIV

This is to certify that the images appearing are an
accurate and complete reproduction of a case file
document delivered in the regular course of business.
Technician Ann Date Processed 2/6/09

EFFLUENT HARDNESS / MG/L

January	RAW HARDNESS MG/L	EFFLUENT HARDNESS MG/L
1	450	142
2	437	142
3	431	144
4	431	138
5	400	140
6	420	137
7	460	148
8	450	142
9	480	145
10	500	144
11	495	141
12	498	143
13	498	140
14	505	145
15	506	141
16	513	145
17	542	138
18	553	137
19	558	138
20	546	133
21	557	144
22	560	136
23	550	135
24	550	146
25	560	142
26	558	144
27	560	150
28	554	134
29	554	132
30	553	138
31	533	143

AVERAGE	508	141
MAX	560	150
MIN	400	132

January 2009
EFFLUENT HARDNESS AVG - 141 MG/L
MARION DISTRICT

