

FILE

19



Bricker & Eckler
ATTORNEYS AT LAW
COLUMBUS • CLEVELAND

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

February 6, 2009

VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

**Re: Case No. 08-1233-WS-UNC
Ohio American Water Company
Stipulation Page No. 9, ¶13 E 4**

PUCO

RECEIVED-DOCKETING DIV
2009 FEB -6 AM 10:22

Dear Ms. Jenkins:

Pursuant to the Commission's November 12, 2008 Opinion and Order in Case No. 07-1112-WS-AIR, Ohio American Water Company ("Ohio American") submits for filing its compliance with the Stipulation and Recommendation, page 9 paragraph 13 E 4 pertaining to the submission of leak logs for the fourth quarter of 2008.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician Am Date Processed 2/6/09

Ohio American Water Company
Ashtabula District
2007 Water Leak Log

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSI = Private Service Leak; PVM = Private Water Main; PO = Private Other DR= Door Tag DTD= Door to Door

Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
DIANE	E SIDE		CSL	3/4"	N	1	DR		12/31/2007	1/2/2008	2	8 x 3	STREET	7/08	
WILSON	HARBOR		CWM	6"	Y	75	DTD	1/5/2008	1/4/2008	1/4/2008	0	20 x 8	STREET	7/08	
EASTWOOD	CENTRAL		CWM	6"	Y	11	DTD	1/6/2008	1/4/2008	1/4/2008	0	14 x 7	DRIVEWAY	4/08	
MICHIGAN	CENTRAL		CWM	2"	N	0			1/7/2008	1/8/2008	1	6 x 12	STREET	4/08	
HUMPHREY	CENTRAL		CWM	8"	N	0			1/7/2008	1/8/2008	1	6 x 12	TREELAWN	5/08	
GLOVER	CENTRAL		CSL	8"	N	0			1/7/2008	1/8/2008	1	6 x 12	TREELAWN	5/08	
FERG	W SIDE		CWM	2 1/2"	N	0			1/7/2008	1/8/2008	1	6 x 12	STREET	4/08	
WORTH	HARBOR		CWM	6"	N	0			1/7/2008	1/8/2008	1	6 x 12	STREET	4/08	
CHURCH	HARBOR		CWM	6"	Y	15	DTD	1/19/2008	1/16/2008	1/16/2008	0	8 x 10	STREET	4/08	
TIWISON	HARBOR		CSL	2"	Y	5	DTD	1/19/2008	1/16/2008	1/16/2008	0	8 x 10	STREET	4/08	
ALLEN	HARBOR		CWM	6"	Y	0			1/25/2008	1/25/2008	0	8 x 8	DRIVEWAY	6/08	
E 29TH	E SIDE		CWM	2"	Y	3	DTD	1/30/2008	1/28/2008	1/28/2008	0	10 x 13	STREET	5/08	
PARK	CENTRAL		CWM	12"	Y	0			1/25/2008	1/26/2008	1	12 x 12	OTHER	5/08	
FOREST & TALL TREES	N CENTRAL		CWM	6"	N	0			1/25/2008	1/26/2008	1	12 x 12	STREET	4/08	
W 18TH	CENTRAL		CWM	6"	N	0			1/25/2008	1/26/2008	1	12 x 12	STREET	4/08	
HUMPHREY	CENTRAL		CWM	2"	N	0			1/25/2008	1/26/2008	1	12 x 12	STREET	4/08	
SCHENLEY	HARBOR		CWM	6"	Y	12	DTD	1/30/2008	1/28/2008	1/28/2008	0	8 x 9	STREET	4/08	
TIWISON	HARBOR		CWM	2 1/2"	N	0			1/28/2008	1/28/2008	0	4 x 20	STREET	5/08	
WEST	W SIDE		CWM	6"	N	90			1/29/2008	1/30/2008	1	12 x 18	TREELAWN	5/08	
TOPPER	E SIDE		CLS	3/4"	N	0			1/31/2008	2/6/2008	6	4 x 5	STREET	4/08	
LARD	HARBOR		CWM	6"	N	0			1/31/2008	2/6/2008	6	4 x 5	STREET	4/08	
RT 20	CENTRAL		VLV	10"	N	0			2/1/2008	2/1/2008	0	4 x 6	STREET	4/08	
LAKE	CENTRAL		CWM	10"	N	0			2/1/2008	2/1/2008	0	10 x 40	TREELAWN	6/08	
CRAWFORD	HARBOR		CWM	10"	Y	26	DTD	2/5/2008	2/3/2008	2/3/2008	0	6 x 12	STREET	4/08	
W 9TH	CENTRAL		CSL	2"	N	0			2/4/2008	2/4/2008	0	4 x 5	STREET	4/08	
PARK	CENTRAL		CWM	2"	N	0			2/7/2008	2/7/2008	0	4 x 6	STREET	4/08	
MICHIGAN	E SIDE		CWM	2"	N	0			2/7/2008	2/8/2008	1	4 x 8	STREET	4/08	
SILVIEUS	E SIDE		CSL	3/4"	N	0			2/13/2008	2/13/2008	0	4 x 6	STREET	4/08	
S RIDGE W	HARBOR		CWM	10"	N	0			2/14/2008	2/15/2008	1	4 x 8	STREET	4/08	
E 15TH	HARBOR		CWM	3/4"	N	0			2/15/2008	2/15/2008	0	8 x 10	TREELAWN	6/08	
WALNUT	E SIDE		CWM	12"	N	0			2/15/2008	2/22/2008	7	8 x 10	TREELAWN	6/08	
LAKE	NK		CWM	4"	N	0			2/15/2008	2/22/2008	7	8 x 10	TREELAWN	6/08	
RT 15G	HARBOR		CWM	2 1/2"	N	0			2/15/2008	2/19/2008	0	4 x 6	STREET	4/08	
TIWISON	E SIDE		CWM	6"	N	0			2/22/2008	2/22/2008	0	8 x 25	TREELAWN	6/08	
E 42ND	W SIDE		CWM	8"	N	0			2/23/2008	2/23/2008	0	8 x 8	STREET	4/08	
MCNUTT	HARBOR		CWM	8"	N	0			2/24/2008	2/25/2008	1	5 x 8	STREET	4/08	
TIWISON	HARBOR		CWM	8"	Y	55	DTD	2/27/2008	2/27/2008	2/27/2008	0	4 x 10	TREELAWN	6/08	
HOMESWOOD	E SIDE		CSL	8"	Y	41	DTD	3/2/2008	2/29/2008	2/29/2008	0	6 x 14	STREET	4/08	
FARGO & E39TH	E SIDE		HYD	6"	N	0			3/3/2008	3/3/2008	0	6 x 8	TREELAWN	7/08	
RT 20	NK		HYD	6"	N	0			3/7/2008	3/7/2008	1	5 x 7	TREELAWN	7/08	
AVONDALE	E SIDE		VLV	2"	N	0			3/9/2008	3/9/2008	0	4 x 7	STREET	6/08	
E 39TH	E SIDE		CWM	2"	N	0			3/10/2008	3/10/2008	0	5 x 8	STREET	6/08	
W 29TH	W SIDE		CWM	2"	N	0			3/20/2008	3/20/2008	0	6 x 8	STREET	6/08	
E 29TH	E SIDE		CSL	3/4"	N	0			3/20/2008	3/20/2008	0	6 x 12	STREET	6/08	
ANN & W 41ST	HARBOR		CWM	2"	N	0			4/1/2008	4/1/2008	7	28 x 9	STREET	7/08	
LAKE	E SIDE		CWM	3/4"	Y	0			4/1/2008	4/1/2008	0	5 x 18	STREET	7/08	
2330 S RIDGE E	CENTRAL		VLV	2 1/2"	N	0			4/2/2008	4/2/2008	1	8 x 5	STREET	7/08	
333 FOX	HARBOR		CWM	2"	N	0			4/3/2008	4/3/2008	0	8 x 8	STREET	7/08	
4117 LAKE	E SIDE		CWM	12"	N	0			4/4/2008	4/4/2008	2	5 x 8	STREET	6/08	
LAKEVIEWCARTPENTER	HARBOR		CSL	12"	N	0			4/4/2008	4/4/2008	2	5 x 8	STREET	6/08	
4117 LAKE	HARBOR		CSL	3/4"	N	0			4/4/2008	4/4/2008	0	8 x 8	STREET	7/08	
3824 SILVIEUS	E SIDE		CWM	2"	N	0			4/6/2008	4/6/2008	0	7 x 8	STREET	7/08	
WOODLEY	HARBOR		CWM	2"	N	0			4/10/2008	4/10/2008	0	4 x 8	STREET	7/08	
FOX	CENTRAL		CWM	2 1/2"	N	0			4/10/2008	4/10/2008	2	4 x 16	DRIVEWAY	8/08	
KAVELA	HARBOR		CSL	3/4"	Y	8	DTD	4/11/2008	4/11/2008	4/11/2008	0	5 x 15	STREET	7/08	
5514 MAIN	CENTRAL		CWM	2"	N	0			4/18/2008	4/18/2008	1	5 x 5	STREET	8/08	
5818 MADISON	CENTRAL		CO	3/4"	N	0			4/18/2008	4/18/2008	3	4 x 5	TREELAWN	6/08	
3215 BLAIR	E SIDE		CWM	2"	N	0			4/18/2008	4/18/2008	2	12 x 8	TREELAWN	6/08	
5127 REED	CENTRAL		CSL	3/4"	N	0			4/18/2008	4/18/2008	1	2 x 4	TREELAWN	6/08	
7149 ALSTINBURG	CENTRAL		CSL	3/4"	N	0			4/25/2008	4/25/2008	1	5 x 12	TREELAWN	6/08	
1735 W 5TH	HARBOR		CSL	3/4"	N	0			4/25/2008	4/25/2008	1	4 x 4	TREELAWN	7/08	
2723 TRYON	W SIDE		CSL	3/4"	N	0			4/24/2008	4/24/2008	0	3 x 3	TREELAWN	7/08	
2514 ASHBROOK	W SIDE		CWM	8"	Y	15	DTD	4/30/2008	4/21/2008	4/21/2008	8	4 x 3	TREELAWN	6/08	

CSL = Company Service Leak, CWM = Company
Water Main; HYD = Hydrant; VLV = Valve; CO =
Company Other; PSL = Private Service Leak; PWM
= Private Water Main; PO = Private Other DR= Door
Tag DTD= Door to Door

Location	Service Area	Township	Leak Type	Size	Bell Order (Y or N)	Number of Services Affected	Method of Notification	Date Bell Order Lined	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
6415 EDWARD	CENTRAL		CWM	2 1/2"	N	0			4/23/2003	5/7/03	7	4 x 8	STREET	9/03	
932 BUNKER HILL	HARBOR		CWM	2"	N	0			4/26/03	4/26/03	1	6 x 8	TREELAWN	9/03	
1817 W 9TH	HARBOR		CSL	6"	N	0			5/1/2003	5/1/03	0	6 x 7	STREET	9/03	
5006 N WOODMAN	W SIDE		CWM	6"	Y	0			5/4/2003	5/4/03	0	6 x 6	TREELAWN	9/03	
6243 RUNKLE	CENTRAL		CWM	2"	N	13	DTD	5/5/2003	4/23/2003	5/5/03	12	3 x 4	STREET	9/03	
7424 AUSTINBURG	CENTRAL		CSL	3/4"	N	0			4/26/2003	5/5/03	10	10 x 5	TREELAWN	9/03	
733 E 14TH	HARBOR		CSL	3/4"	N	0			5/5/2003	5/5/03	0	4 x 4	SIDEWALK	9/03	
2636 E CENTER	NK		VLV	8"	N	0			5/6/2003	5/6/03	0	4 x 4	TREELAWN	7/03	
2001 BROADWAY	W SIDE		CWM	6"	N	0			5/15/2003	5/15/03	0	6 x 8	STREET	9/03	
6317 AUSTIN	CENTRAL		CWM	6"	N	0			5/15/2003	5/15/03	0	4 x 8	TREELAWN	9/03	
1257 HARMON	E SIDE		CWM	6"	N	0			5/15/2003	5/15/03	0	8 x 12	DRIVEWAY	9/03	
4011 THAYER	HARBOR		CSL	3/4"	N	0			5/21/2003	5/21/03	0	4 x 6	STREET	9/03	
LINCOLN	E SIDE		CWM	6"	N	0			5/21/2003	5/21/03	0	8 x 10	DRIVEWAY	9/03	
6235 AUSTIN	CENTRAL		VLV	6"	N	0			5/30/2003	5/30/03	0	8 x 12	TREELAWN	7/03	
6431 FOREST	CENTRAL		CSL	3/4"	N	0			6/2/2003	6/2/03	4	3 x 4	TREELAWN	7/03	
1520 W 7TH	HARBOR		CWM	2 1/2"	N	0			6/12/2003	6/12/03	0	3 x 4	TREELAWN	7/03	
1542 COLUMBUS	HARBOR		CWM	8"	Y	8	DTD	6/14/2003	6/13/2003	6/13/03	0	12 x 12	STREET	9/03	
5019 S MAIN	CENTRAL		CSL	2"	N	0			6/13/2003	6/16/03	3	6 x 6	STREET	9/03	
1016 W 54TH	W SIDE		CSL	3/4"	N	0			6/18/2003	6/18/03	0	4 x 5	TREELAWN	9/03	
1316 W 47TH	W SIDE		CWM	2"	N	0			6/18/2003	6/18/03	0	17 x 14	STREET	9/03	
3113 BLAIR	E SIDE		CWM	2"	N	0			6/19/2003	6/19/03	0	4 x 10	STREET	9/03	
2511 HIGHLAND	HARBOR		CWM	2"	N	0			6/19/2003	6/19/03	0	4 x 7	STREET	9/03	
3730 SOUTHLANE	HARBOR		CSL	3/4"	N	0			6/21/2003	6/21/03	0	5 x 7	TREELAWN	9/03	
3817 WEST	W SIDE		CSL	6"	N	0			6/25/2003	6/25/03	0	5 x 5	STREET	9/03	
1211 NORWOOD	HARBOR		CSL	3/4"	N	0			6/21/2003	6/21/03	0	4 x 4	TREELAWN	9/03	
FERRY DR.	HARBOR		CWM	8"	N	0			7/2/2003	7/2/03	0	8 x 5	TREELAWN	9/03	
LAKE AVE. & RODGERS PL	CENTRAL		VLV	6"	N	0			7/2/2003	7/7/03	5	6 x 6	STREET	9/03	
727 W 38TH ST.	CENTRAL		CWM	2"	N	0			7/12/2003	7/18/03	1	5 x 5	STREET	9/03	
3207 BLAIR AVE.	E SIDE		CWM	2"	N	0			7/25/03	7/25/03	6	3 x 3	DRIVEWAY	9/03	
515 W 35TH ST	CENTRAL		CSL	3/4"	N	0			7/26/2003	7/26/03	0	4 x 4	TREELAWN	9/03	
FOREST & TALL TREES	N. CENTRAL		CWM	6"	N	0			7/29/2003	7/29/03	0	8 x 12	STREET	9/03	
1011 W PROSPECT	CENTRAL		PSL	3/4"	N	0			8/1/2003	8/1/03	0		STREET	9/03	
5816 MAIN AVE.	CENTRAL	NK	CSL	3/4"	N	0			8/4/2003	8/7/03	3	4 x 6	TREELAWN	9/03	
7320 KINGSBORO	CENTRAL		CSL	8"	N	20			8/7/2003	8/7/2003	0	4 x 6	TREELAWN	9/03	
622 W 38TH ST.	CENTRAL		CSL	3/4"	N	0			8/15/2003	8/15/2003	2	4 x 4	TREELAWN	9/03	
574 SANBORN RD.	CENTRAL	SAYBROOK	CWM	8"	N	24			8/15/2003	8/20/2003	5	6 x 5	TREELAWN	9/03	
W 63RD ST & RUNKLE AVE.	S. CENTRAL		CWM	2"	N	4			8/15/2003	8/20/2003	5	6 x 5	STREET	9/03	
4709 FERN AVE.	W. CENTRAL		CWM	2.5"	N	7			8/21/2003	8/21/2003	0	4 x 15	STREET	9/03	
WESTSHORE DR.	HARBOR		HYD	5"	N	23			8/21/2003	8/25/2003	4	12 x 12	TREELAWN	9/03	
1803 W 14TH ST.	HARBOR		CWM	2"	N	0			8/26/2003	8/26/2003	3	5 x 8	STREET	9/03	
4629 TOPPER AVE.	E. CENTRAL		CWM	8"	N	0			8/29/2003	8/29/2003	5	4 x 6	STREET	9/03	
106 W 58TH ST.	S. CENTRAL		CWM	2.5"	N	0			8/29/2003	8/29/2003	5	4 x 8	TREELAWN	10/03	
526 TALL TREES	HARBOR		CWM	2"	N	0			9/2/2003	9/2/2003	3	4 x 6	TREELAWN	10/03	
3817 SILVIEUS	E. SIDE		CWM	6"	N	0			9/2/2003	9/2/2003	4	5 x 12	STREET	10/03	
CARPENTER	HARBOR		CWM	8"	N	0			9/2/2003	9/2/2003	2	8 x 9	STREET	10/03	
1207 W 8TH ST.	HARBOR		CSL	3/4"	N	0			9/10/2003	9/10/2003	4	5 x 13	STREET	10/03	
4015 DENISE DR.	HARBOR	NK	CWM	2"	N	0			9/16/2003	9/22/2003	6	8 x 5	STREET		RESTORATION TO BE DONE
E. 31ST & COLUMBUS	CENTRAL		CWM	20"	N	22			9/18/2003	9/25/2003	7	10 x 12	TREELAWN		RESTORATION TO BE DONE
3328 BLAKE	CENTRAL	NK	CWM	6"	N	0			9/25/2003	9/25/2003	0	4 x 6	TREELAWN		RESTORATION TO BE DONE
UNION & HIGHLAND CRO.	HARBOR		CWM	2"	N	0			9/19/2003	9/26/2003	7	7 x 8	STREET	10/03	
531 COLUMBUS AVE.	CENTRAL		CWM	6"	N	1			9/26/2003	9/26/2003	4	4 x 8	TREELAWN		RESTORATION TO BE DONE
WASHINGTON AVE.	S. CENTRAL	ASH. TWSP.	CWM	2"	N	3			10/1/2003	10/1/2003	0	6 x 6	STREET	10/03	
3115 CREEK RD.	CENTRAL	NK	CWM	10"	N	11			9/29/2003	10/6/2003	8	7 x 12	DRIVEWAY	10/03	
1701 E. 30TH ST.	CENTRAL		CWM	2"	N	15			10/14/2003	10/14/2003	0	10 x 6	SIDEWALK	10/03	
1701 E. 30TH ST.	CENTRAL		CWM	2"	N	15			10/14/2003	10/14/2003	0	7 x 4	STREET	10/03	
5818 MADISON	S. CENTRAL		CWM	2"	N	0			10/17/2003	10/17/2003	0	4 x 5	TREELAWN		RESTORATION TO BE DONE
6236 JEFFERSON RD.	S. CENTRAL		CWM	8"	N	0			10/20/2003	10/20/2003	2	8' x 10'	TREELAWN		RESTORATION TO BE DONE
3225 GLOVER DR.	S. CENTRAL		CSL	3/4"	N	1			10/22/2003	10/28/2003	6	6' x 8'	TREELAWN		RESTORATION TO BE DONE
CARPENTER & WARRICK	CENTRAL	SAYBROOK	CWM	2"	N	0			10/23/2003	10/29/2003	6	8 x 9	STREET	11/10/03	
1501 W. 17TH ST.	W. CENTRAL		CSL	3/4"	Y	1	DTD	11/4/2003	11/3/2003	11/4/2003	1	4 x 6	TREELAWN		RESTORATION TO BE DONE
1501 W. 17TH ST.	W. CENTRAL		CSL	3/4"	Y	1	DTD	11/4/2003	11/3/2003	11/4/2003	1	4 x 5	STREET	11/03	
527 NATIONAL PLG	S. CENTRAL		CWM	2"	N	0			11/3/2003	11/4/2003	0	4 x 20	STREET		RESTORATION TO BE DONE
4507 WEST AVE.	S. CENTRAL		CWM	10"	N	45			11/6/2003	11/7/2003	1	7 x 8	STREET		RESTORATION TO BE DONE
600 W 46TH ST	HARBOR		CSL	3/4"	N	1			11/6/2003	11/11/2003	5	4 x 8	STREET		RESTORATION TO BE DONE
5609 MADISON AVE.	HARBOR	ASH. TWSP.	HYD	6"	N	0			11/6/2003	11/12/2003	2	6 x 5	TREELAWN		RESTORATION TO BE DONE
RT. 23 & WASHINGTON	CENTRAL	SAYBROOK	CWM	12"	N	0			11/13/2003	11/13/2003	0	20 x 20	DRIVEWAY		RESTORATION TO BE DONE
741 W. 39TH ST.	CENTRAL		CSL	3/4"	N	0			11/6/2003	11/13/2003	7	3 x 5	TREELAWN		RESTORATION TO BE DONE
5016 BLAKESLEE	CENTRAL	ASH. TWSP.	CSL	2"	N	1			11/18/2003	11/20/2003	2	5 x 8	TREELAWN		RESTORATION TO BE DONE
4136 MAIN AVE.	CENTRAL		CSL	3/4"	N	1			11/20/2003	11/20/2003	5	6 x 10	STREET		RESTORATION TO BE DONE
1204 PENNSYLVANIA AVE.	HARBOR		CSL	6"	N	14			11/26/2003	11/26/2003	0	5 x 10	TREELAWN		RESTORATION TO BE DONE

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other DR= Door Tag DTD= Door to Door

Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
2528 WALNUT BLVD.	HARBOR		CSL	3/4"	N	0	0		11/26/2008	11/26/2008	0	2' X 4'	STREET		RESTORATION TO BE DONE
3441 SPENCER	CENTRAL		CSL	3/4"	N	0	0		11/26/2008	11/26/2008	4	9' X 9'	STREET		RESTORATION TO BE DONE
COLUMBUS AVE. & E. 31ST.	CENTRAL		CWM	20"	N	0	0		11/26/2008	11/26/2008	13	6' X 12'	STREET		RESTORATION TO BE DONE
516 NATIONAL PLACE	S. CENTRAL		CWM	2"	N	2	2		11/26/2008	12/1/2008	3	5' X 13'	STREET		RESTORATION TO BE DONE
3043 AVONDALE		ASH. TWSP.	VLV	4"	N	0	0		12/4/2008	12/4/2008	1	4' X 5'	DRIVEWAY		RESTORATION TO BE DONE
6326 HIRAN		ASH. TWSP.	CWM	12.5"	N	0	0		12/7/2008	12/8/2008	2	4' X 7'	STREET		RESTORATION TO BE DONE
RT. 30 & VINELAND		ASH. TWSP.	CWM	16"	N	0	0		12/10/2008	12/10/2008	0	35' X 6'	STREET		RESTORATION TO BE DONE
LAKE RD. & EDGEWATER	HARBOR		CWM	10"	N	20	20		12/10/2008	12/10/2008	0	4' X 15'	STREET		RESTORATION TO BE DONE
MAIN AVE. & PARK PL.	S. CENTRAL		CWM	3/4"	N	0	0		12/10/2008	12/10/2008	0	5' X 6'	STREET		RESTORATION TO BE DONE
8405 EDWARD AVE.	S. CENTRAL		CSL	2.5"	N	1	1		12/27/2008	12/27/2008	2	8' X 4'	STREET		RESTORATION TO BE DONE
8405 EDWARD AVE.	S. CENTRAL		CSL	2.5"	N	1	1		12/27/2008	12/29/2008	2	8' X 4'	STREET		RESTORATION TO BE DONE
8535 CONLEY	CENTRAL		CWM	2"	N	0	0		12/29/2008	12/29/2008	1	7'	DRIVEWAY		RESTORATION TO BE DONE

Ohio American Water Company
Franklin County District
2008 Water Leak Log

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other

Updated: 1/20/2009																
Count	Location	Service Area	Township	Leak Type	Size	Soil Order (Y or N)	Number of Customers Affected	Method of Notification	Date Bill Offered	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comments
1	3318 Latonia	BL	Madison	CSL	3/4"	N	1	N/A	N/A	1/10/08	1/10/08	4	3X5	Dir	6/24/2008	Customer made appt. to have service shut off for repairs. Curb valve would not shut off completely. CV found
2	5310 Vedun	BL	Madison	CSL	3/4"	N	1	N/A	N/A	1/10/08	1/10/08	7	3X5	Dir	4/30/2008	Curb valve leaking. CV replaced
3	3337 Windover Court	BL	Madison	PSL	3/4"	N	1	N/A	N/A	1/10/08	1/15/08	4	PSL	PSL	PSL	Private Leak-Repaired
4	3770 Fairview	BL	Madison	CSL	3/4"	N	1	N/A	N/A	2/7/08	2/20/08	13	3X5	Dir	6/24/2008	Curb valve leaking. CV replaced
5	3555 Wynote	BL	Madison	CSL	3/4"	N	1	N/A	N/A	2/11/08	2/19/08	8	3X5	Dir	4/30/2008	Curb valve leaking. CV replaced
6	5663 Sedalia	BL	Madison	CSL	3/4"	N	1	N/A	N/A	2/22/08	3/5/08	11	3-5	Dir	6/24/2008	Curb valve leaking-CV replaced
7	3840 Laguna	BL	Madison	CSL	2"	N	0	N/A	N/A	3/2/08	3/9/08	1	5X5	Dir	PSL	12" raw water main leak-Repaired with clamp
8	5113 Sedalia	BL	Madison	PSL	3/4"	N	1	N/A	N/A	3/13/08	3/13/08	1	PSL	PSL	PSL	Contractor hit meter inside shopping center while doing demolition-Shut off at curb valve-Suite are being
9	4837 Brewster Drive	BL	Madison	PSL	3/4"	N	1	N/A	N/A	3/15/08	4/1/08	7	PSL	PSL	PSL	Private Leak-Repaired
10	4827 Brewster Drive	BL	Madison	CSL	3/4"	N	1	N/A	N/A	4/7/08	4/7/08	2	3-5	Dir	6/24/2008	Flare fitting leaking at corp stop. Replaced service from main to new curb valve
11	3349 Tremaine	BL	Madison	CSL	3/4"	N	1	N/A	N/A	4/23/08	4/29/08	6	3X5	Dir	6/24/2008	Curb valve leaking-CV replaced
12	3424 Beechworth	BL	Madison	PSL	3/4"	N	2	N/A	N/A	5/6/08	5/22/08	14	5X5	Dir	PSL	Private Leak-Repaired
13	3172 Portman	BL	Madison	PSL	3/4"	N	1	N/A	N/A	5/6/08	5/19/08	11	PSL	PSL	PSL	Curb valve leaking. CV replaced
14	3262 Fontaine	BL	Madison	CSL	3/4"	N	1	N/A	N/A	5/20/08	5/29/08	8	3X5	Dir	6/24/2008	Company service leak-Repaired
15	5013 Brewster	BL	Madison	CSL	3/4"	N	1	N/A	N/A	5/28/08	5/31/08	8	3X5	Dir	6/24/2008	Company service leak-Repaired
16	2968 Olivette	BL	Madison	PSL	3/4"	N	1	N/A	N/A	6/9/08	6/13/08	4	PSL	PSL	PSL	Private Leak-Repaired
17	3384 Andy	BL	Madison	PSL	3/4"	N	1	N/A	N/A	6/11/08	6/12/08	1	PSL	PSL	PSL	Private Leak-Repaired
18	5590 Newport Court	BL	Madison	CSL	3/4"	N	1	N/A	N/A	7/10/08	7/14/08	4	3X5	Dir	Pending	Company valve leaking-CV replaced
19	4979 Euclid	BL	Madison	CSL	3/4"	N	1	N/A	N/A	7/11/08	7/14/08	3	3X5	Dir	Pending	Company service leak-Repaired
20	4864 Brewster	BL	Madison	CSL	3/4"	N	1	N/A	N/A	7/14/08	7/21/08	7	6X10	Pavement	Pending	Company service leak-Repaired
21	3511 Rodell	BL	Madison	CSL	3/4"	N	1	N/A	N/A	7/17/08	7/22/08	5	3X5	Dir	Pending	Company valve leaking-CV replaced
22	4947 Albany	BL	Madison	PSL	3/4"	N	1	N/A	N/A	7/22/08	7/25/08	3	PSL	PSL	PSL	Private Leak-Repaired
23	3699 Alanya	BL	Madison	PSL	3/4"	N	1	N/A	N/A	7/29/08	8/12/08	16	PSL	PSL	PSL	Private Leak Shut off on 8/6/08. Repaired on 8/16/08
24	4868 Euclid	BL	Madison	CSL	3/4"	N	1	N/A	N/A	8/5/08	8/19/08	7	3X5	Dir	Pending	Company water main leak-Repaired
25	5452 Newport	BL	Madison	CWM	12"	Y	39	Door to Door	8/12/08	8/13/08	8/11/08	1	5X5	Pavement	Pending	Company service leak-Repaired
26	3424 & 3436 Beechworth	BL	Madison	CSL	3/4"	N	1	N/A	N/A	8/13/08	8/14/08	1	6X10	Dir	Pending	Company service leak-Repaired
27	3949 Euclid	BL	Madison	CSL	3/4"	N	1	N/A	N/A	8/17/08	8/29/08	2	3X5	Dir	Pending	Company service leak-Repaired
28	5043 Fullerton	BL	Madison	CSL	3/4"	N	1	N/A	N/A	9/10/08	9/24/08	14	3X5	Dir	Pending	Company service leak-Repaired
29	2560 Rodell	BL	Madison	CSL	3/4"	N	1	N/A	N/A	9/12/08	9/24/08	12	3X5	Dir	Pending	Company service leak-Repaired
30	3283 Dunlop	BL	Madison	CSL	3/4"	N	1	N/A	N/A	9/19/08	9/24/08	5	3X5	Dir	Pending	Company service leak-Repaired
31	3203 Sundale Road	BL	Madison	PSL	3/4"	N	1	N/A	N/A	9/29/08	10/10/08	11	PSL	PSL	PSL	Private Leak-Repaired
32	3019 Bost	BL	Madison	CSL	3/4"	N	1	N/A	N/A	10/1/08	10/21/08	20	Pending	Pending	Pending	Company service leak-Repaired
33	Aurelia & Benlier	BL	Madison	CWM	6"	N	0	N/A	N/A	10/2/08	10/14/08	12	Pending	Pending	Pending	Company service leak-Repaired
34	3413 Laguna Drive	BL	Madison	PSL	3/4"	N	1	N/A	N/A	10/14/08	10/31/08	7	3X5	PSL	Pending	Company service leak-Repaired
35	3418 Everson Road	BL	Madison	PSL	3/4"	N	1	N/A	N/A	10/15/08	10/17/08	2	PSL	PSL	PSL	Private Leak-Repaired
36	3338 Latonia Court	BL	Madison	PSL	3/4"	N	1	N/A	N/A	10/20/08	10/28/08	8	3X5	Dir	Pending	Company service leak-Repaired
37	4550 Harbor	BL	Madison	CSL	3/4"	N	1	N/A	N/A	10/24/08	11/6/08	13	3X5	Dir	Pending	Company service leak-Repaired
38	3408 Andy	BL	Madison	CSL	3/4"	N	1	N/A	N/A	11/14/08	11/20/08	26	3X5	Dir	Pending	Company service leak-Repaired
39	3451 Tremaine	BL	Madison	CSL	3/4"	N	1	N/A	N/A	11/14/08	11/20/08	16	3X5	Dir	Pending	Company service leak-Repaired
40	3163 Fontaine	BL	Madison	PSL	3/4"	N	1	N/A	N/A	11/14/08	11/20/08	11	PSL	PSL	Pending	Company service leak-Repaired
41	4337 Sundry Rd	HR	Blenden	CWM	6"	N	1	N/A	N/A	11/19/08	11/30/08	12	PSL	PSL	PSL	Private Leak-Repaired
42	3580 Panama	HR	Blenden	CWM	8"	N	N/A	N/A	N/A	12/25/2007	12/26/2007	2	6X6	Pmt/Soil	6/24/2008	Drive approach replaced in January. Soil touched up in June
43	3570 Carriage Ct	HR	Blenden	CWM	6"	Y	19	Door Hangers	1/18/2008	1/23/2008	5	3X6	Soil	4/24/2008	Leak occurred while disconnecting customer who had turned service on illegally.	
44	5798 Montevideo	HR	Blenden	CWM	6"	Y	22	Door Hangers	3/10/2008	3/10/2008	3/12/2008	2	3X6	Soil	4/25/2008	Service replaced under street. Sidewalk restored 4/3/08
45	6006 Sunwood Pl	HR	Blenden	CSL	3/4"	N	N/A	N/A	N/A	3/17/2008	3/16/2008	1	3X6 (2)	Pmt/Soil	4/24/2008	Service replaced under street. Soil restoration completed both sides of street.
46	4261 Valley Quail N	HR	Blenden	CSL	3/4"	N	N/A	N/A	N/A	3/24/2008	3/24/2008	1	3X6	Pmt/Soil	4/25/2008	Service replaced under street. Soil restoration completed both sides of street.
47	4361 Valley Quail N	HR	Blenden	PSL	3/4"	N	N/A	N/A	N/A	3/24/2008	3/25/2008	2	3X6 (2)	Soil	4/24/2008	Turned water off 6/13/08 for not making repairs.
48	5580 Copenhagen	HR	Blenden	VLV	4-1/2"	N	N/A	N/A	N/A	5/29/2008	5/30/2008	23	N/A	N/A	N/A	Hydrant valve - no excavation necessary
49	4497 Valley Quail N	HR	Blenden	PSL	3/4"	N	N/A	N/A	N/A	6/18/2008	7/37/2008	29	8	N/A	N/A	Customer claimed he had WUPP but was trying to sign up after leak confirmed
50	4456 Scissortail Loop	HR	Blenden	PSL	3/4"	N	N/A	N/A	N/A	7/12/2008	7/10/2008	8	N/A	N/A	N/A	
51	4419 Valley Quail N	HR	Blenden	PSL	3/4"	N	N/A	N/A	N/A	7/15/2008	7/25/2008	11	N/A	N/A	N/A	
52	4419 Valley Quail N	HR	Blenden	PSL	3/4"	N	N/A	N/A	N/A	7/15/2008	7/23/2008	8	N/A	N/A	N/A	
53	4432 Scissortail Loop	HR	Blenden	PSL	3/4"	N	N/A	N/A	N/A	7/16/2008	7/23/2008	7	N/A	N/A	N/A	
54	6498 Purplefinch Ct	HR	Blenden	PSL	3/4"	N	N/A	N/A	N/A	7/16/2008	7/24/2008	7	N/A	N/A	N/A	
55	3358 Hunt Club N	HR	Blenden	PSL	3/4"	N	N/A	N/A	N/A	7/30/2008	8/7/2008	9	N/A	N/A	N/A	Turned off for Non Pay 8/7/08; still off
56	3550 Hunt Club N	HR	Blenden	PSL	3/4"	N	N/A	N/A	N/A	8/5/2008	8/5/2008	1	N/A	N/A	N/A	
57	3653 Paris N	HR	Blenden	PSL	3/4"	N	N/A	N/A	N/A	8/8/2008	8/9/2008	27	N/A	N/A	N/A	
58	4221 Valley Quail S	HR	Blenden	PSL	3/4"	N	N/A	N/A	N/A	8/20/2008	8/20/2008	1	N/A	N/A	N/A	
59	4027 Beauty Rose	HR	Blenden	PSL	3/4"	N	N/A	N/A	N/A	9/16/2008	9/23/2008	7	N/A	N/A	N/A	
60	6488 Woodthrush	HR	Blenden	PSL	3/4"	N	N/A	N/A	N/A	9/26/2008	9/30/2008	5	N/A	N/A	N/A	
61	6475 Jesamine Ct	HR	Blenden	PSL	3/4"	N	N/A	N/A	N/A	10/2/2008	10/9/2008	8	N/A	N/A	N/A	
62	3370 Annet Ct	HR	Blenden	CWM	6"	N	N/A	N/A	N/A	10/7/2008	10/7/2008	1	6X6	Pmt/Soil	Pending	
63	5310 Hempstead	HR	Blenden	PSL	3/4"	N	N/A	N/A	N/A	10/15/2008	10/15/2008	1	N/A	N/A	N/A	
64	3828 Paris	HR	Blenden	HYD	5-3/4"	N	N/A	N/A	N/A	10/29/2008	10/29/2008	1	N/A	N/A	N/A	
65	3360 Dempsey	HR	Blenden	CWM	8"	Y	4	Door Hangers	11/13/2008	11/13/2008	11/13/2008	1	6X6	Pmt	Pending	
66	5824 Leaz Ct	HR	Blenden	CWM	2"	Y	5	Door Hangers	11/16/2008	11/16/2008	11/16/2008	2	6X6	Soil	Pending	
67	3730 Dempsey	HR	Blenden	VLV	6"	N	N/A	N/A	N/A	12/17/2008	12/17/2008	3	6X6	Soil	Pending	
68	3500 Cantera Ct	HR	Blenden	VLV	2"	Y	18	Door Hangers	12/15/2008	12/15/2008	12/17/2008	3	6X6	Soil	Pending	
69	4291 Valley Quail S	HR	Blenden	PSL	3/4"	N	N/A	N/A	N/A	12/16/2008	12/30/2008	11	N/A	N/A	N/A	
70	5725 Vienna	HR	Blenden	VLV	2"	N	N/A	N/A	N/A	12/12/2008	12/29/2008	8	6X6	Pmt/Soil	Pending	
71	3922 Silhouette Drive	LD	Prairie	PSL	3/4"	N	1	N/A	N/A	1/1/08	1/1/08	6	PSL	PSL	PSL	Private Leak-Repaired
72	742 Silhouette Drive	LD	Prairie	PSL	3/4"	N	1	N/A	N/A	1/22/08	1/22/08	2	PSL	PSL	PSL	Private Leak-Repaired. Meter was replaced per length of service

Count	Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Customers Affected	Method of Notification	Date Boil Order Unfired	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comments
73	8871 Crestridge Court	LD	Prairie	PSL	PSL	N	1	N/A	N/A	2/14/08	2/13/08	7	PSL	PSL	PSL	Originally thought to be a meter shut off valve leak. Turn out to be a leak in customer's house plumbing.
74	237 Hubbard Road	LD	Prairie	PSL	PSL	N	1	N/A	N/A	2/15/08	2/16/08	1	PSL	PSL	PSL	Private Leak-Repaired
75	8782 Crestwater Drive	LD	Prairie	PSL	3/4"	N	0	N/A	N/A	3/16/08	3/13/08	5	PSL	PSL	PSL	Private Leak-Repaired
76	8496 Silverbell	LD	Prairie	CSL	3/4"	N	0	N/A	N/A	5/16/08	5/10/08	14	3X5	Dirt	6/20/2008	Disconnected leaking service line. Service not connected to a home.
77	8440 Military Court	LD	Prairie	CWM	2"	Y	6	Door to Door	6/2/08	5/31/08	5/31/08	2	6X5	Pavement	7/16/2008	Someone outside of the Co. attempted to turn on the service at 8440 Military Court. The blow-off valve was
78	Fairbrook and Hubbard	LD	Prairie	CWM	6"	Y	50	Door to Door	6/9/08	6/7/08	6/9/08	2	5X5	Dirt	6/25/08	Fire Hydrant hit by automobile-Repaired
79	8395 Silverbell	LD	Prairie	PSL	PSL	N	1	N/A	N/A	8/13/08	8/16/08	3	PSL	PSL	PSL	Private Leak-Repaired
80	8376 Renata	LD	Prairie	PSL	PSL	N	1	N/A	N/A	6/26/08	6/27/08	1	PSL	PSL	PSL	Private Leak-Repaired
81	862 Lakeland Drive	LD	Prairie	PSL	PSL	N	1	N/A	N/A	7/2/08	7/18/08	6	PSL	PSL	PSL	Private Leak-Repaired
82	8887 Canoe	LD	Prairie	CWM	6"	N	0	N/A	N/A	7/21/08	7/23/08	2	5X5	pavement	Pending	Company water main leak - Repaired
83	8433 Edincrest	LD	Prairie	PSL	PSL	N	1	N/A	N/A	10/9/08	10/6/08	3	PSL	PSL	PSL	Private Leak-Repaired
84	247 Innerrest	LD	Prairie	PSL	PSL	N	1	N/A	N/A	10/10/08	10/27/08	19	PSL	PSL	PSL	Private Leak-Repaired
85	8399 Fairbrook	LD	Prairie	PSL	PSL	N	1	N/A	N/A	10/21/08	10/25/08	4	PSL	PSL	PSL	Private Leak-Repaired
86	8628 Edgewater	LD	Prairie	CSL	3/4"	Y	38	Door to Door	12/5/08	12/19/08	12/19/08	1	5X10	Dirt	Pending	Company service leak-Repaired, leak at tapping saddle, found old threads into AC main, removed and threaded
87	8071 Lakeland	LD	Prairie	PSL	PSL	N	1	N/A	N/A	12/19/08	12/29/08	10	PSL	PSL	PSL	Private Leak-Repaired
88	1821 Brentfield Place	TB	North	CSL	3"	Y	5	Door to Door	5/11/08	5/15/08	5/12/08	7	5X5	Pvment	6/24/2008	Company main joint leak-Repaired
89	6189 Meadow Wood Lane	TB	North	CSL	6"	N	1	N/A	N/A	5/16/08	5/16/08	1	10X8	Dirt	7/3/2008	Company main leaking-Repaired
90	6211 Meadow Wood Lane	TB	North	CVLV	6"	N	0	N/A	N/A	5/13/08	5/13/08	6	3X5	Dirt	6/25/2008	Main valve leaking-Repaired
91	1596 Valleycrest Drive	TB	North	PSL	PSL	N	1	N/A	N/A	7/11/08	7/19/08	8	PSL	PSL	PSL	Private Leak
92	1796 Hickory Hill	TB	North	PSL	PSL	N	1	N/A	N/A	8/11/08	8/22/08	11	PSL	PSL	PSL	Private Leak-Repaired
93	6080 Hickory Hill Place	TB	North	PSL	PSL	N	1	N/A	N/A	9/25/08	10/2/08	7	PSL	PSL	PSL	Private Leak-Repaired
94	1667 Valley Crest	TB	North	CSL	6"	Y	31	Door to Door	10/6/08	10/4/08	10/5/08	1	5X5	Dirt	Pending	Company water main leak - Repaired
95	1719 Silverbrook	TB	North	PSL	PSL	N	1	N/A	N/A	10/9/08	10/10/08	2	PSL	PSL	PSL	Private Leak-Repaired
96	1761 Shadybrook	TB	North	CSL	2"	N	0	N/A	N/A	12/13/2007	Pending	Pending	3X6	Soil	4/28/2008	Blow off valve leading by, leak isolated at curb valve on 12/23/08
97	1465 Candlewood	WH	Perry	CWM	6"	N	N/A	N/A	N/A	12/10/2007	12/10/2007	3	3X6	Soil	6/25/2008	Original restoration in April; touched up due to settling in June
98	1154 Blindbrook	WH	Perry	CWM	8"	N	N/A	N/A	N/A	2/5/2008	2/19/2008	2	3X6	Soil	6/25/2008	
99	1248 Clubview 5	WH	Perry	CWM	8"	N	N/A	N/A	N/A	2/28/2008	2/29/2008	2	3X6	Soil	6/25/2008	
100	8222 Copperfield Dr	WH	Perry	PSL	3/4"	N	N/A	N/A	N/A	4/9/2008	4/10/2008	2	N/A	N/A	N/A	
101	1515 Newcomer	WH	Perry	PSL	3/4"	N	N/A	N/A	N/A	5/9/2008	5/15/2008	6	N/A	N/A	N/A	
102	1395 Rungelview	WH	Perry	CWM	6"	N	N/A	N/A	N/A	6/17/2008	6/23/2008	6	3X6	Soil	7/6/2008	
103	1623 Tenyson Ct	WH	Perry	PSL	3/4"	N	N/A	N/A	N/A	8/15/2008	8/15/2008	4	N/A	N/A	N/A	
104	1336 Hickory Ridge	WH	Perry	CWM	5"	N	N/A	N/A	N/A	9/30/2008	10/29/2008	2	3X6	Pvmt/Soil	Pending	Small blacktop patch needed
105	1584 Newcomer	WH	Perry	CSL	3/4"	N	N/A	N/A	N/A	10/1/2008	10/29/2008	28	3X6	Soil	Pending	
106	888 Mission Hills	WH	Sharon	CWM	5"	N	N/A	N/A	N/A	10/6/2008	10/8/2008	1	3X6	Soil	Pending	
107	1510 Oakburne Dr	WH	Perry	CWM	5"	N	N/A	N/A	N/A	10/14/2008	10/14/2008	1	6X6	Pvmt/Soil	11/5/2008	
108	816 Colony Ct	WH	Sharon	CWM	5"	Y	25	Door Hangers	10/16/2008	10/16/2008	10/16/2008	1	6X60	Pvmt	11/14/2008	
109	8237 Copperfield	WH	Perry	PSL	3/4"	N	N/A	N/A	N/A	10/23/2008	10/29/2008	7	N/A	N/A	N/A	
110	1440 Clubview N	WH	Perry	CWM	8"	N	N/A	N/A	N/A	10/23/2008	10/23/2008	1	6X6	Pvmt/Soil	Pending	
111	7928 Greendale Ln	WH	Perry	PSL	3/4"	N	N/A	N/A	N/A	11/4/2008	11/10/2008	7	N/A	N/A	N/A	
112	816 Colony Ct	WH	Sharon	CWM	5"	N	N/A	N/A	N/A	11/12/2008	11/12/2008	1	6X6	Soil	Pending	
113	908 Clubview N	WH	Sharon	CWM	6"	N	N/A	N/A	N/A	11/15/2008	11/17/2008	3	6X6	Soil	Pending	
114	1184 Circle on Green	WH	Perry	CWM	6"	N	N/A	N/A	N/A	12/1/2008	12/1/2008	2	6X6	Pvmt	Pending	
115	8200 Copperfield	WH	Perry	CWM	6"	N	N/A	N/A	N/A	12/4/2008	12/4/2008	1	6X6	Soil	Pending	

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWMI = Private Water Main; PO = Private Other; DR = Door Tag; DTD = Door to Door Date
Date Boil

[illegible]

Ohio American Water Company
Lawrence County District
2008 Water Leak Log

CSL = Company Service Leak; CWM = Company Water Main; HTD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other; DR = Door Tag; DTD = Door to Door

Location	Service Area	Township	Leak Type	Size	Ball Order (Y or N)	Number of Services Affected	Method of Notification	Date Ball Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Data Restoration Completed	Comment
1 Thompson Rd.	Union	Union	CWM	2	N	3		01/08/08	01/08/08	01/08/08	0	5 X 5	Dir	1/8/08	
2 116 Twp. Rd. 1202	Union	Union	CSL	3/4	N	1		01/02/08	01/02/08	01/02/08	6	5 X 5	Yard	5/2008	
3 417 Riverside Dr.	Chesapeake	Chesapeake	CWM	2	N	15		01/07/08	01/07/08	01/07/08	0	4 X 6	Pavement	5/2008	
4 6916 County Rd. 1	Fayette	Fayette	CWM	8	N	75		01/28/08	01/28/08	01/28/08	0	4 X 6	Berm	1/28/08	
5 8148 County Rd. 15	Fayette	Fayette	CWM	6	N	60		02/25/08	02/25/08	02/25/08	0	6 X 6	Pavement	5/2008	
6 177 County Rd. 124	Union	Union	CSL	3/4	N	2		03/14/08	03/14/08	03/14/08	4	4 X 8	Berm	3/18/08	
7 206 Twp. Rd. 1302	Union	Union	CWM	3/4	N	1		02/22/08	02/22/08	02/22/08	7	4 X 6	Berm	5/2008	
8 33 Twp. Rd. 1342	Union	Union	CWM	2	N	10		04/10/08	04/10/08	04/10/08	4	4 X 6	Berm	5/2008	
9 8388 County Rd. 1	Fayette	Fayette	CSL	3/4	N	0		04/20/08	04/20/08	04/20/08	4	4 X 6	Yard	5/2008	
10 240 Twp. Rd. 1338	Union	Union	CSL	3/4	N	1		04/23/08	04/23/08	04/23/08	1	6 X 6	Yard	5/2008	
11 Township Rd. 1202	Union	Union	CWM	6	N	4		05/05/08	05/05/08	05/05/08	5	6 X 6	Berm	5/2008	
12 318 County Rd. 276	Fayette	Fayette	CWM	2	N	6		06/04/08	06/04/08	06/04/08	0	8 X 8	Pavement	7/2008	
13 318 County Rd. 276	Fayette	Fayette	VLV	2	N	6		06/05/08	06/05/08	06/05/08	0	N/A	N/A	7/2008	
14 45 Twp. Rd. 1435	Fayette	Fayette	CSL	3/4	N	1		06/07/08	06/07/08	06/07/08	0	2X4 & 4X4	Yard	7/2008	
15 Forest Drive	Union	Union	CSL	3/4	N	1		06/25/08	06/25/08	07/01/08	7	6 X 6	Yard	8/2008	
16 199 Twp. 1026	Fayette	Fayette	CSL	3/4	N	0		07/04/08	07/04/08	07/04/08	6	4 X 6	Berm	8/2008	
17 Robertson Rd.	Chesapeake	Chesapeake	CWM	2	N	0		07/10/08	07/10/08	07/10/08	4	5 X 5	Pavement	8/2008	
18 519 Rockwood Ave.	Chesapeake	Chesapeake	CO	5/8	N	0		7/17/08	7/17/08	7/17/08	7	4 X 4	Yard	8/2008	
19 62 Township Rd. 1043	Union	Union	CSL	3/4	N	1		8/04/08	8/04/08	8/04/08	2	4 X 6	Berm	8/2008	
20 70 County Rd. 120	Fayette	Fayette	CWM	2	N	12		8/05/08	8/05/08	8/07/08	2	4 X 4	Berm	8/15/08	
21 335 Township Rd. 1273	Union	Union	CSL	3/4	N	1		8/14/08	8/14/08	8/18/08	4	4 X 6	Yard	9/10/08	
22 Willow St.	Union	Union	CO	5/8	N	1		8/22/2008	8/22/2008	8/22/2008	0	N/A	N/A	N/A	
23 313 4th Ave.	Chesapeake	Chesapeake	CSL	3/4	N	1		8/31/2008	8/31/2008	9/12/08	2	3 X 6	Yard	9/10/08	
24 Walnut Street	Fayette	Fayette	CWM	2	N	0		9/8/2008	9/8/2008	9/10/2008	2	6 X 6	Yard	10/5/08	
25 Big Branch Rd.	Union	Union	CWM	6	N	10		9/15/2008	9/15/2008	9/15/2008	0	6 X 4	Berm	10/5/08	
26 1405 Big Branch Rd.	Union	Union	CSL	3/4	N	1		9/20/2008	9/20/2008	9/22/2008	2	6 X 6	Yard	10/5/08	
27 1406 County Rd. 31	Union	Union	CSL	3/4	N	1		9/22/2008	9/22/2008	9/22/2008	1	6 X 6	Yard	10/5/08	
28 C.R. 1 A Sandusky Creek	Fayette	Fayette	CSL	3/4	N	1		10/12/2008	10/22/2008	10/22/2008	1	6 X 6	Creek	10/5/08	
29 408 4th Ave	Chesapeake	Chesapeake	CWM	2.5	N	0		10/6/2008	10/6/2008	10/9/2008	1	6 X 6	Pavement	11/15/08	Replace PE Service Clamp
30 47 Twp. Rd. 1438	Union	Union	CSL	3/4	N	1		10/20/2008	10/20/2008	10/20/2008	0	6 X 8	Yard	11/15/08	Replace PE Service Restoration to be 2009
31 1281 Township Rd. 1020	Fayette	Fayette	CSL	3/4	N	1		10/20/2008	10/20/2008	10/23/2008	3	4 X 4	Yard	N/A	
32 524 2nd Ave.	Chesapeake	Chesapeake	CO	2	N	1		10/31/2008	10/31/2008	11/4/2008	5	2X4 & 4X4	Yard	N/A	
33 Willow Creek	Fayette	Fayette	CWM	6	N	0		11/4/2008	11/4/2008	11/4/2008	2	N/A	N/A	N/A	Inside Meter Box Restoration to be 2009
34 Charley Creek Rd.	Union	Union	CWM	2	N	0		11/10/2008	11/10/2008	11/10/2008	0	5 X 5	Pavement	N/A	Restoration to be 2009
35 Powhatan Ave.	Union	Union	CWM	3/4	N	1		11/14/2008	11/14/2008	11/14/2008	0	6 X 6	Gravel	11/15/08	Restoration to be 2009
36 9 Twp. Rd. 1118	Fayette	Fayette	CWM	2	N	0		11/23/2008	11/23/2008	11/24/2008	1	6 X 6	Berm	N/A	Restoration to be 2009
37 164 County Rd. 104	Union	Union	CWM	2	N	2		12/9/2008	12/9/2008	12/9/2008	4	8 X 8	Yard	N/A	Restoration to be 2009
38 County Rd. 35	Fayette	Fayette	CSL	3/4	N	1		12/13/2008	12/13/2008	12/13/2008	0	5 X 5	Berm	N/A	Restoration to be 2009 Kill Service
39 C.R. 405 @ Sandusky Rd.	Fayette	Fayette	CWM	6	N	10		12/13/2008	12/13/2008	12/13/2008	0	4 X 16	Pavement	N/A	Restoration to be 2009
40 River Drive @ High Ave.	Union	Union	CWM	2	N	0		12/13/2008	12/13/2008	12/13/2008	0	8 X 6	Yard	N/A	Restoration to be 2009
41 C.R. 276 @ US Rt. 52	Fayette	Fayette	VLV	2	N	0		12/13/2008	12/13/2008	12/14/2008	1	5 X 5	Berm	N/A	Restoration to be 2009 Kill Blow Off

**Ohio American Water Company
Mansfield District
2008 Water Leak Log**

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other DR=Door Tag; DTD = Door to Door

Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Data	
														Restoration Completed	Comment
1 Hanna -	Madison	Madison	CWM	2"	N	0			3/21/2007	21-Mar	0				
2 843 Impala -	Imperial	Madison	CWM	2"	N	0			3/30/2007	30-Mar	0			8/19/07	
3 Byronnaire -	Imperial	Mifflin	CO	6"	N	0			3/28/2007	28-Mar	0			5/15/07	Main relocation
4 350 Apple	Harpcrest	Madison	CWM	2"	N	0			3/27/2007	28-Mar	1			5/21/07	
5 Gordon -	Little Valley	Madison	CSL	3/4"	N	0			3/18/2007	20-Mar	2			7/19/07	
6 Fairfax	Madison	Madison	CWM	2"	N	0			5/25/2007	5/25/2007	0			7/19/07	
7 2215 Kentwood	Imperial	Mifflin	CWM	2"	N	0			6/21/2007	6/21/2007	0			9/07/07	
8 Byronnaire -	Imperial	Madison	CWM	6"	N	0			5/25/2007	5/25/2007	0			7/19/07	
9 2215 Kentwood	Imperial	Madison	CWM	2"	N	0			7/25/2007	7/25/2007	0			9/07/07	
10 441 Impala	Madison	Mifflin	CWM	2"	N	0			9/1/2007	9/4/2007	2			9/24/07	
11 920 Belmont	Madison	Madison	CWM	2"	N	0			8/13/2007	8/13/2007	0			9/07/07	
12 195 Colonial	Mifflin	Madison	CWM	2"	N	0			8/1/2007	8/4/2007	2			9/21/07	
13 1550 Peach	Harpcrest	Madison	CWM	2"	N	0	N/A	N/A	11/27/2007	11/27/2007	0	4x4 EST	Yard	Spring 08 EST	
14 378 Apple	Imperial	Madison	CWM	2"	N	0	N/A	N/A	12/17/2007	12/17/2007	0	4x4 EST	Yard	Spring 08 EST	
15 Reedstone	Imperial	Mifflin	CWM	4"	N	0	N/A	N/A	3/26/2008	3/26/2008	2	4x4 EST	Yard	Spring 08 EST	
16 Byronnaire -	Imperial	Mifflin	CO	4"	N	0	N/A	N/A	8/3/2008	8/4/2008	1	6ft x 3ft	Asphalt	33,709	Oyster paving made repairs

ROY

Ohio American Water Company

Marion District

2008 Water Leak Log

CSL = Company Service Leak; CWM = Company Water Main; HTD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other; DR= Door Tag; DTD = Door to Door

Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Affected Services	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Completed	Comment
1 3172 Schell	Marion	Grand Prairie	PSL	P	N	1	HH	NA	12/31/2007	1/7/2008	7	None	N/A	N/A	Repaired
2 183 Sharp	Marion	Marion	CWM	12	Y	10	DR	NA	1/1/2008	1/6/2008	5	6 x 7	Dir	6/3/2008	Repaired
3 303 W of Pole Lane	Marion	Marion	CWM	12	Y	10	DR	NA	1/2/2008	1/2/2008	0	10 x 12	Pavement	6/3/2008	Repaired
4 303 W of Pole Lane	Marion	Marion	CWM	12	Y	10	DR	NA	1/2/2008	1/2/2008	0	10 x 12	Pavement	6/3/2008	Repaired
5 424 Ballentine	Marion	Marion	CWM	6	N	0	HH	NA	1/2/2008	1/2/2008	1	7 x 8	Dir	12/20/08	Repaired
6 Duvarre & Executive	Marion	Marion	CWM	12	Y	30	DR	NA	1/5/2008	1/5/2008	0	25 x 35	Pavement	7/14/2008	Repaired
7 Delaware & Executive	Marion	Marion	CWM	12	Y	30	DR	NA	1/5/2008	1/5/2008	0	25 x 35	Pavement	7/14/2008	Repaired
8 177 Jefferson	Marion	Marion	PSL	P	N	1	HH	NA	1/6/2008	1/6/2008	0	None	N/A	NA	Flushed
9 507 Silver	Marion	Marion	PSL	P	N	1	HH	NA	1/6/2008	1/6/2008	0	None	N/A	NA	Water service was off and leak repaired.
10 813 Uncapher	Marion	Marion	CSL	3/4"	N	1	HH	NA	1/7/2008	1/7/2008	0	6 x 7	Dir	6/10/2008	Repaired
11 11013 Uncapher	Marion	Marion	CSL	3/4"	N	1	HH	NA	1/7/2008	1/7/2008	0	6 x 7	Dir	6/10/2008	Repaired
12 Bennett & Nye	Marion	Marion	Flush	6	Y	50	DR	NA	1/10/2008	1/10/2008	0	7 x 8	Pavement	6/25/2008	Flushed
13 Gooding & Klingel	Prospect	Prospect	CWM	12	Y	500	DR	NA	1/11/2008	1/11/2008	15	20 x 25	Dir	6/10/2008	Repaired Waiting on repair parts
14 John & High	Marion	Marion	Flush	F	N	0	NA	NA	1/11/2008	1/11/2008	0	NA	NA	NA	Flushed
15 Lake Blvd & Bayside	Marion	Marion	Flush	F	N	0	NA	NA	1/14/2008	1/14/2008	0	NA	NA	NA	Flushed
16 Flow Test E Fairground	Marion	Marion	Flush	F	N	0	NA	NA	1/14/2008	1/14/2008	0	NA	NA	NA	Flushed
17 Flow Test Wilson Av	Marion	Marion	Flush	F	N	0	NA	NA	1/16/2008	1/16/2008	0	NA	NA	NA	Flushed
18 Dekalb	Marion	Clardon	CWM	2	N	0	HH	NA	1/16/2008	1/16/2008	3	7 x 8	Dir	6/10/2008	Shut off abandoned line
19 291 Waterloo	Marion	Marion	PSL	P	N	1	HH	NA	1/17/2008	1/17/2008	11	None	N/A	NA	Customer asked for the weekend, plumber scheduled.
20 554 Fair Park Ave	Marion	Marion	PSL	P	N	1	HH	NA	1/18/2008	1/18/2008	0	None	N/A	NA	Water service was off and leak repaired.
21 376 N Greenwood	Marion	Marion	PSL	P	N	1	HH	NA	1/18/2008	1/18/2008	0	None	N/A	NA	Water service was off and leak repaired.
22 226 Tully	Marion	Marion	CWM	6	Y	16	DR	NA	1/20/2008	1/20/2008	1	7 x 8	Pavement	6/23/2008	Repaired
23 569 Herman	Marion	Marion	CWM	2	N	0	HH	NA	1/20/2008	1/20/2008	1	5 x 8	Dir	6/10/2008	Repaired
24 1270 Bakman Dr	Marion	Marion	PSL	P	N	1	HH	NA	1/23/2008	1/23/2008	0	None	N/A	NA	Water service was off and leak repaired.
25 Main & South	Marion	Marion	CWM	6	N	0	HH	NA	1/24/2008	1/24/2008	1	7 x 8	Pavement	7/10/2008	Repaired
26 975 Villard	Marion	Marion	PSL	P	N	1	HH	NA	1/25/2008	1/25/2008	9	6 x 7	Pavement	Complete	Repaired other work took precedent
27 370 Silver	Prospect	Prospect	CWM	12	Y	50	DR	NA	1/26/2008	1/26/2008	4	12 x 14	Pavement	7/15/2008	Repaired
28 Gooding & Klingel	Prospect	Prospect	CWM	12	Y	50	DR	NA	1/26/2008	1/26/2008	4	12 x 14	Pavement	7/15/2008	Repaired
29 Farm & Orchard	Prospect	Prospect	CWM	12	Y	50	DR	NA	1/26/2008	1/26/2008	4	12 x 14	Pavement	7/15/2008	Repaired
30 Weiss & Schell	Prospect	Prospect	CWM	12	Y	50	DR	NA	1/26/2008	1/26/2008	4	12 x 14	Pavement	7/15/2008	Repaired
31 Farm & Orchard	Prospect	Prospect	CWM	12	Y	50	DR	NA	1/26/2008	1/26/2008	4	12 x 14	Pavement	7/15/2008	Repaired
32 461 Fies	Marion	Marion	PSL	P	N	1	HH	NA	1/30/2008	1/30/2008	0	None	N/A	NA	Water service was off and leak repaired.
33 Grand & Central Spya	Marion	Marion	CWM	6	N	0	HH	NA	1/31/2008	1/31/2008	0	None	N/A	NA	Shut off line - Engineering working on new installation
34 883 Vernon His Circle	Marion	Marion	CWM	2	N	0	HH	NA	1/31/2008	1/31/2008	0	5 x 7	Pavement	7/22/2008	Repaired
35 641 Van Buren	Marion	Marion	PSL	P	N	1	HH	NA	1/31/2008	1/31/2008	0	None	N/A	NA	Shut Off
36 GP Properties	Marion	Marion	PSL	P	N	1	HH	NA	1/31/2008	1/31/2008	0	None	N/A	NA	Repaired
37 275 Cass	Marion	Marion	PSL	P	N	1	HH	NA	1/31/2008	1/31/2008	0	None	N/A	NA	Repaired
38 462 Patterson	Marion	Marion	PSL	P	N	1	HH	NA	1/31/2008	1/31/2008	0	None	N/A	NA	Repaired
39 333 Waterloo	Marion	Marion	PSL	P	N	1	HH	NA	1/31/2008	1/31/2008	0	None	N/A	NA	Repaired
40 984 Amberst	Marion	Marion	PSL	P	N	1	HH	NA	1/31/2008	1/31/2008	0	None	N/A	NA	Repaired
41 374 Silver	Marion	Marion	PSL	P	N	1	HH	NA	1/31/2008	1/31/2008	0	None	N/A	NA	Repaired
42 1075 Largeais	Marion	Marion	PSL	P	N	1	HH	NA	1/31/2008	1/31/2008	0	None	N/A	NA	Repaired
43 1000 Ambrose	Marion	Marion	PSL	P	N	1	HH	NA	1/31/2008	1/31/2008	0	None	N/A	NA	Repaired
44 1104 Cheney Ave	Marion	Marion	PSL	P	N	1	HH	NA	1/31/2008	1/31/2008	0	None	N/A	NA	Repaired
45 288 S High	Marion	Marion	PSL	P	N	1	HH	NA	1/31/2008	1/31/2008	0	None	N/A	NA	Repaired
46 1582 Bellfontaine	Marion	Marion	CWM	6	N	0	HH	NA	1/31/2008	1/31/2008	0	None	N/A	NA	Repaired
47 1068 Barbadoes	Marion	Marion	CWM	6	N	0	HH	NA	1/31/2008	1/31/2008	0	None	N/A	NA	Repaired
48 1068 Barbadoes	Marion	Marion	CWM	6	N	0	HH	NA	1/31/2008	1/31/2008	0	None	N/A	NA	Repaired
49 Hwy behind Peko	Marion	Marion	Flush	F	N	0	NA	NA	2/1/2008	2/1/2008	6	7 x 10	Dir	6/12/2008	Repaired
50 310 Eggenwood	Marion	Marion	PSL	P	N	1	HH	NA	2/1/2008	2/1/2008	26	8 x 7	Dir	6/12/2008	Repaired
51 St Rt 257 & Water	Prospect	Prospect	CWM	12	Y	25	DR	NA	2/1/2008	2/1/2008	9	5 x 5	Pavement	6/23/2008	Repaired
52 156 Main	Marion	Marion	PSL	P	N	1	HH	NA	2/1/2008	2/1/2008	10	None	N/A	NA	Repaired
53 Rt Vernon & Fane	Marion	Marion	PSL	P	N	1	HH	NA	2/1/2008	2/1/2008	10	None	N/A	NA	Repaired
54 St Rt 257 & Water	Prospect	Prospect	Flush	F	N	0	NA	NA	2/1/2008	2/1/2008	0	None	N/A	NA	Property leak found and turned off same day.
55 Weiss & Pole Lane	Marion	Marion	Flush	F	N	0	NA	NA	2/1/2008	2/1/2008	0	None	N/A	NA	Flushed
56 Weiss & Pole Lane	Marion	Marion	Flush	F	N	0	NA	NA	2/1/2008	2/1/2008	0	None	N/A	NA	Flushed
57 845 Woodrow	Marion	Marion	CSL	3/4"	N	1	HH	NA	2/1/2008	2/1/2008	0	15 x 20	Dir	6/12/2008	Repaired
58 845 Woodrow	Marion	Marion	CSL	3/4"	N	1	HH	NA	2/1/2008	2/1/2008	0	15 x 20	Dir	6/12/2008	Repaired
59 429 Avondale	Marion	Marion	PSL	P	N	1	HH	NA	2/1/2008	2/1/2008	0	4 x 8	Pavement	6/27/2008	Repaired
60 328 Oliver	Marion	Marion	PSL	P	N	1	HH	NA	2/1/2008	2/1/2008	0	4 x 8	Pavement	6/27/2008	Repaired
61 420 Euclid	Marion	Marion	PSL	P	N	1	HH	NA	2/1/2008	2/1/2008	0	4 x 8	Pavement	6/27/2008	Repaired
62 887 N State St	Marion	Marion	PSL	P	N	1	HH	NA	2/1/2008	2/1/2008	0	4 x 8	Pavement	6/27/2008	Repaired
63 995 Toulon	Marion	Marion	CSL	3/4"	N	1	HH	NA	2/1/2008	2/1/2008	19	None	N/A	NA	Staffing issues have not had a chance to check-Repaired
64 470 Jefferson St	Marion	Marion	CSL	3/4"	N	1	HH	NA	2/1/2008	2/1/2008	22	5 x 7	Pavement	6/19/2008	Repaired-Customer had problems finding plumber
65 531 Ballfontaine	Marion	Marion	PSL	P	N	1	HH	NA	2/26/2008	2/26/2008	5	6 x 7	Dir	6/10/2008	Repaired
66 531 Ballfontaine	Marion	Marion	PSL	P	N	1	HH	NA	2/26/2008	2/26/2008	20	None	N/A	NA	Repaired
67 2424 Pole Lane Rd	Prospect	Prospect	Flush	F	Y	1	DR	NA	3/3/2008	3/3/2008	39	None	N/A	NA	Repaired-Customer had problems finding plumber
68 E Marion	Marion	Marion	PSL	P	N	1	HH	NA	3/3/2008	3/3/2008	0	None	N/A	NA	Flushed
69 125 N Water	Marion	Marion	CWM	6	Y	6	DR	NA	3/5/2008	3/5/2008	0	8 x 10	Pavement	7/12/2008	Done
70 Niles & Silver	Marion	Marion	CWM	6	N	0	HH	NA	3/12/2008	3/12/2008	0	8 x 8	Pavement	6/29/2008	Done

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other DR; Door Tag: DTD = Door to Door															
Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Soil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
71 1174 Montego	Marion	Marion	PSL	P	N	1	NA	NA	3/15/2008	3/16/2008	0	None	N/A	N/A	Done
72 1600 Cascade	Marion	Marion	CWM	10"	N	0	NA	NA	3/16/2008	3/16/2008	0	12 x 14	Dirt	3/16/2008	Done
73 1600 Cascade	Marion	Marion	Flush	F	N	0	NA	NA	3/17/2008	3/17/2008	0	NA	N/A	3/16/2008	Flushed
74 966 Richmond	Marion	Marion	PSL	P	N	1	NA	NA	3/19/2008	3/20/2008	7	None	N/A	N/A	Repaired-Customer had problems finding plumber
75 993 Normandy Circle	Marion	Marion	CWM	2"	Y	6	DR	3/21/2008	3/18/2008	3/20/2008	2	20 x 30	Dirt	5/27/2008	Done
76 Flush 257 & 47	Prospect	Prospect	Flush	F	N	0	NA	NA	3/18/2008	3/18/2008	0	NA	N/A	3/18/2008	Flushed
77 Johnson & Wilson	Marion	Marion	HYD	H	N	0	N	NA	3/24/2008	3/24/2008	0	NA	N/A	3/24/2008	Done
78 Flush University Dr	Marion	Marion	Flush	F	N	0	NA	NA	3/31/2008	3/31/2008	0	NA	N/A	3/31/2008	Flushed
79 473 Merchant	Marion	Marion	PSL	P	N	1	NA	NA	3/14/2008	4/22/2008	19	None	N/A	N/A	Repaired-Customer had problems finding plumber
80 1055 Wilson	Marion	Marion	PSL	P	N	1	NA	NA	3/14/2008	4/22/2008	4	None	N/A	N/A	Done
81 998 S Underwood	Marion	Marion	PSL	P	N	1	NA	NA	3/10/2008	4/2/2008	23	None	N/A	N/A	Repaired-Customer had problems finding plumber
82 1124 Fairwood	Marion	Marion	PSL	P	N	1	NA	NA	4/12/2008	4/12/2008	0	None	N/A	N/A	Done
83 Flow Test Delites	Marion	Marion	Flush	F	N	0	NA	NA	4/12/2008	4/12/2008	0	0	N/A	4/12/2008	Flushed
84 General Machine	Marion	Marion	Flush	F	N	0	NA	NA	4/12/2008	4/12/2008	0	0	N/A	4/12/2008	Flushed
85 Main & Dana	Caledonia	Caledonia	CWM	6"	N	0	NA	NA	4/22/2008	4/16/2008	14	11 x 12	Pavement	7/1/2008	Repaired
86 588 Underwood	Marion	Marion	CSL	3/4"	Y	25	DR	4/2/2008	4/2/2008	4/2/2008	0	0	N/A	4/2/2008	Contractor hit line - Contractor responsible for restoration
87 588 Underwood	Marion	Marion	Flush	F	N	0	NA	NA	4/22/2008	4/22/2008	0	0	N/A	4/22/2008	Flushed
88 250 V1 Liberty	Caledonia	Caledonia	CWM	4"	N	0	NA	NA	4/4/2008	4/16/2008	12	10 x 4	Pavement	7/1/2008	Repaired
89 Mark & Park	Marion	Marion	Flush	F	Y	30	DR	4/8/2008	4/7/2008	4/7/2008	0	0.8 x 9	Pavement	6/16/2008	Flushed
90 966 Bermuda	Marion	Marion	PSL	P	N	1	NA	NA	4/7/2008	4/11/2008	4	None	N/A	N/A	Done
91 Oak & Tully	Marion	Marion	Flush	F	Y	12	NA	NA	4/8/2008	4/8/2008	0	0.10 x 20	Pavement	5/23/2008	Flushed
92 Delalib	Marion	Caledonia	CWM	12"	N	0	NA	NA	4/9/2008	4/9/2008	0	0	N/A	4/9/2008	Shut off old line
93 Flow Test Zwyer	Marion	Marion	Flush	F	N	0	NA	NA	4/9/2008	4/9/2008	0	0	N/A	4/9/2008	Flushed
94 Paula & Fairview	Marion	Marion	Flush	F	N	0	NA	NA	4/14/2008	4/14/2008	0	0	N/A	4/14/2008	Flushed
95 440 Avondale	Marion	Marion	CSL	3/4"	N	0	NA	NA	4/15/2008	4/15/2008	0	0	N/A	4/15/2008	Contractor hit line - Contractor responsible for restoration
96 460 Oak	Marion	Marion	PSL	P	N	1	NA	NA	4/15/2008	4/15/2008	0	0	N/A	4/15/2008	Done
97 456-460 Osceola	Marion	Marion	CWM	2"	N	0	NA	NA	4/15/2008	5/12/2008	27	8 x 12	Dirt	5/18/2008	Repaired - Very small leak other work took precedent
98 Wilson & Carhart	Marion	Marion	Flush	F	N	0	NA	NA	4/16/2008	4/16/2008	0	0	N/A	4/16/2008	Flushed
99 Greenwood & Mark	Marion	Marion	Flush	F	Y	20	DR	4/17/2008	4/17/2008	4/17/2008	0	0.10 x 15	Pavement	5/18/2008	Flushed
100 Quarry & Greenwood	Marion	Marion	CSL	3/4"	N	0	NA	NA	4/21/2008	4/21/2008	0	0	N/A	4/21/2008	Repaired by Contractor
101 965 Bermuda	Marion	Marion	Flush	F	N	0	NA	NA	4/21/2008	4/21/2008	0	0	N/A	4/21/2008	Done
102 Fairground & Catherine	Marion	Marion	Flush	F	N	0	NA	NA	4/22/2008	4/22/2008	0	0	N/A	4/22/2008	Flushed
103 E Center	Marion	Marion	Flush	F	N	0	NA	NA	4/22/2008	4/22/2008	0	0	N/A	4/22/2008	Flushed
104 Oak & Tully	Marion	Marion	Flush	F	Y	30	DR	4/24/2008	4/23/2008	4/23/2008	0	0	N/A	4/23/2008	Flushed
105 168 Seato	Marion	Marion	PSL	P	N	1	NA	NA	4/23/2008	4/23/2008	0	None	N/A	4/23/2008	Done
106 265 Bellevue	Marion	Marion	PSL	P	N	1	NA	NA	4/24/2008	5/2/2008	8	None	N/A	4/23/2008	Done
107 Oak	Marion	Marion	Flush	F	N	0	NA	NA	4/25/2008	4/25/2008	0	0	N/A	4/25/2008	Flushed
108 Cascade Dr	Caledonia	Caledonia	Flush	F	N	0	NA	NA	4/25/2008	4/25/2008	0	0	N/A	4/25/2008	Flushed
109 Airport	Marion	Marion	PSL	P	N	1	NA	NA	4/25/2008	4/25/2008	0	0	N/A	4/25/2008	Done
110 890 Loire Valley	Marion	Marion	PSL	P	N	1	NA	NA	4/25/2008	4/25/2008	0	0	N/A	4/25/2008	Done
111 Adams	Marion	Marion	CWM	2"	N	0	NA	NA	4/26/2008	4/26/2008	0	0	N/A	4/26/2008	Repaired during main replacement project
112 Mt Vernon & Hane	Marion	Marion	Flush	F	N	0	NA	NA	5/1/2008	5/1/2008	0	None	N/A	5/1/2008	Flush
113 965 Bermuda	Marion	Marion	PSL	P	N	1	NA	NA	5/1/2008	5/2/2008	7	None	N/A	5/1/2008	Repaired
114 919 N Main	Marion	Marion	PSL	P	N	1	NA	NA	5/2/2008	5/2/2008	0	None	N/A	5/2/2008	shut off
115 Flush POET	Marion	Marion	Flush	F	N	0	NA	NA	5/2/2008	5/2/2008	0	None	N/A	5/2/2008	Flush
116 Flush Universal	Marion	Marion	Flush	F	Y	40	DR	5/6/2008	5/6/2008	5/6/2008	0	NA	N/A	5/6/2008	Flush
117 Flush POET	Marion	Marion	Flush	F	N	0	NA	NA	5/6/2008	5/6/2008	0	NA	N/A	5/6/2008	Flush
118 338 Patton	Marion	Marion	PSL	P	N	1	NA	NA	5/7/2008	5/7/2008	0	None	N/A	5/7/2008	Repaired - Very small leak
119 314 Windsor	Marion	Marion	CSL	3/4"	N	1	NA	NA	5/7/2008	5/7/2008	0	6 x 8	Dirt	6/11/2008	Replaced
120 765 Creston	Marion	Marion	PSL	P	N	1	NA	NA	5/7/2008	5/7/2008	0	None	N/A	5/7/2008	Repaired
121 264 S Main	Marion	Marion	PSL	P	N	1	NA	NA	5/9/2008	5/9/2008	11	None	N/A	5/9/2008	Repaired - Short staffed - Could not check in 7 day
122 Greenwood & George	Marion	Marion	Flush	F	N	0	NA	NA	5/9/2008	5/9/2008	0	NA	N/A	5/9/2008	Flush
123 Flush POET	Marion	Marion	Flush	F	N	0	NA	NA	5/12/2008	5/12/2008	0	NA	N/A	5/12/2008	Flush
124 Main & Hazen	Marion	Marion	Flush	F	Y	40	DR	5/15/2008	5/15/2008	5/15/2008	0	10 x 15	Pavement	6/10/2008	Flush
125 Flush POET	Marion	Marion	Flush	F	N	0	NA	NA	5/20/2008	5/20/2008	0	NA	N/A	5/20/2008	Flush
126 Flush Barnhart	Marion	Marion	Flush	F	N	0	NA	NA	5/20/2008	5/20/2008	0	NA	N/A	5/20/2008	Flush
127 342 Olney	Marion	Marion	PSL	P	N	1	NA	NA	5/20/2008	6/3/2008	14	None	N/A	5/20/2008	Repaired
128 Flush POET	Marion	Marion	Flush	F	N	0	NA	NA	5/21/2008	5/21/2008	0	NA	N/A	5/21/2008	Flush
129 308 Midlam	Marion	Marion	CSL	3/4"	N	1	NA	NA	5/23/2008	5/26/2008	3	NA	N/A	5/23/2008	Repaired by Contractor
130 801 Congress	Marion	Marion	PSL	P	N	1	NA	NA	5/27/2008	5/27/2008	0	None	N/A	5/27/2008	shut off
131 503 Tyler	Marion	Marion	PSL	P	N	1	NA	NA	5/27/2008	5/27/2008	9	None	N/A	5/27/2008	shut off
132 503 St Gallen	Marion	Marion	CSL	3/4"	N	1	NA	NA	5/27/2008	5/29/2008	2	6 x 8	Dirt	7/16/2008	Replaced
133 Flush Benton Pl	Marion	Marion	Flush	F	N	0	NA	NA	5/29/2008	5/29/2008	0	NA	N/A	5/29/2008	Flush
134 193 Waterloo	Marion	Marion	PSL	P	N	1	NA	NA	5/29/2008	5/29/2008	0	None	N/A	5/29/2008	shut off
135 827 Savannah	Marion	Marion	CSL	3/4"	N	1	NA	NA	5/30/2008	6/24/2008	25	5 x 13	Dirt	7/16/2008	Repaired - Very small leak other work took precedent
136 1007 Robinson	Marion	Marion	PSL	P	N	1	NA	NA	6/3/2008	6/10/2008	7	None	N/A	6/10/2008	Repaired
137 286 S Main	Marion	Marion	PSL	P	N	1	NA	NA	6/4/2008	6/11/2008	7	None	N/A	6/11/2008	Repaired
138 3068 Mar Wabco #108	Marion	Pleasant	PSL	P	N	1	NA	NA	6/8/2008	6/13/2008	7	None	N/A	6/13/2008	Repaired
139 Garfield & Midlam	Marion	Marion	Flush	F	N	0	NA	NA	6/9/2008	6/9/2008	0	NA	N/A	6/9/2008	Flush
140 Wilson & Benton	Marion	Marion	Flush	F	N	0	NA	NA	6/9/2008	6/9/2008	0	NA	N/A	6/9/2008	Flush
141 Barnhart & Wilson	Marion	Marion	CWM	6"	Y	23	DR	6/14/2008	6/14/2008	6/14/2008	5	10 x 10	Pavement	8/13/2008	Replaced Valve
142 Barnhart & Wilson	Marion	Marion	Flush	F	N	0	NA	NA	6/9/2008	6/9/2008	0	NA	N/A	6/9/2008	Flush
143 1765 S Prospect	Marion	Marion	PSL	P	N	1	NA	NA	6/10/2008	6/10/2008	29	None	N/A	6/10/2008	shut off
144 Madison & Ackerman	Marion	Marion	CWM	2"	Y	12	DR	7/10/2008	6/10/2008	6/10/2008	9	9 x 2	Pavement	8/12/2008	Very Small leak - other work took precedent
145 Rosedale	Marion	Marion	CWM	6"	Y	10	DR	6/14/2008	6/14/2008	6/14/2008	2	10 x 10	Dirt	7/15/2008	Repaired

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other DR= Door Tag; DTD = Door to Door																
Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date	Restoration Completed	Comment
146 1445 Plantation	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	6/14/2008	6/28/2008	14	9 x 7	Dir	7/16/2008	7/16/2008	Repaired - Very small leak other work look precedent
147 459 Cherry St	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	6/15/2008	6/17/2008	1	5 x 9	Pavement	9/11/2008	9/11/2008	Repaired
148 698 Wilson	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	6/15/2008	6/20/2008	1	3 x 7	Pavement	8/13/2008	8/13/2008	Repaired
149 227 Windsor	Marion	Marion	PSL	P	N	1 HH	NA	NA	6/19/2008	7/14/2008	25	None	NA	N/A	N/A	WLP did not fix - shut off
150 588 Davis	Marion	Marion	PSL	P	N	1 HH	NA	NA	6/23/2008	7/12/2008	8	None	NA	N/A	N/A	Repaired
151 Wheeler Dr	Marion	Marion	Flush	F	N	0	NA	NA	6/25/2008	6/25/2008	0	None	NA	N/A	N/A	Flush
152 781 Vancouver	Marion	Marion	PSL	P	N	1 HH	NA	NA	6/25/2008	7/12/2008	8	None	NA	N/A	N/A	shut off
153 296 Chestnut	Marion	Marion	PSL	P	N	1 HH	NA	NA	6/25/2008	7/20/2008	33	None	NA	N/A	N/A	Short staffed. Order had been rescheduled.
154 Wheeler Dr	Marion	Marion	Flush	F	N	0	NA	NA	6/26/2008	6/26/2008	0	None	NA	N/A	N/A	Flush
155 Main & South	Caledonia	Marion	CWM	6"	N	0	NA	NA	6/27/2008	6/27/2008	0	9.5 x 12	Pavement	8/13/2008	8/13/2008	Repaired
156 208 E Washington	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/12/2008	7/12/2008	8	None	NA	N/A	N/A	WLP did not fix in 7 day
157 980 Villard	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/12/2008	7/12/2008	8	None	NA	N/A	N/A	Short Staff - Repairs were done
158 Fush Berkis	Marion	Marion	Flush	F	N	0	NA	NA	7/12/2008	7/12/2008	0	None	NA	N/A	N/A	Flush
159 Fush	Marion	Marion	Flush	F	N	0	NA	NA	7/12/2008	7/12/2008	0	None	NA	N/A	N/A	Flush
160 708 Vernon Hts Blvd	Marion	Marion	Flush	F	N	0	NA	NA	7/12/2008	7/20/2008	0	None	NA	N/A	N/A	Flush
161 King & Concord	Marion	Marion	Flush	F	N	0	NA	NA	7/20/2008	7/20/2008	0	None	NA	N/A	N/A	Flush
162 Wheeler Dr flow Test	Marion	Marion	Flush	F	N	0	NA	NA	7/20/2008	7/20/2008	0	None	NA	N/A	N/A	Flush
163 583 Silver St	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/20/2008	7/29/2008	26	None	NA	N/A	N/A	Short Staffed - Turned off
164 251 Columbia	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/20/2008	7/24/2008	17	None	NA	N/A	N/A	Short Staffed
165 Fush	Marion	Marion	Flush	F	N	0	NA	NA	7/20/2008	7/20/2008	0	None	NA	N/A	N/A	Flush
166 492 Biscayne	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/20/2008	7/15/2008	7	None	NA	N/A	N/A	Repaired
167 Fush	Marion	Marion	Flush	F	N	0	NA	NA	7/20/2008	7/15/2008	0	None	NA	N/A	N/A	Flush
168 6 Valve Madison	Marion	Marion	Flush	F	Y	12	DR	7/10/2008	7/10/2008	7/10/2008	0	14 x 20	Pavement	8/13/2008	8/13/2008	Flush
169 344 Francis Flow Test	Marion	Marion	Flush	F	N	0	NA	NA	7/10/2008	7/10/2008	0	None	NA	N/A	N/A	Flush
170 303 Edwards St	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/12/2008	7/12/2008	0	None	NA	N/A	N/A	Repaired
171 897 S Prospect	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/12/2008	7/29/2008	15	None	NA	N/A	N/A	Short staffed - Repaired
172 Elm St	Marion	Marion	CWM	5"	Y	30	DR	7/15/2008	7/14/2008	7/14/2008	0	11.5 x 60	Pavement	8/14/2008	8/14/2008	Done
173 988 Chateau	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/15/2008	7/15/2008	3	None	NA	N/A	N/A	Repaired
174 VHB & Cambridge	Marion	Marion	Flush	F	N	0	NA	NA	7/15/2008	7/15/2008	0	None	NA	N/A	N/A	Flush
175 681 Indiana	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	7/15/2008	8/4/2008	19	None	NA	N/A	N/A	WLP did not fix within 7 days
176 1010 Barbadoes	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/16/2008	7/16/2008	15	None	NA	N/A	N/A	Short staff. Water repairs were done.
177 271 E Farming	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/16/2008	8/4/2008	18	None	NA	N/A	N/A	Short staff. Order had been rescheduled.
178 483 Biscayne	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/17/2008	7/17/2008	10	None	NA	N/A	N/A	Short staff. Water repairs were done.
179 775 Catalina	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/21/2008	7/21/2008	8	None	NA	N/A	N/A	Repaired
180 504 E Fairground	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/21/2008	7/29/2008	8	None	NA	N/A	N/A	Repaired
181 637 Tyler St	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	7/21/2008	7/21/2008	0	10 x 13	Pavement	8/13/2008	8/13/2008	Repaired
182 385 Linda Mal	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	7/23/2008	7/23/2008	1	6 x 12	Dir	9/23/2008	9/23/2008	Small Leak - Other work look precedent
183 220 Kemore	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	7/23/2008	7/24/2008	1	5 x 11	Dir	Complete	Complete	Repaired
184 Barnhart	Marion	Marion	Flush	F	N	0	NA	NA	7/24/2008	7/24/2008	0	None	NA	N/A	N/A	Flush
185 Jefferson & Wilson	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	7/25/2008	8/11/2008	17	7 x 11	Pavement	9/22/2008	9/22/2008	Repaired - Very small leak other work look precedent
186 348 Silver	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/26/2008	7/26/2008	0	None	NA	N/A	N/A	Repaired
187 Traflet Fush Palace	Marion	Marion	Flush	F	N	0	NA	NA	7/26/2008	7/26/2008	0	None	NA	N/A	N/A	Flush
188 194 S Grand	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/29/2008	8/5/2008	7	None	NA	N/A	N/A	Repaired
189 Labrette & Brown	Marion	Marion	CWM	2"	Y	4	DR	7/30/2008	7/29/2008	7/29/2008	0	None	NA	N/A	N/A	Turned off Bad leak
190 395 Davids St	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/30/2008	7/30/2008	0	None	NA	N/A	N/A	Done
191 471 E Center	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	7/30/2008	8/12/2008	2	8 x 13	Pavement	9/3/2008	9/3/2008	Done
192 TRI Rivers	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/30/2008	7/30/2008	0	None	NA	N/A	N/A	Done
193 292 Owens	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	7/30/2008	7/30/2008	0	8 x 13	Dir	Complete	Complete	Repaired
194 1061 National	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/30/2008	8/4/2008	5	None	NA	N/A	N/A	Repaired
195 St Rt 47 W of Gooding	Prospect	Marion	Flush	F	N	0	NA	NA	7/31/2008	7/31/2008	0	None	NA	N/A	N/A	Flush
196 593 Edgfield	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/31/2008	8/1/2008	7	None	NA	N/A	N/A	Done
197 1027 Plantation	Marion	Marion	PSL	P	N	1 HH	NA	NA	7/31/2008	8/7/2008	7	None	NA	N/A	N/A	Done
198 164 Jefferson	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	8/4/2008	8/5/2008	5	6 x 5	Dir	8/18/2008	8/18/2008	Repaired
199 381 Waterloo	Marion	Marion	PSL	P	N	1 HH	NA	NA	8/4/2008	8/11/2008	7	None	NA	N/A	N/A	Done
200 381 Davids	Marion	Marion	PSL	P	N	1 HH	NA	NA	8/4/2008	8/11/2008	7	None	NA	N/A	N/A	Done
201 576 Pok	Marion	Marion	PSL	P	N	1 HH	NA	NA	8/4/2008	8/11/2008	7	None	NA	N/A	N/A	Done
202 Grand & George	Marion	Marion	Flush	F	Y	30	DR	8/5/2008	8/4/2008	8/4/2008	0	None	NA	N/A	N/A	Flush
203 465 Presidential	Marion	Marion	CWM	6"	Y	6	DR	8/9/2008	8/4/2008	8/7/2008	3	8 x 13	Pavement	9/22/2008	9/22/2008	Done
204 195 Banks Rd	Marion	Marion	CWM	12"	N	0	NA	NA	8/4/2008	8/5/2008	2	9 x 13	Pavement	9/11/2008	9/11/2008	Done
205 1205 Somerset Hoffman	Marion	Marion	Flush	F	N	0	NA	NA	8/5/2008	8/5/2008	0	None	NA	N/A	N/A	Flush
206 1205 Somerset Hoffman	Marion	Marion	CWM	6"	Y	3	DR	8/6/2008	8/5/2008	8/5/2008	0	7 x 11	Dir	By Contractor	Done	Done
207 265 Ruth	Marion	Marion	PSL	P	N	1 HH	NA	NA	8/6/2008	8/11/2008	5	None	NA	N/A	N/A	Done
208 Grand & George	Marion	Marion	Flush	F	N	0	NA	NA	8/7/2008	8/7/2008	0	None	NA	N/A	N/A	Flush
209 905 Sheridan	Marion	Marion	PSL	P	N	0	NA	NA	8/7/2008	8/7/2008	0	None	NA	N/A	N/A	Flush
210 975 Underwood	Marion	Marion	PSL	P	N	1 HH	NA	NA	8/7/2008	8/12/2008	4	None	NA	N/A	N/A	Done
211 Grand & George	Marion	Marion	Flush	F	Y	25	DR	8/12/2008	8/11/2008	8/11/2008	0	None	NA	N/A	N/A	Flush
212 350 Spence St	Marion	Marion	CWM	2"	N	0	NA	NA	8/12/2008	8/15/2008	3	5 x 9	Dir	8/18/2008	8/18/2008	Done
213 431 S Vine	Marion	Marion	PSL	P	N	1 HH	NA	NA	8/12/2008	8/21/2008	7	None	NA	N/A	N/A	Done
214 Tait & Williamsport	Marion	Marion	Flush	F	N	0	NA	NA	8/15/2008	8/15/2008	0	None	NA	N/A	N/A	Flush
215 1057 Fairwood	Marion	Marion	PSL	P	N	1 HH	NA	NA	8/18/2008	8/25/2008	7	None	NA	N/A	N/A	Done
216 Grand & George	Marion	Marion	Flush	F	N	0	NA	NA	8/18/2008	8/18/2008	0	None	NA	N/A	N/A	Flush
217 Flow test Kellogg	Marion	Marion	Flush	F	N	0	NA	NA	8/19/2008	8/19/2008	0	None	NA	N/A	N/A	Flush
218 N Settler	Marion	Marion	PSL	P	N	0	NA	NA	8/19/2008	8/19/2008	0	None	NA	N/A	N/A	Flush
219 796 Savannah	Marion	Marion	PSL	P	N	1 HH	NA	NA	8/21/2008	8/27/2008	6	None	NA	N/A	N/A	Done
220 698 Darius	Marion	Marion	PSL	P	N	1 HH	NA	NA	8/21/2008	9/2/2008	12	None	NA	N/A	N/A	Small Leak - Other work look precedent - Not surfacing

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWH = Private Water Main; PO = Private Other DR; Door Tag; DTG = Door to Door															
Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
221 133 forest Linn	Marion	Marion	PSL	P	N	1 HH	NA	8/22/2008	8/22/2008	8/26/2008	4	None	N/A	N/A	Repaired
222 904 Maynard	Marion	Marion	Flush	F	N	0	NA	8/22/2008	8/22/2008	8/22/2008	0	None	N/A	N/A	Flush
223 571 Herman	Marion	Marion	CSL	3/4"	N	1 HH	NA	8/24/2008	8/24/2008	8/24/2008	0	6 x 7	Dir	8/18/2008	Repaired
224 970 villandy	Marion	Marion	PSL	P	N	1 HH	NA	8/25/2008	8/25/2008	9/2/2008	8	None	N/A	N/A	Holiday. Could not check within 7 days
225 696 Brookpark	Marion	Marion	CSL	3/4"	N	1 HH	NA	8/25/2008	8/25/2008	9/2/2008	8	4 x 6	Dir	Incomplete	Repaired
226 1120 Keener	Marion	Marion	PSL	P	N	1 HH	NA	8/27/2008	8/27/2008	9/2/2008	NA	None	N/A	N/A	NO leak here was a washing line to outside
227 940 Congress	Marion	Marion	PSL	P	N	1 HH	NA	8/27/2008	8/27/2008	8/27/2008	0	None	N/A	N/A	Was turned off for repairs
228 283 E George	Marion	Marion	PSL	P	N	1 HH	NA	8/28/2008	8/28/2008	9/6/2008	10	None	N/A	N/A	Customer given extra days by call center
229 385 Thompson	Marion	Marion	Flush	F	N	0	NA	8/28/2008	8/28/2008	8/29/2008	0	None	N/A	N/A	Flush
230 Pro Flush popcorn	Marion	Marion	Flush	F	N	0	NA	8/29/2008	8/29/2008	8/29/2008	0	None	N/A	N/A	Flush
231 890 Congress	Marion	Marion	CSL	3/4"	N	1 HH	NA	8/29/2008	8/29/2008	8/29/2008	0	None	N/A	N/A	Repaired
232 970 villandy	Marion	Marion	PSL	P	N	1 HH	NA	8/29/2008	8/29/2008	9/6/2008	9	None	N/A	N/A	Holiday. Could not check within 7 days
233 283 E George	Marion	Marion	PSL	P	N	1 HH	NA	8/28/2008	8/28/2008	9/2/2008	11	None	N/A	N/A	Customer given extra days by call center
234 Grand & Wilson	Marion	Marion	CWM	V	N	0 HH	NA	9/1/2008	9/1/2008	9/2/2008	2	7 x 9	Pavement	Incomplete	Done
235 Flush Chicago	Marion	Marion	Flush	F	N	0	NA	9/2/2008	9/2/2008	9/2/2008	0	None	N/A	N/A	Flush
236 697 Uncapher	Marion	Marion	PSL	P	N	1 HH	NA	9/2/2008	9/2/2008	9/2/2008	7	None	N/A	N/A	Fixed within 7 days
237 854 Sheridan	Marion	Marion	PSL	P	N	1 HH	NA	9/2/2008	9/2/2008	9/2/2008	0	None	N/A	N/A	Water service turned off due to severity leak
238 384 Chester	Marion	Marion	PSL	P	N	1 HH	NA	9/3/2008	9/3/2008	9/3/2008	0	None	N/A	N/A	Done
239 Mark w of Lincoln	Marion	Marion	Flush	F	N	0	NA	9/3/2008	9/3/2008	9/3/2008	0	None	N/A	N/A	Flush
240 Pop Corn Festival	Marion	Marion	Flush	F	N	0	NA	9/3/2008	9/3/2008	9/4/2008	1	None	N/A	N/A	Flush
241 Central soya	Marion	Marion	Flush	F	N	0	NA	9/5/2008	9/5/2008	9/5/2008	0	None	N/A	N/A	Flush
242 S Main Caledonia	Caledonia	Marion	CWM	6	Y	15	DR	9/5/2008	9/5/2008	9/5/2008	0	7 x 10	Pavement	Incomplete	Done
243 S Main Caledonia	Caledonia	Marion	Flush	F	N	0	NA	9/5/2008	9/5/2008	9/5/2008	0	None	N/A	N/A	Flush
244 State & Short	Marion	Marion	Flush	F	N	0	NA	9/6/2008	9/6/2008	9/6/2008	2	None	N/A	N/A	Flush
245 #4 Woods	Marion	Marion	CWM	2	Y	15	DR	9/6/2008	9/6/2008	9/6/2008	2	5 x 10	Pavement	Incomplete	Done
246 Pop Corn Festival Clean Streets	Marion	Marion	Flush	F	N	0	NA	9/4/2008	9/4/2008	9/4/2008	0	None	N/A	N/A	Flush
247 Prospect & Council	Marion	Marion	Flush	F	N	0	NA	9/7/2008	9/7/2008	9/7/2008	0	None	N/A	N/A	Flush
248 Englewood	Marion	Marion	Flush	F	N	0	NA	9/8/2008	9/8/2008	9/8/2008	0	None	N/A	N/A	Flush
249 Church & Prospect	Marion	Marion	Flush	F	N	0	NA	9/8/2008	9/8/2008	9/8/2008	0	None	N/A	N/A	Flush
250 Mark & Ballentine	Marion	Marion	CSL	3/4"	N	1 HH	NA	9/8/2008	9/8/2008	9/8/2008	0	None	N/A	N/A	Repaired
251 #4 Woods	Marion	Marion	Flush	F	N	0	NA	9/8/2008	9/8/2008	9/8/2008	0	None	N/A	N/A	Flush
252 1990 Grandview	Marion	Marion	PSL	P	N	1 HH	NA	9/8/2008	9/8/2008	9/15/2008	7	None	N/A	N/A	Fixed within 7 days
253 1287 Shelby	Marion	Marion	PSL	P	N	1 HH	NA	9/8/2008	9/8/2008	9/15/2008	7	None	N/A	N/A	Fixed within 7 days
254 348 Cherry	Marion	Marion	CSL	3/4"	N	1 HH	NA	9/9/2008	9/9/2008	9/14/2008	5	7 x 8	Pavement	Incomplete	Repaired
255 913 Banks Ave	Marion	Marion	CSL	3/4"	N	1 HH	NA	9/9/2008	9/9/2008	9/13/2008	4	5 x 7	Dir	Incomplete	Repaired
256 Englewood	Marion	Marion	Flush	F	N	0	NA	9/9/2008	9/9/2008	9/9/2008	0	None	N/A	N/A	Flush
257 Forest & Indiana	Marion	Marion	Flush	F	N	0	NA	9/9/2008	9/9/2008	9/9/2008	0	None	N/A	N/A	Flush
258 Williamsport & Tait	Marion	Marion	PSL	P	N	1 HH	NA	9/9/2008	9/9/2008	9/9/2008	0	None	N/A	N/A	Flush
259 811 Catalina	Marion	Marion	PSL	P	N	1 HH	NA	9/10/2008	9/10/2008	9/10/2008	6	None	N/A	N/A	Fixed within 7 days
260 Wilson & Chicago	Marion	Marion	Flush	F	Y	30	DR	9/10/2008	9/10/2008	9/10/2008	0	None	N/A	N/A	Flush
261 Thompson	Marion	Marion	Flush	F	N	0	NA	9/10/2008	9/10/2008	9/10/2008	0	None	N/A	N/A	Flush
262 Newwood & Pen	Marion	Marion	Hyd	H	N	0	NA	9/11/2008	9/11/2008	10/27/2008	46	None	N/A	N/A	Very small leak. Other work took precedent
263 Central soya	Marion	Marion	Flush	F	N	0	NA	9/11/2008	9/11/2008	9/11/2008	0	None	N/A	N/A	Flush
264 1036 Underwood	Marion	Marion	PSL	P	N	1 HH	NA	9/12/2008	9/12/2008	9/11/2008	6	None	N/A	N/A	Fixed within 7 days
265 1017 Oak Grove	Marion	Marion	PSL	P	N	1 HH	NA	9/12/2008	9/12/2008	9/12/2008	0	None	N/A	N/A	Shut off
266 800 Burgundy	Marion	Marion	CSL	3/4"	N	1 HH	NA	9/12/2008	9/12/2008	9/13/2008	0	10 x 10	Dir	Incomplete	Repaired
267 Englewood	Marion	Pleasant	Flush	F	N	0	NA	9/13/2008	9/13/2008	9/13/2008	0	None	N/A	N/A	Flush
268 764 Oak Grove	Marion	Marion	PSL	P	N	1 HH	NA	9/15/2008	9/15/2008	9/15/2008	11	None	N/A	N/A	Order to check was not issued within 7 days
269 Fairfield Engineering	Marion	Marion	PSL	P	N	1 HH	NA	9/15/2008	9/15/2008	9/15/2008	0	None	N/A	N/A	Shut off
270 Johnson	Marion	Marion	Flush	F	N	0	NA	9/15/2008	9/15/2008	9/15/2008	0	None	N/A	N/A	Flush
271 Englewood	Marion	Pleasant	Flush	F	N	0	NA	9/16/2008	9/16/2008	9/15/2008	0	None	N/A	N/A	Flush
272 1124 Fairwood	Marion	Marion	PSL	P	N	1 HH	NA	9/16/2008	9/16/2008	9/17/2008	1	None	N/A	N/A	Fixed within 7 days
273 Lee & Evans	Marion	Marion	Flush	F	Y	60	DR	9/17/2008	9/17/2008	9/17/2008	0	None	N/A	N/A	Flush
274 245 Vine St	Marion	Marion	CSL	3/4"	N	1 HH	NA	9/17/2008	9/17/2008	9/17/2008	0	None	N/A	N/A	Repaired
275 463 Swiss Dr	Marion	Marion	PSL	P	N	1 HH	NA	9/17/2008	9/17/2008	9/22/2008	5	None	N/A	N/A	Fixed within 7 days
276 Libby Lane	Marion	Marion	CWM	8	N	0	NA	9/19/2008	9/19/2008	9/25/2008	6	5 x 10	Dir	Incomplete	Done
277 328 Summit	Marion	Marion	PSL	P	N	1 HH	NA	9/20/2008	9/20/2008	9/20/2008	0	None	N/A	N/A	Shut off
278 Johnson	Marion	Marion	Flush	F	N	0	NA	9/23/2008	9/23/2008	9/23/2008	0	None	N/A	N/A	Flush
279 145 Franconia	Marion	Marion	PSL	P	N	1 HH	NA	9/23/2008	9/23/2008	9/30/2008	7	None	N/A	N/A	Fixed within 7 days
280 Church & Clover	Marion	Marion	CWM	6	N	0	NA	9/24/2008	9/24/2008	9/25/2008	2	9 x 9	Pavement	Incomplete	Done
281 556 Toledo	Marion	Marion	CSL	3/4"	N	1 HH	NA	9/24/2008	9/24/2008	9/24/2008	0	5 x 7	Pavement	Incomplete	Repaired
282 465 Easy	Marion	Marion	PSL	P	N	1 HH	NA	9/25/2008	9/25/2008	9/26/2008	1	None	N/A	N/A	Fixed within 7 days
283 Weiss Dr	Marion	Grand Prairie	CWM	8	Y	130	DR	9/29/2008	9/29/2008	9/29/2008	0	10 x 12	Dir	Incomplete	Done
284 Weiss Dr	Marion	Grand Prairie	Flush	F	Y	130	DR	9/29/2008	9/29/2008	9/29/2008	0	None	N/A	N/A	Water service turned off due to severity leak
285 674 Marshall	Marion	Marion	PSL	P	N	1 HH	NA	9/29/2008	9/29/2008	9/29/2008	0	None	N/A	N/A	Fixed within 7 days
286 465 Sides	Marion	Marion	PSL	P	N	0	NA	9/29/2008	9/29/2008	10/6/2008	7	None	N/A	N/A	Was turned off due to severity of leak
287 3142 Stral	Marion	Grand Prairie	PSL	P	N	0	NA	10/1/2008	10/1/2008	10/2/2008	1	None	N/A	N/A	Repaired
288 476 S Vine	Marion	Marion	CSL	3/4"	N	0	NA	10/2/2008	10/2/2008	10/2/2008	5	7 x 8	Pavement	Incomplete	Was turned off due to severity of leak
289 316 Bellefontaine	Marion	Marion	PSL	P	N	0	NA	10/2/2008	10/2/2008	10/2/2008	0	None	N/A	N/A	WJPP did not fix the leak within 7 days
290 533 Avondale	Marion	Marion	PSL	P	N	0	NA	10/3/2008	10/3/2008	10/17/2008	14	None	N/A	N/A	Flow lost
291 Flow test McMan Blvd	Marion	Marion	Flush	F	N	0	NA	10/8/2008	10/8/2008	10/6/2008	0	None	N/A	N/A	WJPP did not fix the leak within 7 days
292 574 Wood	Marion	Marion	PSL	P	N	0	NA	10/8/2008	10/8/2008	10/17/2008	11	None	N/A	N/A	Was given 10 days by distribution
293 247 E Church	Marion	Marion	PSL	P	N	0	NA	10/8/2008	10/8/2008	10/10/2008	1	5 x 12	Dir	Incomplete	Repaired
294 314 Forest Lawn Blvd	Marion	Marion	CWM	2	Y	10	DR	10/11/2008	10/11/2008	10/10/2008	0	None	N/A	N/A	Flush
295 Park & Fairground	Marion	Marion	Flush	F	N	0	NA	10/9/2008	10/9/2008	10/9/2008	0	None	N/A	N/A	Flush

[CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other DR= Door Tag; DTD = Door to Door]															
Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
296 N Main 150 S of George	Marion	Marion	CSL	3/4"	N	0	NA	NA	10/10/2008	10/17/2008	7	9 x 12	Pavement	NA	Repaired
297 884 Amburst	Marion	Marion	PSL	P	N	0	NA	NA	10/10/2008	10/17/2008	7	NA	NA	NA	Fixed within 7 days
298 Executive & Ellen Key	Marion	Marion	CWM	8	N	0	NA	NA	10/12/2008	10/13/2008	1	9 x 12	Pavement	NA	Repaired
299 641 Wilson	Marion	Marion	CSL	3/4"	N	0	NA	NA	10/13/2008	10/25/2008	12	12 x 7	Pavement	NA	Other work took precedent
300 217 Dennis	Marion	Marion	CSL	3/4"	N	0	NA	NA	10/13/2008	10/13/2008	0	8 x 10	Dirt	Incomplete	Repaired
301 217 Dennis	Marion	Marion	Flush	F	N	0	NA	NA	10/13/2008	10/13/2008	0	NA	NA	NA	Repaired
302 392 Milburn	Marion	Marion	CSL	3/4"	N	0	NA	NA	10/13/2008	10/13/2008	0	7 x 9	Pavement	NA	Repaired
303 616 Patterson	Marion	Marion	PSL	P	N	0	NA	NA	10/13/2008	10/15/2008	2	NA	NA	NA	Fixed within 7 days
304 341 Avondale	Marion	Marion	PSL	P	N	0	NA	NA	10/14/2008	10/21/2008	7	NA	NA	NA	fixed by WLP within 7 days
305 408 Clarendon Av	Marion	Marion	Flush	F	N	0	NA	NA	10/15/2008	10/15/2008	0	NA	NA	NA	Repaired
306 Summit & King	Marion	Marion	CWM	5	Y	14	DR	10/18/2008	10/16/2008	10/17/2008	1	2 x 13	Pavement	Incomplete	Repaired
307 Summit & King	Marion	Marion	Flush	F	N	0	NA	NA	10/17/2008	10/17/2008	0	NA	NA	NA	Repaired
308 999 Usher	Marion	Marion	CSL	3/4"	N	0	NA	NA	10/17/2008	10/20/2008	3	7 x 10	Dirt	Incomplete	Repaired
309 Country Club	Marion	Marion	Flush	F	N	0	NA	NA	10/20/2008	10/20/2008	0	NA	NA	NA	Repaired
310 801 Cheney	Marion	Marion	PSL	P	N	0	NA	NA	10/20/2008	10/20/2008	0	NA	NA	NA	Repaired
311 Pearl & Church	Marion	Marion	CWM	4	Y	10	DR	10/24/2008	10/22/2008	10/23/2008	2	NA	NA	NA	Fixed within 7 days
312 Pearl & Church	Marion	Marion	Flush	F	N	0	NA	NA	10/23/2008	10/23/2008	0	8 x 10	Pavement	NA	Repaired
313 Johnson	Marion	Marion	Flush	F	N	0	NA	NA	10/23/2008	10/23/2008	0	NA	NA	NA	Repaired
314 Lincoln & Mark	Marion	Marion	Flush	F	N	0	NA	NA	10/23/2008	10/23/2008	0	NA	NA	NA	Repaired
315 Fountain Pl Trailer Pt	Pleasant	Marion	PSL	P	N	0	NA	NA	10/26/2008	10/26/2008	0	NA	NA	NA	Repaired
316 465 S Main	Marion	Marion	CSL	3/4"	N	0	NA	NA	10/26/2008	10/26/2008	0	7 x 14	Pavement	Incomplete	Repaired
317 Clarendon & Mt Vernon	Marion	Marion	Flush	F	N	0	NA	NA	10/29/2008	10/28/2008	0	NA	NA	NA	Repaired
318 Clarendon & Mt Vernon	Marion	Marion	CWM	6	Y	20	DR	10/31/2008	10/30/2008	10/30/2008	0	11 x 14	Pavement	Incomplete	Repaired
319 Marion Senior Center (Marion)	Marion	Marion	CWM	6	Y	20	DR	10/31/2008	10/30/2008	10/30/2008	0	12 x 15	Pavement	Incomplete	Repaired
320 Marion Senior Center (Marion)	Marion	Marion	Flush	F	N	0	NA	NA	10/30/2008	10/30/2008	0	NA	NA	NA	Repaired
321 324 Barnhart	Marion	Marion	PSL	P	N	0	NA	NA	10/30/2008	10/30/2008	0	NA	NA	NA	Water turned off for repairs. Fixed
322 681 Henry	Marion	Marion	PSL	P	N	0	NA	NA	10/30/2008	11/3/2008	11	NA	NA	NA	Church-fixed leak 10/31 will check 11/3
323 1404 Woodridge	Marion	Marion	PSL	P	N	0	NA	NA	10/27/2008	11/30/2008	34	NA	NA	NA	Small leak. Repaired
324 Plant 3	Marion	Marion	PSL	P	N	0	NA	NA	10/31/2008	11/7/2008	7	NA	NA	NA	Repaired
325 Main St Valve #1243	Marion	Marion	Flush	F	Y	30	DR	11/1/2008	11/1/2008	11/1/2008	0	NA	NA	NA	Repaired
326 Main St Valve #478	Marion	Marion	Flush	V	Y	2	DR	11/1/2008	11/1/2008	11/1/2008	0	12 x 15	Pavement	Incomplete	Repaired
327 551 Richmond Ave	Marion	Marion	PSL	3/4"	Y	40	DR	11/2/2008	11/2/2008	11/2/2008	0	NA	NA	NA	Repaired
328 Power Shovel Pump Test	Marion	Marion	PSL	P	N	0	NA	NA	11/2/2008	11/3/2008	0	NA	NA	NA	Repaired
329 Richmond Ave	Marion	Marion	CWM	8	Y	40	DR	11/2/2008	11/3/2008	11/3/2008	0	NA	NA	NA	Repaired
330 Richmond Ave	Marion	Marion	Flush	F	N	0	NA	NA	11/3/2008	11/3/2008	0	NA	NA	NA	Repaired
331 Richmond Ave	Marion	Marion	Flush	F	N	0	NA	NA	11/3/2008	11/3/2008	0	NA	NA	NA	Repaired
332 414 Forest St	Marion	Marion	PSL	P	N	0	NA	NA	11/3/2008	11/3/2008	0	NA	NA	NA	Repaired
333 333 Waterloo	Marion	Marion	PSL	P	Y	35	DR	11/4/2008	11/4/2008	11/4/2008	0	NA	NA	NA	Repaired
334 977 Richmond	Marion	Marion	PSL	3/4"	N	0	NA	NA	11/4/2008	11/7/2008	9	NA	NA	NA	Was found on Saturday, could not check until Monday
335 Main St Valve #478	Marion	Marion	Flush	F	N	0	NA	NA	11/10/2008	11/10/2008	0	NA	NA	NA	Repaired
336 205 Silver	Marion	Marion	PSL	P	N	0	NA	NA	11/10/2008	11/10/2008	0	NA	NA	NA	Repaired
337 578 1/2 Yr	Marion	Marion	CWM	2	Y	20	DR	11/12/2008	11/12/2008	11/12/2008	8	NA	NA	NA	Was short staffed on the 7th day, turned off on 8th day.
338 Creston	Marion	Marion	CWM	2	Y	20	DR	11/12/2008	11/12/2008	11/12/2008	0	9 x 12	Pavement	Incomplete	Repaired
339 Creston	Marion	Marion	Flush	F	N	0	NA	NA	11/12/2008	11/12/2008	0	NA	NA	NA	Repaired
340 148 E Center	Marion	Marion	PSL	3/4"	N	0	NA	NA	11/12/2008	11/12/2008	0	NA	NA	NA	Repaired
341 284 Laburetta	Marion	Marion	PSL	3/4"	N	0	NA	NA	11/12/2008	11/12/2008	0	NA	NA	NA	Repaired
342 820 Central	Marion	Marion	PSL	P	N	0	NA	NA	11/14/2008	11/17/2008	3	8 x 10	Pavement	Incomplete	Repaired
343 888 N State	Marion	Marion	PSL	P	N	0	NA	NA	11/14/2008	11/14/2008	0	NA	NA	NA	Repaired
344 208 Battle St	Prospect	Marion	CSL	3/4"	N	0	NA	NA	11/14/2008	11/21/2008	7	NA	NA	NA	Was not fixed so water service was turned off.
345 287 Nye St	Marion	Marion	CWM	8	N	0	NA	NA	11/16/2008	11/16/2008	0	5 x 10	Pavement	Incomplete	Repaired
346 832 Davids	Marion	Marion	CWM	2	N	0	NA	NA	11/18/2008	11/18/2008	0	2 x 16	Pavement	Incomplete	Repaired
347 210 Summit	Marion	Marion	PSL	P	N	0	NA	NA	11/19/2008	11/21/2008	2	5 x 8	Dirt	Incomplete	Repaired
348 242 Spencer	Marion	Marion	PSL	P	N	0	NA	NA	11/20/2008	11/20/2008	0	NA	NA	NA	Repaired
349 Summit N of VHB	Marion	Marion	PSL	P	N	0	NA	NA	11/20/2008	11/24/2008	4	NA	NA	NA	Repaired
350 333 Joseph	Marion	Marion	CWM	6	N	0	NA	NA	11/20/2008	11/21/2008	1	4 x 11	Pavement	Incomplete	Repaired
351 442 Fiss	Marion	Marion	PSL	P	N	0	NA	NA	11/20/2008	11/21/2008	1	NA	NA	NA	Repaired
352 258 Windsor	Marion	Marion	CWM	2	Y	30	DR	11/25/2008	11/25/2008	11/25/2008	7	8 x 14	Pavement	Incomplete	Repaired
353 845 Chambord	Marion	Marion	PSL	P	N	0	NA	NA	11/25/2008	11/25/2008	0	NA	NA	NA	Repaired
354 430 Fiss	Marion	Marion	PSL	P	N	0	NA	NA	11/25/2008	11/30/2008	1	NA	NA	NA	Repaired
355 250 Ballentine Ave	Marion	Marion	CWM	2	N	0	NA	NA	11/25/2008	12/4/2008	8	5 x 17	Pavement	Incomplete	Repaired
356 666 Universal	Marion	Marion	PSL	P	N	0	NA	NA	11/25/2008	12/1/2008	3	7 x 13	Pavement	Incomplete	Repaired
357 239 Johnson	Marion	Marion	PSL	P	N	0	NA	NA	11/29/2008	12/1/2008	2	NA	NA	NA	Repaired
358 722 N State	Marion	Marion	PSL	P	N	0	NA	NA	12/3/2008	12/11/2008	8	NA	NA	NA	Plumber requested one extra day.
359 223 Clover	Marion	Marion	PSL	P	N	0	NA	NA	12/3/2008	12/3/2008	0	NA	NA	NA	Found leak, turned water off.
360 990 Chester	Marion	Marion	PSL	P	N	0	NA	NA	12/6/2008	12/11/2008	6	NA	NA	NA	Fixed under 7 days.
361 295 Green	Marion	Marion	PSL	P	N	0	NA	NA	12/6/2008	12/6/2008	0	NA	NA	NA	Found leak, turned water off.
362 George East of Jefferson	Marion	Marion	CSL	3/4"	N	0	NA	NA	12/8/2008	12/23/2008	15	NA	NA	NA	Was given 15 days by distribution
363 Prospect Flow Test	Prospect	Marion	Flush	F	N	0	NA	NA	12/8/2008	12/10/2008	2	9 x 11	Pavement	Incomplete	Repaired
364 298 Chicago Flush	Marion	Marion	Flush	F	N	0	NA	NA	12/8/2008	12/8/2008	0	NA	NA	NA	Repaired
365 285 W Columbia	Marion	Marion	PSL	P	N	0	NA	NA	12/9/2008	12/9/2008	0	NA	NA	NA	Flow Test
366 388 E George	Marion	Marion	PSL	P	N	0	NA	NA	12/11/2008	12/12/2008	1	NA	NA	NA	Leak became severe, turned off and repaired
367 Chester Flow Test	Marion	Marion	Flush	F	N	0	NA	NA	12/11/2008	12/11/2008	0	NA	NA	NA	Found leak, turned water off.
368 1265 Indiana	Marion	Marion	CWM	2	N	0	NA	NA	12/12/2008	12/12/2008	0	NA	NA	NA	Flow Test
369 896 Park St	Marion	Marion	PSL	P	N	0	NA	NA	12/13/2008	12/13/2008	0	5 x 7	Dirt	Incomplete	Repaired
370 898 Darius	Marion	Marion	PSL	P	N	0	NA	NA	12/15/2008	1/6/2009	21	NA	NA	NA	Rescheduled by field.
											Ongoing	NA	NA	NA	WLP delayed. Will be replacing line 01/05/09

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PVM = Private Water Main; PO = Private Other DR= Door Tag; DTD = Door to Door															
Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
371 Mill	Marion	Marion	PSL	P	N	0	NA	NA	12/15/2008	12/31/2008	15	NA	NA	NA	Repaired
372 593 Decatur	Marion	Marion	CWM	2	Y	15	NA	12/17/2008	12/16/2008	12/16/2008	0	3 x 16	Pavement	NA	Repaired
373 Lee & Fairground, CSX	Marion	Marion	PSL	P	N	0	NA	NA	12/16/2008	12/16/2008	2	NA	NA	NA	Fixed under 7 days.
374 1410 Woodridge	Marion	Marion	PSL	P	N	0	NA	NA	12/17/2008	1/12/2009	26	NA	NA	NA	Very Small leak. Contractor request more time due to difficulty
375 279 Rose	Marion	Marion	PSL	P	N	0	NA	NA	12/17/2008	12/17/2008	0	NA	NA	NA	Found leak, turned water off.
376 174 Lincoln	Marion	Marion	PSL	P	N	0	NA	NA	12/18/2008	12/23/2008	5	NA	NA	NA	Fixed under 7 days.
377 409 Bightwood	Marion	Marion	CSL	3/4"	N	0	NA	NA	12/18/2008	12/23/2008	0	NA	NA	NA	Repaired. Contractor Responsibility
378 191 Wallace	Marion	Marion	CSL	3/4"	N	0	NA	NA	12/19/2008	12/23/2008	4	6 x 10	Pavement	NA	Repaired
379 1250 Old Pond	Marion	Marion	CSL	3/4"	N	0	NA	NA	12/20/2008	12/20/2008	0	NA	NA	NA	Repaired. Contractor Responsibility
380 130 S State	Marion	Marion	PSL	P	N	0	NA	NA	12/20/2008	12/20/2008	0	NA	NA	NA	Found leak, turned water off.
381 174 Lincoln	Marion	Marion	CSL	3/4"	N	0	NA	NA	12/23/2008	12/31/2008	8	8 x 11	Pavement	NA	Rescheduled by field.
382 217 S Grand	Marion	Marion	PSL	P	N	0	NA	NA	12/23/2008	1/5/2009	13	NA	NA	NA	Rescheduled by field.
383 281 Forest	Marion	Marion	CSL	3/4"	N	0	NA	NA	12/23/2008	1/9/2009	17	6 x 11	Pavement	NA	Very Small leak. Other work took precedent
384 903 & 746	Caledonia	Clairdon	CWM	4	Y	200	News Media	12/24/2008	12/23/2008	12/23/2008	0	10 x 12	Dirt	NA	Repaired
385 High & walnut	Caledonia	Clairdon	CWM	4	N	0	NA	NA	12/23/2008	12/23/2008	0	4 x 8	Pavement	NA	Repaired
386 146 Lincoln	Marion	Marion	PSL	P	N	0	NA	NA	12/24/2008	12/28/2008	2	NA	NA	NA	Fixed under 7 days.
387 Brenner & S Main	Marion	Marion	CWM	2	Y	3	DP	12/25/2008	12/24/2008	12/24/2008	0	20 x 20	Pavement	NA	Repaired
388 275 Chestnut	Marion	Marion	PSL	P	N	0	NA	NA	12/29/2008	12/29/2008	0	NA	NA	NA	Repaired
389 403 S Vine	Marion	Marion	CSL	3/4"	N	0	NA	NA	12/29/2008	12/30/2008	1	10 x 11	Pavement	NA	Repaired
390 610 N State	Marion	Marion	PSL	P	N	0	NA	NA	12/29/2008	12/30/2008	1	NA	NA	NA	Found leak, turned water off.
391 Brenner East of S Main	Marion	Marion	CWM	2	N	0	NA	NA	12/29/2008	1/2/2009	4	8 x 30	Pavement	NA	Repaired
392 Owens W of Park	Marion	Marion	Flush	F	N	0	NA	NA	12/29/2008	12/29/2008	0	NA	NA	NA	Flush

**Ohio American Water Company
Portage County District
2008 Water Leak Log**

CSL = Company Service Leak;
CWM = Company Water Main;
HYD = Hydrant; VLV = Valve;
CO = Company Other; PSL =
Private Service Leak; PWM =
Private Water Main; PO =
Private Other DR= Door Tag;
DTD = Door to Door

Location FIRST QUARTER	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date		Comment
														Restoration Completed	Completed	
3547 Ivanhoe	Beechcrest	Birnfield	CWM	6"	Y	27	Door hangers	1/19/2008	1/16/2008	1/16/2008	0	10x10	Dirt	5/20/08		Shear break on 6" C.I. pipe that runs behind homes
3547 Ivanhoe	Beechcrest	Birnfield	CWM	6"	Y	27	Door hangers	1/19/2008	1/18/2008	1/18/2008	0	10x10	Dirt	5/20/08		Shear break on 6" C.I. pipe that runs behind homes
2758 Starwich	Aurora East	Shallersville	CSL	6"	N	14	Door hangers	N/A	4/5/2008	4/5/2008	0	4x4	Slag stone	None		Service Saddle rotted bolts from sower ground, replaced None needed saddle
THIRD QUARTER																
3555 Gary Drive	Beechcrest	Birnfield	CO	4"	Y	56	DTD	9/5/2008	9/4/2008	9/4/2008	0	6X5	Dirt	Not yet		Replaced Flush point Elbow off below grade
10348 Winthrop	Aurora East	Shallersville	CSL	.75"	N	1			10/2/2008	10/2/2008	0	5X5	Dirt	Not yet		While straightening a CB discovered Service leaking on Company Side of CS. At about 1 gm I'm guessing for 8 months or more, copper was burned through 25mm size hole
FOURTH QUARTER																
3487 Jamison	Beechcrest	Birnfield	CSL	4"	N	1	DTD	N/A	10/25/2008	10/25/2008	0	5X8	Dirt	Not yet		Shear break on 4" C.I. 2' from service line

Ohio American Water Company
Tiffin District
2008 Water Leak Log

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other DR= Door Tag; DTD = Door to Door

Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
1 46-52 BRADEN	Tiffin City	Tiffin City	CWM	2"	N	N/A	N/A	N/A	1/22/2008	1/30/2008	1	5 X 5	STREET	01/30/08	
2 32 HALL	Tiffin City	Tiffin City	CSL	3/4"	N	N/A	N/A	N/A	1/23/12/007	1/22/2008	2	5 X 5	BLVD	01/22/08	
3 198 SECOND	Tiffin City	Tiffin City	CSL	3/4"	N	N/A	N/A	N/A	1/23/12/007	1/22/2008	2	5 X 5	BLVD	01/22/08	
4 40 HUSS	Tiffin City	Tiffin City	CWM	12"	N	N/A	N/A	N/A	1/14/2008	1/18/2008	5	5 X 6	BLVD/STREET	01/18/08	
5 528 W MARKET	Tiffin City	Tiffin City	PSL	8"	N	N/A	N/A	N/A	1/16/2/08	1/16/2008	2	4 X 10	BLVD	01/16/08	
6 235 N SANDUSKY	Tiffin City	Tiffin City	CSL	8"	N	N/A	N/A	N/A	1/20/2008	N/A	N/A	3 X 5, 4 X 6	BLVD/STREET	01/23/08	STILL OFF
7 411-415 S WASHINGTON	Tiffin City	Tiffin City	CSL	8"	N	N/A	N/A	N/A	1/20/2008	1/23/2008	0	3 X 5	STREET	01/22/08	
8 115 OHIO	Tiffin City	Tiffin City	CWM	6"	Y	40	door hangers	1/24/2008	1/25/2008	1/25/2008	0	4 X 6	STREET	01/25/08	
9 9 MAIN	Tiffin City	Tiffin City	CWM	6"	N	N/A	N/A	N/A	1/27/2008	1/27/2008	0	5 X 5	STREET	01/27/08	
10 14 ASH	Tiffin City	Tiffin City	CWM	2"	N	N/A	N/A	N/A	2/2/2008	2/2/2008	0	10 X 25	BLVD/STREET	02/02/08	
11 711 N SANDUSKY	Tiffin City	Tiffin City	CSL	12"	N	N/A	N/A	N/A	2/9/2008	2/11/2008	2	3 X 5, 4 X 8	BLVD/STREET	02/11/08	
12 157 WENTZ	Tiffin City	Tiffin City	PSL	3/4"	N	N/A	N/A	N/A	2/12/2008	2/19/2008	7	N/A	N/A	02/19/08	
13 735 W MARKET	Tiffin City	Tiffin City	CSL	4"	N	N/A	N/A	N/A	2/13/2008	2/13/2008	0	3 X 5	BLVD	02/13/08	
14 80 CENTER	Tiffin City	Tiffin City	PSL	3/4"	N	N/A	N/A	N/A	2/22/2008	2/22/2008	0	N/A	N/A	02/22/08	
15 TEAKWOOD CT.	Tiffin City	Tiffin City	PSL	1"	Y	15	door hangers	2/24/2008	2/25/2008	2/25/2008	0	N/A	N/A	02/22/08	
16 42 CLINTON	Tiffin City	Tiffin City	PSL	5/8"	N	N/A	N/A	N/A	2/26/2008	2/26/2008	0	N/A	N/A	02/26/08	
17 241 FIRST	Tiffin City	Tiffin City	CSL	2"	N	N/A	N/A	N/A	2/26/2008	3/14/2008	0	4 X 6	BLVD	03/04/08	
18 545 E Perry	Tiffin City	Tiffin City	CO	5/8"	N	N/A	N/A	N/A	3/3/2008	3/5/2008	1	2x5 4x5	BLVD	3/5/08	
19 119 Apple	Tiffin City	Tiffin City	PSL	5/8"	N	N/A	N/A	N/A	3/5/2008	3/6/2008	0	3 X 5	BLVD	3/6/08	
20 214 Sixth	Tiffin City	Tiffin City	CO	3/4"	N	N/A	N/A	N/A	3/5/2008	3/6/2008	0	4 X 5	BLVD	03/06/08	
21 60 Hudson	Tiffin City	Tiffin City	CSL	1"	N	N/A	N/A	N/A	3/3/2008	3/7/2008	4	4 X 6	Street	03/07/08	
22 202 Hudson	Tiffin City	Tiffin City	CSL	5/8"	N	N/A	N/A	N/A	3/17/2008	3/24/2008	7	3 X 4	Sidewalk	03/24/08	
23 350 Main	Tiffin City	Tiffin City	CSL	6"	N	N/A	N/A	N/A	3/24/2008	3/25/2008	1	5 x 4 3 x 5	Street/Sidewalk	03/25/08	
24 241 First	Tiffin City	Tiffin City	CSL	3/4"	N	N/A	N/A	N/A	3/25/2008	3/31/2008	6	4 x 7	BLVD	03/31/08	
25 1540 S State Route 53 #24	Tiffin City	Tiffin City	PSL	1"	N	N/A	N/A	N/A	4/2/2008	4/2/2008	0	N/A	N/A	04/02/08	
26 369 W Perry	Tiffin City	Tiffin City	CSL	5/8"	N	N/A	N/A	N/A	4/10/2008	4/14/2008	0	4 X 8	Street/BLVD	04/14/08	
27 368 W Market	Tiffin City	Tiffin City	HYD	6"	N	N/A	N/A	N/A	4/15/2008	4/17/2008	2	12 x 7	BLVD	04/17/08	Replace Hydrant
28 338 Mainone	Tiffin City	Tiffin City	VLV	8"	N	N/A	N/A	N/A	4/17/2008	4/22/2008	5	3 X 5	street	04/22/08	Repaired Valve
29 79 Gibson	Tiffin City	Tiffin City	VLV	8"	N	N/A	N/A	N/A	4/17/2008	4/25/2008	8	4 X 5	Street	04/25/08	Repaired Valve
30 211 Wentz	Tiffin City	Tiffin City	VLV	6"	N	N/A	N/A	N/A	4/17/2008	4/29/2008	12	4 X 5	street	04/29/08	Repaired Valve
31 61 Ene	Tiffin City	Tiffin City	CSL	3/4"	N	N/A	N/A	N/A	4/25/2008	4/28/2008	4	3 x 5 3 x 5	Street/BLVD	05/01/08	
32 259 Jefferson	Tiffin City	Tiffin City	PSL	3/4"	Y	4	door hangers	5/10/2008	5/5/2008	5/7/2008	2	3 X 5	Street	05/07/08	Repaired Hydrant
33 137 S Washington	Tiffin City	Tiffin City	CSL	5/8"	N	N/A	N/A	N/A	5/5/2008	5/8/2008	15	4 X 5	street	05/08/08	
34 106 E Market	Tiffin City	Tiffin City	HYD	6"	N	N/A	N/A	N/A	5/5/2008	5/7/2007	2	N/A	N/A	05/07/08	
35 137 S Washington	Tiffin City	Tiffin City	PSL	5/8"	N	N/A	N/A	N/A	4/30/2008	5/12/2008	12	10 x 10	Street/BLVD	05/12/08	
36 101 Douglas	Tiffin City	Tiffin City	CSL	5/8"	N	N/A	N/A	N/A	5/7/2008	5/13/2008	6	4 X 6	BLVD	05/13/08	
37 383 Greenfield	Tiffin City	Tiffin City	VLV	8"	Y	43	door hangers	5/11/2008	5/5/2008	5/12/2008	6	3 X 5	Street	05/13/08	
38 Melissa & W Market	Tiffin City	Tiffin City	HYD	4"	Y	N/A	N/A	N/A	5/5/2008	5/20/2008	5	5 X 5	BLVD	05/20/08	
39 475 Cee	Tiffin City	Tiffin City	HYD	6"	N	N/A	N/A	N/A	5/15/2008	5/20/2008	5	5 X 5	Street	05/20/08	
40 68 N Monroe	Tiffin City	Tiffin City	CWM	8"	N	N/A	N/A	N/A	5/23/2008	5/21/2008	5	6 X 6	Street	5/21/08	
41 67 Oak	Tiffin City	Tiffin City	CO	5/8"	N	N/A	N/A	N/A	5/23/2008	5/28/2008	5	5 X 4	BLVD	05/28/08	
42 119 Douglas	Tiffin City	Tiffin City	PSL	3/4"	N	N/A	N/A	N/A	5/17/2008	6/25/2008	8	N/A	N/A	06/25/08	
43 46 Jackson	Tiffin City	Tiffin City	PSL	3/4"	N	N/A	N/A	N/A	7/9/2008	7/31/2008	22	N/A	N/A	N/A	
44 635 E St Rt 16	Tiffin City	Tiffin City	CO	3/4"	N	N/A	N/A	N/A	7/14/2008	7/14/2008	4	3 X 5	bld	07/14/08	
45 140 S Monroe	Tiffin City	Tiffin City	CO	3/4"	N	N/A	N/A	N/A	7/14/2008	7/15/2008	1	3 X 5	bld	07/15/08	
46 Clay & Jackson	Tiffin City	Tiffin City	CWM	n/a	N	N/A	N/A	N/A	7/15/2008	7/16/2008	0	N/A	N/A	N/A	
47 163 Schorhardt	Tiffin City	Tiffin City	PSL	n/a	N	N/A	N/A	N/A	7/23/2008	8/23/2008	32	N/A	N/A	N/A	
48 4850 Clay Street	Tiffin City	Tiffin City	CO	1"	N	N/A	N/A	N/A	7/23/2008	7/24/2008	1	4 X 5	bld	07/24/08	
49 200 St. Francis	Tiffin City	Tiffin City	CWM	6"	Y	1	door hangers	7/26/2008	7/26/2008	7/26/2008	0	4 X 16	parking lot	07/26/08	
50 69 Douglas	Tiffin City	Tiffin City	CO	n/a	N	N/A	N/A	N/A	7/24/2008	7/29/2008	5	4 X 5	bld	07/29/08	
51 187 Walker	Tiffin City	Tiffin City	CWM	6"	N	N/A	N/A	N/A	7/26/2008	7/30/2008	2	6 X 6	BLVD/STREET	07/30/08	
52 240 W Market	Tiffin City	Tiffin City	PSL	8"	N	15	N/A	N/A	7/30/2008	7/30/2008	0	4 X 8	street	07/30/08	
53 13 Wentz	Tiffin City	Tiffin City	CWM	3"	N	N/A	N/A	N/A	8/5/2008	8/12/2008	7	N/A	N/A	N/A	
54 635 E St Rt 16	Tiffin City	Tiffin City	CWM	3"	N	N/A	N/A	N/A	8/6/2008	8/6/2008	0	4 X 6	street	08/06/08	
55 195 & 197 S Washington	Tiffin City	Tiffin City	CO	12"	N	N/A	N/A	N/A	8/6/2008	8/7/2008	1	3 X 5	street	08/07/08	
56 intersection OH & W Market	Tiffin City	Tiffin City	CO	6"	Y	77	door hangers	8/15/2008	8/12/2008	8/14/2008	2	4x5/ 5x6	street	08/14/08	Killed Service
57 163 Clinton	Tiffin City	Tiffin City	CWM	4"	N	N/A	N/A	N/A	8/16/2008	8/19/2008	0	4 X 6	street	08/19/08	Replaced Valve
58 68 Schorhardt	Tiffin City	Tiffin City	CO	n/a	N	N/A	N/A	N/A	8/16/2008	8/22/2008	4	3 X 5	street	08/22/08	
59 263 Main	Tiffin City	Tiffin City	CO	n/a	N	N/A	N/A	N/A	8/21/2008	8/21/2008	0	3 X 5	bld	08/21/08	
60 481 E Perry	Tiffin City	Tiffin City	PSL	n/a	N	N/A	N/A	N/A	8/20/2008	8/29/2008	9	N/A	N/A	08/29/08	
61 129 Oak	Tiffin City	Tiffin City	CWM	3"	N	N/A	N/A	N/A	8/25/2008	8/28/2008	3	6 X 4	street	08/28/08	
62 245 First	Tiffin City	Tiffin City	CO	n/a	N	N/A	N/A	N/A	9/8/2008	9/8/2008	9	4 X 6	sldewalk	09/08/08	
63 151 Fifth	Tiffin City	Tiffin City	CO	n/a	N	N/A	N/A	N/A	9/6/2008	9/16/2008	11	3 X 7	street	09/16/08	
64 miami street	Tiffin City	Tiffin City	own	n/a	N	N/A	N/A	N/A	9/11/2008	9/16/2008	5	3 X 9	parking lot	09/16/08	killed main, remove hydrant
65 S Washington & Gibson	Tiffin City	Tiffin City	own	8"	N	12	N/A	N/A	9/11/2008	9/16/2008	5	4 X 12	Street/BLVD	09/23/08	
66 24 Beechwood	Tiffin City	Tiffin City	CO	6"	N	N/A	N/A	N/A	9/24/2008	9/25/2008	1	3 X 9	street	09/25/08	
67 626 S Washington	Tiffin City	Tiffin City	CO	6"	N	15	door hangers	10/6/2008	10/9/2008	10/9/2008	1	6 X 6	bld	10/09/08	
68 57 Sycamore St	Tiffin City	Tiffin City	CSL	n/a	N	N/A	N/A	N/A	10/14/2008	10/16/2008	2	3 X 5	street	10/16/08	
69 192 Hudson	Tiffin City	Tiffin City	CSL	n/a	N	N/A	N/A	N/A	10/6/2008	10/8/2008	2	3 X 5	street	10/08/08	
70 241 First	Tiffin City	Tiffin City	CSL	n/a	N	N/A	N/A	N/A	10/14/2008	10/21/2008	7	3 X 5	BLVD	10/21/08	

CONTRACTOR NEEDED TOP OF BOX OUT OFF
SERVICE LINE HIT BY CONTRACTOR

CONTRACTOR DUG OUT LINE

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other; DR = Door Tag; DTD = Door to Door

Location	Service Area	Township	Leak Type	Size	Bolt Order (Y or N)	Number of Services Affected	Method of Notification	Date Bolt Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
71 431 Webster	Tiffin City	Tiffin City	CO	n/a	n	N/A	N/A	N/A	10/15/2008	10/24/2008	9	4 x 5	bvd	10/24/08	
72 76 Apple	Tiffin City	Tiffin City	CSL	n/a	n	N/A	N/A	N/A	10/21/2008	10/22/2008	1	4 x 5	Sidewalk	10/22/08	
73 35 Grace	Tiffin City	Tiffin City	CO	n/a	n	N/A	N/A	N/A	10/28/2008	11/10/2008	13	4 x 5	Bvd	11/10/08	
74 67 Maule	Tiffin City	Tiffin City	CO	n/a	n	N/A	N/A	N/A	10/31/2008	11/5/2008	5	4 x 5	street	11/5/08	
75 381 N Sandusky	Tiffin City	Tiffin City	CO	n/a	n	N/A	N/A	N/A	11/1/2008	11/3/2008	0	4 x 5	street	11/3/08	
76 20 Wentz	Tiffin City	Tiffin City	Co	n/a	n	N/A	N/A	N/A	11/4/2008	11/10/2008	6	4 x 5	Bvd	11/10/08	
77 202 Second Ave	Tiffin City	Tiffin City	CO	n/a	n	N/A	N/A	N/A	11/5/2008	11/14/2008	9	4 x 5	bvd	11/14/08	Installed Meter Pit
78 303 W Perry	Tiffin City	Tiffin City	CO	n/a	n	N/A	N/A	N/A	11/10/2008	11/13/2008	3	4 x 5	Bvd	11/13/08	
79 250 Jefferson	Tiffin City	Tiffin City	CO	n/a	n	N/A	N/A	N/A	11/11/2008	11/19/2008	8	4 x 5	Street	11/19/08	Killed service
80 508 E SR 18	Tiffin City	Tiffin City	CWM	n/a	n	N/A	N/A	N/A	11/13/2008	11/19/2008	5	5 x 4	Bvd	11/19/08	Killed Main
81 455 S Monroe	Tiffin City	Tiffin City	CO	n/a	n	N/A	N/A	N/A	11/21/2008	11/21/2008	3	4 x 5	Bvd	11/21/08	
82 1750 CR 1	Tiffin City	Tiffin City	VLV	n/a	n	N/A	N/A	N/A	11/21/2008	11/24/2008	3	5 x 5	Bvd	11/24/08	Repaired Valve

Location	Location of leak; may include street address of nearest residence or distance from intersecting street
Service Area Township	If Network service are is segmented, this information should be included Township in which leak occurred
Leak Type Size	List is found at top of sheet; each leak will be either Company or Private; This pertains to mains, valves and services Yor N answer; Service affecting leaks are determined to be those leaks that leave customers with little or no pressure
Service Affecting Report Date	The date the Company became aware of the leak
Repair Date	The date the leak was repaired
Elapsed Days	The number of days from the report date to repair date; under normal conditions, this should be between 0 to 1 days for service affecting leaks and 0 to 7 days for non-service affecting leaks
Boil Order	Was a boil order issued to customers
Comments	Any additional useful information; should include an explanation of any repair outside the regulated number of elaped days
Method of Notification	

CSL	Company Service Line	Yes
CWM	Company Water Main	No
HYD	Hydrant	
VLV	Valve	
CO	Company Other	
PSL	Private Service Line	
PWM	Private Water Main	
PO	Private Other	