



Bricker & Eckler
ATTORNEYS AT LAW
COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

February 17, 2009

VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

Re: Case No. 07-1112-WS-AIR
Case No. 08-1233-WS-UNC
Ohio American Water Company
Stipulation Page No. 11, ¶14D

RECEIVED-DOCKETING DIV
2009 FEB 17 PM 4:02
PUCO

Dear Ms. Jenkins:

In response to the February 4, 2009 letter and as stated in Ohio American Water Company's response dated February 12, 2009, attached are the Lake Darby Hardness Monthly Reports for November and December 2008 which contain the missing daily average sample information. Also attached is the Lake Darby Hardness Report for January 2009.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield
Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician JM Date Processed 2/17/2009

Ohio-American Water Company
Franklin County District
Lake Darby Water Hardness Report

Reporting Month & Year November-08

Date	Day	On-Line Measurement (mg/L) Continuous	On-Line Unit Operational (Y or N)	LDWTP Process Control Measurement (mg/L) Daily	OAWC WQ Lab Measurement (mg/L) Daily	LDWTP Outside Lab Measurement (mg/L) 1/Month	LDWTP Outside Lab Collection Time Sampler	Distribution Outside Lab Measurement (mg/L) 1/Month	Distribution Outside Lab Collection Time Sampler	Water Distribution Measurement (mg/L) 2/week
1	Sat		Y	138	183					
2	Sun		Y	139	136					
3	Mon		Y	122	120					142
4	Tue		Y	125	130					
5	Wed		Y	129	120					128
6	Thu		Y	124	120					
7	Fri		Y	127	130					
8	Sat		Y	128	130					
9	Sun		Y	124	126					
10	Mon		Y	128	126					138
11	Tue		Y	124	124					
12	Wed		Y	127	132					130
13	Thu	LD	Y	128	132					
14	Fri	LD	Y	125	124					
15	Sat	LD	Y	128	126					
16	Sun	LD	Y	121	120					120
17	Mon	117	Y	124	120					
18	Tue	109	Y	110	98					122
19	Wed	LD	Y	112	114					
20	Thu	LD	Y	118	92					
21	Fri	116	Y	112	102					
22	Sat	LD	Y	110	108					
23	Sun	LD	Y	112	110					
24	Mon	114	Y	110	102					110
25	Tue	LD	Y	110	110	97	J Ward	108	J Ward	113
26	Wed	LD	Y	112	102					
27	Thu	110	Y	111	104					
28	Fri	LD	Y	110	116					
29	Sat	126	Y	128	128					
30	Sun	125	Y	122	120					
31										
Average		117		121	120					125
Max		126		139	183					142
Min		109		110	90					110
#>150		0		0	0					0

LD = Lost Data

All other On-line data was taken from on-line unit at the same time as PC measurement.

- NOTES:
- Operator shall make a notation in the Instrumentation Log Book on a DAILY basis on the status of the On-Line Hardness Analyzer.
 - Week is Sunday to Saturday
 - WQ Lab is responsible for delivering monthly sample to outside lab.
 - For any test with a hardness <95 mg/L or >145 mg/L notify the Network Operations Superintendent and the Operations Supervisor immediately.
 - Rate Order & Stipulation effective 11/13/2008

**Ohio-American Water Company
Franklin County District
Lake Darby Water Hardness Report**

Reporting Month & Year December-08

Date	Day	On-Line Measurement (mg/L) Continuous	On-Line Unit Operational (Y or N)	LDWTP Process Control Measurement (mg/L) Daily	OAWC WQ Lab Measurement (mg/L) Daily	LDWTP Outside Lab Measurement (mg/L) 1/Month	LDWTP, Outside Lab, Collection Time, Sampler	Distribution, Outside Lab, Measurement (mg/L) 1/Month	Distribution, Outside Lab, Collection Time, Sampler	Water Distribution Measurement (mg/L) 2/week
1	Mon	LD	Y	120	110	103	7:51 am, J Ward	100	9:30 am J Ward	109
2	Tue	112	Y	108	108					
3	Wed	115	Y	112	120					112
4	Thu	112	Y	117	118					
5	Fri	112	Y	108	107					
6	Sat	LD	Y	106	112					
7	Sun	LD	Y	118	114					
8	Mon	LD	Y	108	102					110
9	Tue	115	Y	114	110					
10	Wed	LD	Y	107	104					106
11	Thu	LD	Y	106	102					
12	Fri	120	Y	106	104					
13	Sat	129	Y	116	114					
14	Sun	139	Y	115	112					
15	Mon	139	Y	112	108					118
16	Tue	140	Y	108	114					
17	Wed	125	Y	112	112					122
18	Thu	126	Y	110	106					
19	Fri	130	Y	103	104					
20	Sat	122	Y	108	106					
21	Sun	133	Y	118	110					
22	Mon	139	Y	115	118					114
23	Tue	131	Y	116	106					120
24	Wed	130	Y	110	110					
25	Thu	133	Y	118	108					
26	Fri	103	Y	112	110					
27	Sat	108	Y	113	110					
28	Sun	133	Y	113	106					
29	Mon	LD	Y	110	108					118
30	Tue	148	Y	116	110					
31	Wed	139	Y	110	108					112
Average		126		112	109					114
Max		148		120	120					122
Min		103		103	102					106
#-150		0		0	0					0

Dec. 1, 6, 7, 8, 10, 11 and 28 - data lost.

All other On-line data was taken from on-line unit at the same time as PC measurement.

NOTES:

- 1) Operator shall make a notation in the Instrumentation Log Book on a DAILY basis on the status of the On-Line Hardness Analyzer.
- 2) Week is Sunday to Saturday
- 3) WQ Lab is responsible for delivering monthly sample to outside lab.
- 4) For any test with a hardness <95 mg/L or >145 mg/L notify the Network Operations Superintendent and the Operations Supervisor immediately.

**Ohio-American Water Company
Franklin County District
Lake Darby Water Hardness Report**

Reporting Month & Year January-09

Date	Day	On-Line Measurement (mg/L) Continuous	On-Line Unit Operational (Y or N)	LDWTP Process Control Measurement (mg/L) Daily	OAWC WQ Lab Measurement (mg/L) Daily	LDWTP Outside Lab Measurement (mg/L) 1/Month	LDWTP, Outside Lab, Collection Time, Sampler	Distribution Outside Lab, Measurement (mg/L) 1/Month	Distribution, Outside Lab, Collection Time, Sampler	Water Distribution Measurement (mg/L) 2/week
1	Thu	134	Y	110	108					
2	Fri	108	Y	108	120					
3	Sat	111	Y	108	102					
4	Sun	147	Y	118	112					
5	Mon	136	Y	108	102	92	7:15 am, J Ward	107	8:18 am, J Ward	117
6	Tue	137	Y	118	110					
7	Wed	137	Y	118	118					110
8	Thu	140	Y	124	120					
9	Fri	136	Y	114	106					
10	Sat	133	Y	128	130					
11	Sun	136	Y	131	126					
12	Mon	137	Y	106	106					118
13	Tue	145	Y	118	116					
14	Wed	138	Y	112	114					
15	Thu	144	Y	118	110					108
16	Fri	142	Y	122	120					
17	Sat	145	Y	129	128					
18	Sun	147	Y	114	110					
19	Mon	138	Y	115	106					122
20	Tue	130	Y	108	104					
21	Wed	136	Y	110	104					118
22	Thu	141	Y	114	106					
23	Fri	135	Y	129	128					
24	Sat	147	Y	117	110					
25	Sun	142	Y	112	104					120
26	Mon	135	Y	114	110					
27	Tue	137	Y	120	108					
28	Wed	136	Y	110	104					118
29	Thu	138	Y	114	106					
30	Fri	130	Y	110	130					
31	Sat	138	Y	118	112					
Average		137		118	112					116
Max		147		131	130					122
Min		108		106	102					108
#-150		0		0	0					0

171 - 1/4 limited data points retrieved from on-line unit

- NOTES:
- Operator shall make a notation in the Instrumentation Log Book on a DAILY basis on the status of the On-Line Hardness Analyzer.
 - Week is Sunday to Saturday
 - WQ Lab is responsible for delivering monthly sample to outside lab.
 - For any test with a hardness <95 mg/L or >145 mg/L notify the Network Operations Superintendent and the Operations Supervisor immediately.