



Bricker & Eckler
ATTORNEYS AT LAW
COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

March 5, 2009

VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

Re: Case No. 08-1233-WS-UNC
Ohio American Water Company
Stipulation Page No. 11, ¶14D

Dear Ms. Jenkins:

Pursuant to the Commission's November 12, 2008 Opinion and Order in Case No. 07-1112-WS-AIR, and to the Stipulation and Recommendation page 11, paragraph 14D, Ohio American Water Company submits for filing the Lake Darby Hardness Monthly Report for February 2009.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

PUCO

RECEIVED-DOCKETING DIV
2009 MAR -5 AM 9:38

**Ohio-American Water Company
Franklin County District
Lake Darby Water Hardness Report**

Reporting Month & Year February-08

1	2	3	4	5	6	7	8	9	10	11
Date	Day	On-Line Measurement (mg/L) Every 2 hrs when LDWTP is ON	On-Line Unit Operational (Y or N)	LDWTP Process Control Measurement (mg/L) Daily	QAWC WQ Lab Measurement (mg/L) Daily	LDWTP Outside Lab Measurement (mg/L) 1/Month	LDWTP Outside Lab Collection Time Sampler	Distribution Outside Lab Measurement (mg/L) 1/Month	Distribution Outside Lab Collection Time Sampler	WQ Water Distribution Measurement (mg/L) 2/week
1	Sun	141	Y	116	114					
2	Mon	138	Y	114	112					120
3	Tue	129	Y	116	120					
4	Wed	137	Y	114	111	101	7:30 AM, Jeff Ward	105	8:45 AM, Jeff Ward	112
5	Thu	133	Y	122	114					118
6	Fri	124	Y	127	100					
7	Sat	130	Y	115	110					
8	Sun	132	Y	113	104					
9	Mon	143	Y	113	114					
10	Tue	119	Y	118	120					128
11	Wed	119	Y	114	104					122
12	Thu	113	Y	105	98					
13	Fri	118	Y	112	104					
14	Sat	103	Y	110	108					
15	Sun	118	Y	115	118					
16	Mon	112	Y	110	110					114
17	Tue	103	Y	110	108					
18	Wed	120	Y	104	96					
19	Thu	110	Y	106	104					110
20	Fri	113	Y	108	108					
21	Sat	117	Y	112	122					
22	Sun	112	Y	104	96					130
23	Mon	108	Y	112	108					
24	Tue	104	Y	108	108					
25	Wed	115	Y	112	104					112
26	Thu	111	Y	118	116					
27	Fri	98	Y	114	110					
28	Sat	109	Y	132	104					
Average		119		113	109					118
Max		143		132	122					130
Min		98		104	98					110
% > 150 mg/L		0		0	0					0

- NOTES:
- 1) Operator shall make a notation in the Instrumentation Log Book on a DAILY basis on the status of the On-Line Hardness Analyzer.
 - 2) Week is Sunday to Saturday
 - 3) WQ Lab is responsible for delivering monthly sample to outside lab.
 - 4) For any test with a hardness <95 mg/L or >145 mg/L notify the Network Operations Superintendent and the Operations Supervisor immediately.