

FILE



Bricker & Eckler
ATTORNEYS AT LAW
COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

RECEIVED-DOCKETING DIV

April 6, 2009

2009 APR -6 PM 4:43

VIA HAND DELIVERY

PUCO

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

**Re: Case No. 08-1233-WS-UNC
Ohio American Water Company
Stipulation Page No. 11, ¶14D**

Dear Ms. Jenkins:

Pursuant to the Commission's November 12, 2008 Opinion and Order in Case No. 07-1112-WS-AIR, and to the Stipulation and Recommendation page 11, paragraph 14D, Ohio American Water Company submits for filing the Lake Darby Hardness Monthly Report for March 2009.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician ANN Date Processed 4/7/09

**Ohio-American Water Company
Franklin County District
Lake Darby Water Hardness Report**

Reporting Month & Year March-09

1	2	3	4	5	6	7	8	9	10	11
Date	Day	On-Line Measurement (mg/L) Every 2 hrs when LDWTP is ON	On-Line Unit Operational (Y or N)	LDWTP Process Control Measurement (mg/L) Daily	OAWC WQ Lab Measurement (mg/L) Daily	LDWTP Outside Lab Measurement (mg/L) 1/Month	LDWTP Outside Lab Collection Time Sampler	Distribution Outside Lab Measurement (mg/L) 1/Month	Distribution System Outside Lab Collection Time Sampler	WQ Water Distribution Measurement (mg/L) 2/week
1	Sun	112	Y	114	104					
2	Mon	102	Y	116	112	107	7:10 AM, Jeff Ward	97	9:02 AM, Jeff Ward	119
3	Tue	82	Y	108	106					
4	Wed	120	Y	110	108					114
5	Thu	117	Y	108	110					
6	Fri	117	Y	122	120					
7	Sat	111	Y	117	112					
8	Sun	111	Y	115	108					
9	Mon	103	Y	110	110					118
10	Tue	111	Y	118	118					
11	Wed	111	Y	123	126					116
12	Thu	108	Y	118	104					
13	Fri	114	Y	106	94					
14	Sat	113	Y	104	98					
15	Sun	119	Y	106	96					
16	Mon	116	Y	120	112					114
17	Tue	107	Y	108	106					
18	Wed	113	Y	110	98					110
19	Thu	120	Y	104	104					
20	Fri	108	Y	108	104					
21	Sat	115	Y	110	100					
22	Sun	111	Y	108	100					
23	Mon	113	Y	128	122					110
24	Tue	117	Y	104	110					
25	Wed	108	Y	105	96					110
26	Thu	116	Y	110	104					
27	Fri	114	Y	108	104					
28	Sat	122	Y	112	110					
29	Sun	121	Y	110	110					
30	Mon	120	Y	112	106					120
31	Tue	125	Y	113	106					
Average		113		112	107					115
Max		125		128	126					120
Min		82		104	94					110
% >150 mg/L		0.0		0.0	0.0					0.0

- NOTES: 1) Operator shall make a notation in the Instrumentation Log Book on a DAILY basis on the status of the On-Line Hardness Analyzer.
2) Week is Sunday to Saturday
3) WQ Lab is responsible for delivering monthly sample to outside lab.
4) For any test with a hardness <95 mg/L or >145 mg/L notify the Network Operations Superintendent and the Operations Supervisor immediately.