

FILE



Bricker & Eckler
ATTORNEYS AT LAW
COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

April 10, 2009

VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

**Re: Ohio American Water Company
Case No. 08-1233-WS-UNC**

PUCO

2009 APR 10 PM 4:01

RECEIVED-DOCKETING DIV

Dear Ms. Jenkins:

Ohio American Water Company submits for filing the March 2009 Hardness Report for the Marion district.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician 10/21 Date Processed 4/10/09

EFFLUENT HARDNESS / MG/L

March	RAW HARDNESS MG/L	EFFLUENT HARDNESS MG/L
1	470	148
2	445	145
3	440	143
4	410	147
5	390	141
6	370	135
7	340	140
8	345	149
9	481	151
10	500	137
11	460	144
12	457	146
13	410	144
14	336	146
15	348	150
16	351	152
17	380	150
18	367	148
19	367	139
20	370	139
21	385	143
22	384	143
23	377	138
24	380	142
25	380	140
26	385	144
27	390	140
28	390	138
29	436	144
30	375	135
31	365	142

AVERAGE	396	143
MAX	500	152
MIN	336	136

March 2009
EFFLUENT HARDNESS AVG - 143 MG/L
MARION DISTRICT

