

FILE

11



Bricker & Eckler
ATTORNEYS AT LAW
COLUMBUS • CLEVELAND

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

April 16, 2009

VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

**Re: Case No. 08-1233-WS-UNC
Ohio American Water Company
Stipulation Page No. 9, ¶13 E 4**

RECEIVED-DOCKETING DIV
2009 APR 16 PM 3:43
PUCO

Dear Ms. Jenkins:

Pursuant to the Commission's November 12, 2008 Opinion and Order in Case No. 07-1112-WS-AIR, Ohio American Water Company submits for filing its compliance with the Stipulation and Recommendation, page 9 paragraph 13 E 4 pertaining to the submission of leak logs for the first quarter of 2009.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

**Ohio American Water Company
Franklin County District
2009 Water Leak Log**

Updated: 4/16/2009

	Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Customers Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comments
1	4979 Ewald	BL	Madison	CSL	3/4"	N	1	N/A	N/A	7/11/08	7/14/08	3	3X5	Soil	Pending	Company service leak repaired--Restoration pending
2	5590 Newport Court	BL	Madison	CSL	3/4"	N	1	N/A	N/A	7/10/08	7/14/08	4	3X5	Soil	Pending	Company curb valve replaced--Restoration pending
3	4564 Brewster	BL	Madison	CSL	3/4"	N	1	N/A	N/A	7/14/08	7/21/08	7	6X10	Pavement	Pending	Company service leak repaired--Pavement restored, soil restoration pending
4	3511 Rodell	BL	Madison	CSL	3/4"	N	1	N/A	N/A	7/17/08	7/22/08	5	3X5	Soil	Pending	Company curb valve replaced--Restoration pending
5	4888 Ewald	BL	Madison	CSL	3/4"	N	1	N/A	N/A	8/12/08	8/12/08	7	3X5	Soil	Pending	Company service leak repaired--Restoration pending
6	5452 Newport	BL	Madison	CWM	12"	Y	39	Door to Door	8/12/08	8/10/08	8/11/08	1	5X5	Pavement	Pending	Company water main repaired--Pavement restored, soil restoration pending
7	3434 & 3438 Beschworth	BL	Madison	CSL	3/4"	N	1	N/A	N/A	8/13/08	8/14/08	1	6X10	Pavement	Pending	Company service leak repaired--Restoration pending
8	3849 Everston	BL	Madison	CSL	3/4"	N	1	N/A	N/A	8/27/08	8/29/08	2	3X5	Soil	Pending	Company service leak repaired--Restoration pending
9	5043 Fullerton	BL	Madison	CSL	3/4"	N	1	N/A	N/A	9/10/08	9/24/08	14	3X5	Soil	Pending	Company service leak repaired--Restoration pending
10	2560 Rodell	BL	Madison	CSL	3/4"	N	1	N/A	N/A	9/12/08	9/24/08	12	3X5	Soil	Pending	Company service leak repaired--Restoration pending
11	3283 Dunloe	BL	Madison	CSL	3/4"	N	1	N/A	N/A	9/19/08	9/24/08	5	3X5	Soil	Pending	Company service leak repaired--Restoration pending
12	3019 Fleet	BL	Madison	CSL	3/4"	N	1	N/A	N/A	10/1/08	10/21/08	20	3X5	Soil	Pending	Company service leak repaired--Restoration pending
13	3683 Laguna Drive	BL	Madison	CSL	3/4"	N	1	N/A	N/A	10/14/08	10/21/08	7	3X5	Soil	Pending	Company service leak repaired--Restoration pending
14	3338 Latonia Court	BL	Madison	CSL	3/4"	N	1	N/A	N/A	10/20/08	10/28/08	8	3X5	Soil	Pending	Company service leak repaired--Restoration pending
15	4550 Harbor	BL	Madison	CSL	3/4"	N	1	N/A	N/A	10/24/08	11/6/08	13	3X5	Soil	Pending	Company service leak repaired--Restoration pending
16	3408 Arnsby	BL	Madison	CSL	3/4"	N	1	N/A	N/A	11/4/08	11/30/08	26	3X5	Soil	Pending	Company service leak repaired--Restoration pending
17	3431 Tremaine	BL	Madison	CSL	3/4"	N	1	N/A	N/A	11/14/08	11/30/08	16	3X5	Soil	Pending	Company service leak repaired--Restoration pending
18	Sedalia Middle School	BL	Madison	PSL	PSL	N	1	N/A	N/A	1/18/09	1/19/09	1	PSL	PSL	PSL	School fire suppression system pipe froze and burst.
19	3020 Fleet	BL	Madison	PSL	PSL	N	1	N/A	N/A	2/16/09	2/17/09	1	PSL	PSL	PSL	Private Leak--repaired
20	3825 Clearwater	BL	Madison	PSL	PSL	N	1	N/A	N/A	3/3/09	3/5/09	2	PSL	PSL	PSL	Private Leak--repaired
21	3222 Latonia	BL	Madison	CSL	3/4"	N	1	N/A	N/A	3/9/09	3/18/09	9	3X5	Soil	Pending	Company service line leak repaired--Restoration pending
22	3219 Fyrcrest	BL	Madison	CSL	3/4"	N	1	N/A	N/A	3/18/09	3/19/09	1	3X5	Soil	Pending	Company curb valve replaced--Restoration pending
23	5185 Benham	BL	Madison	CSL	3/4"	N	1	N/A	N/A	3/20/09	3/20/09	1	3X5	Soil	Pending	Company service line hit by contractor repaired--Restoration pending
24	3527 Telford	BL	Madison	CWM	2"	Y	39	Door to Door	3/22/09	3/21/09	3/21/09	1	5X5	Pavement	Pending	Company water main repaired--Restoration pending
25	3442 Fontaine	BL	Madison	CSL	3/4"	N	1	N/A	N/A	3/25/09	4/6/09	12	5x5	Soil	Pending	Company service leak repaired--Restoration pending
26	3370 Arnsby Ct	HR	Blandon	CWM	6"	N	N/A	N/A	N/A	10/7/2008	10/7/2008	1	6X6	Pavement	Pending	Pavement restored 3/2/09; soil pending
27	3560 Dempsey	HR	Blandon	CWM	8"	Y	4	Door Hangers	11/14/2008	11/13/2008	11/13/2008	1	6X6	Pavmt	Pending	Pavement restored 3/2/09; soil pending
28	5424 Lapaq Ct	HR	Blandon	CWM	2"	Y	5	Door Hangers	11/21/2008	11/19/2008	11/19/2008	2	6X6	Soil	Pending	
29	3730 Dempsey	HR	Blandon	VIV	6"	Y	N/A	N/A	N/A	1/7/2008	12/3/2008	2	6X6	Soil	Pending	
30	3500 Camberts Ct	HR	Blandon	VIV	2"	Y	18	Door Hangers	12/18/2008	12/17/2008	12/17/2008	3	6X6	Soil	Pending	
31	5725 Vienna	HR	Blandon	VIV	2"	N	N/A	N/A	N/A	12/28/2008	12/29/2008	8	6X6	Pavement	Pending	Asphalt
32	6093 Sumbury Rd	HR	Blandon	CWM	8"	N	N/A	N/A	N/A	1/1/2009	1/5/2009	5	6X6	Soil	Pending	
33	4331 Valley Quail S	HR	Blandon	PSL	3/4"	N	N/A	N/A	N/A	1/20/2009	1/27/2009	8	N/A	N/A	N/A	Depressurization/soil advisory caused by CWIR leak below. The repair date given is the date area was isolated from leaking main and repressurized.
34	4110 Carnation Dr	HR	Blandon	CWM	8"	Y	577	Media Door	1/22/2009	1/20/2009	1/21/2009	1	N/A	N/A	N/A	
35	4120 Carnation Dr	HR	Blandon	CWM	8"	Y	1	Hangers/Person al Notices	1/24/2009	1/20/2009	1/23/2009	4	12X12	Soil	Pending	Main turned off on 1/23/09, not repaired and repressurized until 1/23/09
36	4432 Scissorsbill Loop	HR	Blandon	PSL	3/4"	N	N/A	N/A	N/A	1/24/2009	2/4/2009	12	N/A	N/A	N/A	

Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Customers Affected	Method of Notification	Date Bill Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comments
37 3377 Arnett Ct	HR	Blandon	PSL	3/4"	N	N/A	N/A	N/A	2/28/2009	2/11/2009	4	N/A	N/A	N/A	Company water main repaired--Pavement restored, soil restoration pending
38 4238 Rosebay Ct	HR	Blandon	PSL	3/4"	N	N/A	N/A	N/A	3/27/2009	Pending	4	N/A	N/A	N/A	Company water main repaired--Pavement restored, soil restoration pending
39 8897 Canoe	LD	Prairie	CWM	6"	N	0	N/A	N/A	7/21/08	7/23/08	2	5X5	Pavement	Pending	Company water main repaired--Pavement restored, soil restoration pending
40 8628 Edgewater	LD	Prairie	CSL	3/4"	Y	35	Door to Door	12/5/08	12/9/08	12/14/08	1	5X10	Soil	Pending	Company service leak--Repaired, leak at tapping saddle, found old threads into AC main, removed and threaded new corp into main--Restoration pending
41 697 Prairie	LD	Prairie	CSL	3/4"	N	1	N/A	N/A	3/11/09	4/1/09	21	8X8	Pavement	Pending	Company service line leak repaired--Restoration pending
42 785 Lakesfield	LD	Prairie	CWM	6"	Y	54	Door to Door	4/3/09	4/2/09	4/2/09	1	3X5	Soil	Pending	Company water main repaired--Restoration pending
43 1667 Valley Crest	TB	Nonwich	CSL	6"	Y	11	Door to Door	10/6/08	10/4/08	10/5/08	1	5X5	Soil	Pending	Company water main repaired--Restoration pending
44 1761 Shadybrook	TB	Nonwich	CWM	2"	N	0	N/A	N/A	12/23/08	12/23/08	0	None	None	N/A	Blow off valve leaking by, leak isolated at shut off valve on 12/23/08. Tested blow off in 3/10/09, found not leaking.
45 1356 Hickory Ridge	WH	Perry	CWM	6"	N	N/A	N/A	N/A	9/30/2008	10/17/2008	2	3X8	Pavement	Pending	Small blacktop patch needed
46 1584 Newcomer	WH	Perry	CSL	3/4"	N	N/A	N/A	N/A	10/17/2008	10/29/2008	28	3X6	Soil	Pending	
47 888 Mission Hills	WH	Sharon	CWM	6"	N	N/A	N/A	N/A	10/8/2008	10/8/2008	1	3X6	Soil	Pending	
48 3440 Clubview N	WH	Perry	CWM	6"	N	N/A	N/A	N/A	10/28/2008	10/28/2008	1	6X6	Pavement	Pending	Pavement restored 3/2/09, soil pending
49 816 Colony Ct	WH	Sharon	CWM	6"	N	N/A	N/A	N/A	11/12/2008	11/12/2008	1	6X6	Soil	Pending	
50 909 Clubview N	WH	Sharon	CWM	6"	N	N/A	N/A	N/A	11/15/2008	11/17/2008	3	6X6	Soil	Pending	
51 1194 Circle on Green	WH	Perry	CWM	6"	N	N/A	N/A	N/A	12/1/2008	12/1/2008	2	6X6	Pavement	Pending	Pavement restored 3/2/09, soil pending
52 3200 Copperfield	WH	Perry	CWM	6"	N	N/A	N/A	N/A	12/8/2008	12/8/2008	1	6X6	Soil	Pending	
53 1117 Circle on the Green	WH	Perry	CWM	6"	N	N/A	N/A	N/A	1/5/2009	1/5/2009	1	6X6	Soil	Pending	
54 800 Mission Hills Ln	WH	Sharon	CWM	6"	Y	22	Door Hangers	1/16/2009	1/14/2009	1/14/2009	1	6X6	Soil	Pending	
55 1655 Dellhor Dr	WH	Perry	PSL	3/4"	N	N/A	N/A	N/A	2/13/2009	2/23/2009	10	N/A	N/A	N/A	

Codes
 CSL Company Service Leak
 CWM Company Water Main
 CWMB Company Water Main Break
 HYD Hydrant
 VLV Valve
 CO Company Other
 PSL Private Service Leak
 PWB Private Water Main
 PO Private Other

**Ohio American Water Company
Marion District
2009 Water Leak Log**

Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
1:407 Forest St	Marion	Marion	CSL	3/4"	N	1	NA	NA	11/11/2008	3/16/2009	125	6 x 6	Dirt	Incomplete	Repaired Very Small Leak Other work look precedent
2 845 Chamberd	Marion	Marion	PSL	P	N	1	NA	NA	11/12/2008	1/21/2009	70	NA	NA	NA	WLPF leak, no phone #, no claim. Called 12/1 again.
3 388 Park St	Marion	Marion	PSL	P	N	1	NA	NA	12/15/2008	1/5/2009	21	NA	NA	NA	Rescheduled by field.
4 688 Darius	Marion	Marion	PSL	P	N	1	NA	NA	12/15/2008	1/6/2009	26	NA	NA	NA	WLPF delayed. Will be replacing line 01/05/09
5 1410 Woodridge	Marion	Marion	PSL	P	N	1	NA	NA	12/17/2008	1/12/2009	26	NA	NA	NA	Very Small leak. Contractor request more time due to difficulty of location
6 217 S Grand	Marion	Marion	PSL	P	N	1	NA	NA	12/23/2008	1/5/2009	13	NA	NA	NA	Rescheduled by field.
7 281 Forest	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	12/23/2008	1/22/2009	17	6 x 11	Pavement	Incomplete	Very Small leak. Other work look precedent.
8 Brenner East of S Main	Marion	Marion	CWM	2	N	0	NA	NA	1/22/2009	1/22/2009	4	9 x 30	Pavement	Incomplete	Repaired
9 170 Cheston	Marion	Marion	PSL	P	N	1	NA	NA	1/25/2009	1/25/2009	0	NA	NA	NA	Repaired
10 251 Fairview	Marion	Marion	CWM	2	Y	20	DR	1/8/2009	1/7/2009	1/7/2009	0	5 x 14	Pavement	Incomplete	Repaired
11 Francois	Marion	Marion	Flush	F	N	0	NA	NA	1/7/2009	1/7/2009	0	NA	NA	NA	Flushed
12 Eagle Way & Crisinger	Marion	Pleasant	Flush	F	N	0	NA	NA	1/8/2009	1/8/2009	0	NA	NA	NA	Flushed
15 364 Chapter	Marion	Marion	PSL	P	N	1	NA	NA	1/8/2009	1/8/2009	0	NA	NA	NA	Shut off
14 775 York	Marion	Marion	PSL	P	N	1	NA	NA	1/9/2009	1/11/2009	2	NA	NA	NA	Shut off
15 1880 Grandview Dr	Marion	Grand Prairie	PSL	P	N	1	NA	NA	1/12/2009	1/12/2009	20	NA	NA	NA	Repaired
16 Francois	Marion	Marion	Flush	F	N	0	NA	NA	1/13/2009	1/13/2009	0	NA	NA	NA	Flushed
17 285 Belmont	Marion	Marion	PSL	P	N	1	NA	NA	1/13/2009	2/5/2009	23	NA	NA	NA	Repaired
18 Rouay Towers	Marion	Marion	PSL	P	N	1	NA	NA	1/15/2009	1/15/2009	0	NA	NA	NA	Shut off
19 York & Socolo	Marion	Marion	CWM	2	Y	20	DR	1/19/2009	1/18/2009	1/18/2009	0	12 x 14	Pavement	Incomplete	Repaired
20 Scoto & Center	Marion	Marion	CWM	2	Y	12	DR	1/19/2009	1/18/2009	1/18/2009	0	10 x 15	Pavement	Incomplete	Repaired
21 300 Pils	Marion	Marion	CWM	2	N	0	NA	NA	1/18/2009	1/18/2009	0	9 x 11	Pavement	Incomplete	Repaired
22 802 E Center	Marion	Marion	CWM	8	N	0	NA	NA	1/18/2009	1/18/2009	1	9 x 11	Pavement	Incomplete	Repaired
23 3268 Harding Hwy E	Caledonia	Marion	PSL	P	N	1	NA	NA	1/20/2009	1/20/2009	0	NA	NA	NA	Shut off
24 833 E George	Marion	Marion	PSL	P	N	1	NA	NA	1/21/2009	1/21/2009	0	NA	NA	NA	Shut off
25 581 Jefferson	Marion	Marion	CSL	3/4"	Y	1	NA	NA	1/22/2009	3/17/2009	54	10 x 22	Pavement	Incomplete	Repaired Very Small Leak Other work look precedent
26 Caracas Dr	Marion	Marion	CWM	10	Y	2	DR	1/23/2009	1/23/2009	1/23/2009	0	30 x 30	Dirt	Incomplete	Repaired
27 631 S Prospect St	Marion	Marion	CWM	6	N	0	NA	NA	1/23/2009	1/24/2009	1	7 x 12	Pavement	Incomplete	Repaired
28 Cascade Dr	Marion	Marion	Flush	F	N	0	NA	NA	1/23/2009	1/23/2009	0	NA	NA	NA	Flushed
29 Indiana & Kenmore	Marion	Marion	CWM	8	Y	10	DR	1/25/2009	1/25/2009	1/25/2009	0	6 x 8	Pavement	Incomplete	Repaired
30 Indiana & Kenmore	Marion	Marion	Flush	F	N	0	NA	NA	1/25/2009	1/25/2009	0	NA	NA	NA	Flushed
31 Phantasia & Keener	Marion	Marion	CWM	6	Y	10	DR	1/26/2009	1/26/2009	1/26/2009	0	13 x 20	Pavement	Incomplete	Repaired
32 Phantasia & Keener	Marion	Marion	Flush	F	N	0	NA	NA	1/26/2009	1/26/2009	0	NA	NA	NA	Flushed
33 Walnut & Iley	Marion	Marion	CWM	6	N	0	NA	NA	1/26/2009	1/26/2009	3	13 x 19	Pavement	Incomplete	Repaired
34 380 Leader	Marion	Marion	CWM	2	N	0	NA	NA	1/26/2009	2/4/2009	9	7 x 13	Pavement	Incomplete	Repaired
35 Main & Walnut, Prospect	Prospect	Elgin	CWM	12	Y	80	DR	1/28/2009	1/27/2009	1/27/2009	0	22 x 23	Pavement	Incomplete	Repaired
36 Main & Walnut, Prospect	Prospect	Elgin	Flush	F	N	0	NA	NA	1/27/2009	1/27/2009	0	NA	NA	NA	Flushed
37 191 Frederick	Marion	Marion	PSL	P	N	1	NA	NA	1/27/2009	2/9/2009	13	NA	NA	NA	Repaired
38 1478 Likens Rd	Marion	Marion	CWM	10	N	0	NA	NA	1/28/2009	1/28/2009	0	6 x 15	Pavement	Incomplete	Repaired
39 1478 Likens Rd	Marion	Marion	Flush	F	N	0	NA	NA	1/28/2009	1/28/2009	0	NA	NA	NA	Flushed
40 15 Main	Marion	Marion	CSL	3/4"	N	0	NA	NA	1/30/2009	1/30/2009	0	NA	NA	NA	Repaired - Contractor Responsible for Paving
41 610 Herman	Marion	Marion	CWM	2	Y	6	DR	1/31/2009	1/30/2009	1/30/2009	0	6 x 19	Dirt	Incomplete	Repaired
42 502 N Greenwood	Marion	Marion	PSL	P	N	1	NA	NA	1/31/2009	1/31/2009	0	NA	NA	NA	Shut Off
43 Francois	Marion	Marion	PSL	P	N	0	NA	NA	2/2/2009	2/2/2009	0	NA	NA	NA	Flushed
44 704 Henry St	Marion	Marion	CWM	6	N	0	NA	NA	2/2/2009	2/2/2009	0	10 x 14	Pavement	Incomplete	Repaired
45 350 Commercial	Marion	Marion	CWM	2	N	0	NA	NA	2/3/2009	2/3/2009	0	7 x 11	Dirt	Incomplete	Repaired
46 230 Jefferson	Marion	Marion	CSL	3/4"	N	1 HH	NA	NA	2/4/2009	2/4/2009	0	8 x 8	Dirt	Incomplete	Repaired
47 Gooding & Pickvertoft	Marion	Pleasant	CWM	12	Y	500	Press Release, Reverse 911	2/8/2009	2/4/2009	2/4/2009	0	9 x 18	Dirt	Incomplete	Repaired
48 Gooding & Pickvertoft	Marion	Pleasant	Flush	F	N	0	NA	NA	2/4/2009	2/4/2009	0	NA	NA	NA	Flushed
49 117 Harcourt	Marion	Marion	CWM	2	N	0	NA	NA	3/12/2009	3/12/2009	37	8 x 10	Pavement	Incomplete	Flushing
50 305 N State	Marion	Marion	CWM	2	N	0	NA	NA	2/6/2009	2/6/2009	0	NA	NA	NA	Repaired
51 Gay & Toledo	Marion	Marion	CWM	2	N	0	NA	NA	2/6/2009	2/10/2009	17	12 x 14	Pavement	Incomplete	Repaired
52 1282 Slatwood	Marion	Marion	PSL	P	N	1	NA	NA	2/8/2009	2/8/2009	0	NA	NA	NA	Repaired
53 Plymouth	Marion	Marion	CWM	2	N	0	NA	NA	2/10/2009	2/10/2009	0	4 x 14	Pavement	Incomplete	Repaired
54 Alley betw Grand & Seffner	Marion	Marion	CWM	4	N	0	NA	NA	2/10/2009	2/10/2009	0	7 x 12	Dirt	Incomplete	Repaired
55 Church & High Caledonia	Caledonia	Caledonia	CWM	4	N	0	NA	NA	2/12/2009	2/12/2009	0	10 x 14	Pavement	Incomplete	Repaired
56 485 Patterson	Marion	Marion	PSL	P	N	1	NA	NA	2/12/2009	2/12/2009	5	NA	NA	NA	Water turned off for repairs, same day.
57 783 Cheney	Marion	Marion	PSL	P	N	1	NA	NA	2/12/2009	2/12/2009	0	NA	NA	NA	Water turned off for repairs, same day.
58 198 E George	Marion	Marion	PSL	P	N	1	NA	NA	2/12/2009	2/12/2009	67	NA	NA	NA	WLPF plumber can't find leak. Gave more time
59 Center & Dix	Marion	Marion	CWM	8	N	0	NA	NA	2/17/2009	2/17/2009	0	NA	NA	NA	Repaired
60 500 Blains	Marion	Marion	PSL	P	N	1	NA	NA	2/18/2009	2/18/2009	0	NA	NA	NA	Repaired
61 478 Reed	Marion	Marion	Flush	F	N	0	NA	NA	2/20/2009	2/20/2009	0	NA	NA	NA	Flushed

CSL = Company Service Leak; CVM = Company Water Main; HYD = Hydrant; VLV = Valve; CD = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other DR= Door Tag; DTD = Door to Door	Location	Service Area	Township	Leak Type	Leak Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
	62 510 Pennsylvania	Marion	Marion	CSL	2"	N	1	NA	NA	2/20/2009	3/24/2009	32	4 x 14	Pavement	incomplete	Repaired Other work look precedent
	63 Fairview & Main	Marion	Marion	CVM	2"	N	0	NA	NA	2/22/2009	2/24/2009	2	4 x 6	DR	incomplete	Repaired
	64 1311 Mt Vernon	Marion	Marion	PSL	P	N	1	NA	NA	2/23/2009	2/24/2009	1	NA	NA	NA	Repaired
	65 467 Park	Marion	Marion	PSL	P	N	1	NA	NA	2/24/2009	3/5/2009	9	NA	NA	NA	Repaired
	66 260 Bellevue	Marion	Marion	PSL	P	N	1	NA	NA	2/24/2009	2/24/2009	0	NA	NA	NA	Water turned off for repairs, same day.
	67 467 Park	Marion	Marion	PSL	P	N	1	NA	NA	2/24/2009	3/4/2009	8	NA	NA	NA	Repaired
	68 252 Bennett	Marion	Marion	CSL	3/4"	N	1	NA	NA	2/24/2009	3/29/2009	24	9 x 10	Pavement	incomplete	Repaired Other work look precedent
	69 222 Merchant	Marion	Marion	PSL	P	N	1	NA	NA	2/25/2009	2/25/2009	0	NA	NA	NA	Water turned off for repairs, same day.

Ohio American Water Company

Portage County District

2009 Water Leak Log

Location	Service Area	Township	Leak Type	Size	Boil Order (Y/N)	Number of Services Affected	Method of Notification	Date Soil Origin Lit	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
3472 Janssen	Beechcrest	Birmingham	CWM	6" AC	N	0	N/A	N/A	N/A	3/19/2009	0	10'x10'	Grass/Soil		
10311 Ventworth	Aurora East	Shilohville	CSL	8" AC	Y	58	FRCC	3/26/2008	3/26/2008	3/26/2009	0	10'x10'	Ditch line dirt		
10333 Ventworth	Aurora East	Shilohville	CWM	8" AC	Y	58	FRCC	4/12/09	3/27/2008	3/27/2009	0	10'x10'	Ditch line dirt		
2763 Cleburn	Aurora East	Shilohville	CSL	8" AC	Y	58	FRCC	4/12/09	3/27/2008	3/27/2009	0	10'x10'	Ditch line dirt		

CSL = Company Service Leak; CWM = Company Water Main; HTD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PVM = Private Water Main; PO = Private Other DR- Door Tag; DTD = Door to Door

Location Location of leak; may include street address of nearest residence or distance from intersecting street
Service Area Township If Network service area is segmented, this information should be included Township in which leak occurred
Leak Type Size List is found at top of sheet; each leak will be either Company or Private; This pertains to mains, valves and services
Service Affecting Report Date Y or N answer; Service affecting leaks are determined to be those leaks that leave customers with little or no pressure
Repair Date The date the Company became aware of the leak
Elapsed Days The date the leak was repaired
Boil Order The number of days from the report date to repair date; under normal conditions, this should be between 0 to 1 days for service affecting leaks and 0 to 7 days for non-service affecting leaks
Comments Was a boil order issued to customers
Method of Notification Any additional useful information; should include an explanation of any repair outside the regulated number of elapsed days

CSL Company Service Line
CWM Company Water Main
HYD Hydrant
VLV Valve
CO Company Other
PSL Private Service Line
PWM Private Water Main
PO Private Other

Yes
No