

FILE



Bricker & Eckler
ATTORNEYS AT LAW

COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2398
sbloomfield@bricker.com

RECEIVED-DOCKETING DIV

May 27, 2009

2009 MAY 27 PM 4:26

PUCO

VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

Re: Case No. 08-1233-WS-UNC
Ohio American Water Company
Stipulation Page No. 11, ¶14D

Dear Ms. Jenkins:

Pursuant to the Commission's November 12, 2008 Opinion and Order in Case No. 07-1112-WS-AIR, and to the Stipulation and Recommendation page 11, paragraph 14D, Ohio American Water Company submits for filing the Lake Darby Hardness Monthly Report for April 2009.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business
Technician AC Date Processed 5/27/09

**Ohio-American Water Company
Franklin County District
Lake Darby Water Hardness Report**

Reporting Month & Year April-09

1	2	3	4	5	6	7	8	9	10	11
Date	Day	On-Line Measurement (mg/L) Every 2 hrs when LDWTP is ON	On-Line Unit Operational (Y or N)	LDWTP Process Control Measurement (mg/L) Daily	OAWC WQ Lab Measurement (mg/L) Daily	LDWTP Outside Lab Measurement (mg/L) 1/Month	LDWTP Outside Lab Collection Time Sampler	Distribution Outside Lab Measurement (mg/L) 1/Month	Distribution System Outside Lab Collection Time Sampler	WQ Water Distribution Measurement (mg/L) 2/week
1	Wed	123	Y	117	102					118
2	Thu	126	Y	108	100					
3	Fri	109	Y	104	98					
4	Sat	113	Y	103	241					
5	Sun	107	Y	108	118					
6	Mon	132	Y	106	102	102	7:27 AM, Jeff Ward	108	8:32 AM, Jeff Ward	108
7	Tue	103	Y	108	100					
8	Wed	103	Y	104	100					114
9	Thu	108	Y	104	100					
10	Fri	106	Y	103	104					
11	Sat	106	Y	100	98					
12	Sun	110	Y	103	94					
13	Mon	111	Y	124	120					104
14	Tue	113	Y	107	102					
15	Wed	116	Y	112	102					112
16	Thu	112	Y	130	120					
17	Fri	102	Y	117	106					
18	Sat	105	Y	110	110					
19	Sun	110	Y	106	100					
20	Mon	105	Y	104	104					118
21	Tue	107	Y	118	114					
22	Wed	104	Y	110	106					110
23	Thu	110	Y	104	102					
24	Fri	108	Y	114	100					
25	Sat	112	Y	108	104					
26	Sun	113	Y	106	100					
27	Mon	108	Y	104	106					102
28	Tue	106	Y	102	96					
29	Wed	108	Y	110	104					102
30	Thu	100	Y	112	106					
Average		110		109	109					110
Max		132		130	241					118
Min		100		100	94					102
% >150 mg/L		0.0		0.0	3.2					0.0

- NOTES: 1) Operator shall make a notation in the Instrumentation Log Book on a DAILY basis on the status of the On-Line Hardness Analyzer.
2) Week is Sunday to Saturday
3) WQ Lab is responsible for delivering monthly sample to outside lab.
4) For any test with a hardness <95 mg/L or >145 mg/L notify the Network Operations Superintendent and the Operations Supervisor immediately.