



Bricker & Eckler
ATTORNEYS AT LAW

COLUMBUS • CLEVELAND

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

July 17, 2009

RECEIVED-DOCKETING DIV

2009 JUL 17 PM 1:43

VIA HAND DELIVERY

PUCO

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

Re: Case No. 08-1233-WS-UNC
Ohio American Water Company
Stipulation Page No. 9, ¶13 E 4

Dear Ms. Jenkins:

Pursuant to the Commission's November 12, 2008 Opinion and Order in Case No. 07-1112-WS-AIR, Ohio American Water Company submits for filing its compliance with the Stipulation and Recommendation, page 9 paragraph 13 E 4 pertaining to the submission of leak logs for the second quarter of 2009.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.

Technician SM Date Processed JUL 17 2009

Ohio American Water Company
Ashtabula District
2008 Water Leak Log

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other; DR = Door Tag DTD = Door to Door																
	Location	Service Area	Township	Leak Type	Size	Soil Order (Y or N)	Number of Services Affected	Method of Notification	Date Bill Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
1	533 AUDREY PL	CENTRAL		CWM	2.5"	N	0			1/2/2009	1/2/2009	0	4 X 6	STREET	5/09	
2	6917 WEST AVE.	CENTRAL		CWM	6"	Y	0	DTD	1/15/2009	1/12/2009	1/12/2009	0	8 X 10	TREELAWN/DRIVEWAY	4/09	
3	1708 E. PROSPECT (RT. 20)	EAST SIDE		CWM	6"	N	0			1/14/2009	1/14/2009	0	10 X 8	STREET	TBD	
4	5853 SHEPARD	SAYBROOK		CWM	2.5"	Y	0	DTD	1/20/2009	1/16/2009	1/16/2009	0	5 X 8	STREET	5/09	
5	3115 W. 13TH ST.	HARBOR		CWM	6"	N	0			1/17/2009	1/17/2009	0	6 X 8	STREET/TREELAWN	4/08	
6	2854 W. PROSPECT	WEST SIDE		CWM	2"	N	0			1/20/2009	1/21/2009	1	8 X 4	STREET	5/09	
7	2213 W. 16th ST.	HARBOR		CWM	6"	N	12			1/21/2009	1/22/2009	1	8 X 10	TREELAWN	4/09	
8	2651 WALNUT BLVD.	HARBOR		CWM	6"	N	0			1/20/2009	1/20/2009	0	8 X 5	TREELAWN	4/09	
9	1111 W. 17th ST.	HARBOR		CWM	6"	N	0			1/26/2009	1/26/2009	1	3 X 8	TREELAWN	4/09	
10	3823 HOMEWOOD	SAYBROOK		PSL	8"	Y	1	DTD	2/5/2009	2/3/2009	2/3/2009	0	4 X 6	TREELAWN	4/02/08	
11	W. 48th ST. & ELM ST.	CENTRAL		HYD	8"	Y	0			2/6/2009	2/6/2009	0	5 X 10	STREET	4/09	
12	5386 SAVANNAH	SAYBROOK		HYD	8"	Y	13	DTD	2/10/2009	2/6/2009	2/6/2009	0	15 X 20	TREELAWN	4/18/09	
13	4524 ELM ST.	CENTRAL		PSL	2"	N	1			2/6/2009	2/6/2009	4	4 X 6	STREET	5/09	
14	4713 STRONG AVE	CENTRAL		CWM	6"	N	0			2/6/2009	2/6/2009	0	6 X 8	STREET	6/09	
15	412 W. 41th ST.	CENTRAL		CWM	6"	N	0			2/6/2009	2/16/2009	1	4 X 7	STREET	6/09	
16	8623 ANGELA	SAYBROOK		CWM	2"	N	0			2/6/2009	2/11/2009	2	8 X 12	TREELAWN	4/02/09	
17	5843 SHEPARD	HARBOR		CWM	6"	N	0			2/11/2009	2/11/2009	0	6 X 6	TREELAWN/DRIVEWAY	4/18/09	
18	419 COLUMBUS AVE.	HARBOR		CWM	2"	N	0			2/12/2009	2/12/2009	0	4 X 6	STREET	TBD	
19	1227-1314 TIVISON PL	HARBOR		CWM	2.5"	N	0			2/12/2009	2/12/2009	0	4 X 12	STREET	5/09	
20	3310 WILSON AVE.	EAST SIDE		CWM	3/4"	N	1			2/16/2009	2/16/2009	2	8 X 8	TREELAWN	4/08	
21	MYRTLE AVE. & W. 8th ST.	HARBOR		CWM	6"	N	0			2/16/2009	2/18/2009	0	8 X 6	STREET	TBD	
22	3414 FORESTAL	CENTRAL		CWM	2.5"	Y	1	DTD	2/20/2009	2/18/2009	2/18/2009	0	5 X 10	STREET	TBD	
23	1136 E. 17th ST.	HARBOR		CWM	6"	N	0			2/18/2009	2/18/2009	0	5 X 10	STREET	TBD	
24	4811 DUNSMORE	CENTRAL		CWM	2.5"	N	0			2/20/2009	2/23/2009	3	6 X 4	STREET	TBD	
25	781 E. 14th ST.	HARBOR		CWM	6"	N	0			2/25/2009	2/25/2009	0	8 X 5	STREET	TBD	
26	2847 HIGHLAND	HARBOR		CWM	2"	N	0			2/25/2009	2/27/2009	1	5 X 7	STREET	TBD	
27	529 ALDREY	CENTRAL		CWM	2.5"	N	0			2/27/2009	3/9/2009	4	4 X 8	STREET	TBD	
28	2314 HARBOR AVE	HARBOR		CWM	2"	N	16			3/2/2009	3/9/2009	3	5 X 8	TREELAWN	4/09	
29	2628 WALNUT BLVD.	HARBOR		CBL	3/4"	N	1			3/9/2009	3/9/2009	0	4 X 8	TREELAWN	5/09	
30	1501 E. 30th ST.	ASH		VLV	6"	N	0			3/13/2009	3/23/2009	10	4 X 8	STREET	TBD	
31	4005 SHI MAR	HARBOR	NK	CBL	3/4"	N	1			3/24/2009	3/25/2009	1	4 X 8	STREET	TBD	
32	2335 HIGHLAND DR.	HARBOR		CWM	6"	N	0			3/26/2009	3/31/2009	5	5 X 12	STREET	TBD	
33	4815 STRONG AVE	CENTRAL		CWM	6"	N	0			3/30/2009	4/22/2009	1	6 X 12	STREET/TREELAWN	TBD	
34	3311 WILSON AVE		ASH	CWM	2"	N	0			4/9/2009	4/9/2009	2	1 X 5	STREET/TREELAWN	6/09	
35	8716 CONLEY	SAYBROOK		CWM	2"	N	0			4/16/2009	4/17/2009	1	4 X 13	DRIVEWAY	TBD	
36	3448 E. CENTER	NK		CWM	6"	N	0			4/16/2009	4/17/2009	1	4 X 6	TREELAWN	5/09	
37	6093 WRIGHT ST.	NK		CBL	2"	Y	1	DTD	4/22/2009	4/21/2009	4/21/2009	0	5 X 8	TREELAWN	5/09	
38	W. 5th ST. & FRANKLIN	HARBOR		HYD	6"	N	0			4/22/2009	4/22/2009	0	7 X 10	SIDEWALK	TBD	
39	2621 W. 16th ST.	HARBOR		CWM	6"	Y	2	DTD	4/26/2009	4/26/2009	4/26/2009	0	2 X 10	TREELAWN	5/09	
40	W. 8TH ST.	HARBOR		VLV	6"	N	0			4/28/2009	4/28/2009	0	5 X 5	STREET	TBD	
41	1331 W. PROSPECT	WESTSIDE		CBL	3/4"	N	1			4/28/2009	4/28/2009	0	4 X 4, 3 X 8	STREET/TREELAWN	5/09	
42	PARK AVE.	CENTRAL		VLV	6"	N	0			5/12/2009	5/14/2009	2	8 X 6	STREET	TBD	
43	5015 BENEFIT AVE.	WEST SIDE		SERVICE	3/4"	N	1			5/12/2009	5/14/2009	2	4 X 6	DRIVEWAY	TBD	
44	610 BUNKER HILL	CENTRAL		CBL	3/4"	N	1			5/18/2009	6/1/09	12	4 X 8	TREELAWN	6/09	
45	873 PROSPECT	CENTRAL		CBL	3/4"	N	1			5/19/2009	6/1/09	12	4 X 8	TREELAWN	6/09	
46	LAKE RD. (ACROSS F/OE)	ASH		CWM	17"	N	0			5/21/2009	5/21/2009	7	30 X 30	TREELAWN	TBD	
47	5313 REED AVE.	CENTRAL		CBL	3/4"	N	1			5/22/2009	5/22/2009	0	3 X 8	DRIVEWAY/SH	TBD	
48	E. 28th ST & STATE	ASH		CWM	6"	Y	3	DTD	5/25/2009	5/23/2009	5/23/2009	0	10 X 4	STREET	TBD	
49				CWM	6"	Y	0			5/29/2009	5/27/2009	0	7 X 8	DRIVEWAY	TBD	

PSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CD = Company Other; PSL = Private Service Leak; PVM = Private Water Main; PO = Private Other

PSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CD = Company Other; PSL = Private Service Leak; PVM = Private Water Main; PO = Private Other

CSL = Company Service Leak; CWM = Company Water Maint; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PVM = Private Water Maint; PO = Private Other (Re Door Tag; DTD = Door to Door Date

[illegible]

Ohio American Water Company
Lawrence County District
2009 Water Leak Log

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; FSL = Private Service Leak; PWM = Private Water Main; PO = Private Other DR= Door Tag; DTD = Door to Door

Location	Service Area	Township	Leak Type	Size	Bell Order (Y or N)	Number of Services Affected	Method of Notification	Date Bell Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
1 FIRST QUARTER															
2 Overlook Drive	Ches-Village	CWM	CWM	2	N	2			12/30/08	01/02/09	2	4 X 4	Gravel	1/2/09	Main Crushed By Truck Bom
3 Burlington Fire Dept.	Fayette	CSL	CSL	1	N	1			01/13/09	01/13/09	0	6 X 8	Gravel	5/6/09	
4 Randolph Street	Union	CO	CO	1	N	1			01/18/09	01/18/09	0	4 X 4	Grass	N/A	Unseen Leak For Some Time
5 Sandusky Rd. 41 US 52	Fayette	CWM	CWM	6	N	0			N/A	01/20/09	7	5 X 4	Gravel	1/20/09	Had been leaking for some time. Killed IA account.
6 375 County Rd. 3	Union	CO	CO	1	N	0			01/24/09	01/24/09	0	4 X 4	Gravel	1/24/09	
7 Madison Street	Fayette	CWM	CWM	6	N	0			02/05/09	02/05/09	0	6 X 6	Gravel	2/05/09	Killed IA service at saddle.
8 Robertson Rd.	Union	CWM	CWM	2	N	0			02/02/09	02/06/09	4	4 X 8	Gravel	2/06/09	Spill
10 Township Rd. 1011	Fayette	CWM	CWM	2	N	0			02/22/09	02/23/09	3	5 X 6	Gravel	2/23/09	Clean Break
11															
12 Comfort Inn at CR 144	Fayette	CWM	CWM	6	N	0			03/02/09	03/05/09	3	N/A	N/A	N/A	No restoration needed.
13 Tinsler Drive	Union	CWM	CWM	6	N	0			03/06/09	03/06/09	0	8 X 8	Berm/Grass	6/10/08	Hillside Movement
14 8350 CR 15	Fayette	CO	CO	3/4	N	1			03/14/09	03/20/09	7	5X5	Grass	N/A	Replace setter valve
15 Davis Street	Fayette	CO	CO	3/4	N	1			03/01/09	03/24/09	24	6X6	Grass	N/A	Replace setter valve
16 Jane Street	Union	CO	CO	2	N	10			04/18/09	04/19/09	0	6X8	Berm/Grass	5/15/09	Repaired Blow Off
17 Kimberly Lane	Fayette	CSL	CSL	3/4	N	0			04/16/09	04/23/09	7	2X2	Grass	6/23/08	Repair Clamp
18 Hawthorn Lane	Union	CWM	CWM	2	N	4			05/06/09	05/06/09	0	6X4	Gravel	5/5/09	Coupling
19 Kellys Lane & Ellis Trailer Pk.	Ches-Village	CWM	CWM	2	N	15			01/18/2009	01/18/2009	6	4X4	Grass	6/10/08	80 Degree PVC Band
20 151 Township 1068	Fayette	CO	CO	3/4	N	1			02/12/2009	02/12/2009	6	N/A	Gravel	6/10/08	Angle Meter Valve
21 Virginia Ave.	Fayette	CSL	CSL	3/4	N	1			03/07/2009	03/07/2009	3	4X8	Ditchline	6/1/09	Replace Service
22 Symmes Creek Rd.	Union	CWM	CWM	8	N	8			03/07/2009	03/07/2009	3	N/A	Ditchline	6/1/09	Hillside Movement
23 County Road 32	Union	CWM	CWM	8	N	46			03/07/2009	03/07/2009	6	N/A	Ditchline	6/1/09	Spill
24 Symmes Creek Rd.	Union	CWM	CWM	8	N	6			03/13/2009	03/13/2009	0	N/A	Ditchline	6/13/09	Hillside Movement
25 County Road 32	Union	CWM	CWM	8	N	15			03/17/2009	03/17/2009	6	N/A	Ditchline	6/21/09	Spill
26 Glenney Acres	Fayette	CO	CO	3/4	N	1			03/20/2009	03/23/2009	3	2X4	Grass	6/21/09	Angle Meter Valve
27 Thompson Hollow	Union	CWM	CWM	1.5	N	4			03/17/2009	03/23/2009	7	N/A	Ditchline	6/23/09	Galvanized

Ohio American Water Company
Mansfield District
2009 Water Leak Log

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other

Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Customers Affected	Method of Notification	Date Boil Order Lined	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment	VERIFIED
1 890 Springhill Road	Mansfield	Madison	CWM	6"	N	0	N/A	N/A	3/9/2009	3/9/2009	0	4ft x 4ft	Yard	06/05/09	Leak located on company property	Yes
2 Benedict Drive	Mansfield	Madison	CSL	3/4"	N	0	N/A	N/A	3/11/2009	3/11/2009	0	4ft x 4ft	Yard	06/05/09	Saddle clamp leaking	Yes
3 Wedgewood Drive Sys #3	Mansfield	Mifflin	CWM	6"	N	5	N/A	N/A	3/9/2009	3/9/2009	0	4ft x 4ft	Yard	06/05/09	Leak at point of lowering main due to storm sewer upgrades	Yes
4 Redstone Drive Sys #3	Mansfield	Mifflin	CWM	6"	Y	40	Door hanger	3/13/2009	3/12/2009	3/12/2009	0	4ft x 4ft	Yard	06/05/09	Contractor installing storm sewer will repair yard	Yes
5 910 Benedict Drive	Mansfield	Madison	CWM	4"	N	0	N/A	N/A	3/9/2009	3/11/2009	2	2ft x 20ft	Asphalt	5/05/09	Cylinder paving repaired road cut	Yes
6 1828 Plum Place	Mansfield	Madison	CSL	2"	N	0	N/A	N/A	5/7/2009	5/13/2009	5	4ft x 4ft	Yard	6/08/09	Repaired flush hydrant	Yes
7 1058 Harting	Mansfield	Madison	CSL	3/4"	N	0	N/A	N/A	3/16/2009	3/16/2009	3	4ft x 4ft	Yard	6/08/09	Saddle clamp leaking	Yes
8 853 Belmont	Mansfield	Madison	HYD	2"	N	0	N/A	N/A	6/19/2009	6/19/2009	4	4ft x 4ft	Yard	6/08/09	Repaired flush hydrant	Yes
9 514 Imperial	Mansfield	Mifflin	CSL	3/4"	N	0	N/A	N/A	6/28/2009	6/28/2009	0	3ft x 4ft	Yard	5/18/09	dig up curb stop to shut off	Yes
10 1104 Walnut	Mansfield	Schofield	CSL	3/4"	N	0	N/A	N/A	10/20/2008	10/20/2009	0	3ft x 4ft	Yard	06/05/09	locate curb box	Yes
11 228 Walnut	Mansfield	Mifflin	CWM	2"	N	0	N/A	N/A	11/10/2008	11/10/2009	0	5ft x 11ft	Yard	06/05/09	low pressure complaint dig up curb stop found plugged with iron	Yes
12 222 Imperial	Mansfield	Mifflin	CWM	2"	N	0	N/A	N/A	5/28/2009	5/28/2009	0	4ft x 4ft	Yard	06/05/09	dig up curb stop to shut off	Yes
13 587 Dogwood	Mansfield	Mifflin	CWM	2"	N	0	N/A	N/A	11/10/2008	11/10/2009	0	4ft x 4ft	Yard	06/05/09	4" valve broke @ bolts - replaced oring and new bolts	Yes
14 442 N. McElroy	Mansfield	Madison	VLV	4"	Y	311	Door hanger	1/17/2009	1/17/2009	1/17/2009	0	3ft x 4ft	Yard	06/05/09		Yes

15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75

Ohio American Water Company Marion District 2009 Water Leak Log

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PVM = Private Water Main; PD = Private Other; DFR = Door Tag; CTD = Door to Door															
Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Data Ball Order Filed	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
1407 Forest St	Marion	Marion	CSL	3/4"	N	1	NA	1/11/2009	1/11/2009	3/18/2009	126	6 x 6	Dit	6/22/2009	Repaired Very Small Leak Other work took precedent
2845 Chambers	Marion	Marion	PSL	P	N	1	NA	1/12/2009	1/12/2009	1/21/2009	70	NA	NA	NA	WLPP leak, no phone #, no claim. Called 1/21 again
3106 Park St	Marion	Marion	PSL	P	N	1	NA	1/15/2009	1/15/2009	1/25/2009	21	NA	NA	NA	Rescheduled by field.
4088 Darius	Marion	Marion	PSL	P	N	1	NA	1/15/2009	1/15/2009	1/25/2009	25	NA	NA	NA	WLPP delayed. Will be replacing line 01/05/09
5114 Woodbridge	Marion	Marion	PSL	P	N	1	NA	1/21/2009	1/21/2009	1/22/2009	26	NA	NA	NA	Very Small leak. Contractor request more time due to difficulty
6217 S Grand	Marion	Marion	PSL	P	N	1	NA	1/23/2009	1/23/2009	1/25/2009	13	NA	NA	NA	Rescheduled by field.
7281 Forest	Marion	Marion	CSL	3/4"	N	1	NA	1/23/2009	1/23/2009	1/25/2009	17	8 x 11	Pavement	6/6/2009	Very Small leak. Other work took precedent
8 Brenner East of S Main	Marion	Marion	CWM	2"	N	0	NA	1/23/2009	1/23/2009	1/25/2009	4	8 x 30	Pavement	6/6/2009	Repaired
9170 Creston	Marion	Marion	PSL	P	N	1	NA	1/23/2009	1/23/2009	1/25/2009	0	NA	NA	NA	Repaired
10251 Fairview	Marion	Marion	CWM	2"	Y	20	DR	1/23/2009	1/23/2009	1/25/2009	0	5 x 14	Pavement	6/1/2009	Repaired
11 Francella	Marion	Marion	Flush	F	N	0	NA	1/23/2009	1/23/2009	1/25/2009	0	NA	NA	NA	Flushed
12 Eagle View & Crisler	Marion	Marion	Flush	F	N	0	NA	1/23/2009	1/23/2009	1/25/2009	0	NA	NA	NA	Flushed
13244 Chester	Marion	Marion	PSL	P	N	1	NA	1/23/2009	1/23/2009	1/25/2009	0	NA	NA	NA	Shut off
14775 York	Marion	Marion	PSL	P	N	1	NA	1/23/2009	1/23/2009	1/25/2009	2	NA	NA	NA	Shut off
15190 Grandview Dr	Marion	Grand Prairie	PSL	P	N	1	NA	1/23/2009	1/23/2009	1/25/2009	20	NA	NA	NA	Repaired
16 Francella	Marion	Marion	Flush	F	N	0	NA	1/23/2009	1/23/2009	1/25/2009	0	NA	NA	NA	Flushed
17283 Belmont	Marion	Marion	PSL	P	N	1	NA	1/23/2009	1/23/2009	1/25/2009	23	NA	NA	NA	Repaired
18 Rotary Towers	Marion	Marion	PSL	P	N	1	NA	1/19/2009	1/19/2009	1/15/2009	0	NA	NA	NA	Shut off
19 York & Solado	Marion	Marion	CWM	2"	Y	20	DR	1/19/2009	1/19/2009	1/18/2009	0	12 x 14	Pavement	5/12/2009	Repaired
20 Scio & Center	Marion	Marion	CWM	2"	Y	12	DR	1/19/2009	1/19/2009	1/18/2009	0	10 x 15	Pavement	5/12/2009	Repaired
21300 Fies	Marion	Marion	CWM	2"	N	0	NA	1/19/2009	1/19/2009	1/18/2009	0	8 x 11	Pavement	5/27/2009	Repaired
22602 E Center	Marion	Marion	CWM	8"	N	0	NA	1/19/2009	1/19/2009	1/18/2009	1	9 x 11	Pavement	5/27/2009	Repaired
23388 Harding Hwy E	Caledonia	Marion	PSL	P	N	1	NA	1/20/2009	1/20/2009	1/20/2009	0	NA	NA	NA	Shut off
24633 E George	Marion	Marion	PSL	P	N	1	NA	1/21/2009	1/21/2009	1/21/2009	64	10 x 22	Pavement	5/27/2009	Repaired Very Small Leak Other work took precedent
25381 Jefferson	Marion	Marion	CSL	3/4"	N	1	NA	1/22/2009	1/22/2009	1/22/2009	0	30 x 30	Dit	6/10/2009	Repaired
26 Cascade Dr	Marion	Marion	CWM	18"	Y	2	DR	1/23/2009	1/23/2009	1/22/2009	1	7 x 12	Pavement	6/4/2009	Repaired
27631 S Prospect St	Marion	Marion	CWM	6"	N	0	NA	1/23/2009	1/23/2009	1/22/2009	0	NA	NA	NA	Repaired
28 Cascade Dr	Marion	Marion	Flush	F	N	0	NA	1/23/2009	1/23/2009	1/22/2009	0	NA	NA	NA	Flushed
28 Indiana & Korman	Marion	Marion	CWM	8"	Y	10	DR	1/23/2009	1/23/2009	1/22/2009	0	6 x 8	Pavement	6/25/2009	Repaired
30 Indiana & Korman	Marion	Marion	Flush	F	N	10	DR	1/23/2009	1/23/2009	1/22/2009	0	13 x 20	Pavement	6/25/2009	Repaired
31 Plantation & Korman	Marion	Marion	CWM	6"	Y	10	DR	1/23/2009	1/23/2009	1/22/2009	0	13 x 20	Pavement	6/25/2009	Repaired
32 Plantation & Korman	Marion	Marion	Flush	F	N	10	DR	1/23/2009	1/23/2009	1/22/2009	0	13 x 20	Pavement	6/25/2009	Repaired
33 Walnut & Ivy	Marion	Marion	CWM	6"	N	0	NA	1/26/2009	1/26/2009	1/26/2009	3	13 x 18	Pavement	6/25/2009	Repaired
34390 Leander	Marion	Marion	CWM	2"	N	0	NA	1/26/2009	1/26/2009	1/26/2009	9	7 x 13	Pavement	6/10/2009	Repaired
35 Main & Walnut, Prospekt	Prospekt	Marion	CWM	12"	Y	50	DR	1/27/2009	1/27/2009	1/27/2009	0	22 x 23	Pavement	6/10/2009	Repaired
36 Main & Walnut, Prospekt	Prospekt	Marion	Flush	F	N	0	NA	1/27/2009	1/27/2009	1/27/2009	0	NA	NA	NA	Flushed
37161 Frederick	Marion	Marion	PSL	P	N	1	NA	1/27/2009	1/27/2009	1/27/2009	12	NA	NA	NA	Repaired
381476 Littera Rd	Marion	Marion	CWM	10"	N	0	NA	1/28/2009	1/28/2009	1/28/2009	0	6 x 15	Pavement	5/28/2009	Repaired
391476 Littera Rd	Marion	Marion	Flush	F	N	0	NA	1/28/2009	1/28/2009	1/28/2009	0	NA	NA	NA	Flushed
40 S Main	Marion	Marion	CSL	3/4"	N	1	NA	1/30/2009	1/30/2009	1/30/2009	0	NA	NA	NA	Repaired
41610 Herman	Marion	Marion	CWM	2"	Y	8	DR	1/31/2009	1/31/2009	1/31/2009	0	8 x 19	Dit	6/2/2009	Repaired
42502 N Greenwood	Marion	Marion	PSL	P	N	1	NA	1/31/2009	1/31/2009	1/31/2009	0	NA	NA	NA	Shut off
43 Francella	Marion	Marion	Flush	F	N	0	NA	2/2/2009	2/2/2009	2/2/2009	0	10 x 14	Pavement	6/4/2009	Repaired
44704 Henry St	Marion	Marion	CWM	6"	N	0	NA	2/2/2009	2/2/2009	2/2/2009	0	7 x 11	Dit	6/2/2009	Repaired
45350 Commercial	Marion	Marion	CWM	2"	N	0	NA	2/4/2009	2/4/2009	2/4/2009	0	6 x 8	Dit	6/2/2009	Repaired
46230 Jefferson	Marion	Marion	CSL	3/4"	N	1	NA	2/4/2009	2/4/2009	2/4/2009	0	9 x 18	Dit	6/2/2009	Repaired
47 Gooding & Holmstrom	Marion	Prospect	CWM	12"	Y	500	Press Release, Reverts \$11	2/4/2009	2/4/2009	2/4/2009	0	NA	NA	NA	Repaired
48 Gooding & Holmstrom	Marion	Prospect	Flush	F	N	0	NA	2/4/2009	2/4/2009	2/4/2009	0	NA	NA	NA	Flushed
49117 Harcourt	Marion	Marion	CWM	2"	N	0	NA	2/4/2009	2/4/2009	2/4/2009	0	NA	NA	NA	Repaired
50305 N State	Marion	Marion	PSL	P	N	1	NA	2/4/2009	2/4/2009	2/4/2009	37	8 x 10	Pavement	6/10/2009	Repaired
51 Gay & Toledo	Marion	Marion	CWM	2"	N	0	NA	2/4/2009	2/4/2009	2/4/2009	0	12 x 14	Pavement	5/12/2009	Repaired
521282 Skawwood	Marion	Marion	PSL	P	N	1	NA	2/4/2009	2/4/2009	2/4/2009	17	NA	NA	NA	Repaired
53 Plymouth	Marion	Marion	CWM	2"	N	0	NA	2/4/2009	2/4/2009	2/4/2009	0	4 x 14	Pavement	5/12/2009	Repaired
54 Alley down Grand & Seifner	Marion	Marion	CWM	4"	N	0	NA	2/4/2009	2/4/2009	2/4/2009	0	7 x 12	Dit	6/2/2009	Repaired
55 Church & High Caledonia	Caledonia	Marion	CWM	4"	N	0	NA	2/4/2009	2/4/2009	2/4/2009	0	10 x 14	Pavement	6/17/2009	Repaired
56485 Patterson	Marion	Marion	PSL	P	N	1	NA	2/4/2009	2/4/2009	2/4/2009	0	NA	NA	NA	Was fixed within 7 days.
57733 Cherry	Marion	Marion	PSL	P	N	1	NA	2/4/2009	2/4/2009	2/4/2009	0	NA	NA	NA	Water turned off for repairs, same day.
58188 E George	Marion	Marion	PSL	P	N	1	NA	2/4/2009	2/4/2009	2/4/2009	60	NA	NA	NA	WLPP plumber can't find leak. Gave more time
59 Center & Dix	Marion	Marion	CWM	6"	N	0	NA	2/4/2009	2/4/2009	2/4/2009	0	NA	NA	NA	Repaired
61476 Road	Marion	Marion	Flush	F	N	0	NA	2/4/2009	2/4/2009	2/4/2009	0	NA	NA	NA	Repaired
62570 Pinnawalla	Marion	Marion	CSL	2"	N	1	NA	2/4/2009	2/4/2009	2/4/2009	32	4 x 14	Pavement	6/17/2009	Repaired Other work took precedent
63 Fairfield & Main	Marion	Marion	CWM	2"	N	0	NA	2/4/2009	2/4/2009	2/4/2009	2	4 x 6	Dit	6/6/2009	Repaired
641311 Mt Vernon	Marion	Marion	PSL	P	N	1	NA	2/4/2009	2/4/2009	2/4/2009	9	NA	NA	NA	Repaired
65487 Park	Marion	Marion	PSL	P	N	1	NA	2/4/2009	2/4/2009	2/4/2009	0	NA	NA	NA	Repaired
66260 Bellevue	Marion	Marion	PSL	P	N	1	NA	2/4/2009	2/4/2009	2/4/2009	0	NA	NA	NA	Water turned off for repairs, same day.
67457 Park	Marion	Marion	PSL	P	N	1	NA	2/4/2009	2/4/2009	2/4/2009	0	NA	NA	NA	Repaired
68752 Bennett	Marion	Marion	CSL	3/4"	N	1	NA	2/4/2009	2/4/2009	2/4/2009	24	9 x 10	Pavement	6/2/2009	Repaired Other work took precedent
69222 Merchant	Marion	Marion	PSL	P	N	1	NA	2/4/2009	2/4/2009	2/4/2009	0	NA	NA	NA	Water turned off for repairs, same day.

**Ohio American Water Company
Portage County District
2009 Water Leak Log**

CSL = Company Service Leak; CWM = Company Water Main; HYD = Hydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other DR= Door Tag; DTD = Door to Door

Location	Service Area	Township	Leak Type	Size	Bolt Order (Y or N)	Number of Services		Method of Notification	Date Bolt Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration		Type of Restoration	Date Restoration Completed	Comment
						Affected	Unaffected						Restoration	Completed			
FIRST QUARTER																	
3471 Jamison	Beechcrest	Brimfield	CWM	8" C.I.	N	0	0	N/A	N/A	N/A	3/19/2009	0	10X10	0	Grass/Soil	5/6/09	
3471 Keswick	Beechcrest	Brimfield	CSL	8" C.I.	Y	84	0	FRCC	3/14/2009	2/13/2009	2/13/2009	0	5 X 10	0	In the grass	5/6/09	

CSL = Company Service Leak; CWM = Company Water Main; NYD + Mydrant; VLV = Valve; CO = Company Other; PSL = Private Service Leak; PWM = Private Water Main; PO = Private Other; DR = Door Tag; DTD = Door to Door

Location	Service Area	Township	Leak Type	Size	Boil Order (Y or N)	Number of Services Affected	Method of Notification	Date Boil Order Lifted	Report Date	Repair Date	Elapsed Days	Size of Restoration	Type of Restoration	Date Restoration Completed	Comment
1 143 Mohawk St	Tiffin City	Tiffin City	CSL	8"	N	N/A	N/A	N/A	12/16/2008	1/23/2009	8	5 x 5	street	01/23/09	
2 54 & 80 Circular	Tiffin City	Tiffin City	CSL	6"	N	N/A	N/A	N/A	1/23/2009	1/23/2009	4	3 x 10	street	01/23/09	
3 262 W Market St	Tiffin City	Tiffin City	CO	6"	N	N/A	N/A	N/A	1/20/2009	1/20/2009	1	4 x 6	bld	01/20/09	
4 19 Eila	Tiffin City	Tiffin City	CO	6"	N	N/A	N/A	N/A	1/20/2009	1/20/2009	0	3 x 5	bld	01/20/09	
5 118 Grand	Tiffin City	Tiffin City	CWM	6"	N	N/A	N/A	N/A	1/23/2009	1/23/2009	0	3 x 6	bld	01/23/09	
6 94 & 100 Indian	Tiffin City	Tiffin City	CWM	6"	N	N/A	N/A	N/A	1/23/2009	1/26/2009	3	4 x 6	street	01/26/09	
7 380 Veniz	Tiffin City	Tiffin City	CSL	8"	N	N/A	N/A	N/A	1/30/2009	1/30/2009	0	4 x 8, 3 x 6	bld	01/30/09	
8 336 Circular St	Tiffin City	Tiffin City	CO	8"	N	N/A	N/A	N/A	2/4/2009	2/6/2009	1	3 x 7	bld	02/06/09	
9 55 Ohio	Tiffin City	Tiffin City	CO	8"	N	N/A	N/A	N/A	2/5/2009	2/6/2009	0	5 x 6, 4 x 5	street	02/06/09	
10 288 Hall	Tiffin City	Tiffin City	CWM	8"	N	N/A	N/A	N/A	2/6/2009	2/6/2009	0	8 x 14	street	02/06/09	
11 Eida St	Tiffin City	Tiffin City	CWM	8"	N	N/A	N/A	N/A	2/7/2009	2/7/2009	0	16 x 3, 5 x 3	street/bld	02/07/09	
12 192 St. Francis	Tiffin City	Tiffin City	CSL	N/A	N	N/A	N/A	N/A	2/9/2009	2/10/2009	1	4 x 8	bld	02/10/09	
13 79 Grand	Tiffin City	Tiffin City	CO	2"	N	N/A	N/A	N/A	2/10/2009	2/13/2009	1	3 x 5	street	03/10/09	
14 52 Postoria	Tiffin City	Tiffin City	CWM	2"	N	N/A	N/A	N/A	2/13/2009	2/13/2009	0	4 x 12	street	2/13/09	
15 27 Main	Tiffin City	Tiffin City	CO	N/A	N	N/A	N/A	N/A	2/22/2009	2/19/2009	17	N/A	bld	02/18/09	
16 16 Beethle St	Tiffin City	Tiffin City	CWM	8"	N	N/A	N/A	N/A	2/25/2009	2/25/2009	0	7 x 8	street	02/25/09	
17 255 N Washington	Tiffin City	Tiffin City	CO	N/A	N	N/A	N/A	N/A	3/2/2009	3/2/2009	0	2 x 5	sidewalk	03/02/09	
18 248 S Washington	Tiffin City	Tiffin City	CO	N/A	N	N/A	N/A	N/A	3/4/2009	3/4/2009	0	3 x 5	bld	03/04/09	
19 817 N Sandusky	Tiffin City	Tiffin City	CWM	2"	N	N/A	N/A	N/A	3/6/2009	3/6/2009	0	4 x 8	bld	03/09/09	
20 328 Greenfield	Tiffin City	Tiffin City	CO	6"	N	N/A	N/A	N/A	3/6/2009	3/12/2009	2	4 x 5	bld	03/11/09	
21 198 - 208 Cottage	Tiffin City	Tiffin City	CO	4"	N	N/A	N/A	N/A	3/8/2009	3/17/2009	3	4 x 5	street	03/12/09	
22 158 Hudson	Tiffin City	Tiffin City	CWM	8"	N	N/A	N/A	N/A	3/18/2009	3/17/2009	1	3 x 23	street	3/17/09	
23 272 Charles St	Tiffin City	Tiffin City	CO	N/A	N	N/A	N/A	N/A	3/18/2009	3/19/2009	3	3 x 6	bld	03/19/09	
24 134 N Washington	Tiffin City	Tiffin City	CWM	3"	N	N/A	N/A	N/A	3/18/2009	3/19/2009	3	5 x 4	street	03/19/09	
25 75 S Washington	Tiffin City	Tiffin City	CO	10"	N	N/A	N/A	N/A	3/16/2009	3/23/2009	7	3 x 5	street	03/23/09	
26 145 Madison	Tiffin City	Tiffin City	CWM	6"	N	N/A	N/A	N/A	3/27/2009	3/27/2009	0	4 x 5	street	03/27/09	
27 248 Miami Street	Tiffin City	Tiffin City	CO	6"	N	N/A	N/A	N/A	3/25/2009	3/30/2009	4	5x8	bld	03/30/09	
28 55 Sycamore Street	Tiffin City	Tiffin City	CO	14"	N	N/A	N/A	N/A	3/25/2009	3/31/2009	5	4x4	street	03/31/09	
29 128 Elmer Street	Tiffin City	Tiffin City	CO	8"	N	N/A	N/A	N/A	3/31/2009	4/1/2009	1	3x5	bld	04/01/09	
30 1780 Winfield Drive	Tiffin City	Tiffin City	CO	8"	N	N/A	N/A	N/A	3/31/2009	4/2/2009	10	4x8	bld	04/02/09	
31 Miami Street	Tiffin City	Tiffin City	CO	12"	N	N/A	N/A	N/A	3/31/2009	4/2/2009	11	5x10	street/bld	04/03/09	
32 263 S. Monroe Street	Tiffin City	Tiffin City	CO	10"	N	N/A	N/A	N/A	4/8/2009	4/7/2009	1	3x5	street	04/07/09	
33 34 Madison Blvd	Tiffin City	Tiffin City	CO	10"	N	N/A	N/A	N/A	4/8/2009	4/8/2009	2	4x8	bld	04/09/09	
34 242 Hudson Street	Tiffin City	Tiffin City	CSL	6"	N	N/A	N/A	N/A	4/8/2009	4/8/2009	0	3x5, 3x5	street/sidewalk/bld	04/09/09	
35 Center Street & W. Market St	Tiffin City	Tiffin City	CO	6"	N	N/A	N/A	N/A	4/8/2009	4/8/2009	0	3x5	street	04/13/09	
36 225 Eighth Avenue	Tiffin City	Tiffin City	CO	6"	N	N/A	N/A	N/A	4/13/2009	4/13/2009	6	3x5	street	04/13/09	
37 230 Seventh Avenue	Tiffin City	Tiffin City	CSL	6"	N	N/A	N/A	N/A	4/14/2009	4/16/2009	2	3x5	street	04/16/09	
38 60 Sycamore's Street	Tiffin City	Tiffin City	CO	6"	N	N/A	N/A	N/A	4/20/2009	4/21/2009	1	3x5	street	04/21/09	
39 111Clyde Street	Tiffin City	Tiffin City	CO	N/A	N	N/A	N/A	N/A	4/8/2009	4/21/2009	13	3x5	street	04/21/09	
40 259 W. Market Street	Tiffin City	Tiffin City	CO	N/A	N	N/A	N/A	N/A	4/16/2009	4/22/2009	6	3x5	bld	04/22/09	
41 210 Bananal Street	Tiffin City	Tiffin City	CO	12"	N	N/A	N/A	N/A	4/21/2009	4/23/2009	2	3x5	bld	04/23/09	
42 20 Maplewood Street	Tiffin City	Tiffin City	CO	12"	N	N/A	N/A	N/A	4/20/2009	4/24/2009	4	8x10, 3x5	bld	04/24/09	
43 448 Miami Street	Tiffin City	Tiffin City	CSL	6"	N	N/A	N/A	N/A	4/27/2009	4/27/2009	0	6x10	street	04/27/09	
44 Wall & W. Davis Street	Tiffin City	Tiffin City	CO	6"	N	N/A	N/A	N/A	5/1/2009	5/4/2009	3	3x5	street	05/04/09	
45 62 Main Street	Tiffin City	Tiffin City	CSL	6"	N	N/A	N/A	N/A	5/2/2009	5/6/2009	9	3x5	street	05/09/09	
46 26 Canton Avenue	Tiffin City	Tiffin City	CO	N/A	N	N/A	N/A	N/A	5/1/2009	5/11/2009	10	4x5	bld	05/11/09	
47 71 Beachwood Drive	Tiffin City	Tiffin City	CO	6"	N	N/A	N/A	N/A	5/1/2009	5/6/2009	5	4x5	bld	05/06/09	
48 87 Greenfield Street	Tiffin City	Tiffin City	CO	6"	N	N/A	N/A	N/A	5/6/2009	5/12/2009	2	8x6	bld	05/07/09	
49 Off Street & Lellner Avenue	Tiffin City	Tiffin City	CO	N/A	N	N/A	N/A	N/A	5/6/2009	5/13/2009	4	3x5	bld	05/12/09	
50 N. Washington & Webber St	Tiffin City	Tiffin City	CO	6"	N	N/A	N/A	N/A	5/12/2009	5/19/2009	7	5x5	street	05/19/09	
51 60 Circular St	Tiffin City	Tiffin City	CSL	6"	N	N/A	N/A	N/A	5/12/2009	5/13/2009	1	4x5, 3x5	street/bld	05/13/09	
52 143 Mohawk St	Tiffin City	Tiffin City	CO	16"	N	N/A	N/A	N/A	5/18/2009	5/19/2009	6	4x5	street/bld	05/18/09	
53 422 Miami St	Tiffin City	Tiffin City	CO	8"	Y	8	IDA	5/29/2009	5/22/2009	8	2x30, 6x7, 4x1	street/sidewalk/bld	05/19/09		
54 1540 W Co Rd 54	Tiffin City	Tiffin City	CO	12"	N	N/A	N/A	N/A	5/1/2009	5/23/2009	6	4x5, 4x8	street	05/23/09	
55 81 Eida St	Tiffin City	Tiffin City	CO	8"	N	N/A	N/A	N/A	5/1/2009	5/23/2009	1	7x5	bld	05/23/09	
56 380 Miami St	Tiffin City	Tiffin City	CO	8"	N	N/A	N/A	N/A	5/4/2009	5/23/2009	2	4x5	street	05/23/09	
57 95 Main Ave	Tiffin City	Tiffin City	CO	N/A	N	N/A	N/A	N/A	5/4/2009	5/4/2009	0	3x5, 12x7	street	05/04/09	
58 155 Hampden Park	Tiffin City	Tiffin City	CO	N/A	N	N/A	N/A	N/A	5/28/2009	5/25/2009	7	3x5	bld	05/05/09	
59 13 Alan St	Tiffin City	Tiffin City	CO	N/A	N	N/A	N/A	N/A	5/28/2009	5/25/2009	11	3x5	bld	05/05/09	
60 178 N. Washington St	Tiffin City	Tiffin City	CO	N/A	N	N/A	N/A	N/A	6/11/2009	6/12/2009	4	3x5	bld	06/03/09	
61 95 Center St	Tiffin City	Tiffin City	CO	N/A	N	N/A	N/A	N/A	6/10/2009	6/17/2009	7	4x6	bld	06/17/09	
62 237 Canton Ave	Tiffin City	Tiffin City	CO	N/A	N	N/A	N/A	N/A	6/18/2009	6/23/2009	5	3x5	street	06/23/09	
63 201 E. Perry St	Tiffin City	Tiffin City	CO	N/A	N	N/A	N/A	N/A	6/19/2009	6/24/2009	6	4x5	bld	06/24/09	
64 255 Perry St	Tiffin City	Tiffin City	CO	N/A	N	N/A	N/A	N/A	6/19/2009	6/25/2009	6	2x5	street	06/25/09	

Location	Location of leak; may include street address of nearest residence or distance from intersecting street
Service Area Township	If Network service are is segmented, this information should be included Township in which leak occurred
Leak Type Size	List is found at top of sheet; each leak will be either Company or Private; This pertains to mains, valves and services Yor N answer; Service affecting leaks are determined to be those leaks that leave customers with little or no pressure
Service Affecting	The date the Company became aware of the leak
Report Date	The date the leak was repaired
Repair Date	The number of days from the report date to repair date; under normal conditions, this should be between 0 to 1 days for service affecting leaks and 0 to 7 days for non-service affecting leaks
Elapsed Days	Was a boil order issued to customers
Boil Order	Any additional useful information; should include an explanation of any repair outside the regulated number of elapsed days
Comments	
Method of Notification	

CSL	Company Service Line
CWM	Company Water Main
HYD	Hydrant
VLV	Valve
CO	Company Other
PSL	Private Service Line
PWM	Private Water Main
PO	Private Other

Yes
No