Staff Investigation Report and Recommendation

Case No.:	09-568-EL-BNR		2009	RECE	
Project:	Midway-OI Levis 138 kV Transmissio Relocation for Roachton Road Widenia	PUC	2009 AUG -6	RECEIVED-DOCKETING DIV	
Applicant:	00	· A	KE T#		
Report Da	te: 5 August 2009			8: 42	₽
Automatic	Approval Date: 18 August 2009	(Construction Notice process	s)		
Waiver Re	equest: None				
Inspection Staff Assig	Date(s): 16 July 2009 gned: J. O'Dell				
Summary	of Staff Recommendations (see report	text for discussion):			
Applicati Waiver:	on: [X] Approval [] Disapproval [] Approval [] Disapproval		ns		
Summary	of Staff Recommended Conditions (se	e report text for discussion):			
• No	ne				
Projected .	Docket Closure Date (if automatically	approved): 31 March 2012			
Investigati	ian Renart				

Project Description: This project involves the relocation of one transmission pole and two guy poles. The project is necessary to accommodate a planned road widening.

Site Description: The project is located along Roachton Road, just west of State Route 25 in the City of Perrysburg, Wood County. The current transmission pole location would be shifted approximately 35 feet west and the guy poles would be relocated 22 feet to the south. The Applicant will not need to obtain any new r-o-w, as the city is providing all necessary easements.

Discussion/Comments/Concerns: The construction of this project should pose only minimal negative social and ecological impacts.

This is to cer	tify that	the images	appearing	are an
This is to cer accurate and c document deliver	omplete re	production	mirse of bu	siness.
Technician		Date Proce	893 <u>8-6-</u>	09_