

FILE



Bricker & Eckler
ATTORNEYS AT LAW
COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2388
sbloomfield@bricker.com

August 7, 2009

VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

**Re: Case No. 08-1233-WS-UNC
Ohio American Water Company
Stipulation Page No. 11, ¶14D**

Dear Ms. Jenkins:

Pursuant to the Commission's November 12, 2008 Opinion and Order in Case No. 07-1112-WS-AIR, and to the Stipulation and Recommendation page 11, paragraph 14D, Ohio American Water Company submits for filing the Lake Darby Hardness Monthly Report for July 2009.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

RECEIVED-DOCKETING DIV
2009 AUG - 7 PM 3:22
PUCO

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.

Technician TS Date Processed 8-2-09

Ohio-American Water Company
Franklin County District
Lake Darby Water Hardness Report

Reporting Month & Year July-09

1	2	3	4	5	6	7	8	9	10	11
Date	Day	On-Line Measurement (mg/L) Every 2 hrs when LDWTP is ON	On-Line Unit Operational (Y or N)	LDWTP Process Control Measurement (mg/L) Daily	OAWC WQ Lab Measurement (mg/L) Daily	LDWTP Outside Lab Measurement (mg/L) 1/Month	LDWTP Outside Lab Collection Time Sampler	Distribution Outside Lab Measurement (mg/L) 1/Month	Distribution System Outside Lab Collection Time Sampler	WQ Water Distribution Measurement (mg/L) 2/week
1		114	Y	110	108					118
2		119	Y	116	114					
3		117	Y	114	110					
4		121	Y	114	112					
5		119	Y	116	112					
6		118	Y	108	106					
7		119	Y	112	104	98	7:38 AM, Jeff Ward	106	8:03 AM, Jeff Ward	116
8		118	Y	110	108					118
9		123	Y	110	106					
10		117	Y	112	108					
11		117	Y	110	108					
12		115	Y	110	114					
13		111	Y	112	108					120
14		96	Y	108	110					
15		100	Y	110	110					122
16		94	Y	112	112					
17		95	Y	110	108					
18		110	Y	108	108					
19		109	Y	110	108					
20		119	Y	110	104					120
21		108	Y	108	106					
22		108	Y	110	106					118
23		104	Y	112	110					
24		105	Y	110	106					
25		108	Y	108	102					
26		105	Y	108	110					
27		109	Y	112	108					114
28		110	Y	114	110					
29		110	Y	116	114					122
30		108	Y	114	110					
31		113	Y	110	106					
Average		111		111	108					119
Max		123		116	114					122
Min		94		108	102					114
% >150 mg/L		0.0		0.0	0.0					0.0

- NOTES:
- 1) Operator shall make a notation in the Instrumentation Log Book on a DAILY basis on the status of the On-Line Hardness Analyzer.
 - 2) Week is Sunday to Saturday
 - 3) WQ Lab is responsible for delivering monthly sample to outside lab.
 - 4) For any test with a hardness <96 mg/L or >145 mg/L notify the Network Operations Superintendent and the Operations Supervisor immediately.