



COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

September 3, 2009

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793


**Re: Ohio American Water Company
Case No. 08-1233-WS-UNC**

Dear Ms. Jenkins:

Ohio American Water Company submits for filing the August 2009 Hardness Report for the Marion district.

If you have any questions, please call me at the number listed above.

Sincerely,


Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician SM Date Processed SEP 03 2009

2
RECEIVED-DOCKETING DIV
2009 SEP -3 AM 11:55
VIA HAND DELIVERY
P/CO

EFFLUENT HARDNESS / MG/L

August	RAW HARDNESS MG/L	EFFLUENT HARDNESS MG/L
1	410	155
2	370	149
3	357	152
4	375	149
5	428	151
6	457	150
7	440	143
8	450	145
9	448	148
10	443	146
11	435	142
12	423	143
13	433	146
14	441	147
15	430	148
16	413	143
17	440	148
18	445	143
19	455	142
20	440	146
21	430	145
22	410	150
23	400	148
24	423	155
25	411	146
26	441	154
27	453	137
28	410	144
29	412	136
30	403	143
31	397	146

clarifier tank out of service for cleaning & maintenance
clarifier tank out of service for cleaning & maintenance
clarifier tank out of service for cleaning & maintenance

settle tank out of service for cleaning & maintenance
settle tank out of service for cleaning & maintenance
settle tank out of service for cleaning & maintenance
settle tank out of service for cleaning & maintenance
settle tank out of service for cleaning & maintenance
settle tank out of service for cleaning & maintenance
settle tank out of service for cleaning & maintenance
settle tank out of service for cleaning & maintenance

AVERAGE	423	146
MAX	457	155
MIN	357	136

August 2009
EFFLUENT HARDNESS AVG - 146 MG/L
MARION DISTRICT

