



COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

RECEIVED-DOCKETING DIV

September 4, 2009

2009 SEP -4 AM 11:55

PUCO

VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

Re: Case No. 08-1233-WS-UNC
Ohio American Water Company
Stipulation Page No. 11, ¶14D

Dear Ms. Jenkins:

Pursuant to the Commission's November 12, 2008 Opinion and Order in Case No. 07-1112-WS-AIR, and to the Stipulation and Recommendation page 11, paragraph 14D, Ohio American Water Company submits for filing the Lake Darby Hardness Monthly Report for August 2009.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician JM Date Processed SEP 04 2009

**Ohio-American Water Company
Franklin County District
Lake Darby Water Hardness Report**

Reporting Month & Year August-09

1	2	3	4	5	6	7	8	9	10	11
Date	Day	On-Line Measurement (mg/L) Every 2 hrs when LDWTP is ON	On-Line Unit Operational (Y or N)	LDWTP Process Control Measurement (mg/L) Daily	OAWC WQ Lab Measurement (mg/L) Daily	LDWTP Outside Lab Measurement (mg/L) 1/Month	LDWTP Outside Lab Collection Time Sampler	Distribution Outside Lab Measurement (mg/L) 1/Month	Distribution System Outside Lab Collection Time Sampler	WQ Water Distribution Measurement (mg/L) 2/week
1	Sat	115	Y	115	114					
2	Sun	119	Y	130	122					
3	Mon	116	Y	120	116	105	6:56 AM, Jeff Ward	103	8:55 AM, Jeff Ward	118
4	Tue	112	Y	116	120					
5	Wed	115	Y	110	110					108
6	Thu	117	Y	124	120					
7	Fri	121	Y	116	110					
8	Sat	116	Y	112	110					
9	Sun	116	Y	112	106					
10	Mon	119	Y	110	110					120
11	Tue	119	Y	124	126					
12	Wed	119	Y	110	110					122
13	Thu	116	Y	114	114					
14	Fri	119	Y	114	108					
15	Sat	118	Y	114	110					
16	Sun	115	Y	113	110					
17	Mon	112	Y	113	112					120
18	Tue	57	Y	103	104					112
19	Wed	121	Y	120	120					
20	Thu	123	Y	119	116					
21	Fri	114	Y	115	110					
22	Sat	121	Y	123	118					
23	Sun	126	Y	125	118					
24	Mon	131	Y	118	116					112
25	Tue	118	Y	120	104					
26	Wed	126	Y	114	114					122
27	Thu	125	Y	118	118					
28	Fri	124	Y	126	128					
29	Sat	123	Y	108	104					
30	Sun	118	Y	108	108					
31	Mon	127	Y	110	108					114
Average		117		116	113					116
Max		131		130	128					122
Min		57		103	104					108
% >150 mg/L		0.0		0.0	0.0					0.0

- NOTES:
- 1) Operator shall make a notation in the Instrumentation Log Book on a DAILY basis on the status of the On-Line Hardness Analyzer.
 - 2) Week is Sunday to Saturday
 - 3) WQ Lab is responsible for delivering monthly sample to outside lab.
 - 4) For any test with a hardness <95 mg/L or >145 mg/L notify the Network Operations Superintendent and the Operations Supervisor immediately.