

**Case No. 09-724-EL-REN
AMP/OMEGA JV 6 Wind Farm
Staff Interrogatories – Initial Set**

Question 1: Please provide digital photographs that depict an accurate characterization of your installed system and the dates the photographs were taken.

Answer 1: Please see the attached photos (on pages 3 and 4) for a depiction of the characterization of our four-turbine system. These photos were taken on September 21 and September 23, 2006. Electronic versions are also being downloaded via DIS.

Question 2: Section G of the Application Form requests a detailed description of how the output from the facility is going to be measured and verified and a description of the meter configuration. Please provide this information.

Answer 2: The revenue meter is placed on the distribution line that leaves the wind farm and connects to the City of Bowling Green's distribution system. The meter measures a total net output of all four units and provides what we call an hourly integrated (or average) reading. This data is remotely read and stored via AMP's SCADA system.

Each unit also has its own computerized control system, and in that system is data storage capability. The control systems individually record the output of the unit. This data is downloaded at the site, from each unit each month.

At the end of each month, we do a side-by-side comparison of the meter values as received by SCADA to the data from the controllers. Any variances are identified and reconciled before the data is provided to AMP's billing department for the monthly billing to the 10 OMEGA JV6 project participants.

Question 3: Section N of the Application Form requests a photograph of the meter(s) with the dates the images were taken. Please provide the date(s) when the photographs were taken.

Answer 3: All four (4) photos of the meters provided with the original certification application were taken on 08/13/2009. The date is depicted as part of the meter reading itself under the "kWh receive" data.

1. I am the duly authorized representative of the AMP / OMEGA JV 6 Wind Farm.
2. I have personally examined and am familiar with all information contained in the foregoing responses, including any exhibits and attachments, and that based upon my inquiry of those persons immediately responsible for obtaining the information contained in the responses, I believe that the information is true, accurate and complete.

3. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

Joleen M. Thompson
Signature and Title

9/8/09
Date

Senior VP External Affairs

Attachments (2)





This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

9/8/2009 11:12:37 AM

in

Case No(s). 09-0724-EL-REN

Summary: Response to initial staff interrogatories for AMP/OMEGA JV6 Wind Farm application for certification as an eligible Ohio renewable energy resource generating facility electronically filed by Ms. Julia M Blankenship on behalf of American Municipal Power, Inc.