

NC  
FILE**FirstEnergy.**

RECEIVED-DOCKETING DIV

13  
76 South Main St.  
Akron, Ohio 44308

2009 SEP 25 AM 9:36

1-800-633-4766

PUCO

September 24, 2009

Ms. Renee J. Jenkins  
Director, Administration Department  
Secretary to the Commission  
Docketing Division  
The Public Utilities Commission of Ohio  
180 East Broad Street  
Columbus, OH 43215-3793

**Letter of Notification**  
**Bayshore-Jackman and Bayshore-Lemoyne**  
**138 kV Transmission Line Loops to BP Oil Project**  
**Case No. 09-860-EL-BLN**

Dear Ms. Jenkins:

In accordance with Rule 4906-1-11 American Transmission Systems, Incorporated ("ATSI"), a subsidiary of FirstEnergy Corp, transmit one (1) original and eleven (11) copies of the enclosed Letter of Notification for the above captioned project. In this project, ATSI is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new BP Oil owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

Please be advised of the following:

- |  |   |
|--|---|
| a) Name and address of the applicants: | American Transmission Systems, Incorporated<br>76 South Main Street<br>Akron, Ohio 44308  |
| b) Name of proposed facilities:        | Bayshore-Jackman and Bayshore-Lemoyne 138 kV 138 kV<br>Transmission Line Loops to BP Oil Project.   |
| c) Location of proposed facilities:    | The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio. |

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.  
Technician Jim Date Processed SEP 25 2009


August 21, 2009

- d) Description of proposed facilities:      The Project involves constructing 5 new steel pole structures on concrete foundations and looping the Bayshore-Lemoyne 138 kV circuit and the Bayshore-Jackman 138 kV circuit into a new customer owned substation.
- e) Applicant's representative:      Scott M. Humphrys, Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company  
76 South Main Street  
Akron, OH 44308-1890

After docketing this filing, please return one time-stamped copy of the Letter of Notification for our records to us in the enclosed envelope. We have provided a copy of the Letter of Notification by certified mail, with return receipt requested, to each official of the political subdivisions immediately affected by the proposed project as listed in the attached Exhibit 1. Copies of the transmittal letters addressed to the local government representatives of the City of Oregon and Lucas County are enclosed for your file.

Should the Ohio Power Siting Board desire further information or discussion of this submittal, please contact me at (330) 384-2526.

Sincerely,



Scott M. Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachments

**EXHIBIT 1: OFFICIALS SERVED COPY OF LON**  
**Bayshore-Jackman and Bayshore-Lemoyne**  
**138 kV Transmission Line Loop to BP Oil Project**  
**Case No. 09-        -EL-BLN**

**Lucas County**

The Honorable Tina Skeldon Wozniak  
Lucas County Commissioner  
One Government Center Ste 800  
Toledo, Ohio 43604

The Honorable Ben Konop  
Lucas County Commissioner  
One Government Center Ste 800  
Toledo, Ohio 43604

The Honorable Pete Gerken  
Lucas County Commissioner  
One Government Center Ste 800  
Toledo, Ohio 43604

Mr. Keith G. Earley, P.E., P.S.  
Lucas County Engineer  
One Government Center Ste 800  
Toledo, Ohio 43604

**City of Oregon**

The Honorable Marge Brown  
Mayor, City of Oregon  
5330 Seaman Road  
Oregon, Ohio 43616

Ms. Tina M. Evans  
Clerk of Council, City of Oregon  
City Council  
5330 Seaman Road  
Oregon, Ohio 43616

The Honorable Michael P. Sheehy  
President, City of Oregon City Council  
5330 Seaman Road  
Oregon, Ohio 43616

Mr. Paul Roman  
Public Service Director, City of Oregon  
5330 Seaman Road  
Oregon, Ohio 43616

Mr. Rodney Schultz, P.E.  
Deputy City Engineer, City of Oregon  
5330 Seaman Road  
Oregon, Ohio 43616

Mr. Ken Filipiak  
City Administrator, City of Oregon  
5330 Seaman Road  
Oregon, Ohio 43616

September 24, 2009

The Honorable Tina Skeldon Wozniak  
Lucas County Commissioner  
One Government Center Ste 800  
Toledo, Ohio 43604

**Letter of Notification**  
**Bayshore-Jackman and Bayshore-Lemoyne**  
**138 kV Transmission Line Loops to BP Oil Project**  
**Case No. 09-        -EL-BLN**

Dear Ms. Wozniak,

In the above captioned project, American Transmission Systems, Inc. ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new BP Oil owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

September 24, 2009

The Honorable Pete Gerken  
Lucas County Commissioner  
One Government Center Ste 800  
Toledo, Ohio 43604

**Letter of Notification**  
**Bayshore-Jackman and Bayshore-Lemoyne**  
**138 kV Transmission Line Loops to BP Oil Project**  
**Case No. 09- -EL-BLN**


Dear Mr. Gerken,

In the above captioned project, American Transmission Systems, Inc. ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new customer owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

September 24, 2009

The Honorable Ben Konop  
Lucas County Commissioner  
One Government Center Ste 800  
Toledo, Ohio 43604

**Letter of Notification**  
**Bayshore-Jackman and Bayshore-Lemoyne**  
**138 kV Transmission Line Loops to BP Oil Project**  
**Case No. 09-        -EL-BLN**

Dear Mr. Konop,

In the above captioned project, American Transmission Systems, Inc. ("ATSP"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new customer owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

September 24, 2009

Mr. Keith G. Earley, P.E., P.S.  
Lucas County Engineer  
One Government Center Ste 800  
Toledo, Ohio 43604

**Letter of Notification**  
**Bayshore-Jackman and Bayshore-Lemoyne**  
**138 kV Transmission Line Loops to BP Oil Project**  
**Case No. 09-        -EL-BLN**

Dear Mr. Earley,

In the above captioned project, American Transmission Systems, Inc. ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new customer owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

September 24, 2009

The Honorable Marge Brown  
Mayor, City of Oregon  
5330 Seaman Road  
Oregon, Ohio 43616

**Letter of Notification**  
**Bayshore-Jackman and Bayshore-Lemoyne**  
**138 kV Transmission Line Loops to BP Oil Project**  
**Case No. 09- -EL-BLN**

Dear Ms. Brown,

In the above captioned project, American Transmission Systems, Inc. ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new customer owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment



September 24, 2009

The Honorable Michael P. Sheehy  
President, City of Oregon City Council  
5330 Seaman Road  
Oregon, Ohio 43616

**Letter of Notification**  
**Bayshore-Jackman and Bayshore-Lemoyne**  
**138 kV Transmission Line Loops to BP Oil Project**  
**Case No. 09- -EL-BLN**

Dear Mr. Sheehy,

In the above captioned project, American Transmission Systems, Inc. ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new customer owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

September 24, 2009

Mr. Rodney Schultz, P.E.  
Deputy City Engineer, City of Oregon  
5330 Seaman Road  
Oregon, Ohio 43616

**Letter of Notification**  
**Bayshore-Jackman and Bayshore-Lemoyne**  
**138 kV Transmission Line Loops to BP Oil Project**  
**Case No. 09- -EL-BLN**

Dear Mr. Shultz,

In the above captioned project, American Transmission Systems, Inc. ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new customer owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

September 24, 2009

Ms. Tina M. Evans  
Clerk of Council, City of Oregon  
City Council  
5330 Seaman Road  
Oregon, Ohio 43616

**Letter of Notification**  
**Bayshore-Jackman and Bayshore-Lemoyne**  
**138 kV Transmission Line Loops to BP Oil Project**  
**Case No. 09-        -EL-BLN**

Dear Ms. Evans,

In the above captioned project, American Transmission Systems, Inc. ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new customer owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

September 24, 2009

Mr. Paul Roman  
Public Service Director, City of Oregon  
5330 Seaman Road  
Oregon, Ohio 43616

**Letter of Notification**  
**Bayshore-Jackman and Bayshore-Lemoyne**  
**138 kV Transmission Line Loops to BP Oil Project**  
**Case No. 09-      -EL-BLN**


Dear Mr. Roman,

In the above captioned project, American Transmission Systems, Inc. ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new customer owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

September 24, 2009

Mr. Ken Filipiak  
City Administrator, City of Oregon  
5330 Seaman Road  
Oregon, Ohio 43616

**Letter of Notification**  
**Bayshore-Jackman and Bayshore-Lemoyne**  
**138 kV Transmission Line Loops to BP Oil Project**  
**Case No. 09-        -EL-BLN**

Dear Mr. Filipiak,

In the above captioned project, American Transmission Systems, Inc. ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new customer owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment