

NC

FILE

13

FirstEnergy

RECEIVED-DOCKETING DIV

76 South Main St.
Akron, Ohio 44308

2009 SEP 25 AM 9:36

1-800-633-4766

PUCO

September 24, 2009

Ms. Renee J. Jenkins
Director, Administration Department
Secretary to the Commission
Docketing Division
The Public Utilities Commission of Ohio
180 East Broad Street
Columbus, OH 43215-3793

Letter of Notification
Bayshore-Jackman and Bayshore-Lemoyne
138 kV Transmission Line Loops to BP Oil Project
Case No. 09-860-EL-BLN

Dear Ms. Jenkins:

In accordance with Rule 4906-1-11 American Transmission Systems, Incorporated ("ATSI"), a subsidiary of FirstEnergy Corp, transmit one (1) original and eleven (11) copies of the enclosed Letter of Notification for the above captioned project. In this project, ATSI is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new BP Oil owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

Please be advised of the following:

- a) Name and address of the applicants: American Transmission Systems, Incorporated
76 South Main Street
Akron, Ohio 44308
- b) Name of proposed facilities: Bayshore-Jackman and Bayshore-Lemoyne 138 kV 138 kV
Transmission Line Loops to BP Oil Project.
- c) Location of proposed facilities: The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.


This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician Jim Date Processed SEP 25 2009

- d) Description of proposed facilities: The Project involves constructing 5 new steel pole structures on concrete foundations and looping the Bayshore-Lemoyne 138 kV circuit and the Bayshore-Jackman 138 kV circuit into a new customer owned substation.
- e) Applicant's representative: Scott M. Humphrys, Associate Distribution Specialist
Energy Delivery Technical Services
FirstEnergy Service Company
76 South Main Street
Akron, OH 44308-1890

After docketing this filing, please return one time-stamped copy of the Letter of Notification for our records to us in the enclosed envelope. We have provided a copy of the Letter of Notification by certified mail, with return receipt requested, to each official of the political subdivisions immediately affected by the proposed project as listed in the attached Exhibit 1. Copies of the transmittal letters addressed to the local government representatives of the City of Oregon and Lucas County are enclosed for your file.

Should the Ohio Power Siting Board desire further information or discussion of this submittal, please contact me at (330) 384-2526.

Sincerely,



Scott M. Humphrys
Associate Distribution Specialist
Energy Delivery Technical Services
FirstEnergy Service Company

Attachments

**EXHIBIT 1: OFFICIALS SERVED COPY OF LON
Bayshore-Jackman and Bayshore-Lemoyne
138 kV Transmission Line Loop to BP Oil Project
Case No. 09- -EL-BLN**

Lucas County

The Honorable Tina Skeldon Wozniak
Lucas County Commissioner
One Government Center Ste 800
Toledo, Ohio 43604

The Honorable Ben Konop
Lucas County Commissioner
One Government Center Ste 800
Toledo, Ohio 43604

The Honorable Pete Gerken
Lucas County Commissioner
One Government Center Ste 800
Toledo, Ohio 43604

Mr. Keith G. Earley, P.E., P.S.
Lucas County Engineer
One Government Center Ste 800
Toledo, Ohio 43604

City of Oregon

The Honorable Marge Brown
Mayor, City of Oregon
5330 Seaman Road
Oregon, Ohio 43616

Ms. Tina M. Evans
Clerk of Council, City of Oregon
City Council
5330 Seaman Road
Oregon, Ohio 43616

The Honorable Michael P. Sheehy
President, City of Oregon City Council
5330 Seaman Road
Oregon, Ohio 43616

Mr. Paul Roman
Public Service Director, City of Oregon
5330 Seaman Road
Oregon, Ohio 43616

Mr. Rodney Schultz, P.E.
Deputy City Engineer, City of Oregon
5330 Seaman Road
Oregon, Ohio 43616

Mr. Ken Filipiak
City Administrator, City of Oregon
5330 Seaman Road
Oregon, Ohio 43616

September 24, 2009

The Honorable Tina Skeldon Wozniak
Lucas County Commissioner
One Government Center Ste 800
Toledo, Ohio 43604

Letter of Notification
Bayshore-Jackman and Bayshore-Lemoyne
138 kV Transmission Line Loops to BP Oil Project
Case No. 09- -EL-BLN

Dear Ms. Wozniak,

In the above captioned project, American Transmission Systems, Inc. ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new BP Oil owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys
Associate Distribution Specialist
Energy Delivery Technical Services
FirstEnergy Service Company

Attachment

September 24, 2009

The Honorable Pete Gerken
Lucas County Commissioner
One Government Center Ste 800
Toledo, Ohio 43604

Letter of Notification
Bayshore-Jackman and Bayshore-Lemoyne
138 kV Transmission Line Loops to BP Oil Project
Case No. 09- -EL-BLN

Dear Mr. Gerken,

In the above captioned project, American Transmission Systems, Inc. ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new customer owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys
Associate Distribution Specialist
Energy Delivery Technical Services
FirstEnergy Service Company

Attachment

September 24, 2009

The Honorable Ben Konop
Lucas County Commissioner
One Government Center Ste 800
Toledo, Ohio 43604

Letter of Notification
Bayshore-Jackman and Bayshore-Lemoyne
138 kV Transmission Line Loops to BP Oil Project
Case No. 09- EL-BLN


Dear Mr. Konop,

In the above captioned project, American Transmission Systems, Inc. ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new customer owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys
Associate Distribution Specialist
Energy Delivery Technical Services
FirstEnergy Service Company

Attachment

September 24, 2009

Mr. Keith G. Earley, P.E., P.S.
Lucas County Engineer
One Government Center Ste 800
Toledo, Ohio 43604

Letter of Notification
Bayshore-Jackman and Bayshore-Lemoyne
138 kV Transmission Line Loops to BP Oil Project
Case No. 09- -EL-BLN

Dear Mr. Earley,

In the above captioned project, American Transmission Systems, Inc. ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new customer owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys
Associate Distribution Specialist
Energy Delivery Technical Services
FirstEnergy Service Company

Attachment

September 24, 2009

The Honorable Marge Brown
Mayor, City of Oregon
5330 Seaman Road
Oregon, Ohio 43616

Letter of Notification
Bayshore-Jackman and Bayshore-Lemoyne
138 kV Transmission Line Loops to BP Oil Project
Case No. 09- EL-BLN

Dear Ms. Brown,

In the above captioned project, American Transmission Systems, Inc. ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new customer owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys
Associate Distribution Specialist
Energy Delivery Technical Services
FirstEnergy Service Company

Attachment

September 24, 2009

The Honorable Michael P. Sheehy
President, City of Oregon City Council
5330 Seaman Road
Oregon, Ohio 43616

Letter of Notification
Bayshore-Jackman and Bayshore-Lemoyne
138 kV Transmission Line Loops to BP Oil Project
Case No. 09- EL-BLN


Dear Mr. Sheehy,

In the above captioned project, American Transmission Systems, Inc. ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new customer owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys
Associate Distribution Specialist
Energy Delivery Technical Services
FirstEnergy Service Company

Attachment

September 24, 2009

Mr. Rodney Schultz, P.E.
Deputy City Engineer, City of Oregon
5330 Seaman Road
Oregon, Ohio 43616

Letter of Notification
Bayshore-Jackman and Bayshore-Lemoyne
138 kV Transmission Line Loops to BP Oil Project
Case No. 09-EL-BLN

Dear Mr. Shultz,

In the above captioned project, American Transmission Systems, Inc. ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new customer owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys
Associate Distribution Specialist
Energy Delivery Technical Services
FirstEnergy Service Company

Attachment

September 24, 2009

Ms. Tina M. Evans
Clerk of Council, City of Oregon
City Council
5330 Seaman Road
Oregon, Ohio 43616

Letter of Notification
Bayshore-Jackman and Bayshore-Lemoyne
138 kV Transmission Line Loops to BP Oil Project
Case No. 09- -EL-BLN

Dear Ms. Evans,

In the above captioned project, American Transmission Systems, Inc. ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new customer owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys
Associate Distribution Specialist
Energy Delivery Technical Services
FirstEnergy Service Company

Attachment

September 24, 2009

Mr. Paul Roman
Public Service Director, City of Oregon
5330 Seaman Road
Oregon, Ohio 43616

Letter of Notification
Bayshore-Jackman and Bayshore-Lemoyne
138 kV Transmission Line Loops to BP Oil Project
Case No. 09- -EL-BLN


Dear Mr. Roman,

In the above captioned project, American Transmission Systems, Inc. ("ATSI"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new customer owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys
Associate Distribution Specialist
Energy Delivery Technical Services
FirstEnergy Service Company

Attachment

September 24, 2009

Mr. Ken Filipiak
City Administrator, City of Oregon
5330 Seaman Road
Oregon, Ohio 43616

Letter of Notification
Bayshore-Jackman and Bayshore-Lemoyne
138 kV Transmission Line Loops to BP Oil Project
Case No. 09- EL-BLN

Dear Mr. Filipiak,

In the above captioned project, American Transmission Systems, Inc. ("ATSP"), a subsidiary of FirstEnergy Corp., is proposing to construct 5 new steel pole structures on concrete foundations and loop two (2) 138 kV circuits (from the Bayshore-Jackman and the Bayshore-Lemoyne lines) into a new customer owned substation. The Project area is located immediately south of Cedar Point Road adjacent to the BP Oil Refinery in the City of Oregon, Lucas County Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys
Associate Distribution Specialist
Energy Delivery Technical Services
FirstEnergy Service Company

Attachment