

Resulting CAIDI From 50% Reduction of Circuit Lockouts							
	SAIFI			CAIDI		SAIDI	
Report Year	Reported/Current SAIFI, MEDs and Transmission Excluded	50% of Circuit Lockout SAIFI	Reported/Current SAIFI Reduced by 50% of Lockouts	Reported/Current CAIDI, MEDs and Transmission Excluded	Resulting CAIDI With 50% of Lockouts Backed Out	Reported/Current SAIDI, MEDs and Transmission Excluded	50% of Circuit Lockout SAIDI
Dec-04	1.353	0.407	0.95	84.01	91.73	113.638	26.913
Dec-05	1.490	0.471	1.02	82.20	92.81	122.450	27.865
Dec-06	1.481	0.410	1.07	87.81	95.84	130.076	27.374
Dec-07	1.330	0.362	0.97	96.77	100.32	128.660	20.873
Dec-08	1.325	0.328	1.00	98.31	107.37	130.281	23.217
12 m ending Sep 30, 2009	1.243	0.325	0.92	105.70	116.14	131.388	24.796
				Mean Adj. CAIDI:	100.70		
				Std Dev Adj CAIDI:	9.48		
				Mean + 2 Std Dev:	119.7		



**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**10/9/2009 2:57:19 PM**

**in**

**Case No(s). 09-0757-EL-ESS**

Summary: Exhibit Amended Application Exhibit C electronically filed by Ms. Elizabeth H Watts on behalf of Duke Energy Ohio, Inc.