



Bricker & Eckler
ATTORNEYS AT LAW
COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

RECEIVED-DOCKETING DIV

October 13, 2009

2009 OCT 13 PM 4:00

PUCO

VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

**Re: Case No. 08-1233-WS-UNC
Ohio American Water Company
Stipulation Page No. 11, ¶14D**

Dear Ms. Jenkins:

Pursuant to the Commission's November 12, 2008 Opinion and Order in Case No. 07-1112-WS-AIR, and to the Stipulation and Recommendation page 11, paragraph 14D, Ohio American Water Company submits for filing the Lake Darby Hardness Monthly Report for September 2009.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business
Technician _____ Date Processed **OCT 13 2009**

**Ohio-American Water Company
Franklin County District
Lake Darby Water Hardness Report**

Reporting Month & Year September-09

1	2	3	4	5	6	7	8	9	10	11
Date	Day	On-Line Measurement (mg/L) Every 2 hrs when LDWTP is ON	On-Line Unit Operational (Y or N)	LDWTP Process Control Measurement (mg/L) Daily	OAWC WQ Lab Measurement (mg/L) Daily	LDWTP Outside Lab Measurement (mg/L) 1/Month	LDWTP Outside Lab Collection Time Sampler	Distribution Outside Lab Measurement (mg/L) 1/Month	Distribution System Outside Lab Collection Time Sampler	WQ Water Distribution Measurement (mg/L) 2/week
1	Sun	143	Y	114	114					
2	Mon	123	Y	114	112					120
3	Tue	126	Y	110	104					
4	Wed	118	Y	106	108					
5	Thu	128	Y	116	110					
6	Fri	134	Y	118	116					
7	Sat	120	Y	117	114					
8	Sun	123	Y	115	114	100	7:42 AM, Jeff Ward	104	8:09 AM, Jeff Ward	118
9	Mon	121	Y	115	114					120
10	Tue	113	Y	118	114					
11	Wed	113	Y	110	104					
12	Thu	117	Y	113	118					
13	Fri	122	Y	112	98					
14	Sat	64	Y	116	114					124
15	Sun	58	Y	112	108					
16	Mon	131	Y	110	110					114
17	Tue	132	Y	114	112					
18	Wed	130	Y	114	110					
19	Thu	126	Y	118	116					
20	Fri	135	Y	108	112					
21	Sat	131	Y	110	116					116
22	Sun	116	Y	122	116					
23	Mon	124	Y	114	112					120
24	Tue	116	Y	116	114					
25	Wed	126	Y	120	116					
26	Thu	112	Y	110	104					
27	Fri	122	Y	107	105					
28	Sat	115	Y	128	128					118
29	Sun	114	Y	108	100					
30	Mon	124	Y	118	108					110
Average		119		114	111					118
Max		143		128	128					124
Min		54		106	98					110
% > 150 mg/L		0.0		0.0	0.0					0.0

- NOTES:
- Operator shall make a notation in the Instrumentation Log Book on a DAILY basis on the status of the On-Line Hardness Analyzer.
 - Week is Sunday to Saturday
 - WQ Lab is responsible for delivering monthly sample to outside lab.
 - For any test with a hardness <96 mg/L or >145 mg/L notify the Network Operations Superintendent and the Operations Supervisor immediately.