



Bricker & Eckler
ATTORNEYS AT LAW

COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

November 10, 2009

RECEIVED-DOCKETING DIV
2009 NOV 10 PM 2:36
PUC
VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

Re: Case No. 08-1233-WS-UNC
Ohio American Water Company
Stipulation Page No. 11, ¶14D

Dear Ms. Jenkins:

Pursuant to the Commission's November 12, 2008 Opinion and Order in Case No. 07-1112-WS-AIR, and to the Stipulation and Recommendation page 11, paragraph 14D, Ohio American Water Company submits for filing the Lake Darby Hardness Monthly Report for October 2009.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician Dmm Date Processed 11/10/09

**Ohio-American Water Company
Franklin County District
Lake Darby Water Hardness Report**

Reporting Month & Year October-09

1	2	3	4	5	6	7	8	9	10	11
Date	Day	On-Line Measurement (mg/L) Every hour when LDWTP is ON	On-Line Unit Operational (Y or N)	LDWTP Process Control Measurement (mg/L) Daily	OAWC WQ Lab Measurement (mg/L) Daily	LDWTP Outside Lab Measurement (mg/L) 1/Month	LDWTP Outside Lab Collection Time Sampler	Distribution Outside Lab Measurement (mg/L) 1/Month	Distribution Outside Lab Collection Time Sampler	WQ Water Distribution Measurement (mg/L) 2/week
1	Tue	112	Y	120	104					
2	Wed	127	Y	110	110					
3	Thu	118	Y	110	108					
4	Fri	120	Y	110	114	94	6:54 AM, Jeff Ward	103	8:29 AM, Jeff Ward	118
5	Sat	127	Y	114	110					
6	Sun	125	Y	116	108					
7	Mon	118	Y	114	112					120
8	Tue	127	Y	112	114					
9	Wed	128	Y	112	110					
10	Thu	148	Y	108	106					
11	Fri	132	Y	110	104					
12	Sat	137	Y	110	104					116
13	Sun	128	Y	108	106					
14	Mon	134	Y	114	104					114
15	Tue	124	Y	108	104					
16	Wed	109	Y	107	104					
17	Thu	128	Y	118	106					
18	Fri	119	Y	112	106					
19	Sat	127	Y	116	104					118
20	Sun	137	Y	114	108					
21	Mon	130	Y	118	120					110
22	Tue	122	Y	108	100					
23	Wed	110	Y	112	100					
24	Thu	127	Y	110	110					
25	Fri	124	Y	118	112					120
26	Sat	117	Y	105	106					
27	Sun	122	Y	114	110					
28	Mon	115	Y	104	110					118
29	Tue	124	Y	116	102					
30	Wed	120	Y	105	102					
31	Thu	116	Y	108	104					
Average		124		112	107					117
Max		148		120	120					120
Min		109		104	100					110
% >150 mg/L		0.0		0.0	0.0					0.0

- NOTES:
- Operator shall make a notation in the Instrumentation Log Book on a DAILY basis on the status of the On-Line Hardness Analyzer.
 - Week is Sunday to Saturday
 - WQ Lab is responsible for delivering monthly sample to outside lab.
 - For any test with a hardness <95 mg/L or >145 mg/L notify the Network Operations Superintendent and the Operations Supervisor immediately.