

**FILE**

**Staff Investigation Report and Recommendation**

**Case No.:** 09-860-EL-BLN

**Project:** Bayshore-Jackman and Bayshore-Lemonye 138 kV  
Transmission Line Loops to BP Oil

**Applicant:** American Transmission Systems, Inc.

**Report Date:** 19 November 2009

**Automatic Approval Date:** 28 November 2009 (Letter of Notification process)

**Waiver Request:** None

**Inspection Date(s):** 20 October 2009

**Staff Assigned:** J. O'Dell

**Summary of Staff Recommendations (see report text for discussion):**

Application:  Approval  Disapproval  Approval with Conditions  
Waiver:  Approval  Disapproval  Not Applicable

**Summary of Staff Recommended Conditions (see report text for discussion):**

- If the Board does not certificate BP-Husky's Preferred Site, then the Applicant shall withdraw this filing.

**Projected Docket Closure Date (if automatically approved):** 31 May 2011

**Investigation Report**

**Project Description:** This project involves extending two 138 kV transmission line loops to serve a proposed BP-Husky Substation. The substation application will be addressed separately by the Board (Ref: 09-750-EL-BSB). The transmission line loops would be approximately 1,200 feet in length and five steel structures are required.

**Site Description:** The project is located in an industrial area adjacent to the BP-Husky Oil Refinery in the City of Oregon, Lucas County. The proposed lines would link into a major transmission line corridor immediately to the south. Current leased agricultural production on the Applicant's easement would be largely unaffected by this project.

**Discussion/Comments/Concerns:** The construction of this project should pose only minimal negative social and ecological impacts.

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business  
Technician mm Date Processed 11-19-09

RECEIVED-BOOKETING BIN  
2009 NOV 19 PM 1:53  
PUCO