

FILE

22

**EXHIBIT 1: OFFICIALS SERVED COPY OF LON  
Hunt 138 kV Transmission Line Extension To  
V & M Star Steel  
Case No. 09-1829-EL-BLN**

**Mahoning County**

The Honorable David Ludt  
Mahoning County Commissioner  
21 W. Boardman Street  
Second Floor  
Youngstown, OH 44503

Mr. Richard A. Marsico, P.E., P.S.  
Mahoning County Engineer  
940 Bears Den Road  
Youngstown, OH 44512

The Honorable John McNally  
Mahoning County Commissioner  
21 W. Boardman Street  
Second Floor  
Youngstown, OH 44503

Michael O'Shaughnessy  
Director, Planning Commission  
50 Westchester Drive, Suite 203  
Youngstown, OH 44515

The Honorable Anthony Traficanti  
Mahoning County Commissioner  
21 W. Boardman Street  
Second Floor  
Youngstown, OH 44503

RECEIVED-DOCKETING DIV  
2009 DEC -1 PM 5:23  
PUCO

**City of Youngstown**

The Honorable Jay Williams  
Mayor, City of Youngstown  
6<sup>th</sup> Floor, City Hall  
26 South Phelps Street  
Youngstown, OH 44503

Chuck Shasho  
City Engineer, City of Youngstown  
5<sup>th</sup> Floor, City Hall  
26 South Phelps Street  
Youngstown, OH 44503

The Honorable Chuck Sammarone  
President of Council, City of Youngstown  
6<sup>th</sup> Floor, City Hall  
26 South Phelps Street  
Youngstown, OH 44503

Valencia Y. Marrow  
Clerk of Council, City of Youngstown  
6<sup>th</sup> Floor, City Hall  
26 South Phelps Street  
Youngstown, OH 44503

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.  
Technician SM Date Processed DEC 02 2009

American Transmission Systems Incorporated  
& Ohio Edison  
Hunt 138 kV Transmission  
Line Tap to V & M Steel

**Trumbull County**

The Honorable Paul E. Heltzel  
Trumbull County Commissioner  
160 High St.  
Warren, OH 44481

The Honorable Daniel E. Polivka  
Trumbull County Commissioner  
160 High St.  
Warren, OH 44481

The Honorable Frank S. Fuda  
Trumbull County Commissioner  
160 High St.  
Warren, OH 44481

David DeChristofaro, P.E., P.S.  
Trumbull County Engineer  
650 North River Rd. NW  
Warren, OH 44483

Bill Miller  
Director, Planning Commission  
347 North Park Avenue  
Warren, OH 44481

**City of Girard**

The Honorable James L. Melfi  
Mayor, City of Girard  
City Hall  
100 W. Main Street  
Girard, OH 44420

The Honorable Reynold Paolone  
President of Council, City of Girard  
City Hall  
100 W. Main Street  
Girard, OH 44420

George Finelli  
Chair, Planning Commission, City of  
Girard  
365 Beaver  
Girard, OH 44420

David Hall  
City Engineer, City of Girard  
100 W. Main Street  
Girard, OH 44420

November 30, 2009

Ms. Renee J. Jenkins  
Director, Administration Department  
Secretary to the Commission  
Docketing Division  
The Public Utilities Commission of Ohio  
180 East Broad Street  
Columbus, OH 43215-3793

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**

Dear Ms. Jenkins:

In accordance with Rule 4906-1-11 of the Ohio Administrative Code, American Transmission Systems, Incorporated ("ATSI") and Ohio Edison Company ("OE"), transmit one (1) original and eleven (11) copies of the enclosed Letter of Notification for the above captioned project. In this project, ATSI and OE are proposing to install an approximately 1600 foot long, radial transmission line extension from the existing Hunt 138kV Transmission Line to a new customer owned station. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

Please be advised of the following:

- |  |  |
|--|--|
| a) Name and address of the applicants: | American Transmission Systems, Incorporated<br>76 South Main Street<br>Akron, Ohio 44308<br><br>Ohio Edison Company<br>76 South Main Street<br>Akron, Ohio 44308 |
| b) Name of proposed facilities:        | Hunt 138 kV Transmission Line Extension To<br>V & M Star Steel   |

November 30, 2009

- c) Location of proposed facilities: The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.
- d) Description of proposed facilities: The Project involves installing an approximately 1600 foot radial transmission line extension from ATSI's existing Hunt 138 kV transmission line to a new customer owned station. As a part of installing the transmission line extension, nine (9) new poles will be installed.
- e) Applicant's representative: Scott M. Humphrys, Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company  
76 South Main Street  
Akron, OH 44308-1890

After docketing this filing, please return one time-stamped copy of the Letter of Notification for our records to us in the enclosed envelope. We have provided a copy of the Letter of Notification by certified mail, with return receipt requested, to each official of the political subdivisions immediately affected by the proposed project as listed in the attached Exhibit 1. Copies of the transmittal letters addressed to the local government representatives of the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, are enclosed for your file.

Should the Ohio Power Siting Board desire further information or discussion of this submittal, please contact me at (330) 384-2526.

Sincerely,



Scott M. Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachments

November 30, 2009

The Honorable David Ludt  
Mahoning County Commissioner  
21 W. Boardman Street  
Second Floor  
Youngstown, OH 44503

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**


Dear Mr. Ludt,

In the above captioned project, American Transmission Systems, Inc. ("ATSI") and Ohio Edison Company ("OE"), subsidiaries of FirstEnergy Corp., are proposing to install one approximately 1600 foot long, radial transmission line extension from ATSI's existing Hunt 138 kV Transmission Line to a new customer owned station. The transmission line extension will extend from the existing Hunt 138 kV transmission line that trends east to west to the new customer substation which is being installed approximately 2,444 feet northwest of the intersection of US 422 and SR 711 on property currently occupied by V & M Star Steel. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

November 30, 2009

The Honorable John McNally  
Mahoning County Commissioner  
21 W. Boardman Street  
Second Floor  
Youngstown, OH 44503

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**


Dear Mr. McNally,

In the above captioned project, American Transmission Systems, Inc. ("ATSI") and Ohio Edison Company ("OE"), subsidiaries of FirstEnergy Corp., are proposing to install one approximately 1600 foot long, radial transmission line extension from ATSI's existing Hunt 138 kV Transmission Line to a new customer owned station. The transmission line extension will extend from the existing Hunt 138 kV transmission line that trends east to west to the new customer substation which is being installed approximately 2,444 feet northwest of the intersection of US 422 and SR 711 on property currently occupied by V & M Star Steel. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

November 30, 2009

The Honorable Anthony Traficanti  
Mahoning County Commissioner  
21 W. Boardman Street  
Second Floor  
Youngstown, OH 44503

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**


Dear Mr. Traficanti,

In the above captioned project, American Transmission Systems, Inc. ("ATSI") and Ohio Edison Company ("OE"), subsidiaries of FirstEnergy Corp., are proposing to install one approximately 1600 foot long, radial transmission line extension from ATSI's existing Hunt 138 kV Transmission Line to a new customer owned station. The transmission line extension will extend from the existing Hunt 138 kV transmission line that trends east to west to the new customer substation which is being installed approximately 2,444 feet northwest of the intersection of US 422 and SR 711 on property currently occupied by V & M Star Steel. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

November 30, 2009

Mr. Richard A. Marsico, P.E., P.S.  
Mahoning County Engineer  
940 Bears Den Road  
Youngstown, OH 44512

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**


Dear Mr. Marsico,

In the above captioned project, American Transmission Systems, Inc. ("ATSI") and Ohio Edison Company ("OE"), subsidiaries of FirstEnergy Corp., are proposing to install one approximately 1600 foot long, radial transmission line extension from ATSI's existing Hunt 138 kV Transmission Line to a new customer owned station. The transmission line extension will extend from the existing Hunt 138 kV transmission line that trends east to west to the new customer substation which is being installed approximately 2,444 feet northwest of the intersection of US 422 and SR 711 on property currently occupied by V & M Star Steel. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment



November 30, 2009

Michael O'Shaughnessy  
Director, Planning Commission  
50 Westchester Drive, Suite 203  
Youngstown, OH 44515

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**


Dear Mr. O'Shaughnessy,

In the above captioned project, American Transmission Systems, Inc. ("ATSI") and Ohio Edison Company ("OE"), subsidiaries of FirstEnergy Corp., are proposing to install one approximately 1600 foot long, radial transmission line extension from ATSI's existing Hunt 138 kV Transmission Line to a new customer owned station. The transmission line extension will extend from the existing Hunt 138 kV transmission line that trends east to west to the new customer substation which is being installed approximately 2,444 feet northwest of the intersection of US 422 and SR 711 on property currently occupied by V & M Star Steel. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

November 30, 2009<sup>1-800-633-4766</sup>

The Honorable Jay Williams  
Mayor, City of Youngstown  
6<sup>th</sup> Floor, City Hall  
26 South Phelps Street  
Youngstown, OH 44503

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**


Dear Mayor Williams,

In the above captioned project, American Transmission Systems, Inc. ("ATSI") and Ohio Edison Company ("OE"), subsidiaries of FirstEnergy Corp., are proposing to install one approximately 1600 foot long, radial transmission line extension from ATSI's existing Hunt 138 kV Transmission Line to a new customer owned station. The transmission line extension will extend from the existing Hunt 138 kV transmission line that trends east to west to the new customer substation which is being installed approximately 2,444 feet northwest of the intersection of US 422 and SR 711 on property currently occupied by V & M Star Steel. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

November 30, 2009

The Honorable Chuck Sammarone  
President of Council, City of Youngstown  
6<sup>th</sup> Floor, City Hall  
26 South Phelps Street  
Youngstown, OH 44503

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**

Dear Mr. Sammarone,

In the above captioned project, American Transmission Systems, Inc. ("ATSI") and Ohio Edison Company ("OE"), subsidiaries of FirstEnergy Corp., are proposing to install one approximately 1600 foot long, radial transmission line extension from ATSI's existing Hunt 138 kV Transmission Line to a new customer owned station. The transmission line extension will extend from the existing Hunt 138 kV transmission line that trends east to west to the new customer substation which is being installed approximately 2,444 feet northwest of the intersection of US 422 and SR 711 on property currently occupied by V & M Star Steel. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

November 30, 2009

Chuck Shasho  
City Engineer, City of Youngstown  
5<sup>th</sup> Floor, City Hall  
26 South Phelps Street  
Youngstown, OH 44503

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**

Dear Mr. Shasho,

In the above captioned project, American Transmission Systems, Inc. ("ATSI") and Ohio Edison Company ("OE"), subsidiaries of FirstEnergy Corp., are proposing to install one approximately 1600 foot long, radial transmission line extension from ATSI's existing Hunt 138 kV Transmission Line to a new customer owned station. The transmission line extension will extend from the existing Hunt 138 kV transmission line that trends east to west to the new customer substation which is being installed approximately 2,444 feet northwest of the intersection of US 422 and SR 711 on property currently occupied by V & M Star Steel. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

November 30, 2009

Valencia Y. Marrow  
Clerk of Council, City of Youngstown  
6<sup>th</sup> Floor, City Hall  
26 South Phelps Street  
Youngstown, OH 44503

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**


Dear Ms. Marrow,

In the above captioned project, American Transmission Systems, Inc. ("ATSI") and Ohio Edison Company ("OE"), subsidiaries of FirstEnergy Corp., are proposing to install one approximately 1600 foot long, radial transmission line extension from ATSI's existing Hunt 138 kV Transmission Line to a new customer owned station. The transmission line extension will extend from the existing Hunt 138 kV transmission line that trends east to west to the new customer substation which is being installed approximately 2,444 feet northwest of the intersection of US 422 and SR 711 on property currently occupied by V & M Star Steel. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

November 30, 2009

The Honorable Paul E. Heltzel  
Trumbull County Commissioner  
160 High St.  
Warren, OH 44481

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**


Dear Mr. Heltzel,

In the above captioned project, American Transmission Systems, Inc. ("ATSI") and Ohio Edison Company ("OE"), subsidiaries of FirstEnergy Corp., are proposing to install one approximately 1600 foot long, radial transmission line extension from ATSI's existing Hunt 138 kV Transmission Line to a new customer owned station. The transmission line extension will extend from the existing Hunt 138 kV transmission line that trends east to west to the new customer substation which is being installed approximately 2,444 feet northwest of the intersection of US 422 and SR 711 on property currently occupied by V & M Star Steel. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

November 30, 2009

The Honorable Daniel E. Polivka  
Trumbull County Commissioner  
160 High St.  
Warren, OH 44481

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**

Dear Mr. Polivka,

In the above captioned project, American Transmission Systems, Inc. ("ATSI") and Ohio Edison Company ("OE"), subsidiaries of FirstEnergy Corp., are proposing to install one approximately 1600 foot long, radial transmission line extension from ATSI's existing Hunt 138 kV Transmission Line to a new customer owned station. The transmission line extension will extend from the existing Hunt 138 kV transmission line that trends east to west to the new customer substation which is being installed approximately 2,444 feet northwest of the intersection of US 422 and SR 711 on property currently occupied by V & M Star Steel. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

November 30, 2009

The Honorable Frank S. Fuda  
Trumbull County Commissioner  
160 High St.  
Warren, OH 44481

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**


Dear Mr. Fuda,

In the above captioned project, American Transmission Systems, Inc. ("ATSI") and Ohio Edison Company ("OE"), subsidiaries of FirstEnergy Corp., are proposing to install one approximately 1600 foot long, radial transmission line extension from ATSI's existing Hunt 138 kV Transmission Line to a new customer owned station. The transmission line extension will extend from the existing Hunt 138 kV transmission line that trends east to west to the new customer substation which is being installed approximately 2,444 feet northwest of the intersection of US 422 and SR 711 on property currently occupied by V & M Star Steel. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment



November 30, 2009

David DeChristofaro, P.E., P.S.  
Trumbull County Engineer  
650 North River Rd. NW  
Warren, OH 44483

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**


Dear Mr. DeChristofaro,

In the above captioned project, American Transmission Systems, Inc. ("ATSI") and Ohio Edison Company ("OE"), subsidiaries of FirstEnergy Corp., are proposing to install one approximately 1600 foot long, radial transmission line extension from ATSI's existing Hunt 138 kV Transmission Line to a new customer owned station. The transmission line extension will extend from the existing Hunt 138 kV transmission line that trends east to west to the new customer substation which is being installed approximately 2,444 feet northwest of the intersection of US 422 and SR 711 on property currently occupied by V & M Star Steel. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

November 30, 2009

The Honorable James L. Melfi  
Mayor, City of Girard  
City Hall  
100 W. Main Street  
Girard, OH 44420

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**

Dear Mayor Melfi,

In the above captioned project, American Transmission Systems, Inc. ("ATSI") and Ohio Edison Company ("OE"), subsidiaries of FirstEnergy Corp., are proposing to install one approximately 1600 foot long, radial transmission line extension from ATSI's existing Hunt 138 kV Transmission Line to a new customer owned station. The transmission line extension will extend from the existing Hunt 138 kV transmission line that trends east to west to the new customer substation which is being installed approximately 2,444 feet northwest of the intersection of US 422 and SR 711 on property currently occupied by V & M Star Steel. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

November 30, 2009

The Honorable Reynold Paolone  
President of Council, City of Girard  
City Hall  
100 W. Main Street  
Girard, OH 44420

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**

Dear Mr. Paolone,

In the above captioned project, American Transmission Systems, Inc. ("ATSI") and Ohio Edison Company ("OE"), subsidiaries of FirstEnergy Corp., are proposing to install one approximately 1600 foot long, radial transmission line extension from ATSI's existing Hunt 138 kV Transmission Line to a new customer owned station. The transmission line extension will extend from the existing Hunt 138 kV transmission line that trends east to west to the new customer substation which is being installed approximately 2,444 feet northwest of the intersection of US 422 and SR 711 on property currently occupied by V & M Star Steel. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

November 30, 2009

George Finelli  
Chair, Planning Commission, City of Girard  
365 Beaver  
Girard, OH 44420

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**

Dear Mr. Finelli,

In the above captioned project, American Transmission Systems, Inc. ("ATSI") and Ohio Edison Company ("OE"), subsidiaries of FirstEnergy Corp., are proposing to install one approximately 1600 foot long, radial transmission line extension from ATSI's existing Hunt 138 kV Transmission Line to a new customer owned station. The transmission line extension will extend from the existing Hunt 138 kV transmission line that trends east to west to the new customer substation which is being installed approximately 2,444 feet northwest of the intersection of US 422 and SR 711 on property currently occupied by V & M Star Steel. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

November 30, 2009

Bill Miller  
Director, Planning Commission  
347 North Park Avenue  
Warren, OH 44481

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**


Dear Mr. Miller,

In the above captioned project, American Transmission Systems, Inc. ("ATSI") and Ohio Edison Company ("OE"), subsidiaries of FirstEnergy Corp., are proposing to install one approximately 1600 foot long, radial transmission line extension from ATSI's existing Hunt 138 kV Transmission Line to a new customer owned station. The transmission line extension will extend from the existing Hunt 138 kV transmission line that trends east to west to the new customer substation which is being installed approximately 2,444 feet northwest of the intersection of US 422 and SR 711 on property currently occupied by V & M Star Steel. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment

November 30, 2009

David Hall  
City Engineer, City of Girard  
100 W. Main Street  
Girard, OH 44420

**Letter of Notification**  
**Hunt 138 kV Transmission Line Extension To**  
**V & M Star Steel**  
**Case No. 09-1829-EL-BLN**

Dear Mr. Rau,

In the above captioned project, American Transmission Systems, Inc. ("ATSI") and Ohio Edison Company ("OE"), subsidiaries of FirstEnergy Corp., are proposing to install one approximately 1600 foot long, radial transmission line extension from ATSI's existing Hunt 138 kV Transmission Line to a new customer owned station. The transmission line extension will extend from the existing Hunt 138 kV transmission line that trends east to west to the new customer substation which is being installed approximately 2,444 feet northwest of the intersection of US 422 and SR 711 on property currently occupied by V & M Star Steel. As a part of installing the transmission line extension, nine (9) new poles will be installed. The Project area is located northwest of the intersection of US 422 and SR 711, in the City of Youngstown, Mahoning County, and the City of Girard, Trumbull County, Ohio.

In accordance with the provisions of Ohio Administrative Code ("OAC") Rule 4906-1-01, this project falls within the Ohio Power Siting Board's requirements for a Letter of Notification ("LON"). Therefore, in compliance with OAC 4906-11-01 of the OPSB's Rules and Regulations, we have prepared and filed the attached LON with the OPSB for their review and approval. The LON contains a description of the project, and is provided for your information.

I will be happy to answer your questions concerning this matter. You can contact me at (330) 384-2526.

Sincerely,



Scott Humphrys  
Associate Distribution Specialist  
Energy Delivery Technical Services  
FirstEnergy Service Company

Attachment