



Bricker & Eckler
ATTORNEYS AT LAW

COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Sally W. Bloomfield
614.227.2368
sbloomfield@bricker.com

FILE

December 3, 2009

VIA HAND DELIVERY

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

**Re: Case No. 08-1233-WS-UNC
Ohio American Water Company
Stipulation Page No. 11, ¶14D**

Dear Ms. Jenkins:

Pursuant to the Commission's November 12, 2008 Opinion and Order in Case No. 07-1112-WS-AIR, and to the Stipulation and Recommendation page 11, paragraph 14D, Ohio American Water Company submits for filing the Lake Darby Hardness Monthly Report for November 2009.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

PUCO

2009 DEC -3 PM 3:44

RECEIVED-DOCKETING DIV

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.
Technician SM Date Processed DEC 03 2009

Ohio-American Water Company
Franklin County District
Lake Darby Water Hardness Report

Reporting Month & Year November-09

1	2	3	4	5	6	7	8	9	10	11
Date	Day	On-Line Measurement (mg/L) Every hour when LDWTP is ON	On-Line Unit Operational (Y or N)	LDWTP Process Control Measurement (mg/L) Daily	OAWC WQ Lab Measurement (mg/L) Daily	LDWTP Outside Lab Measurement (mg/L) 1/Month	LDWTP Outside Lab Collection Time Sampler	Distribution Outside Lab Measurement (mg/L) 1/Month	Distribution Outside Lab Collection Time Sampler	WQ Water Distribution Measurement (mg/L) 2/week
1		121	Y	106	106					
2		124	Y	102	100	88	7:23 AM, Jeff Ward	96	9:27 AM, Jeff Ward	106
3		157	Y	110	106					
4			N	110	100					120
5			N	104	No Sample					
6		109	Y	102	No Sample					
7		110	Y	104	98					
8		109	Y	111	102					
9		113	Y	111	104					108
10		112	Y	104	110					
11		112	Y	106	100					108
12		119	Y	103	96					
13		129	Y	114	110					
14		127	Y	120	108					
15		127	Y	115	114					
16		114	Y	112	110					118
17		115	Y	103	100					
18		126	Y	114	110					110
19		118	Y	102	106					
20		132	Y	110	106					
21		122	Y	106	102					
22		126	Y	108	104					
23		120	Y	106	102					120
24		119	Y	102	98					
25		124	Y	102	100					112
26		114	Y	104	98					
27		113	Y	105	100					
28		124	Y	110	100					
29		110	Y	105	106					
30		123	Y	108	106					106
Average		120		107	104					112
Max		157		120	114					120
Min		109		102	96					106
% > 150 mg/L		3.2		0.0	0.0					0.0

NOTES: 1) Operator shall make a notation in the Instrumentation Log Book on a DAILY basis on the status of the On-Line Hardness Analyzer.
2) Week is Sunday to Saturday
3) WQ Lab is responsible for delivering monthly sample to outside lab.
4) For any test with a hardness <95 mg/L or > 145 mg/L, notify the Network Operations Superintendent and the Operations Supervisor immediately.