

FILE



**Bricker & Eckler**  
ATTORNEYS AT LAW

COLUMBUS | CLEVELAND  
CINCINNATI-DAYTON

**BRICKER & ECKLER LLP**  
100 South Third Street  
Columbus, Ohio 43215-4291  
MAIN: 614.227.2300  
FAX: 614.227.2390

www.bricker.com  
info@bricker.com

Sally W. Bloomfield  
614.227.2368  
sbloomfield@bricker.com

March 5, 2010

RECEIVED-DOCKETING DIV  
2010 MAR -5 AM 10:47  
**PUCO**  
VIA HAND DELIVERY

Ms. Renee Jenkins  
Public Utilities Commission of Ohio  
Administration/Docketing  
180 East Broad Street, 13<sup>th</sup> Floor  
Columbus, OH 43215-3793

**Re: Ohio American Water Company**  
**Case No. 08-1233-WS-UNC**

Dear Ms. Jenkins:

Ohio American Water Company submits for filing the February 2010  
Hardness Report for the Marion district.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

This is to certify that the documents appearing are an  
accurate and complete reproduction of a case file  
document delivered in the regular course of business  
Technician \_\_\_\_\_ Date Processed **MAR 05 2010**

EFFLUENT HARDNESS / MG/L

February	RAW HARDNESS MG/L	EFFLUENT HARDNESS MG/L
1	440	139
2	435	142
3	430	134
4	443	142
5	440	140
6	445	142
7	480	146
8	453	143
9	465	145
10	470	143
11	460	140
12	442	142
13	460	143
14	470	148
15	468	143
16	467	145
17	468	140
18	453	130
19	453	144
20	450	145
21	433	137
22	435	142
23	420	138
24	382	128
25	400	138
26	412	149
27	382	144
28	386	146

<b>AVERAGE</b>	<b>441</b>	<b>141</b>
<b>MAX</b>	<b>480</b>	<b>149</b>
<b>MIN</b>	<b>382</b>	<b>128</b>

**February 2010**  
**EFFLUENT HARDNESS AVG - 141 MG/L**  
**MARION DISTRICT**

