



**Bricker & Eckler**  
ATTORNEYS AT LAW

COLUMBUS | CLEVELAND  
CINCINNATI-DAYTON

**BRICKER & ECKLER LLP**  
100 South Third Street  
Columbus, Ohio 43215-4291  
MAIN: 614.227.2300  
FAX: 614.227.2390

www.bricker.com  
info@bricker.com

Sally W. Bloomfield  
614.227.2368  
sbloomfield@bricker.com

**FILE**

April 6, 2010

RECEIVED-DOCKETING DIV

2010 APR -6 PM 3:50

VIA HAND DELIVERY

**PUCO**

Ms. Renee Jenkins  
Public Utilities Commission of Ohio  
Administration/Docketing  
180 East Broad Street, 13<sup>th</sup> Floor  
Columbus, OH 43215-3793

**Re: Ohio American Water Company**  
**Case No. 08-1233-WS-UNC**

Dear Ms. Jenkins:

Ohio American Water Company submits for filing the March 2010 Hardness Report for the Marion district.

If you have any questions, please call me at the number listed above.

Sincerely,

Sally W. Bloomfield

Enclosure

cc: Parties of Record (w/Enclosure)

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.  
Technician Sm Date Processed APR 07 2010

EFFLUENT HARDNESS / MG/L

March	RAW HARDNESS MG/L	EFFLUENT HARDNESS MG/L
1	380	141
2	365	137
3	330	141
4	350	148
5	365	140
6	355	143
7	355	141
8	383	148
9	428	145
10	418	133
11	443	149
12	441	141
13	402	140
14	443	145
15	473	151
16	456	141
17	437	141
18	403	130
19	380	137
20	370	140
21	361	136
22	390	144
23	380	136
24	388	144
25	382	136
26	408	146
27	395	140
28	395	141
29	480	147
30	490	148
31	425	133

<b>AVERAGE</b>	<b>396</b>	<b>141</b>
<b>MAX</b>	<b>490</b>	<b>151</b>
<b>MIN</b>	<b>330</b>	<b>130</b>

**March 2010**  
**EFFLUENT HARDNESS AVG - 141 MG/L**  
**MARION DISTRICT**

