

Legal Department

**American Electric Power**  
1 Riverside Plaza  
Columbus, OH 43215-2373  
AEP.com

April 12, 2010

Betty McCaulley  
Docketing Department  
Public Utilities Commission of Ohio  
180 East Broad Street  
Columbus, OH 43215-3793

**Matthew J. Satterwhite**  
Legal Counsel –  
Regulatory Services  
(614) 716-1915 (P)  
(614) 716-2014 (F)  
mjsatterwhite@aep.com

**Re: 09-1546-EL-EEC - Corrected Attachment 1 to Joint Application**

Dear Ms. McCaulley,

Upon review, the Joint Applicants in this case discovered that some of the information included in Attachment 1 to the Joint Application was in error. Those errors have been addressed in the document attached. Please accept this as the corrected Attachment 1 replacing the incorrect document previously filed.

Sincerely,

/s/ Matthew J. Satterwhite  
Matthew J. Satterwhite, Legal Counsel

Attachment



## **Self Direct Project Overview & Commitment**

<b><u>Project Name:</u></b>	Owens Corning Sales LLC
<b><u>Project Number:</u></b>	061
<b><u>Date Received</u></b>	06/26/09
<b><u>Project Installation Date</u></b>	08/2008
<b><u>kWh Reduction:</u></b>	584,314
<b><u>Peak kW Demand Reduction:</u></b>	112.6
<b><u>Total Project Cost</u></b>	\$205,145.67
<b><u>Preliminary/Unadjusted Incentive Calculation</u></b>	\$41,350.17
<b><u>Option 1 - Self Direct Incentive (75%)</u></b>	\$31,012.63
<b><u>Option 2 - EE/PDR Rider Exemption</u></b>	4 months (after PUCO approval)
<b><u>Simple Payback</u></b>	8.9 years

### **Project Overview:**

After reviewing the Self Direct Prescriptive projects requested incentive and the attached scope of work, we were able to determine that the project being applied for was the retrofit of:

- 1394 T12 to T8 conversions
- 638 T12 delampings
- 95 kW of lighting placed on occupancy sensors
- 52 kW reduction due to HID to T8/T5 conversion

The invoicing that was provided proved the quantities that were applied for were installed. There were also labor quotes and check stubs to provide proof of purchase of the lighting system. The lamps that were installed meet all the current energy savings requirements. It should be noted that the 304 CFL purchases were not backed up by invoices, and additional kW and kWh reductions due to HID conversions are not prescriptive, but may be submitted as custom projects.

*By signing this document, the Mercantile customer affirms its intention to commit and integrate the above listed demand reduction, response, and/or energy efficiency resources into the utility's demand reduction, demand response, and energy efficiency programs. By signing, the Mercantile customer also agrees to serve as a joint applicant in any filings necessary to secure approval of this arrangement by the Public Utilities Commission of Ohio, and comply with any information and compliance reporting requirements imposed by rule or as part of that approval.*

**Ohio Power Company**

**Owens Corning Sales LLC**

By: \_\_\_\_\_

By: \_\_\_\_\_

Title: **Manager**

Title: \_\_\_\_\_

Date: \_\_\_\_\_

Date: \_\_\_\_\_

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**4/12/2010 4:00:41 PM**

**in**

**Case No(s). 09-1546-EL-EEC**

Summary: Exhibit --Corrected Exhibit electronically filed by Mr. Matthew J Satterwhite on behalf of Ohio Power Company