



Bricker & Eckler
ATTORNEYS AT LAW

COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Thomas J. O'Brien
614.227.2335
tobrien@bricker.com

May 6, 2010

VIA HAND DELIVERY

RECEIVED-DOCKETING DIV
2010 MAY -6 PM 2:22
PUCO

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

Re: Case No. 08-1233-WS-UNC
Ohio American Water Company
Stipulation Page No. 11, ¶14D

Dear Ms. Jenkins:

Pursuant to the Commission's November 12, 2008 Opinion and Order in Case No. 07-1112-WS-AIR, and to the Stipulation and Recommendation page 11, paragraph 14D, Ohio American Water Company submits for filing the Lake Darby Hardness Monthly Report for April 2010.

If you have any questions, please call me at the number listed above.

Sincerely,

Thomas J. O'Brien

Enclosure

cc: Parties of Record (w/Enclosure)

This is to certify that the images appearing are an
accurate and complete reproduction of a case file
document delivered in the regular course of business

Technician JA Date Processed 5-6-2010

**Ohio-American Water Company
Franklin County District
Lake Darby Water Hardness Report**

Reporting Month & Year April-10

1	2	3	4	5	6	7	8	9	10	11	12
Date	Day	On-Line Measurement (mg/L) Every hour when LDWTP is ON	On-Line Unit Operational (Y or N)	LDWTP Process Control Measurement (mg/L) Daily	OAWC WQ Lab Measurement (mg/L) Daily	LDWTP Outside Lab Measurement (mg/L) 1/Month	LDWTP Outside Lab Collection Time Sampler	Distribution Outside Lab Measurement (mg/L) 1/Month	Distribution System Outside Lab Collection Time Sampler	WQ Water Distribution Measurement (mg/L) 2/week	Water Distribution Sample Location
1	Thu	123	Y	138	132						
2	Fri	119	Y	118	110						
3	Sat	124	Y	127	130						
4	Sun	121	Y	122	114						
5	Mon	124	Y	120	104						
6	Tue	116	Y	108	102	96	6:49 AM, Jeff Ward	107	7:49 AM, Jeff Ward	118	LD-SS#1
7	Wed	117	Y	118	112					116	LD-SS#2
8	Thu	115	Y	108	104						
9	Fri	119	Y	108	106						
10	Sat	118	Y	114	104						
11	Sun	118	Y	115	102						
12	Mon	116	Y	110	104					118	LDWWTP
13	Tue	117	Y	116	114						
14	Wed	115	Y	108	106						
15	Thu	118	Y	114	108					124	LD-SS#3
16	Fri	123	Y	108	75						
17	Sat	112	Y	110	106						
18	Sun	113	Y	114	110						
19	Mon	113	Y	110	110					114	LDWWTP
20	Tue	114	Y	128	130						
21	Wed	119	Y	104	102						
22	Thu	116	Y	108	104					124	LD-SS#3
23	Fri	117	Y	114	114						
24	Sat	113	Y	124	110						
25	Sun	116	Y	120	104						
26	Mon	118	Y	108	104					114	LDWWTP
27	Tue	120	Y	110	110						
28	Wed	126	Y	134	130						
29	Thu	117	Y	112	94					118	LDWWTP
30	Fri	119	Y	114	108						
Average		118		115	109					118	
Max		126		138	132					124	
Min		112		104	75					114	
% >150 mg/L		0.0		0.0	0.0					0.0	

- NOTES:
- 1) Operator shall make a notation in the Instrumentation Log Book on a DAILY basis on the status of the On-Line Hardness Analyzer.
 - 2) Week is Sunday to Saturday
 - 3) WQ Lab is responsible for delivering monthly sample to outside lab.
 - 4) For any test with a hardness <95 mg/L or >145 mg/L notify the Network Operations Superintendent and the Operations Supervisor immediately.