

FILE



Bricker & Eckler
ATTORNEYS AT LAW

COLUMBUS | CLEVELAND
CINCINNATI-DAYTON

BRICKER & ECKLER LLP
100 South Third Street
Columbus, Ohio 43215-4291
MAIN: 614.227.2300
FAX: 614.227.2390

www.bricker.com
info@bricker.com

Thomas J. O'Brien
614.227.2335
tobrien@bricker.com

2

May 6, 2010

VIA HAND DELIVERY

RECEIVED-DOCKETING DIV
2010 MAY -6 PM 2:23
PUCO

Ms. Renee Jenkins
Public Utilities Commission of Ohio
Administration/Docketing
180 East Broad Street, 13th Floor
Columbus, OH 43215-3793

**Re: Ohio American Water Company
Case No. 08-1233-WS-UNC**

Dear Ms. Jenkins:

Ohio American Water Company submits for filing the April 2010 Hardness Report for the Marion district.

If you have any questions, please call me at the number listed above.

Sincerely,

Thomas J. O'Brien

Enclosure

cc: Parties of Record (w/Enclosure)

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business
Technician RC Date Processed 5-6-2010

EFFLUENT HARDNESS / MG/L

April	RAW HARDNESS MG/L	EFFLUENT HARDNESS MG/L
1	340	134
2	340	146
3	360	143
4	370	143
5	380	144
6	380	141
7	380	139
8	373	143
9	347	136
10	368	142
11	348	142
12	356	140
13	380	145
14	387	140
15	391	138
16	422	147
17	413	140
18	424	140
19	420	142
20	420	140
21	424	138
22	420	141
23	418	138
24	425	141
25	428	142
26	420	145
27	395	143
28	400	148
29	390	141
30	400	146

AVERAGE	391	142
MAX	428	148
MIN	340	134

April 2010
EFFLUENT HARDNESS AVG - 142 MG/L
MARION DISTRICT

