

Legal Department

**American Electric Power**  
1 Riverside Plaza  
Columbus, OH 43215-2373  
AEP.com

June 24, 2010

**Matthew J. Satterwhite**  
Legal Counsel –  
Regulatory Services  
(614) 716-1915 (P)  
(614) 716-2014 (F)  
mjsatterwhite@aep.com

Betty McCaulley  
Docketing Department  
Public Utilities Commission of Ohio  
180 East Broad Street  
Columbus, OH 43215-3793

**Re: 09-2242-EL-EEC - Corrected Attachment 1 to Joint Application**

Dear Ms. McCaulley,

Upon review, the Joint Applicants in this case discovered that some of the information included in Attachment 1 to the Joint Application was in error. Those errors have been addressed in the document attached. Please accept this as the corrected Attachment 1 replacing the incorrect document previously filed.

Sincerely,

/s/ Matthew J. Satterwhite  
Matthew J. Satterwhite, Legal Counsel



### **Self Direct Project Overview & Commitment**

<b><u>Customer Name:</u></b>	Colgate Palmolive Co.
<b><u>Project Number:</u></b>	388
<b><u>Date Received</u></b>	9/21/09
<b><u>Project Installation Date</u></b>	8/1/06, 10/31/07, 2/26/08, 12/1/08 & 7/9/09
<b><u>Annual kWh Reduction:</u></b>	2,124,630
<b><u>Peak KW Demand Reduction:</u></b>	234.7
<b><u>Total Project Cost</u></b>	\$737,613.00
<b><u>Preliminary/Unadjusted Incentive Calculation</u></b>	\$193,440.40
<b><u>Option 1 – Self Direct Incentive (75%)</u></b>	\$145,080.30
<b><u>Option 2 – EE/PDR Rider Exemption</u></b>	44 months (after PUCO approval)
<b><u>Simple Payback (yrs)</u></b>	7.9 years

#### **Project Overview:**

The Self Direct Custom project that Colgate Palmolive has completed and applied is as follows.

- Replace 7 rooftop air cooled and 3 outdoor air cooled chillers (total 585 tons) with new 500 ton water cooled high efficiency chiller with VFD on compressor. The documentation that was included with the application proved that the energy measures applied for were purchased and installed.
- Replace 3 air compressors with new compressor with VFD on motor to match load.
- Replace 2 air compressors with new compressor with VFD on motor to match load.
- Upgrade the chiller plant with replacement of 2 150 ton chillers with new 750 chiller and replace 14 low efficiency pumps with 4 new higher efficiency VFD pumps.
- Replace motor starter on air compressor with a new VFD motor to match load.

The documentation that was included with the application proved that the energy measures applied for were purchased and installed.

*By signing this document, the Mercantile customer affirms its intention to commit and integrate the above listed demand reduction, response, and/or energy efficiency resources into the utility's demand reduction, demand response, and energy efficiency programs. By signing, the Mercantile customer also agrees to serve as a joint applicant in any filings necessary to secure approval of this arrangement by the Public Utilities Commission of Ohio, and comply with any information and compliance reporting requirements imposed by rule or as part of that approval.*

**Ohio Power Company**

**Colgate Palmolive Co.**

By: \_\_\_\_\_

By: \_\_\_\_\_

Title: **Manager**

Title: \_\_\_\_\_

Date: \_\_\_\_\_

Date: \_\_\_\_\_

**This foregoing document was electronically filed with the Public Utilities**

**Commission of Ohio Docketing Information System on**

**6/28/2010 5:13:14 PM**

**in**

**Case No(s). 09-2242-EL-EEC**

Summary: Amended Application -- Corrected Attachment 1 -- electronically filed by Mr. Matthew J Satterwhite on behalf of Ohio Power Company