

Legal Department

American Electric Power
1 Riverside Plaza
Columbus, OH 43215-2373
AEP.com

June 24, 2010

Betty McCaulley
Docketing Department
Public Utilities Commission of Ohio
180 East Broad Street
Columbus, OH 43215-3793

Matthew J. Satterwhite
Legal Counsel –
Regulatory Services
(614) 716-1915 (P)
(614) 716-2014 (F)
mjsatterwhite@aep.com

Re: 09-1480-EL-EEC - Corrected Attachment 1 to Joint Application

Dear Ms. McCaulley,

Upon review, the Joint Applicants in this case discovered that some of the information included in Attachment 1 to the Joint Application was in error. Those errors have been addressed in the document attached. Please accept this as the corrected Attachment 1 replacing the incorrect document previously filed.

Sincerely,

/s/ Matthew J. Satterwhite
Matthew J. Satterwhite, Legal Counsel



Self Direct Project Overview & Commitment

<u>Customer Name:</u>	Northwest Bd of Education
<u>Project Number:</u>	598
<u>Date Received</u>	11/2/09
<u>Project Installation Date</u>	08/27/08
<u>Annual kWh Reduction:</u>	337,634
<u>Peak KW Demand Reduction:</u>	66.9
<u>Total Project Cost</u>	\$174,350.00
<u>Preliminary/Unadjusted Energy Efficiency Credit (EEC) Calculation</u>	\$30,611.11
<u>Option 1 - Self Direct EEC</u>	\$22,958.33
Or	
<u>Option 2 – EE/PDR Rider Exemption</u>	204 months (after PUCO approval)
<u>Simple Payback (yrs)</u>	5.4 years

Project Overview:

The Self Direct Prescriptive Lighting project that Northwest Bd of Education has completed and applied is as follows: retrofit of 119 of 4L4'T12 lighting fixtures with 31 4L4'T8 and 88 of 3L4'T8 lighting fixtures, 816 of 3L4'T12 lighting fixtures with 816 of 3L4'T8 lighting fixtures, 66 of 2L4'T12 lighting fixtures with 66 of 2L4'T8 lighting fixtures, 36 2L4'T12 U-shape lighting fixtures with 9 of 2L4'T8 U-shape and 27 of 2L2,T8 lighting fixtures, replacement of 42 fluorescent EXIT signs with 42 of LED EXIT signs and installation of 87 occupancy sensors in classrooms. T12 to T8 conversion, 4-foot delamping, New T8/T5 fixture, LED EXIT signs and Lighting occupancy sensors measures were applied in this project. The documentation that was included with the application proved that the energy measures applied for were purchased and installed.

By signing this document, the Mercantile customer affirms its intention to commit and integrate the above listed demand reduction, response, and/or energy efficiency resources into the utility's demand reduction, demand response, and energy efficiency programs. By signing, the Mercantile customer also agrees to serve as a joint applicant in any filings necessary to secure approval of this arrangement by the Public Utilities Commission of Ohio, and comply with any information and compliance reporting requirements imposed by rule or as part of that approval.

Columbus Southern Power Company

Northwest Bd of Education

By: _____

By: _____

Title: **Manager**

Title: _____

Date: _____

Date: _____

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

6/28/2010 5:29:57 PM

in

Case No(s). 09-1480-EL-EEC

Summary: Amended Application -- Corrected Attachment 1 -- electronically filed by Mr. Matthew J Satterwhite on behalf of Columbus Southern Power Company