

FILE

**Ohio Power Siting Board**

**Staff Investigation Report and Recommendation**

**Case No.:** 10-789-EL-BNR

**Project:** Huston 138 kV Electric Transmission Line Loop

**Applicant:** Duke Energy Ohio

**Report Date:** 13 July 2010

**Automatic Approval Date:** 21 July 2010 (Construction Notice process)

**Waiver Request:** None

**Inspection Date(s):** 15 June 2010

**Staff Assigned:** J. O'Dell

RECEIVED-DOCKETING DIV  
2010 JUL 14 AM 11:47  
PUCO

**Summary of Staff Recommendations (see report text for discussion):**

Application: ☒ Approval    ☐ Disapproval    ☐ Approval with Conditions  
Waiver:        ☐ Approval        ☐ Disapproval    ☒ Not Applicable

**Summary of Staff Recommended Conditions (see report text for discussion):**

- None

**Projected Docket Closure Date (if automatically approved):** 31 October 2012

**Investigation Report**

**Project Description:** This project requires approximately 800 feet of 138 kV transmission line and six new wood pole structures. The line is needed to provide service to a new distribution substation for Butler Rural Electric Cooperatives. The new substation will serve future load growth and improve reliability in the area.

**Site Description:** Land use in proximity to the project consists of agricultural, wood lot and rural residential uses. No appreciable vegetative clearing is required. This project is located immediately off Huston Road in Milford Township, Butler County.

**Discussion/Comments/Concerns:** The construction of this project should pose only minimal negative social and ecological impacts.

This is to certify that the images appearing are an accurate and complete reproduction of a case file document delivered in the regular course of business.  
Technician TNM Date Processed 7-13-10