

FILE

1

Ohio Power Siting Board

Staff Investigation Report and Recommendation

Case No.: 10-904-EL-BLN

Project: Allen Junction – Stryker 138 kV Transmission Line
Loop to East Fayette Substation

Applicants: American Transmission Systems, Inc.

Report Date: 19 August 2010

Automatic Approval Date: 31 August 2010 (Letter of Notification process)

Waiver Request: None

Inspection Date(s): 21 July 2010

Staff Assigned: J. O'Dell

Summary of Staff Recommendations (see report text for discussion):

Application: Approval Disapproval Approval with Conditions
Waiver: Approval Disapproval Not Applicable

Summary of Staff Recommended Conditions (see report text for discussion):

- None

Projected Docket Closure Date (if automatically approved): 31 October 2012

Investigation Report

Project Description: This project involves the construction of approximately 985 feet of 138 kV transmission line. Portions of the new line will be designed to support a 69 kV circuit as well. Six new wood pole structures will be installed. The line is needed to provide service to a new substation.

Site Description: The predominant nearby land use is agricultural. The project is located in Gorham Township, Fulton County.

Discussion/Comments/Concerns: The construction of this project should pose only minimal negative social and ecological impacts.