1

FILE

Ohio Power Siting Board

Staff Investigation Report and Recommendation

Case No.: 10-904-EL-BLN
Project: Allen Junction – Stryker 138 kV Transmission Line Loop to East Fayette Substation
Applicants: American Transmission Systems, Inc.
Report Date: 19 August 2010
Automatic Approval Date: 31 August 2010 (Letter of Notification process)
Waiver Request: None
Inspection Date(s): 21 July 2010 Staff Assigned: J. O'Dell
Summary of Staff Recommendations (see report text for discussion):
Application: [X] Approval [] Disapproval [] Approval with Conditions Waiver: [] Approval [] Disapproval [X] Not Applicable
Summary of Staff Recommended Conditions (see report text for discussion):
• None
Projected Docket Closure Date (if automatically approved): 31 October 2012
Investigation Report
Project Description : This project involves the construction of approximately 985 feet of 138 kV transmission line. Portions of the new line will be designed to support a 69 kV circuit as well. Single mew wood pole structures will be installed. The line is needed to provide service to a new substation.
Site Description: The predominant nearby land use is agricultural. The project is located in Gorhan Township, Fulton County.
Discussion/Comments/Concerns: The construction of this project should pose only minima negative social and ecological impacts.

This is to certify that the images appearant are en accurate and complete repredestion of a case file document delivered in the regular course of business reconscion.

Date Processed AND 1-2018