



Case No.: 09-526-EL-REN (09-BO-OH-GATS-12)

Notification of Change of Facility Information

G. Certification Criteria 2: Qualified Resource or Technology

You should provide information for only one generation facility in this application; please check and/or fill out only one of the sections below. If you are applying for more than one facility, you will need to complete a separate application for each facility.

G.1. For the resource or technology you identify in Sections G.4 – G.13 below, please provide a written description of the system. *We are increasing the size of the generator head to 600kW from 400kW because the Anaerobic Digester plant is producing more biogas than was expected in our first projections. Producing the extra electricity will eliminate the need to run the waste gas flare as much as we need to currently. No other changes are required in the system and the metering remains the same.*

I. Facility Information

I.a The nameplate capacity of the entire facility in megawatts (MW): **.600 MW**

I.b If applicable, what is the expected net heat rate of the facility:

9100 BTU/kWh

Number of Generating Units: **1**

I.1 For each generating unit, provide the following information:

In-Service date of each unit	The nameplate capacity of each unit in megawatts (MW)	Projected Annual Generation (MWh)	Expected Annual Capacity Factor %
9/29/2010	.600 MW	4730	90%

This foregoing document was electronically filed with the Public Utilities

Commission of Ohio Docketing Information System on

10/5/2010 12:08:40 PM

in

Case No(s). 09-0526-EL-REN

Summary: Letter of Notification electronically filed by Mrs. Deborah H Elias on behalf of Schmack Biomass - OARDC, LLC